

SANDIA REPORT

SAND89-2840 • UC-236
Unlimited Release
Printed February 1990

RS-8232-2/ 70147



8232-2/070147



00000001 -

Test Bed Concentrator # 1 Calorimetry Results

K. Scott Rawlinson, Vern E. Dudley

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550
for the United States Department of Energy
under Contract DE-AC04-76DP00789



Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from
Office of Scientific and Technical Information
PO Box 62
Oak Ridge, TN 37831

Prices available from (615) 576-8401, FTS 626-8401

Available to the public from
National Technical Information Service
US Department of Commerce
5285 Port Royal Rd
Springfield, VA 22161

NTIS price codes
Printed copy: A03
Microfiche copy: A01

SAND89-2840
Unlimited Release
Printed February 1990

Distribution
Category UC-236

TEST BED CONCENTRATOR #1

CALORIMETRY RESULTS

K. Scott Rawlinson and Vern E. Dudley
Solar Thermal Test Facility Division
Sandia National Laboratories
Albuquerque, NM 87185

ABSTRACT

Calorimetry was performed on Sandia National Laboratories' Test Bed Concentrator #1 (TBC-1) during late July and early August 1989. The purpose of the tests was to determine the total power available from the concentrator and the amount of the total power that can be focused through a 22-cm aperture plate located at the nominal focal point of the dish. The 22-cm aperture corresponds to the diameter of several reflux receivers that are currently under development, fabrication and testing at Sandia. The calorimeter tests will allow the efficiency of the sodium reflux receivers to be calculated. The total power (normalized to 1000 W/m²) available from TBC-1 is 66.4 kW into the 22-cm aperture plate. Within error limits, this power level is the same with or without the aperture plate. The power levels stated are for this time (July 1989) and will probably change as the mirrors further degrade. Since the last calorimetry tests were performed, the mirror facets have degraded significantly, and the results presented here support this effect. Finally, three of the 220 facets were missing.

Foreword: Solar Thermal Technology

The research and development described in this document were conducted within the U.S. Department of Energy's Solar Thermal Technology Program. The goal of the Solar Thermal Technology Program is to advance the engineering and scientific understanding of solar thermal technology and to establish the technology base from which private industry can develop solar thermal power production options for introduction into the competitive energy market.

Solar thermal technology concentrates solar radiation by means of tracking mirrors or lenses onto a receiver where the solar energy is absorbed as heat and converted into electricity or incorporated into products as process heat. The two primary solar thermal technologies, central receivers and distributed receivers, employ various point and line-focus optics to concentrate sunlight. Current central receiver systems use fields of heliostats (two-axis tracking mirrors) to focus the sun's radiant energy onto a single tower-mounted receiver. Parabolic dishes up to 17 meters in diameter track the sun in two axes and use mirrors to focus radiant energy onto a receiver. Troughs and bowls are line-focus tracking reflectors that concentrate sunlight onto receiver tubes along their focal lines. Concentrating collector modules can be used alone or in a multi-module system. The concentrated radiant energy absorbed by the solar thermal receiver is transported to the conversion process by a circulating working fluid. Receiver temperatures range from 100°C in low-temperature troughs to over 1500°C in dish and central receiver systems.

The Solar Thermal Technology Program is directing efforts to advance and improve promising system concepts through the research and development of solar thermal materials, components, subsystems, and the testing and performance evaluation of subsystems and systems. These efforts are carried out through the technical direction of the Department of Energy and its network of national laboratories, who work with private industry. Together they have established a comprehensive, goal-directed program to improve performance and provide technically proven options for eventual incorporation into the nation's energy supply.

To be successful in contributing to an adequate national energy supply at reasonable cost, solar thermal energy must eventually be economically competitive with a variety of other energy sources. Components and system-level performance targets have been developed as quantitative program goals. The performance targets are used in planning research and development activities, measuring progress, assessing alternative technology options, and making optimal component developments. These targets will be pursued vigorously to ensure a successful program.

Introduction

The Test Bed Concentrators (TBCs) were transferred from the Jet Propulsion Laboratory (JPL) to Sandia National Laboratories (SNL) in Albuquerque, New Mexico in 1983. The TBCs are rigid structures that track the sun in azimuth and elevation. Each TBC has 220 mirror facets mounted on a parabolic structure. The facets are made from foam glass with a spherical silvered glass surface. The nominal radius of curvature of the facets varies slightly. The "A" mirrors, which comprise the inner 64 facets, have a nominal radius of curvature of 13.21 m. The "B" and "C" mirrors have nominal radii of curvature of 15.80 m and 16.13 m, respectively. The average slope error of the mirrors (a measure of the actual surface contour to a perfect spherical contour) is 1.2 mrad. Each facet can be individually aimed. With all of the facets aimed at the nominal focal point, the peak flux is over 14,000 suns contained in a 15-cm diameter flux distribution.

Calorimetry tests on Test Bed Concentrator #1 (TBC-1) were last performed in August of 1985. Since that time, many of the mirror facets have degraded. In addition to the normal decrease in reflectivity, many of the mirror facets are "speckled"--most likely due to outgassing from the foam glass diffusing through the copper substrate and corroding the silver.

Figure 1 is a photo of the cold-water cavity calorimeter that was used to absorb and measure the incident power. The photo in Figure 2 shows the TBC during a full-power calorimetry test. For partial-power tests, some of the incident power is eliminated by placing mirror covers over individual facets. Figure 3 is a close-up of calorimeter aperture while on-sun.

Test Preparation

TBC-1 was last aligned in October 1987. Extreme care was taken in this alignment. The bipods, which support the receiver ring, were aligned relative to the parabolic structure so that the center of the receiver ring was on an axis perpendicular to the elevation axis. This procedure defined the correct optical axis of the dish. Also, the distance from the vertex of the dish to the mounting plane was accurately measured using a theodolite. A target, consisting of 220 return images corresponding to each facet, was mounted 61.7 cm (24.3 in) behind the "B" and "C" aim point. The target was constructed so that the "A" mirrors were aimed along the optical axis 641.7 cm (252.625 in) from the vertex, while the "B" and "C" mirrors (the remaining outer facets) were aimed at a distance of 638.5 cm (251.75 in) from the dish vertex. The alignment was performed in the following manner--a laser was mounted on the optical axis of the concentrator, defined by placing the laser in-line with two sets of crosshairs--one set located at the vertex of the dish and another set located inside the receiver ring. The laser beam was aimed at a distant light source located in the mesa north of the TBC. Then the facets were aligned by adjusting the return images of the illuminated mirrors to match the images plotted on the target board. Figure 4 is a photo of the target board following the alignment procedure.

The alignment was checked using the same equipment as described above just before the calorimetry tests. Only six facets needed minor adjustments.

A 22-cm aperture plate, machined from Fiberfrax 3000 insulating board, was mounted to the front surface of the calorimeter. The aperture plate was used to determine the amount of power that could be delivered through a 22-cm diameter aperture, the aperture size established for reflux receivers that will be tested on the TBCs, under identical conditions. Based on the calorimeter measurements, the power available to a receiver, and therefore the receiver efficiency, can be determined.

After the calorimeter was mounted, plumbed, and instrumented, three mirror facets were destroyed during a wind storm with gusts up to 82 mph. Replacing the mirrors would have required personnel to tear down the calorimeter, mount the new mirrors and target board, and align the mirrors at night with a distant light source. Due to manpower and time constraints, the three facets were not replaced. The important aspect of the test was to maintain consistency between the calorimeter tests and the receiver tests.

The aperture plate on the calorimeter was mounted 638.5 cm from the dish vertex (69.7 cm from the receiver ring mounting plane). This location corresponds to the aim point for the "B" and "C" mirrors, the nominal focal point.

Other equipment used in the test includes the water-cooled aperture plate and shutter plate, along with back-up systems for cooling and driving the dish off-sun during an emergency. This equipment is discussed below.

The water-cooled aperture plate and shutter plate are used to protect the equipment mounted on the receiver ring when coming on-sun and going off-sun (see Figure 3). The cooling plates are made from aluminum plates with 1/2-in water jackets between the plates. Water at 57 l/min (15 gpm) is pumped through the system with a portable pump and radiator system. The position of the shutter is controlled from a panel in the control room and is driven with compressed air.

Water for the calorimeter is provided by a hose bib located near the base of the TBC. An automatic flow controller maintains a steady flowrate of 76 l/min (20 gpm) regardless of supply pressure fluctuations.

In the event of a power failure, there are several back-up systems to allow the TBC to be brought off-sun without damage to the equipment. When the power is interrupted, an emergency generator is automatically started. This generator provides power to dc power supplies that are paralleled to the motor control unit for the azimuth and elevation drive motors. The TBCs can then be controlled from a panel in the control room. The panel is powered by an uninterruptable power supply (UPS) system. In addition, an air drive motor on the azimuth drive can be driven with compressed air that is contained in the air compressor tank. If the compressed air is exhausted, a bank of nitrogen bottles is automatically valved into the system, allowing the azimuth rotation to continue.

Instrumentation and Calibration

The important parameters that were needed to calculate the input power accurately were the solar energy input, the calorimeter water flowrate, the inlet temperature, and the

delta-temperature through the calorimeter. The inlet and outlet pressures were also measured. Each of the transducers used to make these measurements are discussed below.

Weather Data

Solar energy input to the TBC dish collector was measured with an Eppley normal incidence pyrheliometer. The pyrheliometer was calibrated against a Kendall radiometer at the Sandia Flux Gage Calibration Station; accuracy of the instrument is $\pm 0.7\%$, including uncorrected temperature effects. Wind speed, wind direction, and ambient air temperature were measured by Weathermeasure instruments, located 10 meters above the surface, just north of the TBC dish site.

Fluid Flow

Cold water through the calorimeter was provided from the site's domestic water supply, which maintains a nearly constant water temperature of about 25°C . Water flowrate was controlled by a Griswold automatic flow controller, which minimized any flow fluctuations due to changes in local water pressure. Volumetric flowrate of the water was measured with a Flow Technology turbine flowmeter and associated pulse rate converter. The flowmeter and pulse rate converter were calibrated immediately before the test to an accuracy of better than 1%. During the tests, the mass flowrate of water through the system was periodically checked by dumping the output water into a 55-gallon drum for a closely timed interval, while noting the weight change of the water drum on a balance scale. In all cases, the measured mass flowrate was consistent with that calculated using the turbine flowmeter measurement.

Temperature

Since an accurate measurement of the temperature rise across the calorimeter is critical to the success of the experiment, a differential temperature transducer manufactured by the Delta-T Co. was installed in the calorimeter water flow. This transducer contains a 20-junction thermopile constructed from identical type-T thermocouples (TCs), and provides an output signal of about 0.401 millivolts per degree C temperature differential, with a stated accuracy of 0.04°C . This accuracy was verified by the SNL Standards Lab.

Calculation of differential temperature from the voltage output signal of the Delta-T device requires that the input temperature be known. Input water temperatures were measured with a type-T reference thermocouple internal to the Delta-T transducer. Input and output temperatures were also measured with a separately installed pair of type-T thermocouples, so that an independent calculation of temperature rise (of lower accuracy) could be made to detect any gross failure of the differential temperature device.

The input temperature measurement did not have to be highly accurate, since the iterative calculation of temperature differential from the transducer voltage output was not very sensitive to input temperature. A 5-degree error in input temperature would result in a temperature differential error of only 0.1°C . [See Wald (1), available from the Delta-T Company].

Other thermocouples include water-cooled aperture plate and shutter plate temperatures and the TC isothermal plane reference temperatures. The water-cooled aperture and shutter plate signals are taken for safety shutdown considerations. Finally, all isothermal plane reference junction temperatures are needed to calculate the actual temperature at the TC measuring point. All of these temperatures are recorded with the calorimeter data.

Fluid Pressure

Input water pressure and pressure drop across the calorimeter were measured with Rosemount pressure transducers. These transducers have a stated accuracy of 0.25% of calibrated span. Stability is 0.25% of upper range limit for six months, and the temperature effect is 0.2% of range plus 0.2% of span per 20°C. The transducers were calibrated immediately before the test to an accuracy of 1%.

Data Acquisition System

The data acquisition system was controlled by a Hewlett Packard (HP) 9845B desktop computer. Data channels were sequentially scanned with an HP3497A data acquisition unit, and the resulting analog signals were then measured with an HP3456A digital voltmeter. The voltmeter was calibrated by the SNL Measurement Standards Lab to a stated accuracy better than 0.01%. Data were recorded on the computer's hard disk, and later transferred to floppy disk for archival storage. Data were normally recorded at 10-second intervals during active testing; slower data rates were sometimes used while waiting for weather improvements.

Software Calculations

The absorbed power was calculated by multiplying the mass flowrate by the change in enthalpy of the water as it flowed through the calorimeter. The calculation is valid if the following assumptions are made when performing an energy balance:

- (1) Measurement is made at steady state.
- (2) No heat loss from the calorimeter occurs.
- (3) Changes in potential and kinetic energy are negligible.

The published numbers were taken at steady-state conditions. Heat losses are negligible since the device is a "cold-water" calorimeter, i.e., the convective and radiation losses from the surfaces are small. Assumption #3 is absolutely true for the construction of this particular calorimeter.

The mass flowrate of water was calculated in software by multiplying the volumetric flowrate by the density (based on temperature). The inlet and outlet enthalpies were also calculated in software as a function of temperature and pressure. The polynomials used to calculate these properties produce results that agree within 0.2% of the steam tables found in Keenan and Keyes (2).

Test Procedure

After the water flows were established and the emergency systems were checked, the TBC was brought on-sun with the shutter closed. The shutter was then opened. The calorimeter was allowed to reach steady state, which takes about 15 minutes. The power levels presented later are given for a period of time after steady state has been reached and the isolation level is constant. During the test, test personnel verified that all the temperatures were stable and reasonable. Also, since the flowrate is critical to the power measurement, the mass flowrate is measured by dumping the water into a 55-gallon drum for 1 minute, and weighing the drum with a balance scale. The "bucket and scale" mass flowrate was consistent with the turbine flowmeter measurement. After a satisfactory data point was obtained, the TBC was driven off-sun so that the next test condition could be set.

Observations During Testing

The calorimeter testing was completed without any major problems. However, there were several items worth noting. First, with the 22-cm aperture plate mounted on the calorimeter, there was some amount of spill of solar flux to the left of the aperture. That spot was probably an "A" mirror near the video camera that was knocked loose during another wind gust. Also, when the dish was tracked using "suntrack," the feedback loop using the sun sensors, the TBC oscillated enough to move the beam up and down about 5-cm (2 inches). The gains for the feedback system were adjusted with minor success. These tuning parameters will be fine tuned in the near future. Finally, the offsets for "memtrack," in which the controller sends the TBC to a point based on the solar time and the day of the year, had to be modified slightly from day to day. The adjustments were small (about 0.1-0.2 degrees), but noticeable. At this point, it is not known whether the encoder wheel slipped slightly or not. The TBC itself is quite rigid. No changes in power measurements were noted during these adjustments.

Test Results

The test results are summarized in Table I. Multiple data points exist for some of the mirror patterns and mirror cleanliness. These data points represent different segments (approximately 5 minutes containing 30 data scans) during the test when conditions were stable. A sample of the data plots and the data summaries can be found in Appendix I.

Table I

Test Results

Date	Mirrors	Note	Inlet Temp C	Delta-T Temp C	Flow Rate L/min	Solar Flux W/m ²	Meas. Power kW	Norm Power kW	Est Err kW
07/13/89	100%	1	26.5	11.3	75.7	923.4	59.2	64.1	.82
07/13/89	100%	1	26.9	16.8	51.0	929.9	59.6	64.2	.80
07/14/89	100%	2	25.5	11.4	76.2	911.3	60.5	66.4	.84
07/14/89	100%	2	25.6	11.4	76.2	911.2	60.4	66.3	.84
07/14/89	100%	2	25.8	11.4	76.4	909.6	60.6	66.6	.85
07/17/89	75%	3	26.3	8.8	76.3	962.8	46.6	48.4	.63
07/18/89	50%	4	25.7	5.9	76.2	951.9	31.3	32.9	.46
07/20/89	100%	4	25.7	11.5	76.3	941.0	60.8	64.6	.82
07/27/89	100%	5	24.2	10.8	76.3	879.8	57.5	65.3	.83
08/03/89	100%	6	24.2	11.9	74.1	940.0	61.2	65.1	.83
08/03/89	100%	7	24.6	12.4	73.0	963.3	63.0	65.4	.83
Typical Sigma:			0.2	0.05	0.2	5.0	0.3	0.4	

Notes:

- 1) Mirrors dirty, uncleaned for several months.
- 2) Mirrors freshly washed with de-ionized water.
- 3) Mirrors not cleaned for several days, some light dust.
- 4) Light rain caused mirrors to appear fairly dirty.
- 5) Mirrors rain-washed (heavy rain).
- 6) Mirrors washed with de-ionized water previous day, some light dust.
- 7) Aperture removed from calorimeter.

Prior to cleaning the mirrors, one test was performed with dirty mirrors to obtain the lower power limit that could be expected from the TBC. The mirrors had not been cleaned for several months and appeared very dirty visually. However, the difference between extremely dirty mirrors and freshly washed mirrors was only 2.5 kW maximum. Also, as indicated by the power levels with and without the 22-cm aperture, nearly all the power is contained in a 22-cm beam. Note that the power level for the full power test after the first cleaning (7/14/89) is slightly higher than the power level after the next cleaning (8/03/89). This may be explained by the fact that the first test was performed immediately following the cleaning, while the later test (8/03/89) was performed one day following the washing, allowing dust to settle for a few hours. Another possibility for the discrepancy is that the mirrors may have been initially scrubbed more vigorously initially to remove the heavy residue than the mirrors on the next washing. Also note that a rain-wash cleans the mirrors about as well as spraying the facets with de-ionized water.

The estimated error is based on the root-sum-square error analysis accounting for measurement errors and accuracy specifications with respect to the NIP reading, flowrate, reference temperature, and delta-temperature. The derivation of the equation used can be found in Appendix II.

Comparison With Past Tests

As indicated above, calorimetry had not been performed on TBC-1 since August 1985. At that time, the normalized power (without an aperture plate) was 78 kW. The temperature rise was recorded with RTDs, with thermocouples used as a check. The calibration accuracy of the instrumentation used during that experiment is not known. During the recent test, it was noted that the thermocouples indicated a temperature rise at least 1°C higher than the delta-T device, which would have resulted in an almost 10% increase in power. Also, the mirrors were much less corroded back in 1985. The 12-kW loss in power during the past four years is probably because of a combination of mirror degradation and measurement accuracy, but the breakdown of the difference is not known.

Conclusions

The calorimetry tests were performed with careful attention to calibrations and therefore accuracy. The accuracy of the power measurements is within 0.85 kW (1.3% at maximum power), based on the combination of all measurement errors and calibration accuracies.

The original advertised power of the TBCs was nearly 80 kW. TBC-1 will be used as a solar furnace in the near future. The losses from the attenuator shadowing (7.6%) and from the additional reflectance from the heliostat (10%) bring the full power level from 66 kW to 55 kW. Also, the Stirling Thermal Motors (STM) Stirling cycle engine (25 kW output) to be tested on one of the TBCs will require 69-kW input based on a 90% receiver efficiency and a 40% engine efficiency. Therefore, it is recommended that the mirror facets be replaced to maintain the effectiveness of these two concentrators. Without a doubt, the TBCs have easily been the most reliable, accurate, and rigid concentrators that have been tested at the Solar Thermal Test Facility to this date.

References

1. D. Wald, "Differential Temperature Transducer. An Iterative Method of Evaluating the Signal," Delta-T Company, Santa Clara, CA, n.d.
2. J.H. Keenan, F.G. Keyes, P.G. Hill, J.G. Moore, Steam Tables, Wiley-Interscience, New York, 1978.
3. E.O. Doebelin, Measurement Systems: Application and Design, McGraw-Hill, Inc., New York, 1983, pp. 58-67.




Figure 1. Cold-Water Cavity Calorimeter




Figure 2. TBC-1 Full-Power Calorimeter Test




Figure 3. Close-Up of Focal Point Area While On Sun





Figure 4. Target Board Following Mirror Facet Alignment Procedure

Appendix I - Sample Data Plot and Data Summary

CWCC #3 Mountain Standard Time HH:MM:SS	89/07/20	Increment of 1 records			METRIC UNITS		
	#10	#23	#18	#22	#38	#39	
	NIP41	FT738	TC021	DT100			
	Solar Flux W/m ²	CWCC Flow L/min	CWCC in Temp Deg C	CWCC Delta T Deg C	CWCC Heat gain kW	CWCC Norm Heat gain kW	
10:40:00	944.24	76.37	25.57	11.47	60.83	64.42	
10:40:06	942.77	76.20	25.54	11.48	60.71	64.40	
10:40:16	935.43	76.47	25.50	11.48	60.94	65.14	
10:40:31	942.77	76.17	25.60	11.48	60.68	64.36	
10:40:37	939.84	76.22	25.52	11.43	60.47	64.35	
10:40:46	941.30	76.32	25.55	11.48	60.82	64.61	
10:40:59	939.84	75.97	25.58	11.52	60.77	64.66	
10:41:06	945.71	76.70	25.53	11.48	61.11	64.62	
10:41:16	941.30	75.87	25.55	11.50	60.58	64.36	
10:41:29	944.24	76.30	25.58	11.52	61.04	64.64	
10:41:36	935.43	76.25	25.57	11.53	61.01	65.22	
10:41:46	944.24	76.61	25.56	11.48	61.04	64.65	
10:42:00	950.12	76.38	25.63	11.50	60.97	64.17	
10:42:06	942.77	76.37	25.54	11.50	60.97	64.68	
10:42:15	941.30	75.97	25.51	11.57	61.03	64.84	
10:42:29	950.12	76.36	25.58	11.55	61.21	64.42	
10:42:35	947.18	76.23	25.54	11.48	60.73	64.12	
10:42:45	945.71	76.58	25.56	11.48	61.01	64.51	
10:42:58	941.30	75.76	25.55	11.43	60.10	63.84	
10:43:05	942.77	76.51	25.58	11.45	60.83	64.52	
10:43:15	933.96	76.05	25.54	11.50	60.72	65.02	
10:43:30	935.43	76.34	25.59	11.45	60.69	64.88	
10:43:35	942.77	76.01	25.49	11.53	60.82	64.51	
10:43:44	942.77	76.61	25.50	11.50	61.17	64.89	
10:43:58	944.24	76.27	25.60	11.50	60.89	64.49	
10:44:04	935.43	76.51	25.54	11.41	60.58	64.76	
10:44:14	936.90	76.22	25.51	11.38	60.23	64.28	
10:44:27	942.77	76.43	25.55	11.52	61.14	64.85	
10:44:34	932.49	76.29	25.52	11.45	60.66	65.05	
10:44:44	933.96	76.42	25.52	11.36	60.26	64.52	
10:44:59	932.49	76.15	25.60	11.45	60.54	64.92	

Statistics for 31 data values.

Largest data value	950.115	76.696	25.634	11.573	61.207	65.218
Smallest data value	932.493	75.758	25.492	11.358	60.097	63.844
Range of data	17.622	.939	.142	.215	1.110	1.373
Arithmetic mean	941.020	76.287	25.552	11.479	60.792	64.603
Population Standard Deviation (Sigma)	4.832	.224	.035	.046	.278	.310
3-Sigma	14.497	.673	.104	.139	.833	.931
Population Variance	23.350	.050	.001	.002	.077	.096



Appendix II - Error Analysis

Calorimeter Error Analysis

The errors stated in this report were calculated using the root-sum-square method, i.e., the 3-sigma limit on the normalized power measurements. The root-sum-square error is defined as [Doebelin (3)]:

$$E_{\text{rss}} = \sqrt{\left(\Delta u_1 \frac{\partial \mathcal{E}}{\partial u_1}\right)^2 + \left(\Delta u_2 \frac{\partial \mathcal{E}}{\partial u_2}\right)^2 + \dots + \left(\Delta u_n \frac{\partial \mathcal{E}}{\partial u_n}\right)^2} \quad (1)$$

where

- u_i = measured quantity
- Δu_i = error in measured quantity
- $\frac{\partial \mathcal{E}}{\partial u_i}$ = partial derivative of the calculated function with respect to the measured quantity.

By performing an energy balance, the normalized power assuming steady-state conditions, no changes in kinetic or potential energy, can be derived as

$$\dot{Q} = \frac{I_o}{I} \dot{m} (h_2 - h_1) = \frac{I_o}{I} \rho \dot{V} (h_2 - h_1) \quad (2)$$

where

- \dot{Q} = normalized power
- I_o = direct normal insolation for standard conditions ($1000 \frac{\text{W}}{\text{m}^2}$)
- I = measured direct normal insolation
- \dot{m} = mass flowrate of cooling water
- ρ = density of water
- \dot{V} = volumetric flowrate of water
- h_2 = outlet enthalpy
- h_1 = inlet enthalpy.

Using the equations that duplicate the tables found in Keenan and Keyes (2), density is a function of the reference temperature; the inlet enthalpy is a function of pressure and the reference temperature; and the outlet enthalpy is a function of pressure, the reference temperature and the delta temperature through the calorimeter. Equation (2) becomes

$$\dot{Q} = \frac{I_o}{I} \rho (T_{ref}) \dot{V} \left[h_2(P, T_{ref}, dT) - h_1(P, T_{ref}) \right] \quad (3)$$

However, enthalpy is a very weak function of pressure at near atmospheric conditions and can be ignored without affecting the enthalpies to four decimal places. Therefore

$$\dot{Q} = \frac{I_o}{I} \rho (T_{ref}) \dot{V} \left[h_2(T_{ref}, dT) - h_1(T_{ref}) \right] \quad (4)$$

For this particular analysis, Equation 1 becomes:

$$E_{rss} = \sqrt{\left[\Delta I \frac{\partial \dot{Q}}{\partial I} \right]^2 + \left[\Delta T_{ref} \frac{\partial \dot{Q}}{\partial T_{ref}} \right]^2 + \left[\Delta dT \frac{\partial \dot{Q}}{\partial dT} \right]^2 + \left[\Delta \dot{V} \frac{\partial \dot{Q}}{\partial \dot{V}} \right]^2} \quad (5)$$

where

$$\frac{\partial \dot{Q}}{\partial I} = \frac{-I_o}{I^2} \rho (T_{ref}) \dot{V} \left[h_2(T_{ref}, dT) - h_1(T_{ref}) \right] \quad (6)$$

$$\begin{aligned} \frac{\partial \dot{Q}}{\partial T_{ref}} = & \rho (T_{ref}) \frac{I_o}{I} \dot{V} \frac{\partial h_2(T_{ref}, dT)}{\partial T_{ref}} + \frac{I_o}{I} \dot{V} h_2(T_{ref}, dT) \frac{\partial \rho(T_{ref})}{\partial T_{ref}} \\ & - \rho (T_{ref}) \frac{I_o}{I} \dot{V} \frac{\partial h_1(T_{ref})}{\partial T_{ref}} - \frac{I_o}{I} \dot{V} h_1(T_{ref}) \frac{\partial \rho(T_{ref})}{\partial T_{ref}} \end{aligned} \quad (7)$$

$$\frac{\partial \dot{Q}}{\partial dT} = \rho (T_{ref}) \frac{I_o}{I} \dot{V} \frac{\partial h_2(T_{ref}, dT)}{\partial dT} \approx \rho (T_{ref}) \frac{I_o}{I} \dot{V} \frac{\partial h_2(T_{ref}, dT)}{\partial T_{ref}} \quad (8)$$

$$\frac{\partial Q}{\partial V} = \rho(T_{\text{ref}}) \frac{I}{I} \left(\frac{h_2(T_{\text{ref}}, dT) - h_1(T_{\text{ref}})}{I} \right) \quad (9)$$

The polynomial for the density of water is

$$\rho = 10^3 \left(a + b T_{\text{ref}} + c T_{\text{ref}}^2 \right)^{-1} \quad (10)$$

Therefore,

$$\frac{\partial \rho}{\partial T_{\text{ref}}} = -10^3 \left(\frac{b + 2cT_{\text{ref}}}{\left(a + b T_{\text{ref}} + c T_{\text{ref}}^2 \right)^2} \right) \quad (11)$$

where

$$\begin{aligned} a &= .9999 \\ b &= 2.209 \times 10^{-7} \\ c &= 4.863 \times 10^{-6} \end{aligned}$$

The polynomial for the enthalpy of water is given as

$$h = a + b T_{\text{ref}} + c T_{\text{ref}}^2 \quad (12)$$

Therefore,

$$\frac{\partial h}{\partial T_{\text{ref}}} = b + 2cT_{\text{ref}} \quad (13)$$

where

$$\begin{aligned} a &= -9.590 \times 10^{-3} \\ b &= 4.203 \\ c &= -3.070 \times 10^{-4} \end{aligned}$$

The inlet enthalpy and slope, h_1 and $\frac{\partial h_1}{\partial T_{\text{ref}}}$, are evaluated at T_{ref} , while the outlet enthalpy and slope, h_2 and $\frac{\partial h_2}{\partial T_{\text{ref}}}$, are evaluated at $T_{\text{ref}} + dT$.

Example:

$$\begin{aligned}
 T_{\text{ref}} &= 25^\circ\text{C} \\
 dT &= 10^\circ\text{C} \\
 \dot{V} &= 76.5 \text{ l/min} = 1.275 \times 10^{-3} \text{ m}^3/\text{sec} \\
 I &= 950 \text{ W/m}^2 \\
 \Delta I &= 6.6 \text{ W/m}^2 \text{ (0.7\% of } I) \\
 \Delta T_{\text{ref}} &= 0.8^\circ\text{C} \text{ (Type T TC)} \\
 \Delta dT &= 0.04^\circ\text{C} \text{ (Manufacturer's specification)} \\
 \Delta \dot{V} &= .01275 \times 10^{-3} \text{ m}^3/\text{sec} \text{ (1\% of } \dot{V}).
 \end{aligned}$$

Using these values in the above equations yields

$$\rho = 997 \text{ kg/m}^3$$

$$\frac{\partial \rho}{\partial T_{\text{ref}}} = -.242 \frac{\text{kg}}{\text{m}^3 \cdot \text{C}}$$

$$h_1 = h(T_{\text{ref}}) = 104.9 \text{ kJ/kg}$$

$$h_2 = h(T_{\text{ref}} + dT) = 146.7 \text{ kJ/kg}$$

$$\frac{\partial h_1(T_{\text{ref}})}{\partial T_{\text{ref}}} = \frac{\partial h}{\partial T_{\text{ref}}}(T_{\text{ref}}) = 4.188 \frac{\text{kJ}}{\text{kg} \cdot \text{C}}$$

$$\frac{\partial h_2 (T_{\text{ref}}, dT)}{\partial T_{\text{ref}}} = \frac{\partial h}{\partial T_{\text{ref}}} (T_{\text{ref}} + dT) = 4.182 \frac{\text{kJ}}{\text{kg-C}}$$

Substituting these values into Equations (6) through (9) yields

$$\frac{\partial \dot{Q}}{\partial I} = -.059 \frac{\text{kW} \cdot \text{m}^2}{\text{W}}$$

$$\frac{\partial \dot{Q}}{\partial T_{\text{ref}}} = -.022 \text{ kW}/^\circ\text{C}$$

$$\frac{\partial \dot{Q}}{\partial dT} = 5.596 \text{ kW}/^\circ\text{C}$$

$$\frac{\partial \dot{Q}}{\partial V} = 43,868 \text{ kJ}/\text{m}^3$$

Substituting into Equation (1), the root-sum-square error becomes

$$E_{\text{rss}} = \sqrt{.152 + 3.098 \times 10^{-4} + .050 + .313} \quad \text{kW} \quad (14)$$

$$E_{\text{rss}} = .72 \text{ kW.}$$

By noting the relative size of the terms in Equation (14), the largest errors come from the calibration accuracies of the pyrheliometer and the flowmeter.

DISTRIBUTION:

AAI Corporation
York Rd. & Industry Lane
Cockeysville, MD 21030-0126

Acurex Aerotherm
Attn: H. Morse
555 Clyde Avenue
Mountain View, CA 94039

Alabama A&M University (2)
Department of Physics
Attn: M. D. Aggarwal,
A. Tan
P.O. Box 271
Normal, AL 35762

Alpha Solarco, Inc.
11534 Gondola Dr.
Cincinnati, OH 45241

Applied Concepts
Attn: J. S. Hauger
107 North Kent St.
Suite 200
Winchester, VA 22601

Applied Concepts
Attn: S. Pond
2501 S. Larimer County Rd. 21
Berthound, CO 80513

Argonne National Laboratory
Attn: Robert E. Holtz
Materials and Components Technology Div.
9700 South Cass Avenue
Argonne, IL 60439

Arizona Public Service Co.
Attn: J. McGuirk
P.O. Box 53999
Phoenix, AZ 85072-3999

B&E Technical Services Inc.
Attn: William R. Lang
6314 S. Piccadilly St.
Aurora, CO 80016

Barber-Nichols Engineering
Attn: R. Barber
6325 West 55th Ave.
Arvada, CO 80002

BDM Corporation
Attn: W. E. Schwinkendorf
1801 Randolph Street
Albuquerque, NM 87106

Battelle Memorial Institute
Pacific Northwest Laboratory
Attn: K. Drumheller
4000 NE 41st St.
Seattle, WA 98105

Battelle Memorial Institute
Pacific Northwest Laboratory
Attn: T. Williams
P.O. Box 999
Richland, WA 99352

Bechtel Group, Inc.
Attn: P. DeLaquil
P.O. Box 3965
50 Beale Street
San Francisco, CA 94119

Black & Veatch
Attn: J. C. Grosskreutz
P.O. Box 8405
Kansas City, MO 64114

Boeing Engineering & Construction
Attn: R. Gillette
P.O. Box 3999
Seattle, WA 98124

The Budd Company
Attn: W. W. Dickhart
1515 Atlantic Blvd.
Auburn Hills, MI 48055

The Budd Company
Plastic R&D Center
Attn: K. A. Iseler
356 Executive Drive
Troy, MI 48084

Burns & Roe
Attn: J. Whipple
800 Kinderkamack Road
Oradell, NJ 07649

California Energy Commission
Attn: Alec Jenkins
1516 - 9th Street
Sacramento, CA 95814

Cal Poly State University
Attn: E. J. Carnegie
San Luis Obispo, CA 93407

California Institute of Technology
Aeronautics Library
Attn: Jean Anderson
MS 205-45
Pasadena, CA 91125

California Polytechnic University
Dept. of Mechanical Engineering
Attn: W. B. Stine
Pomona, CA 91768

Chicago Bridge and Iron
Attn: J. M. Shah
800 Jorie Blvd.
Oak Brook, IL 60521

Clarkson University
Attn: Eric F. Thacher
Mechanical Engineering Dept.
Potsdam, NY 13676

Colorado State University
Attn: T. G. Lenz
Ft. Collins, CO 80523

Columbia Gas System Service Corp.
Attn: J. Philip Dechow
1600 Dublin Road
Columbus, OH 43215

Cummins Engine Company (2)
Attn: Dr. Isoroku Kubo
Mail Code 50179
Box 3005
Columbus, IN 47202-3005

Datron Systems, Inc.
200 West Los Angeles Ave.
Simi Valley, CA 93065-1650

DSET
Attn: G. A. Zerlaut
Box 1850
Black Canyon Stage I
Phoenix, AZ 85029

Donnelly Corporation
Attn: M. DeVries
49 West Third Street
Holland, MI 49423

Electric Power Research Inst. (2)
Attn: E. A. Demeo,
J. E. Cummings
3412 Hillview Avenue
Palo Alto, CA 94303

Energy Technology Engr. Ctr.
Rockwell International Corp.
Attn: W. L. Bigelow
P.O. Box 1449
Canoga Park, CA 91304

ENTECH, Inc. (3)
Attn: R. R. Walters,
W. Hesse,
M. O'Neill
P.O. Box 612246
DFW Airport, TX 75261

Eurodrive, Inc.
30599 San Antonio Rd.
Hayward, CA 94544

Florida Solar Energy Center
Attn: Library
300 State Road 401
Cape Canaveral, FL 32920

Ford Motor Company
Glass Div., Technical Center
Attn: V. L. Lindberg
25500 West Outer Drive
Lincoln Park, MI 48246

Foster Wheeler Solar Dev. Corp. (2)
Attn: M. D. Garber,
R. J. Zoschak
12 Peach Tree Hill Road
Livingston, NJ 07039

Garrett Turbine Engine Co.
Attn: Ed Strain
111 South 34th Street
P.O. Box 5217
Phoenix, AZ 85010

Georgia Power Co. (2)
Attn: E. Ney,
E. Ellingston
7 Solar Circle
Shenandoah, GA 30264

Heery Energy Consultants, Inc.
Project Energy Manager
Attn: Glenn Bellamy
880 West Peachtree St. NW
Atlanta, GA 30309

Highland Plating
Attn: M. Faith
10001 N. Orange Drive
Los Angeles, CA 90038

Industrial Solar Technologies
Attn: Randy Gee
5775 West 52nd Ave.
Denver, CO 80212

Institute of Gas Technology
Attn: Library
34245 State Street
Chicago, IL 60616

Jet Propulsion Laboratory
Attn: M. Alper
4800 Oak Grove Drive
Pasadena, CA 91109

Kearney & Associates
Attn: David W. Kearney
14022 Condessa Drive
Del Mar, CA 92014

LaCour Kiln Service
Attn: J. A. LaCour
P.O. Box 247
Canton, MS 39046

LaJet Energy Co. (2)
Attn: Monte McGlaun,
Carl Williams
P.O. Box 3599
Abilene, TX 79604

Lawrence Berkeley Laboratory
Building 90-2024
University of California
Attn: Dr. Arlon Hunt
1 Cyclotron Road
Berkeley, CA 94720

L'Garde Inc.
Attn: Mitchell Thomas
15181 Woodlawn Ave.
Tustin, CA 92680-6419

John Lucas
865 Canterbury Road
San Marino, CA 91108

Luz International Limited
Attn: Dr. D. W. Kearney
924 Westwood Blvd.
Los Angeles, CA 90024

McCarter Corporation
Attn: R. A. Powell
200 E. Washington St.
P.O. Box 351
Norristown, PA 19404

McDonnell-Douglas Astronautics
Company (3)
Attn: R. L. Gervais,
J. Rogan,
D. Steinmeyer
5301 Bolsa Avenue
Huntington Beach, CA 92647

Mechanical Technology, Inc. (2)
Attn: G. R. Dochat,
J. Wagner
968 Albany Shaker Road
Latham, NY 12110

Meridian Corporation
Attn: D. Kumar
4300 King St.
Suite 400
Alexandria, VA 22302-1508

Midwest Research Institute (2)
Attn: R. L. Martin,
J. Williamson
425 Volker Blvd.
Kansas City, MO 64110

NASA Lewis Research Center
Attn: R. Corrigan, M/S 500-316
T. McCoy, M/S 301-5
R. Puthoff
J. Savino, M/S 301-5
R. Shaltens, MS 301-2
J. Slaby, M/S 301-2
21000 Brookpark Road
Cleveland, OH 44135

New Mexico Solar Energy Institute
New Mexico State University
Box 3SOL
Las Cruces, NM 88003

Parsons of California
Attn: D. R. Biddle
P.O. Box 6189
Stockton, CA 95206

PG&E (2)
Attn: J. Iannucci,
G. Braun
3400 Crow Canyon Rd.
San Ramon, CA 94583

Power Kinetics, Inc.
Attn: W. E. Rogers
415 River Street
Troy, NY 12180-2822

Renewable Energy Institute
Attn: Kevin Porter
1001 Connecticut Avenue NW
Suite 719
Washington, DC 20036

Rockwell International
Rocketdyne Div.
Attn: T. Springer
6633 Canoga Ave.
Canoga Park, CA 91304

Rockwell International
Space Station Systems Division
Attn: I. M. Chen
12214 Lakewood Blvd.
Downey, CA 90241

Sanders Associates
Attn: J. Kesseli
NCA 1-6220
CS 2034
Nashua, NH 03061-2034

Science Applications
International Corp.
Attn: Barry Butler
10401 Roselle Street
San Diego, CA 92121

Solactor Corporation
Attn: Joseph Womack
12900 Auralia Rd.
Miami, FL 33181

Solar Energy Industries Association (2)
Attn: C. LaPorta,
S. Sklar
Suite 610
1730 North Lynn St.
Arlington, VA 22209-2009

Solar Energy Research Inst. (5)
Attn: B. P. Gupta,
J. Thornton,
M. Murphy,
D. Hawkins,
G. Nix
1617 Cole Blvd.
Golden, CO 80401

Solar Kinetics, Inc.
Attn: J. A. Hutchison
P.O. Box 540636
Dallas, TX 75354-0636

Solar Steam
Attn: D. E. Wood
P.O. Box 32
Fox Island, WA 98333

Southern California Edison
Attn: C. Lopez
P.O. Box 800
Rosemead, CA 92807

SLEMCO
Attn: A. J. Slemmons
19655 Redberry Dr.
Los Gatos, CA 95030

Stearns-Catalytic Corp.
Attn: T. E. Olson
Box 5888
Denver, CO 80217

Stirling Technology Company (2)
Attn: Mr. Maurice A. White
2952 George Washington Way
Richland, WA 99352

Stirling Thermal Motors
Attn: Ted Godett
2841 Boardwalk
Ann Arbor, MI 48104

Sun Exploration and Production Co.
Attn: R. I. Benner
P.O. Box 2880
Dallas, TX 75221-2880

Sun Power, Inc.
Attn: Mac Thayer
6 Byard St.
Athens, OH 45701

Sundstrand ATG
Attn: D. Chaudoir
P.O. Box 7002
Rockford, IL 61125

Sunsteam
Attn: Eric Micko
998 San Antonio Rd.
Palo Alto, CA 94303

Suntec Systems, Inc. (2)
Attn: Harrison Randolph,
J. H. Davison
Suite B-4
Loring Park Office Bldg.
430 Oak Grove St.
Minneapolis, MN 55403

Swedlow, Inc.
Attn: E. Nixon
12122 Western Avenue
Garden Grove, CA 92645

3M-Energy Control Products (2)
Attn: B. Benson,
J. L. Roche
207-1W 3M Center
St. Paul, MN 55144

Texas Tech University
Dept. of Electrical Engineering
Attn: E. A. O'Hair
P.O. Box 4439
Lubbock, TX 79409

Thermacore, Inc. (2)
Attn: Mr. Donald Ernst
780 Eden Road
Lancaster, PA 17601

TRW (3)
Space & Technology Group
Attn: G. M. Reppucci,
A. D. Schoenfeld,
J. S. Archer
One Space Park
Redondo Beach, CA 90278

U.S. Department of Energy (3)
Albuquerque Operations Office
ETWMD
Attn: C. Garcia,
G. Tennyson,
N. Lackey
P.O. Box 5400
Albuquerque, NM 87185

U.S. Department of Energy
Office of Solar Heat Technologies
Attn: Fred Morse
Forrestal Building
Washington, DC 20585

U.S. Department of Energy
Office of Solar Heat Technologies
Attn: C. Carwile
Forrestal Building
Washington, DC 20585

U.S. Department of Energy (5)
Division of Solar Thermal Tech.
Attn: Howard S. Coleman,
R. Shivers,
S. Gronich,
M. Scheve,
F. Wilkins
Forrestal Building
Washington, DC 20585

U.S. Department of Energy
San Francisco Operations Ofc.
Attn: R. W. Hughey
1333 Broadway
Oakland, CA 94612

U.S. Robotics
Attn: Paul Collard
8100 N. McCormack Blvd.
Skokie, IL 60076

University of Houston (2)
Energy Laboratory; SPA
Attn: Lorin Vant-Hull,
A. F. Hildebrandt
Houston, TX 77004

University of Houston
Dept. of Chem. Engineering
Attn: J. T. Richardson
Houston, TX 77204-6052

University of Minnesota
Dept. of Mechanical Engineering
Attn: E. A. Fletcher
111 Church St., S.E.
Minneapolis, MN 55455

University of New Mexico (2)
Department of Mechanical Engr.
Attn: M. W. Wilden,
W. A. Gross
Albuquerque, NM 87131

Viking Solar Systems, Inc.
Attn: George Goranson
1850 Earlmont Ave.
La Canada, CA 91011

WG Associates
Attn: Vern Goldberg
6607 Stonebrook Circle
Dallas, TX 75240

Australian National University
Department of Engineering Physics
Attn: Prof. Stephen Kaneff
P.O. Box 4
Canberra ACT 2600, AUSTRALIA

DLR (2)
Institute for Technical Thermodynamics
Attn: R. Buck,
R. Kohne
Pfaffenwaldring 38-40
7000 Stuttgart 80
FEDERAL REPUBLIC OF GERMANY

Wolfgang Schiel
Schlaich, Bergermann und Partner
Hohenzollernstr. 1
D-7000 Stuttgart 1
FEDERAL REPUBLIC OF GERMANY

400 J. A. Leonard
1510 J. W. Nunziato
1512 R. D. Skocypec
1513 D. W. Larson
1513 R. E. Hogan
1820 J. B. Woodard
1840 R. E. Loehman
1841 R. E. Loehman, Actg.
1842 B. C. Bunker
1846 D. H. Doughty
2520 N. J. Magnani
2525 R. P. Clark
2540 G. N. Beeler
2541 J. P. Abbin
3141 S. A. Landenberger (5)
3151 W. I. Klein (3)
3154-1 C. L. Ward (8) for DOE/OSTI
3160 J. E. Mitchell
4031 R. P. Stromberg
6000 D. L. Hartley
6200 V. L. Dugan
6210 B. W. Marshall
6215 J. T. Holmes
6215 K. S. Rawlinson (20)
6216 C. E. Tyner
6217 P. C. Klimas
6220 D. G. Schueler
6221 E. C. Boes
6223 G. J. Jones
6224 D. E. Hasti
6225 H. M. Dodd
7470 J. L. Ledman
7471 D. L. Stewart

8470 R. L. Rinne
8471 A. C. Skinrod
8524 J. A. Wackerly



8232-2/070147



00000001 -



8232-2/070147



00000001 -



8232-2/070147



00000001 -

