# SAND74-0375

Unlimited Release UC-13

# Selection of Parabolic Solar Collector Field Arrays

G. W. Treadwell

Prepared by Sandia Laboratories, Albuquerque, New Mexico 87115 and Livermore, California 94550 for the United States Energy Research and Development Administration under Contract AT(29-1)-789

Printed May 1975





Issued by Sandia Laboratories, operated for the United States Atomic Energy Commission by Sandia Corporation.

# NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

SF 1004-DF(2-74)

Printed in the United States of America

Available from National Technical Information Service U. S. Department of Commerce 5285 Port Royal Road Springfield, Virginia 22151 Price: Printed Copy \$4.00; Microfiche \$2,25 SAND74-0375 Unlimited Release Printed May 1975 UC-13

## SELECTION OF PARABOLIC SOLAR COLLECTOR FIELD ARRAYS

G. W. Treadwell Solar Energy Projects Division 5712 Sandia Laboratories Albuquerque, New Mexico 87115

#### ABSTRACT

A technique has been developed whereby the number of columns and rows of parabolic solar collectors required to achieve a given task can be determined for steady state operational conditions.

# TABLE OF CONTENTS

	Page
Introduction	5
Analyses of Field Arrays	5
Limits	5
Evaluation Designs	5
Computer Code	7
Determination of Minimum Acceptable Flow Rate	7
Determination of Maximum Allowable Flow Rate	10
Summary	12
References	13
APPENDIX A - Computer Code	14
APPENDIX B - Velocity and Pump Work Calculations	15

#### SELECTION OF PARABOLIC SOLAR COLLECTOR FIELD ARRAYS

#### Introduction

Among the numerous problems which must be addressed in the design, layout, and control of a parabolic solar collector field are the number of rows and columns of the parabolic solar collectors required to achieve a given task. There are many influencing factors, including the required liquid temperature rise, the volume flow rate, the temperature of operation, external environmental conditions, collector design, and solar tracking technique.

This particular problem has been analyzed rather thoroughly by Lee, Schimmel, and Abbin.<sup>1</sup> However, the analysis excluded wind losses and collector design variations. In addition, the noted work was not reduced to a set of design curves. The purpose of this study is to analyze the influence of varying solar insolation, collector design variations, and external environmental conditions, and to present the material in such a manner that selection of field arrays can be easily made as a function of differing requirements.

#### Analyses of Field Arrays

#### Limits

It is obvious that when there is no liquid flow through a solar collector field, the energy collected, or collector efficiency, is zero. One can also imagine the situation in which the liquid must be pumped through an array at such a high velocity that the pump work required due to friction losses could equal the energy absorbed by the collectors. Both situations are obviously undesirable, but they illustrate the approach taken in the present analysis, which is to select arrays that will operate within acceptable flow limits. The object is to establish flow rate limits which permit adequate energy collection and have acceptable pump losses.

In order to accomplish this, most factors which are normally considered as variable must be held as constant for the moment (e.g. wind velocity, sink temperature, receiver tube size, etc.). Furthermore, certain limits of validity must be assumed for the results to allow a more compact presentation. For example, the total hemispherical emittance of an absorber coating changes slightly with operating temperature. In this study, as will be shown, it is reasonable to assume that the results are not significantly affected by the variations in operating temperatures.

#### Evaluation Designs

The basic collector design selected for analysis consists of a 2.745 x 3.66 m (9 x 12 feet) parabolic reflector with a  $90^{\circ}$  rim angle.<sup>2</sup> The receiver tube design is shown in Figure 1. The

calculated tube diameter is 1.67 inches.<sup>2</sup> The glass envelope annulus is approximately 0.35 in. to prevent convection losses across the unevacuated gap. This study was conducted without a vacuum in the gap.



Figure 1

As a variation in the design, internal tubular plugs to force annular liquid flow within the receiver tubes are also included. Although plugs will cause lower Reynolds numbers, the change in the hydraulic diameter results in an increase in the film coefficient of heat transfer and there-fore a higher collector efficiency.

The reflectance of the mirror surface is important. For this study, two values were used,  $\rho = 0.68$  and  $\rho = 0.78$ . A measured specular reflectance, within a 10 milliradian solid angle, of Alzac<sup>\*</sup> specimens is 0.68<sup>3</sup>; 0.78 represents the reflectance of a material yet to be defined.

The fluid used for this study is Therminol  $66^{\dagger}$ , a liquid used in heat transfer applications.

\* Alcoa

<sup>&</sup>lt;sup>†</sup> Monsanto Industrial Chemicals Co.

#### Computer Code

The analysis was conducted with the use of the code developed by M. W. Edenburn.<sup>4</sup> The code was modified slightly (Appendix A). This code analyzes heat balances along incremental lengths of the receiver tube. In this analysis, the collector axis was always normal to the sun. As will be seen, this approach allows nonnormality to be handled through simple manual calculations and therefore allows the results to be applicable to either north-south or east-west collector orientations since the analysis considers one collector at a time.

#### Determination of Minimum Acceptable Flow Rate

The results of a number of computer runs for a given set of conditions as listed in the legend are portrayed on Figure 2. Inspection of Figure 2 reveals that the efficiency curves, in general, have a significant slope change in the vicinity of a volume flow rate equal to 0.00008  $m^3/sec$ . The effect of internal plugs is to permit slower flow for the same efficiency as non-plugged receiver tubes. The efficiency relates directly to the energy absorbed in the collector fluid  $\left[e. g., 1003 \frac{W}{m^2} \left(\frac{1 J}{Wsec}\right) (2.743m) (3.658m) (50\% efficiency) = 5032 \frac{J}{sec} energy absorbed\right];$  therefore, it is very desirable for the volume flow rate to be such that the efficiency remains to the right of the knee in Figure 2.



If the minimum flow rate is limited to 0.00008 m<sup>3</sup>/sec, it is observed that a 10<sup>o</sup>C temperature change of the liquid in the receiver tube cannot be obtained with a solar insolation of 315  $\frac{W}{m^2}$ ; an insolation of approximately 475  $\frac{W}{m^2}$  would be required (see intersection of dotted lines).

A collector requiring a temperature rise of  $10^{\circ}$ C could be operated between insolation limits of  $475 \frac{W}{m^2}$  and  $1003 \frac{W}{m^2}$ , with corresponding flow rates between 0.00008  $\frac{m^3}{sec}$  and 0.00028  $\frac{m^3}{sec}$ .

If it is assumed that Figure 2 applies to collectors connected in series, a series of 10 nonplugged collectors, with a flow of 0.00028  $\frac{\text{m}^3}{\text{sec}}$  and solar insolation of  $1003 \frac{\text{W}}{\text{m}^2}$ , can achieve a  $100^{\circ}$ C temperature rise. At an insolation of 757  $\frac{\text{W}}{\text{m}^2}$  and a flow rate of 0.00040  $\frac{\text{m}^3}{\text{sec}}$ , 20 collectors in series will achieve a  $100^{\circ}$ C temperature rise.

Once the required temperature rise through a string of collectors is established, inspection of Figure 2 permits determination of the number of collectors in series and the flow rate limits.

In Figure 3, the mirror reflectance has been lowered when compared to Figure 2 data. The minimum flow rate should still be  $0.00008 \frac{\text{m}^3}{\text{sec}}$ . A review of Figure 3 shows that for insolations between 599 W/m<sup>2</sup> and 915 W/m<sup>2</sup>, 20 collectors in series could be operated at flow rates between  $0.00026 \text{ m}^3$ /sec and  $0.00045 \text{ m}^3$ /sec and 10 collectors in series could be operated at flow rates between  $0.00012 \text{ m}^3$ /sec and  $0.00022 \text{ m}^3$ /sec to maintain a total temperature rise of  $100^{\circ}$ C. In essence, the minimum acceptable insolation determines the lowest flow rate and options for the number of collections in series. As can be judged from Figure 3, 20 collectors in series can operate at lower insolation levels than 10 in series without going below a flow rate of  $0.00008 \text{ m}^3$ /sec.

In for foregoing examples, the data on Figures 2 and 3 have been assumed to be valid for approximately a  $100^{\circ}$ C range. This is not an unreasonable assumption, as will be illustrated through the use of Figure 4. This figure illustrates changes in efficiencies and temperature changes due to collector operation at temperatures other than  $260^{\circ}$ C ( $500^{\circ}$ F). Inspection of Figure 4 reveals a linearity of the  $\Delta$ T curves and a slight nonlinearity in the efficiency curves. For example, at a flow rate of 0.000285 m<sup>3</sup>/sec:

$$\Delta T \ 204^{\circ}C = 11.1^{\circ} \\ \Delta T \ 316^{\circ}C = 8.9^{\circ} \\ \epsilonff. \ 204^{\circ}C = 59.9\% \\ eff. \ 316^{\circ}C = 51.5\% \\ \epsilonff. \ = 55.7\% \ vs \ eff. \ 260^{\circ}C = 55.1\%$$



Figure 4

As has been illustrated, the  $260^{\circ}C$  plots from Figures 2 and 3 can be used within minimal  $\Delta T$  error for a collector string inlet temperature range from  $204^{\circ}C$  to  $316^{\circ}C$ . A small error may accrue if the efficiency data are used.

#### Determination of Maximum Allowable Flow Rate

If some fraction of the energy collected, say 1 percent of the maximum, is allowed for pump work to drive the liquid through the collectors, the maximum velocity and volume flow rate can be established as shown in Appendix B. The pump work limit, for liquid flow through a collector using the results from Appendix B, is shown in Figure 5. Using the presented data, the maximum allowable flow is  $0.00258 \text{ m}^3$ /sec. Should a 0.0318 m plug be used, the maximum allowable flow would be  $0.000661 \text{ m}^3$ /sec.

These data hold for contiguous collectors. Should collectors be separated as in a northsouth field layout, in which each collector individually tracks the sun, the interconnecting fluid lines between them would lose energy due to thermal losses and pumping losses. An approximation of these losses, which results in decreasing the maximum allowable flow rate, is also shown in Figure 5.<sup>\*</sup> East-west contiguous collectors will also have some line thermal and pump losses but not of the magnitude of the north-south arrangement.

The result of these considerations is that more collectors, for a horizontal surface construction, can be used in an east-west string than in a north-south string due to these interconnecting line losses. Each situation must be individually calculated to determine its flow limits; however, 20 collectors in an east-west series appear feasible before the 1 percent limit is exceeded.

For the collector design given in Figure 3, the resulting pump work calculations are as shown in Table I. In the situation of Condition 7, 20 collectors in series would exceed the 1 percent energy limitation.

 $^{*}_{\mathrm{~By~comparison}}$  of the pump limits and the pump and line loss limits



TABLE I

Condition	Field Array	Plug Diameter (m)	Solar Insolation (W/m <sup>2</sup> )	1% Energy Available To Pump (w/collector	Liquid Velocity ) (m/sec)	Allowable Max Flow Rate (m <sup>3</sup> /sec)	Desired Max Flow Rate (m <sup>3</sup> /sec)	Desired Liquid Velocity (m/sec)	Energy to Pump to Achieve Needs (w/collector)
1	10 Collectors In Series	0	915	7.07	1.77	0.002021	0.000216	0.19	0.008
2		0	599	4.07	1.47	0.001680	0.000125	0.11	0.002
3		0.0318	915	7.30	1.22	0.000418	0.000224	0.66	1.15
4		0.318	599	4.27	1.01	0.000346	0.000130	0.38	0.224
5	20 Collectors In Series	0	915	7.21	1.78	0.002033	0.000440	0.39	0.075
6		0	599	4.21	1.49	0.001700	0.000255	0.23	0.015
7		0.0318	915	7.33*	1.22	0.000419	0.000445	1.30	8.99*
8		0.0318	599	4.33	1.01	0.000347	0.000265	0.78	1.90

Pump Work Calculations for Data From Figure 3

\*Need exceeds 1% energy limit.

For the conditions considered, 20 collectors in series are probably the maximum number which should be used. The determination of the number of parallel rows then is then calculated by dividing the total energy needs by the energy gain from one string of collectors in series.

The data shown in Figures 2 through 5 are based upon normal insolation. These data are applicable to conditions other than normal insolation by applying the cosine angle effect. Therefore, north-south collectors that are not fully sun-tracking and east-west collectors can still be analyzed using these Figures [e.g. with the sun at a 41<sup>°</sup> angle from normal, the insolation would be (1003 W/m<sup>2</sup>) (0.75471) or 757 W/m<sup>2</sup>].

#### Summary

A technique has been developed whereby the number of columns and rows of collectors, north-south or east-west, required to achieve a given task can be determined. This technique is based upon the establishment of a minimum volume flow rate, for the conditions considered, of  $0.00008 \text{ m}^3$ /sec because of a collector efficiency decrease. It also permits the establishment of a maximum volume flow rate, for the conditions considered, of approximately  $0.00045 \text{ m}^3$ /sec. This limit is based upon an arbitrary pump work and line thermal loss amount. Extrapolations and interpolations of these results can be performed depending upon the establishment and use of other designs and conditions.

#### References

- 1. D. O. Lee, W. P. Schimmel, Jr., and J. P. Abbin, Jr., <u>Sizing of Focused Solar</u> <u>Collector Fields with Specified Collector Tube Inlet</u>, SAND74-0295, Sandia Laboratories, <u>Albuquerque</u>, N. M., 1974.
- 2. The justification is contained in <u>Solar Total Energy Program Quarterly Report</u> <u>July - September 1974</u>, SAND74-0391, Sandia Laboratories, Albuquerque, New Mexico, November 1974.
- 3. Unpublished measurement results for 10 milliradian aperature per R. B. Pettit, Division 5842, to the author.
- 4. M. W. Edenburn, <u>Performance of a Focusing Cylindrical Parabolic Solar Energy</u> <u>Collector: Analysis and Computer Program, SLA-74-0031, Sandia Laboratories,</u> <u>Albuquerque, New Mexico, April 1974.</u>

• 4

	D OLDPL	IDENT	PERN		UPDATE V1,2	06/28/74	14,53,30,
***DUPL)	CATE IDENT CHANGED	TO PERN.	***		,	· .	. <b>.</b>
****	+IDENT PERN ★INSERT FOCL.307 GO TO 90			- - -			
UNLABEL	ED OLDPL	IDENT	DO		UPDATE V1,2	06/28/74	14.53,30,
*****	+TDENT DO LOOP	· ·					
11111	+INSEPT FORM 19						
	CFMV0L=.0004	ŧ					
	D0 500 LACE=	:1,11					
11111	*INSERT FOCL,220						
	500 FMVOL=FMVOL-	•CFMVQL					
****	+DELETE FOCL 210,F	OCL 212					
****	+DELETE FOCL 214,F	OCL,216					
11111	*DELETE FOCL,331,F DATA (TEMF() 1477,,505,,53 DATA (PR())	'UCL,337  ),I=1,15)/22 33.,561,,589, ,I=1,15)/6.67	25,,283,,311,, ,616,,644,/ 7E+05,3040,,36	339,,366,,394, 6,,138,,63,2,3	,422,,450,, 9,3,26,9,		
	110 6 14 5 12		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		0.01		
	119,6,14,5,12 DATA (VISC()	(), I=1,15)/62	?,,255,028,.	0098,0042,00	124, 0016,		
	119 6,14 5,12 DATA (VISC(1 1 0011 0007	L),I=1,15)/62 78,,00058,.00	2,,255,028, )045,00036,0	0031,00027,0	124, 0016,	•	•
	119,6,14,5,12 DATA (VISC() 1 0011,0007 *DELETE FOCL,339	[),I=1,15)/62 78,,00058,.00	2,,255,028, )045,00036,0	0031,00027,0	124,0016, 1002/		•
	119,6,14,5,12 DATA (VISC(1 1 0011,0007 *DELETE FOCL 339 DO 10 I=1,15	; ;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;	2,,.255,,028,. )045,,00036,0	0031,00027,0	124,,0016, 1002/		·
	119.6,14.5,12 DATA (VISC(1 1 0011,0007 *DELETE FOCL.339 DO 10 I=1,15 *DELETE FOCL.351,F	; ;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;	2,,255,028, )045,00036,0	0031,00027,0	24, 0018, 002/		• • • •
 	119.6,14.5,12 DATA (VISC(1 1 0011.0007 *DELETE FOCL.339 DO 10 I=1,15 *DELETE FOCL.351,F 40 PRA=PP(15)	; ;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;	2,,,255,,028,. )045,,00036,0	0031,00027,0	24, 0016, 0002/		• • •
,,,,, ,,,,,	119.6,14.5,12 DATA (VISC(1 1 0011 0007 *DELETE FOCL 339 DO 10 I=1,15 *DELETE FOCL 351,F 40 PRA=PP(15) VISCO=VISC(1	5) 1), I=1,15)/62 78,,00058,,00 5 10CL,353	2,,,255,,028,. )045,,00036,0	0031,00027,0	24, 0016, 0007/		•
,,,,,, ,,,,,	119.6,14.5,12 DATA (VISC(1 1.0011.0007 *DELETE FOCL.339 DO 10 I=1,15 *DELETE FOCL.351,F 40 PRA=PP(15) VISCO=VISC(1 50 CONTINUE	2,9,9,83,8,8,8,8 1),I=1,15)/62 78,,00058,,00 5 CCL,353 L5)	2,,,255,028,. 0045,,00036,0	0031,00027,0	124, 0016, 1002/		• • • •
*****	119.6,14.5,12 DATA (VISC(1 1.0011.0007 *DELETE FOCL.339 DO 10 I=1,15 *DELETE FOCL.351,F 40 PRA=PP(15) VISCO=VISC(1 50 CONTINUE *DELETE FOCL.290 VISC=2.0E-05	; ; ; ; ; ; ; ; ; ; ; ; ; ;	2,,,255,028, 0045,,00036,0	0031,00027,0	24, 0016, 0002/		· · · · · · · · · · · · · · · · · · ·
·/////	119.6,14.5,12 DATA (VISC(1 1.0011.0007 *DELETE FOCL.339 DO 10 I=1,15 *DELETE FOCL.351,F 40 PRA=PP(15) VISC0=VISC(1 50 CONTINUE *DELETE FOCL.290 VISC=2.0E=05 *DELETE FOCL.354 COND=.137710	;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;;	7TEM)	0031,00027,0	24, 0016, 0002/		· · · ·

# APPENDIX A

n n n Niteration Niteration

APPEN

#### APPENDIX B

Velocity and Pump Work Calculations

# A. NO PLUG

### Energy into Liquid

Collector Surface Area:  $(9 \text{ ft x } 12 \text{ ft}) = 108 \text{ ft}^2 (10.029 \text{ m}^2)$ Maximum Solar Insolation:  $318 \text{ Btu/ft}^2$ -hr  $(1003 \text{ W/m}^2)$ Intercepted Energy: 318 (108) = 34344 Btu/hr(9853.2 W)(Figure 2) 10 Collectors in Series; No Plug; Flow of 0.00028 m<sup>3</sup>/sec; Efficiency = 54.1% Energy Gain in Liquid: (0.541) (34344) = 18580.1 Btu/hr

(5443.41 W)

Pump Work

@ 1% Energy for Pump Work: (0.01) (18580.1) = 185.80 Btu/hr (54.4 W)

@ 17% Turbo-Generator Efficiency:  $\frac{(0.17) (185.80) (778 \text{ ft-lb/ Btu})}{3600 \text{ sec/hr}}$ 

= 6.83 ft - 1b/sec (9.26W)

Energy Available for Pump Work @ 78% pump Efficiency:

(6.83) (0.78) = 5.325 ft-1b/sec (7.22W)

#### Velocity Determination

Mass Flow Rate x Head Loss = Available Pump Work

$$\frac{lb}{sec} \propto ft = \frac{ft-lb}{sec}$$

$$(\rho AV) \propto \left( f \frac{L}{D} \frac{V^2}{2g} \right)^1 = 5.325 \frac{ft-lb}{sec}$$
 (7.22W)

where:

$$\rho = 50.46 \frac{\text{lb}}{\text{ft}^3} (810 \text{ kg/m}^3)$$

$$A = \frac{\pi (0.12979 \text{ ft})^2}{4} = 0.01323 \text{ ft}^2 (0.00123 \text{m}^2)$$

$$f = 0.017^2$$

<sup>1.</sup> Dercy-Weisbach form of head loss equation.

<sup>2.</sup> Per L. F. Moody, ASME Transactions Vol. 66, No. 8, Nov. 1944, page 671.

$$2g = 64.34 \frac{ft}{sec^2} (1.96 \text{ m/sec}^2)$$
$$L = 12 \text{ ft } (3.658 \text{m})$$
$$D = 0.12979 \text{ ft } (0.0396 \text{m})$$

 $\frac{(50.46)(0.01323)(0.017)(12)}{(0.12979)(64.34)} \quad V^{3} = 5.325 \frac{\text{ft-lb}}{\text{sec}} (7.22W)$ 

$$v^3 = 326.49 \text{ ft}^3/\text{sec}^3$$

V = 6.886 ft/sec (2.099 m/sec)

Allowable Flow Rate for 1 Percent Limit

 $Q = AV = (0.01323) (6.886) = 0.091 \text{ ft}^3/\text{sec} (0.00258 \text{ m}^3/\text{sec}).$ 

B. 1.25 IN. DIAMETER PLUG

Energy into Liquid

Collector Surface Area =  $108 \text{ ft}^2 (10.029 \text{ m}^2)$ Maximum Solar Insolation =  $318 \text{ Btu/ft}^2 \text{-hr} (1003 \text{ W/m}^2)$ Intercepted Energy = 34344 Btu/hr (10062.84W)(Figure 2) 10 Collectors in Series, 1.25 In. Dia. Plug, Flow of 0.00028 m<sup>3</sup>/sec; Efficiency = 55.6%Energy Gain in Liquid: 0.556 (34344) = 19095.3 Btu/hr (5594.91W)

Pump Work

@ 1% energy for Pump Work: (0.01) (19095.3) = 190.95 Btu/hr (55.95W)

@ 17% Turbo-Generator Efficiency:  $\frac{(0.17)(190.95)(778)}{3600} =$ 

7.015 
$$\frac{\text{ft-lb}}{\text{sec}}$$
 (9.51W)

Energy Available for Pump Work @ 78% Pump Efficiency:

 $(7.015) (0.78) = 5.472 \frac{\text{ft-lb}}{\text{sec}} (7.41\text{W})$ 

Velocity Determination

$$(\rho AV) \propto \left( f \frac{L}{De} \frac{V^2}{2g} \right) = 5.472 \frac{\text{ft-lb}}{\text{sec}} (7.41W)$$

where:

$$\rho = 50.46 \text{ lb/ft}^3 (810 \text{ kg/m}^2)$$

$$A = 0.01323 \text{ ft}^2 = \frac{\pi (0.1042)^2}{4} = 0.00471 \text{ ft}^2 (0.00044 \text{ m}^2)$$

$$f = 0.026$$

$$2g = 64.34 \text{ ft/sec}^2 (1.96 \text{ m/sec}^2)$$

$$L = 12 \text{ ft} (3.658\text{m})$$

$$De = Do-Di = 0.02563 \text{ ft} (0.0078\text{m})$$

$$\frac{(50.46) (0.00471) (0.026) (12)}{(0.02563) (64.34)} \text{ V}^3 = 5.472$$

v<sup>3</sup> = 121.69

V = 4.955 ft/sec (1.51 m/sec)

Allowable Flow Rate for 1 Percent Limit

Q = AV = (0.00471) (4.955) = 0.0232 ft<sup>3</sup>/sec (0.000661 m<sup>3</sup>/sec)

DISTRIBUTION: TID-4500-R62-UC-13 (143)

A. Warren Adam Sundstrand Electric Power 4747 Harrison Avenue Rockford, Illinois 61101

J. D. Balcomb
Los Alamos Scientific Lab
Assistant Division Leader for Analysis & Planning
Mail Stop 571
Los Alamos, NM 87544

Richard Balzhizer Office of Science & Technology Executive Office of the President Washington, D. C. 20506

Barber-Nichols Engineering 6325 West 55th Avenue Arvada, Colorado 80002

Charles D. Beach Westinghouse Georesearch Laboratory 8401 Baseline Road Boulder, Colorado 80303

Jerry O. Bradley Midwest Research Institute 425 Volker Blvd. Kansas City, Missouri 64110

Floyd Blake Martin Marietta Aerospace Denver Division P. O. Box 179 Denver, Colorado 80201

Karl W. Boer Institute of Energy Conversion University of Delaware Newark, Delaware 19711

P. B. Bos
Manager, Solar Projects
Energy Projects Group
P. O. Box 92957
Aerospace Corporation
Los Angeles, California 90045

James C. Bresee E463 Division of Applied Technology ERDA Germantown, Maryland 20767 Harold Bullis Science Policy Division Congressional Research Service Library of Congress Washington, D.C. 20540

J. O. Carnes Southern Union Gas Company Fidelity Union Tower Building Room 1537 1507 Pacific Avenue Dallas, Texas 75201

Ronal Larsen Office of Technology Assessment Old Immigration Building, Rm. 722 119 D St., NE Washington, D. C. 20002

Commanding General White Sands Missile Range Attn: STEWS-TE-NT Marvin Squires White Sands Missile Range, NM 88002

John Martin Argonne National Laboratory 9700 S. Cass Ave. Argonne, Ill., 60439

J. R. Cotton, Chief Reimbursable Activities Branch ERDA/ALO Albuquerque, NM 87115

Joe Guthrie Enviro-Dynamics 3700 McKinney Ave. Dallas, Texas 75204

B. D. Daugherty Southern Union Gas Company 8th and Silver SW Albuquerque, NM 87103

Jesse C. Denton National Center for Energy Management and Power 113 Towne Building University of Pennsylvania Philadelphia, Pennsylvania 19104

Gus Dorough Deputy Director for Research & Advanced Technology Room 3E144/Pentagon Mail Stop 103 Washington, D. C. 20540

#### DISTRIBUTION: (cont)

Solar Energy Application Lab. Colorado State University Ft. Collins, Colorado 80521

H. Silha University of Idaho Moscow, Idaho 83843

Harold Spuhler National Science Foundation 1800G St. NW Washington, D. C. 20550

Lou Werner Division of Applied Technology ERDA Germantown, Maryland 20767

Frank Zarb Office of Management and Budget Washington, D. C.

Louis O. Elsaesser Director of Research Edison Electric Institute 90 Park Avenue New York, New York 10016

Edward H. Fleming Room E-479 Division of Applied Technology ERDA Germantown, Maryland 20767

Richard Hill Federal Power Commission 441 G. Street, N. W. Room 4005 Washington, D. C. 20426

George Kaplan ERDA 1800 G. Street, N. W. Washington, D. C. 20550

Charles Kelber Argonne National Laboratory 9700 South Cass Avenue Argonne, Illinois 60439

D. K. Nowlin, Director Special Programs Division ERDA Albuquerque, NM 87115 Martin Prochnik Deputy to the Science Advisor U. S. Department of Interior Room 5204 Washington, D. C. 20204

James E. Rannels Division of Applied Technology ERDA Germantown, Maryland 20767

M. W. Rosenthal Oak Ridge National Laboratory Holifield National Laboratory P. O. Box Y Oak Ridge, Tennessee 37830

R. San Martin New Mexico State University Las Cruces, NM 88001

R. Schmidt Systems & Research Center Honeywell Incorporated 2700 Ridgeway Road Minneapolis, Minnesota 55413

G. Schreiber Public Service Company 414 Silver Avenue, SW Albuquerque, NM 87103

J. W. Schroer, Chief Special Projects Branch ERDA/ALO Albuquerque, NM 87115

Robert W. Scott Manager, USAEC/SAO Albuquerque, NM 87115

Alan R. Siegel
Director, Environmental Factors & Public Utilities Division
Department of Housing & Urban Development
Washington, D. C. 20410

F. M. Smits Bell Laboratories 555 Union Boulevard Allentown, Pennsylvania 18103

Dwain Spencer Electric Power Research Institute 3412 Hillview Avenue Palo Alto, California 94304

#### DISTRIBUTION: (cont)

Ross Stickley G. T. S. Sheldahl Company Northfield, Minnesota 55057 Pete Susey American Gas Association 1515 Wilson Boulevard Arlington, Virginia 22209 Ira Thierer Southern California Edison P. O. Box 800 2244 Walnut Grove Avenue Rosemead, California 91770 ERDA Division of Military Application Attn: Major Gen. Frank A. Camm Asst. Gen. Manager for Military Application Washington, D. C. 20545 Lorin L. Vant-Hull Department of Physics University of Houston 3801 Cullen Boulevard Houston, Texas 77004 Michael Wahlig Lawrence Berkeley Laboratory Building 50A, Room 6121 University of California

W. A. Cross Attn: M. Wilden Department Mechanical Engineering University of New Mexico Albuquerque, NM 87106

Berkeley, California 94720

Karl Willenbrock Director, Institute for Applied Technology National Bureau of Standards Room B-112 - Tech (400.00) Washington, D. C. 20234

Leonard S. Raymond Optical Sciences Center Tucson, Arizona 85721

Samuel J. Taylor Federal Energy Administration Solar Energy Office Room 3443 1200 Pennsylvania Ave NW Washington, D. C. 20461

 1100 C. D. Broyles, Attn: J. D. Kennedy, 1110 G. E. Hansche, 1120
 1540 T. B. Lane, Attn: H. C. Hardee, 1543

W. H. McCulloch 1543 2300 L. D. Smith K. Gillespie, Attn: L. W. Schulz, 2324 2320 2400 R. S. Claassen O. M. Stuetzer, Attn: G. W. Gobeli, 2441 2440 3620 R. S. Wilson 3622L. G. Rainhart D. B. Shuster 4700 R. G. Clem, Attn: V. L. Dugan, 4734 4730 5000 A. Narath, Attn: J. K. Galt, 5100 E. H. Beckner, 5200 A. Y. Pope, 5600 5110 F. L. Vook S. T. Picraux 5111 G. A. Samara 5130 J. E. Schirber 5150 5220 J. V. Walker, Attn: J. H. Renken, 5223 R. C. Maydew 5620 J. H. Scott, Attn: M. L. Kramm, 5720 5700 G. E. Brandvold 5710 5712 R. H. Braasch G. W. Treadwell 5712R. P. Stromberg 5717 5718 M. M. Newsom 5721C. E. Dalton 5800 L. M. Berry, Attn: R. L. Schwoebel 5824 R. W. Lynch 5830 M. J. Davis, Attn: D. M. Mattox, 5834 5834 R. R. Sowell 5840 D. M. Schuster, Attn: R. C. Heckman, 5842 F. P. Gerstle, 5844 E. K. Beauchamp, 5846 R. B. Pettit 58428100 L. Gutierrez C. S. Selvage, Attn: A. C. Skinrood, 8184 8180 L. J. Paddison 9300 A. J. Clark, Jr., Attn: P. H. Adams,9331 9330 9340 W. E. Caldes, Attn: E. R. Julius, 9344 9400 L. A. Hopkins R. L. Brin, Attn: R. K. Petersen, 9412 9410 9474 L. W. Scully 9700 R. E. Hopper, Attn: H. H. Pastorius, 9740 R. W. Hunnicutt, 9750 3141L. S. Ostrander (5) 8266 E. A. Aas (2) W. L. Garner (3) 3151 For: ERDA/TIC (Unlimited Release) 3171-1 R. P. Campbell (25) For: ERDA/TIC

Org.	Bidg.	Name	Rec'd by*	Org.	Bldg.	Name	Rec'd by*
	n San San Sa						
				×			
	,					· · · · · · · · · · · · · · · · · · ·	
			i			-	
							1

\*Recipient must initial on classified documents.