

SAND80-2526
Unlimited Release
UC-62

Pump Heat Loss Test Report

Michael A. Quintana, Leroy E. Torkelson

Prepared by Sandia National Laboratories, Albuquerque, New Mexico 87185
and Livermore, California 94550 for the United States Department
of Energy under Contract DE-ACO4-76DPO0789

Printed January 1981

***When printing a copy of any digitized SAND
Report, you are required to update the
markings to current standards.***



Sandia National Laboratories

Issued by Sandia Laboratories, operated for the United States
Department of Energy by Sandia Corporation.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America

Available from
National Technical Information Service
U. S. Department of Commerce
5285 Port Royal Road
Springfield, VA 22161
Price: Printed Copy \$4.50; Microfiche \$3.00

SAND80-2526
Unlimited Release
Printed January 1981

Category
UC-62

PUMP HEAT LOSS TEST REPORT

M. A. Quintana
and
L. E. Torkelson
Experimental Systems Operations Division 4721
Sandia National Laboratories
Albuquerque, New Mexico 87185

ABSTRACT

This report describes a test which measures the heat loss from a centrifugal pump under both insulated and uninsulated conditions. Results showed a 27% reduction in heat loss by insulating the pump and an additional 50% reduction by changing to a pump seal not requiring liquid cooling.

CONTENTS

	<u>Page</u>
Introduction	7
Design Objectives	7
Test Configuration	9
Test Procedure	11
Test Results	13
Discussion	13

ILLUSTRATIONS

Figure

1	Test Setup for Pump Heat Loss Test	8
2	Pump Heat Loss Test Setup without Insulation	10
3	Thermal Loss from Centrifugal Pump <u>Uninsulated</u>	14
4	Thermal Loss from Centrifugal Pump <u>Insulated</u>	15
5	Thermal Loss from Centrifugal Pump <u>Insulated</u> and <u>Uninsulated</u>	16

TABLES

Table

1	Test Data: Uninsulated Pump	17
2	Test Data: Insulated Pump	18

PUMP HEAT LOSS TEST REPORT

Introduction

Thermal losses in plumbing components decrease the overall efficiency of solar collector fields. Pumps, typically not well insulated, are major contributors to these thermal losses. Pumps rated for the midtemperature range, up to 572°F (300°C), are often equipped with Teflon seals, nominally rated for 436°F (224°C). These seals must be cooled. Both the introduction of a seal coolant, usually water, and the large mass of the pump and its metal base make a pump a principal source of thermal energy loss.

This report examines thermal loss from a pump during operation. Test configuration, test procedures, and test results are detailed. These results will aid in computation of thermal losses in solar collector field designs.

Design Objectives

The main purpose of the test was to measure the heat lost from the fluid as it passed through the pump. The improvement due to insulating the pump was to be measured also. The test configuration is shown schematically in Figure 1. Heat losses from the fluid loop were minimized by thick insulation and by keeping the fluid loop as compact as possible. The heat lost through the pump was deduced by measuring the energy input to the pumped fluid. Critical test parameters were

1. Torque on the pump,
2. Energy input from a heater rod in the fluid loop,




Figure 1. Test Setup for Pump Heat Loss Test

3. Fluid flow rate through the pump,
4. Fluid temperature in the loop,
5. Input and output temperature of the pump seal coolant,
6. Coolant flow rate through the seal,
7. Input and output pressure at the pump flanges, and
8. Ambient temperature and wind speed.

The flow rate and temperature of the pumped fluid, Therminol 66®, were varied. Seal coolant (water) temperature varied with loop temperature and flow rate.

Test Configuration

The following equipment was used in the test.

Components	Instrumentation and Control
Torque sensor: LeBow 1604-200	Readout: LeBow 7521
Flowmeter: Flow Technology, Inc. FTI 3176	Pulse Rate Converter: Flow Technology, Inc. PRC104AA3BZ
Heater: Watlow Firerod, 120 V, 3 kW	Variable Autotransformer: 120 V, 50 A
	Power Analyzer: Magtrol 4610
	Recorder: Hewlett-Packard 5050B
Thermocouples: Omega Type K	Recorder: Honeywell Type K1127-3
Pump: Dean Bros. Type R-434, Size: 1" x 3" x 7-1/2"	Recorder: Strip-chart, MFE Model 1600
Pressure Gauge: 2 @ Wika, 0 to 100 psi	
Vacuum Gauge: Marsh, 0 to 30 inches of Hg	

The loop was fabricated by Sandia National Laboratories (SNL) support personnel and set up at the Collector Module Test Facility (CMTF) in Albuquerque. Figure 2 is a photograph of the test setup prior to application of the insulation. Schedule 40 pipe was used to connect the pump output with the input. The 3-inch inlet pipe was reduced to 1 inch at the flange. A total of 2.8 linear meters of 1-inch schedule 40 pipe makes up the complete loop. Three inches of




Figure 2. Pump Heat Loss Test Setup without Insulation

insulation and an aluminum jacket (0.016 inches thick) were applied to the pipe. The two innermost layers of insulation are each 1-inch-thick Johns-Manville Micro Lok-650 preformed fiberglass. The outermost layer is 1-inch-thick Upjohn U-thane 190 polyurethane. A pump pad (6 feet by 2 feet by 4 inches), fabricated with 0.25-inch steel, supported the motor, the torque sensor, and the pump assembly. The pump pad was mounted on a concrete pad. This is the typical mounting configuration of a pump in the Midtemperature Solar Systems Test Facility (MSSTF).

Test Procedure

Heat loss during pump operation was measured at two different flow rates. Flow rate variation was accomplished by insertion of a 0.50-inch orifice plate at the flange interface of the output side of the pump. The first series of measurements was taken at the two flow rates with the pump uninsulated. Water was routed through the pump seal and then through a jacket around the pump bearing housing. Water flow was controlled to keep the heat loss to the water as low as possible while maintaining the bearing housing temperature in the 120° to 160°F (49° to 71°C) range, as per the manufacturer's specifications. Temperatures of the cooling water at the input and output of the seal and the output of the pump bearing housing were recorded. Water flow was determined by measuring the amount of time necessary to fill a quart container. The thermal loss due to cooling water was calculated as a function of temperature differential and flow rate. Additional heat loss occurs through conduction to the pad and by convection and radiation to the atmosphere. This quantity was not measured.

Thermal losses were measured at approximately 50-degree increments in loop temperature from 150° to 500°F (66° to 260°C). Power input from the heater, regulated by a variable autotransformer, was measured with a power analyzer in terms of kilowatts electric. The second power input is a function of the revolutions/minute and the

torque transmitted to the pump by the motor. The revolutions/minute were measured with a strobe light. Total power input is the sum of the above inputs as calculated per the following equation.

$$\sum P_{in} = P_e + P_m$$

where

$$\begin{aligned} \sum P_{in} &= \text{Total power input to the fluid loop} \\ P_e &= \text{Electrical power consumed by the heater} \\ P_m &= \text{Mechanical power input to the pump} \end{aligned}$$

P_m is calculated as follows:

$$P_m = \frac{2\pi NT}{33,000} \text{ (horsepower)} = \frac{2\pi NT}{44.25} \text{ (watts)}$$

where

$$\begin{aligned} N &= \text{Rotational speed of the pump shaft} \\ &\quad \text{(revolutions/minute)} \\ T &= \text{Torque applied to the pump shaft} \\ &\quad \text{(foot-pounds)} \end{aligned}$$

Critical thermal loss measurements were taken after the system reached thermal equilibrium. A data point was then generated by integrating several measurements over a period of time. Over a period of 12 minutes, 12 temperature measurements were recorded. Power measurements began a minimum of 1 hour prior to thermal equilibrium then were integrated over time. Torque and flow indicators remained steady in most cases. When a deviation occurred, the measurement was integrated. Water flow was measured immediately prior to temperature recording.

The first set of data was taken with the pump uninsulated. Data were first taken at full flow, then with a flow restrictor in place. The pump was then insulated. A shell of 0.016-inch-thick aluminum

sheet, slightly larger than the pump, was constructed. Within the shell was a lining of 2.5 inches of Owens Corning IQ 950 fiberglass. Small, odd-size pieces of insulation were used to fill the remaining space between the inner lining and the pump. All joints and penetrations in the shell were caulked with silicone. The second set of data was then recorded with the pump fully insulated.

Test Results

The test results are presented in Figures 3, 4, and 5 and in Tables 1 and 2. The figures are plots of thermal loss from the pump versus Therminol 66® temperature in the loop minus ambient air temperature. Figure 3 was plotted for the uninsulated pump; Figure 4, for the insulated pump; and Figure 5 is a comparison between the insulated and uninsulated pumps. The plots labeled "total loss" represent the sum of the losses from the pump and the fluid loop fastened to it. The maximum loss from the fluid loop was calculated to be 0.2 kW at peak loop temperatures. The loss from the loop, being small compared to the total, can be ignored. Since the test data were collected under equilibrium conditions, the values for total power input, as calculated above, were also used here as "total loss" values.

The plot of the thermal loss to the cooling water in Figures 3 and 4 illustrates the portion of the total thermal loss from the pump that is carried away by the cooling water which protects the seal.

The test data are presented in Tables 1 and 2. Table 1 contains the data for the uninsulated pump; Table 2, for the insulated pump.

Discussion

The results show that at an operating temperature of 500°F (260°C), the total thermal loss from an uninsulated pump, with a water-cooled seal, can be cut by 27% by insulating the pump body. A




Figure 3. Thermal Loss from Centrifugal Pump Uninsulated




Figure 4. Thermal Loss from Centrifugal Pump Insulated




Figure 5. Total Thermal Loss from Centrifugal Pump
Insulated and Uninsulated

Table 1

Test Data: Uninsulated Pump

<u>Run No.</u>	<u>Therminol Flow (gpm)</u>	<u>Therminol Temp. (°F)</u>	<u>Water Flow (lb/h)</u>	<u>Water In Temp. (°F)</u>	<u>Water Out Temp. (°F)</u>	<u>Ambient Temp. (°F)</u>
1	25.7	504.2	104.3	86.7	149.2	83.8
2	27.0	461.4	89.8	96.2	170.2	92.1
3	28.2	380.3	107.3	93.9	139.6	99.3
4	28.0	338.2	60.7	88.2	150.0	93.1
5	28.0	245.2	0.0	--	--	87.9
6	28.2	295.9	50.4	105.8	155.2	96.8
7	44.5	310.0	67.9	95.0	139.9	103.8
8	45.6	503.0	158.0	88.0	144.3	89.6
9	46.2	397.9	90.1	89.4	147.0	93.7

	<u>Inlet Pressure (psi)</u>	<u>Outlet Pressure (psi)</u>	<u>Heater Power (kWe)</u>	<u>Pump Shaft Torque (in./lb)</u>	<u>Pump Shaft Rotation (rpm)</u>	<u>Wind Velocity (m/s)</u>
1	2.0	14.0	3.52	40.4	1818	3.4
2	2.0	17.0	2.84	41.4	1818	2.4
3	2.0	17.0	1.92	44.0	1818	3.2
4	2.0	17.0	1.34	46.0	1818	3.5
5	1.5	18.0	0.0	51.0	1818	2.2
6	1.5	17.0	0.84	48.0	1818	3.1
7	2.0	15.0	0.96	54.0	1818	6.9
8	1.5	14.0	3.54	48.0	1818	2.7
9	2.0	15.0	2.02	50.7	1818	4.5

Table 2

Test Data: Insulated Pump

Run No.	Therminol Flow (gpm)	Therminol Temp. (°F)	Water Flow (lb/h)	Water In Temp. (°F)	Water Out Temp. (°F)	Ambient Temp. (°F)
1	44.0	240.3	73.3	91.9	119.9	102.1
2	44.3	304.7	92.6	92.0	120.9	102.7
3	44.3	361.7	76.3	92.0	145.4	89.6
4	44.3	421.6	139.7	92.8	127.2	93.6
5	28.1	373.2	0.0	--	--	89.0
6	28.1	219.7	87.1	90.0	119.6	84.8
7	28.1	290.9	74.0	91.7	137.9	90.9
8	24.8	502.2	104.3	93.4	148.9	99.3
9	25.8	452.0	85.1	98.6	161.4	95.2
10	25.8	404.7	65.5	91.7	162.3	84.4
11	27.0	358.9	65.5	97.0	149.2	101.7

	Inlet Pressure (psi)	Outlet Pressure (psi)	Heater Power (kWe)	Pump Shaft Torque (in./lb)	Pump Shaft Rotation (rpm)	Wind Velocity (m/s)
1	2.5	16.0	0.0	52.8	1818	2.30
2	2.5	15.0	0.56	51.3	1818	2.21
3	1.5	15.0	0.93	50.0	1818	2.42
4	2.0	14.0	1.57	52.0	1818	2.20
5	1.0	19.0	0.0	42.0	1818	--
6	1.0	19.0	0.0	47.3	1818	2.09
7	2.0	18.0	0.56	46.0	1818	3.77
8	2.5	12.0	2.24	37.0	1818	3.18
9	2.0	16.0	1.80	39.5	1818	1.63
10	1.5	17.0	1.37	41.0	1818	1.28
11	2.0	18.0	0.85	48.0	1818	1.15

little over half the total loss from the insulated pump was shown to be carried off by the seal cooling water. It is possible to specify seals for pumps that do not require cooling water for operating temperatures up to 600°F (316°C). One high-temperature pump with such a seal has been operating successfully at the MSSTF in Albuquerque for the past 3 years. The seal is a metal bellows type with a carbon ring rotating on a tungsten-carbide ring. The external surfaces of the rings are flushed with nitrogen gas at a flow rate of 0.15 ft³/h (1 cm³/s).

The results also show that the heat loss from a well-insulated pump that does not require cooling water for its seal will still be significant. This suggests that work needs to be done in the area of pump mounting in order to block the heat leakage path from the base of the pump to its mounting pad.

In conclusion, when a pump is being specified for a solar heating system, some type of seal not requiring liquid cooling should be selected. Also, the pump should be well insulated, and care should be taken to minimize the heat loss from the base of the pump.

DISTRIBUTION:
TID-4500-R66, UC62 (268), 11/80

AAI Corporation
P.O. Box 6787
Baltimore, MD 21204

Acurex Aerotherm
485 Clyde Avenue
Mountain View, CA 94042
Attn: J. Vindum

Advanco Corporation
999 N. Sepulveda Blvd.
Suite 314
El Segundo, CA 90245
Attn: B. J. Washom

Alpha Solarco
1014 Vine Street
Suite 2230
Cincinnati, OH 45202

American Boa, Inc.
Suite 4907, One World
Trade Center
New York, NY 10048
Attn: R. Brundage

Anaconda Metal Hose Co.
698 South Main Street
Waterbury, CT 06720
Attn: W. Genshino

Applied Concepts Corp.
P.O. Box 2760
Reston, VA 22090
Attn: J. S. Hauger

Arizona Public Service Co.
Box 21666, MS 1795
Phoenix, AZ 85036
Attn: Dr. B. L. Broussard

Argonne National Laboratory (3)
9700 South Cass Avenue
Argonne, IL 60439
Attn: K. Reed
W. W. Schertz
R. Winston

BDM Corporation
1801 Randolph Street
Albuquerque, NM 87106
Attn: T. Reynolds

Battelle Memorial Institute
Pacific Northwest Laboratory
P.O. Box 999
Richland, WA 99352
Attn: K. Drumheller

Bechtel National, Inc.
P.O. Box 3965
50 Beale Street
San Francisco, CA 94119
Attn: E. Y. Lam

Black and Veatch (2)
P.O. Box 8405
Kansas City, MO 64114
Attn: Dr. J. C. Grosskreutz
D. C. Gray

Boeing Space Center (2)
M/S 86-01
Kent, WA 98131
Attn: S. Duzick
A. Lunde

Boomer-Fiske, Inc.
4000 S. Princeton
Chicago, IL 60609
Attn: C. Cain

Budd Company
Fort Washington, PA 19034
Attn: W. W. Dickhart

The Budd Company
Plastic R&D Center
356 Executive Drive
Troy, MI 48084
Attn: J. N. Epel

Compudrive Corp.
76 Trebel Core Road
N. Billerica, MA 01862
Attn: T. Black

Cone Drive
Division of Excello Corp.
P.O. Box 272
240 E. 12 St.
Traverse City, MI 49684
Attn: J. E. McGuire

DISTRIBUTION (Continued)

Congressional Research Service
Library of Congress
Washington, DC 20540
Attn: H. Bullis

Corning Glass Company (2)
Corning, NY 14830
Attn: A. F. Shoemaker
W. Baldwin

Custom Engineering, Inc.
2805 South Tejon St.
Englewood, CO 80110
Attn: C. A. Moraes

DSET
Black Canyon Stage
P.O. Box 185
Phoenix, AZ 85029
Attn: G. A. Zerlaut

Del Manufacturing Co.
905 Monterey Pass Road
Monterey Park, CA 91754
Attn: M. M. Delgado

Desert Research Institute Energy
Systems Laboratory
1500 Buchanan Blvd.
Boulder City, NV 89005
Attn: J. O. Bradley

Donnelly Mirrors, Inc.
49 West Third Street
Holland, MI 49423
Attn: J. A. Knister

E-Systems, Inc.,
Energy Tech. Center
P.O. Box 226118
Dallas, TX 75266
Attn: R. R. Walters

Easton Utilities Commission
219 North Washington St.
Easton, MD 21601
Attn: Mr. W. H. Corkran, Jr.

Eaton Corporation
Industrial Drives Operations
Cleveland Division
3249 East 80 St.
Cleveland, OH 44104
Attn: R. Glatt

Edison Electric Institute
90 Park Avenue
New York, NY 10016
Attn: L. O. Elsaesser

Electric Power Research Institute
(2)
3412 Hillview Avenue
Palo Alto, CA 94303
Attn: Dr. J. Cummings
J. E. Bigger

Energetics
833 E. Arapahoe Street, Suite 202
Richardson, TX 75081
Attn: G. Bond

Energy Institute
1700 Las Lomas NE
Albuquerque, NM 87131

Eurodrive, Inc.
2001 W. Main St.
Troy, OH 45373
Attn: S. D. Warner

Exxon Enterprises (3)
P.O. Box 592
Florham Park, NJ 07923
Attn: J. Hamilton
P. Joy
Dr. M. C. Noland

Florida Solar Energy Center (2)
300 State Road, Suite 401
Cape Canaveral, FL 32920
Attn: C. Beech
D. Block

Ford Aerospace and Communications
3939 Fabian Way
Palo Alto, CA 94303
Attn: H. J. Sund

DISTRIBUTION (Continued)

Ford Glass Division
Glass Technical Center
25500 West Outer Drive
Lincoln Park, MI 48146
Attn: H. A. Hill

General Atomic
P.O. Box 81608
San Diego, CA 92138
Attn: A. Schwartz

General Electric Co. (2)
P.O. Box 8661
Philadelphia, PA 19101
Attn: W. Pijawka
C. Billingsley

General Motors
Harrison Radiator Division
Lockport, NY
Attn: L. Brock

General Motors Corporation
Technical Center
Warren, MI 48090
Attn: J. F. Britt

Georgia Institute of Technology
Atlanta, GA 30332
Attn: J. D. Walton

Georgia Power Company
270 Peachtree
P.O. Box 4545
Atlanta, GA 30302
Attn: J. Roberts

Glitsch, Inc.
P.O. Box 226227
Dallas, TX 75266
Attn: R. W. McClain

Haveg Industries, Inc.
1287 E. Imperial Highway
Santa Fe Springs, CA 90670
Attn: J. Flynt

Hexcel
11711 Dublin Blvd.
Dublin, CA 94566
Attn: R. Johnston

Highland Plating
1128 N. Highland
Los Angeles, CA 90038
Attn: M. Faeth

Honeywell, Inc.
Energy Resources Center
2600 Ridgeway Parkway
Minneapolis, MN 55413
Attn: J. R. Williams

Insights West
900 Wilshire Blvd.
Los Angeles, CA 90017
Attn: J. H. Williams

Jacobs Engineering Co. (2)
251 South Lake Avenue
Pasadena, CA 91101
Attn: B. Eldridge
R. Morton

Jet Propulsion Laboratory (3)
4800 Oak Grove Drive
Pasadena, CA 91103
Attn: J. Becker
J. Lucas
V. C. Truscello

Kingston Industries Corporation
205 Lexington Ave.
New York, NY 10016
Attn: M. Sherwood

Lawrence Livermore Laboratory
University of California
P.O. Box 808
Livermore, CA 94500
Attn: W. C. Dickinson

Los Alamos National Lab. (3)
Los Alamos, NM 87545
Attn: J. D. Balcomb
C. D. Bankston
D. P. Grimmer

McDonnell Douglas Astronautics
Company (3)
5301 Bolsa Avenue
Huntington Beach, CA 92647
Attn: J. B. Blackmon
J. Rogan
D. Steinmeyer

DISTRIBUTION (Continued)

Morse Chain
Division of Borg-Warner Corp.
4650 Steele St.
Denver, CO 80211
Attn: G. Fukayama

Motorola Inc.
Government Electronics Division
8201 E. McDowell Road
P.O. Box 1417
Scottsdale, AZ 85252
Attn: R. Kendall

New Mexico State University
Solar Energy Department
Las Cruces, NM 88001

Oak Ridge National Laboratory (3)
P.O. Box Y
Oak Ridge, TN 37830
Attn: S. I. Kaplan
G. Lawson
W. R. Mixon

Office of Technology Assessment
U.S. Congress
Washington, DC 20510
Attn: R. Rowberg

Omnium G
1815 Orangethorpe Park
Anaheim, CA 92801
Attn: S. P. Lazzara

Owens-Illinois
1020 N. Westwood
Toledo, OH 43614
Attn: Y. K. Pei

PPG Industries, Inc.
One Gateway Center
Pittsburgh, PA 15222
Attn: R. C. Frownfelter

PRC Energy Analysis Company
7600 Old Springhouse Road
McLean, VA 22102
Attn: J. Meglan

Parsons of California
3437 S. Airport Way
Stockton, CA 95206
Attn: D. R. Biddle

Progress Industries, Inc.
7290 Murdy Circle
Huntington Beach, CA 92647
Attn: K. Busche

Ronel Technetics, Inc.
501 West Sheridan Rd.
McHenry, IL 60050
Attn: N. Wensel

Scientific Applications, Inc.
100 Mercantile, Commerce Bldg.
Dallas, TX 75201
Attn: Dr. J. W. Doane

Scientific Atlanta, Inc.
3845 Pleasantdale Road
Atlanta, GA 30340
Attn: A. Ferguson

Schott America
11 East 26th St.
New York, NY 10010
Attn: J. Schrauth

Solar Energy Information Center
1536 Cole Blvd.
Golden, CO 80401
Attn: R. Ortiz

Solar Energy Research Institute
(13)
1536 Cole Blvd.
Golden, CO 80401
Attn: B. L. Butler
L. G. Dunham (4)
B. P. Gupta
F. Kreith
J. Thornton
K. Touryan
N. Woodley
D. W. Kearney
C. Bishop
F. Feasby

Solar Energy Technology
Rocketdyne Division
6633 Canoga Avenue
Canoga Park, CA 91304
Attn: J. M. Friefeld

DISTRIBUTION (Continued)

Solar Kinetics Inc.
P.O. Box 47045
8120 Chancellor Row
Dallas, TX 75247
Attn: G. Hutchinson

Southwest Research Institute
P.O. Box 28510
San Antonio, TX 78284
Attn: D. M. Deffenbaugh

Stanford Research Institute
Menlo Park, CA 94025
Attn: A. J. Slemmons

Stearns-Rogers
4500 Cherry Creek
Denver, CO 80217
Attn: W. R. Lang

W. B. Stine
317 Monterey Rd., Apt. 22
South Pasadena, CA 91303

Sun Gas Company
Suite 800, 2 No. Pk. E
Dallas, TX 75231
Attn: R. C. Clark

Sundstrand Electric Power
4747 Harrison Avenue
Rockford, IL 61101
Attn: A. W. Adam

Sunpower Systems
510 S. 52 Street
Tempe, AZ 85281
Attn: W. Matlock

Suntec Systems Inc.
2101 Woodale Drive
St. Paul, MN 55110
Attn: L. W. Rees

Swedlow, Inc.
12122 Western Avenue
Garden Grove, CA 92645
Attn: E. Nixon

3M-Decorative Products Division
209-2N 3M Center
St. Paul, MN 55101
Attn: B. Benson

3M-Product Development
Energy Control Products
207-1W 3M Center
St. Paul, MN 55101
Attn: J. R. Roche

Texas Tech University
Dept. of Electrical Engineering
P.O. Box 4709
Lubbock, TX 79409
Attn: J. D. Reichert

TRW, Inc.
Energy Systems Group of TRW, Inc.
One Space Park, Bldg. R4,
Room 2074
Redondo Beach, CA 90278
Attn: J. M. Cherne

Toltec Industries, Inc.
40th and East Main
Clear Lake, IA 50428
Attn: D. Chenault

U.S. Department of Energy (3)
Albuquerque Operations Office
P.O. Box 5400
Albuquerque, NM 87185
Attn: G. N. Pappas
C. B. Quinn
J. Weisiger

U.S. Department of Energy
Division of Energy Storage
Systems
Washington, DC 20545
Attn: J. Gahimer

U.S. Department of Energy (8)
Division of Solar Thermal
Energy Systems
Washington, DC 20545
Attn: W. W. Auer
G. W. Braun
J. E. Greyerbiehl
M. U. Gutstein
L. Melamed
J. E. Rannels
F. Wilkins
J. Dollard

DISTRIBUTION (Continued)

U.S. Department of Energy (2)
 San Francisco Operations Office
 1333 Broadway, Wells Fargo Bldg.
 Oakland, CA 94612
 Attn: R. W. Hughey

University of Kansas Center for
 Research, CRINC
 2291 Irving Hall Rd.
 Lawrence, KS 66045
 Attn: R. F. Riordan

University of New Mexico (2)
 Department of Mechanical Eng.
 Albuquerque, NM 87113
 Attn: M. W. Wilden
 W. A. Cross

Winsmith
 Div. of UMC Industries, Inc.
 Springville, NY 14141
 Attn: R. Bhise

1520 T. J. Hoban
 1530 W. E. Caldes
 1550 F. W. Neilson
 2320 K. L. Gillespie
 2323 C. M. Gabriel
 2324 R. S. Pinkham
 2326 G. M. Heck
 3161 J. E. Mitchell
 3600 R. W. Hunnicutt
 Attn: H. H. Pastorius,
 3640
 3700 J. C. Strassell
 4000 A. Narath

4231 J. H. Renken
 4700 J. H. Scott
 4710 G. E. Brandvold
 4713 B. W. Marshall
 4714 R. P. Stromberg (20)
 4715 R. H. Braasch
 4718 E. Burgess
 4719 D. G. Schueler
 4720 V. L. Dugan (100)
 4721 Author (20)
 4721 J. V. Otts
 4722 J. F. Banas
 4723 W. P. Schimmel
 4725 L. A. Leonard
 4730 H. M. Stoller
 5510 D. B. Hayes
 5513 D. W. Larson
 5520 T. B. Lane
 5523 R. C. Reuter
 5810 R. G. Kepler
 5820 R. E. Whan
 5830 M. J. Davis
 5833 J. L. Jellison
 5840 N. Magnani
 8266 E. A. Aas (2)
 8450 R. Wayne
 8451 C. F. Melius
 8452 A. C. Skinrood
 8452 T. Bramlette
 8453 W. G. Wilson
 3141 T. L. Werner (5)
 3151 W. L. Garner (3)
 (Unlimited Release)
 For DOE/TIC
 (Unlimited Release)
 6011 Patents