

SAND81-8236 Unlimited Release

Comparative Economics of Solar Thermal Central Receivers

M. J. Fish

Prepared by Sandia National Laboratories, Albuquerque, New Mexico 87185 and Livermore, California 94550 for the United States Department of Energy under Contract DE-AC04-76DP00789.

Printed August 1981





Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability to responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

> Printed in the United States of America Available from National Technical Information Service U. S. Department of Commerce 5285 Port Royal Road Springfield, VA 22161 Price: Printed Copy \$5.25 ; Microfiche \$3.00

SAND81-8236 Unlimited Release Printed August 1981

COMPARATIVE ECONOMICS OF SOLAR THERMAL CENTRAL RECEIVERS

Miriam J. Fish Thermal Sciences Division Sandia National Laboratories, Livermore

ABSTRACT

The most convincing justification for the development of the solar central receiver concept lies in its potential to compete with conventional fossil fired alternatives on strictly economic grounds. For both electrical and industrial process heat (IPH) generation, central receivers compare favorably with oil and gas, and in many cases, coal. This report presents calculational results in which the levelized energy costs from central receiver plants are compared with those from oil, gas, and coal fired plants. Both electrical and IPH applications are discussed. Uncertainties in future capital costs, fuel price escalation rates, and the underlying economic climate are included in the analysis.

ACKNOWLEDGMENTS

The author wishes to acknowledge P. J. Eicker of Sandia National Laboratories, Livermore, for his original guidance in this work. Special thanks also go to Judy C. Foster, Cynthia Bahr, Terri Goin, and Fran Rupley for their help in the preparation of this manuscript.

CONTENTS

	Page
Introduction	13
Summary	13
Levelized Energy Cost	13
General Economic Assumptions	15
Electrical Generation	16
Capital Costs of Central Receiver Plants	16
Economic Assumptions	16
Fossil Fired Plants	21
Levelized Energy Cost Comparisons for Electrical Generation	23
Industrial Process Heat Generation	30
Capital Costs of Central Receiver Plants	30
Economic Assumptions	30
Fossil Fired Plants	31
Levelized Energy Cost Comparisons for Industrial Process Heat	32
REFERENCES	34
APPENDIX ACALCULATION OF THE FIXED CHARGE RATE	37
APPENDIX BRESULTS FOR A SCENARIO ASSUMING A HIGHER INFLATION RATE	39
APPENDIX CEQUIVALENT SCENARIOS OF CONSTANT AND VARIABLE FUEL ESCALATION RATES	51

-

-

7/8

ILLUSTRATIONS

<u>No.</u>		Page
1	Capital Cost of Central Receivers vs. Capacity Factor	18
2	Levelized Energy Cost of Central Receivers vs. Capacity Factor	20
3	Levelized Energy Cost Breakdown of Central Receivers vs. Capacity Factor	22
4	Energy Cost Comparison of Central Receivers and Oil Fired Plants, O% Fuel Esclation Rate above Inflation	24
5	Energy Cost Comparison of Central Receivers and Oil Fired Plants, 3% Fuel Escalation Rate above Inflation	25
6	Energy Cost Comparison of Central Receivers and Gas Fired Plants, 0% Fuel Escalation Rate above Inflation	26
7	Energy Cost Comparison of Central Receivers and Gas Fired Plants, 3% Fuel Escalation Rate above Inflation	27
8	Energy Cost Comparison of Central Receivers and Coal Fired Plants, 0% Fuel Escalation Rate above Inflation	28
9	Energy Cost Comparison of Central Receivers and Coal Fired Plants, 3% Fuel Escalation Rate above Inflation	29
10	Energy Cost Comparison of Central Receivers and Fossil Fuels for Industrial Process Heat	33
B-1	Levelized Energy Cost of Central Receivers vs. Capacity Factor; 12% Inflation Rate	41
B-2	Energy Cost Comparison of Central Receivers and Oil Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation	42
B-3	Energy Cost Comparison of Central Receivers and Oil Fired Plants; 12% Inflation, 3% Fuel Escalation Rate above Inflation	43
B -4	Energy Cost Comparison of Central Receivers and Gas Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation	44
B-5	Energy Cost Comparison of Central Receivers and Gas Fired	45

9/10

ILLUSTRATIONS

No.		Page
B-6	Energy Cost Comparison of Central Receivers and Coal Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation	46
B-7	Energy Cost Comparison of Central Receivers and Coal Fired Plants; 12% Inflation, 3% Fuel Escalation Rate above Inflation	47
B-8	Energy Cost Comparison of Central Receivers and Fossil Fuels for Industrial Process Heat; 12% Inflation Rate	49
C-1	Variable Fuel Escalation Rate Scenario Equivalent to Constant Rate of 3% above Inflation - Utility Application	52
C-2	Variable Fuel Escalation Rate Scenario Equivalent to Constant Rate of 3% above Inflation - Industrial Process Heat Application	53

TABLES

<u>No.</u>		Page
I	Summary of Levelized Energy Cost Comparisons	14
II	Initial Assumptions for Central Receiver Capital Costs	17
III	Economic Assumptions for Investor Owned Utilities	19
IV	Fossil Fired Plant Assumptions for Utility Applications	21
۷	Economic Assumptions for Industrial Process Heat Applications	31
VI	Fossil Fuel Assumptions for Industrial Process Heat Applications	31
B-I	Economic Assumptions for Investor Owned Utilities, High Inflation Rate Scenario	40
B-II	Economic Assumptions for Industrial Process Heat Applications, High Inflation Rate Scenario	48

COMPARATIVE ECONOMICS OF SOLAR THERMAL CENTRAL RECEIVERS

Introduction

Proposed designs for solar central receivers have progressed through several iterations since the first major effort was undertaken for the Barstow pilot plant (refs. 1, 2). Accompanying this has been extensive materials development, prototype hardware construction and testing, and the evolution of increasingly sophisticated analytical capabilities. As a result, performance and capital cost projections for the technology can now be made with increased certainty.

Using these most recent estimates, energy costs from central receivers can be calculated and compared to conventional options in order to evaluate the potential competitiveness of the technology. This report presents such a comparison with fossil fired alternatives - oil, gas, and coal burning facilities - for both electrical and industrial process heat (IPH) generation.

Summary

Under reasonable assumptions on capital costs, economic parameters, and fuel price and escalation rates, solar central receivers appear to be competitive with oil and gas for both electrical and industrial process heat generation. Competitiveness with coal will occur, as well, provided that projected plant costs for central receivers are attained and that coal price escalation rates above inflation and/or high coal plant construction costs continue. Some of the important results discussed in this report are presented in Table I.

Levelized Energy Cost

The basis for comparison is the levelized (or discounted average) cost of energy delivered by a system over its design lifetime. It is calculated according to the equation:

 $LEC = \frac{FCR*CC_{tot} + LOM + LFC}{E_{net}}$

where LEC = levelized energy cost;

Utility	Applications	(Capacity	Factor	= 50%)
			Energ	y Cost	t (Mills/kw/hr)
0il*				10	0-188
Gas*				69	9-124
Coal*				6	5-106
Central	Receiver**			79	9-105

B. Industrial Process Heat Applications (Fuel Saving)

Α.

	Energy Cost (\$/10 ⁶ BTU)
0il*	9.40 - 16.20
Gas*	5.90 - 10.15
Coal*	4.70 - 8.10
Central Receiver**	7.60 - 11.90

*Range covers fuel escalation rates of 0% to 3% above inflation

**Lower bound: baseline "nth" plant (\$85/m² heliostats)
Upper bound: lower bound + 50% increase in heliostat cost, + 100% increase in receiver, storage costs.

TABLE I

SUMMARY OF LEVELIZED ENERGY COST COMPARISONS

- FCR = annual fixed charge rate on the capital investment, including the effects of taxes, tax credits, depreciation, insurance, and financing costs;
- CC_{tot} = total capital cost, including interest during construction;
 - LOM = levelized annual operating and maintenance costs, excluding fuel cost;
 - LFC = levelized annual fuel cost;

E_{net} = net yearly energy production.

This equation is developed and discussed in detail in references 3 and 4. The relation of the fixed charge rate to the pertinent economic parameters is given in Appendix A and reference 5.

The approach is a particularly useful one for comparing options which differ markedly among themselves in capital investment vs. operating (i.e., fuel) expenses. It is often used by utilities in evaluating technology options (ref. 6) and also appears to be an acceptable screening device for industrial applications (ref. 7). The different operating requirements and financing structure of utilities compared to private industry, however, will lead to different values and ranges for the levelized energy cost and to slightly different conclusions in the comparison. These two potential markets will be discussed separately.

General Economic Assumptions

The underlying economic scenario assumed here is based on the author's analysis of information supplied by several private industrial firms (ref. 7) and on the historic performance of the utility financial market. Simply stated, it is observed that debt cost is normally 3-5 percentage points above the general inflation rate and that in turn, a company's return on equity is 4-6 percentage points above the cost of borrowing. Thus, the following general scenario has been used:

General inflation rate = 8% Capital escalation rate = 8% Debt cost = 11% Return on equity = 15%

Other assumptions particular to a utility or private industrial company are given in the subsequent sections. Results for a second scenario in which the general inflation rate is higher are presented in Appendix B.

Electrical Generation

Capital Costs of Central Receiver Plants

Cost estimates used here assume mature designs for the solar subsystems. Heliostats are mass-produced (refs. 8-11), conventional tower construction (ref. 12) and electrical generating components (refs. 2, 13) are employed, and contingency and indirect budgets are typical of "nth" plant projects, i.e., projects involving well established construction practices (ref. 2). The results are based on a molten salt receiver and storage design (ref. 2) scaled from 100 MW_e to 300 MW_e and glass/steel heliostats of ~ 50 m² reflective area per unit. Instead of a single set of values, a range of costs for the solar components is considered here in order to accommodate uncertainties in the cost projections. The lower bound is the baseline "nth" plant estimate in which heliostats cost $885/m^2$ (refs. 8-11, 14). The upper bound allows an uncertainty of +50% on heliostat cost and +100% on receiver and storage costs. A budget for interest during construction is also included. Table II summarizes the important assumptions on which the total capital costs are based.

The baseline "nth" plant of reference 2 is designed with \sim 3 hours of thermal storage, which corresponds to a capacity factor* of ~ 40% at a location similar to Barstow, CA. (Reference 15 provides guidelines for estimating levelized energy costs at other locations.) The baseline plant has been optimally redesigned (refs. 4, 5, 16) for both lower and higher capacity factors in order to compare central receivers with conventional options over the full range of operating interest to utilities: peaking (< \sim 25% capacity factor), intermediate (~ 25% to 60% capacity factor), and base load (> ~ 60% capacity factor) applications. Figure 1 presents central receiver capital costs in KW_e as a function of capacity factor for the assumptions of Table II. (Note the contrast in solar vs. fossil plant design with respect to capacity factor. Higher capacity factors are achieved in a solar plant by increasing the collection and storage capability of the plant. The result is higher capital costs as the capacity factor is increased. Fossil plant components, however, are sized to handle the fuel rate necessary to achieve the design power output; hence, the capital cost is roughly fixed regardless of capacity factor. In the fossil case, capacity factor increases are achieved by burning fuel for longer periods of time.)

Economic Assumptions

The important assumptions for calculating the LEC are given in Table III. These values are typical of an investor-owned utility and reflect the returns traditionally required by the financial markets. Figure 2 presents the levelized energy costs resulting from the range of values in Figure 1 and the economic scenario of Table III. Operating and maintenance (O&M) costs are derived from studies on heliostat O&M requirements (ref. 17) plus the assumption that O&M for the rest of the plant will be comparable to conventional technologies. A first-year O&M cost of 1.5% of the capital cost is escalated and discounted through the 30-year plant life.

*Capacity factor is defined as the ratio of the actual energy production from a plant to the theoretical maximum energy production (=plant power rating x8760 hrs).

INITIAL ASSUMPTIONS FOR CENTRAL RE	CEIVER CAPITAL COSTS
• Plant Description	"nth" Plant
	50 m ² mirror area/heliostat
	Molten salt receiver/storage
	300 MWe
• Costs	
Heliostats	\$85-\$128/m ²
Receivers/storage	Baseline (ref. 2) + 100%
Turbine/generator	\$225/kW _e
• Contingency	10%
 Indirects (construction management, fees) 	15%
 Interest during construction 	10%

TABLE II



Figure 1. Capital costs of central receiver plants for electrical generation vs. capacity factor; lower bound, mature plant design with \$85/m² heliostats; upper bound, heliostats at 50% higher cost, receivers and storage at 100% higher cost

Fixed charge rate (FCR)	<u>15.9%</u>	
Discount rate*	10.0%	
Income tax rate	48.0%	
Property tax, insurance	2.5%	
Investment tax credit	10.0%	
Tax life (sum-of-years digits)	24 year	۶
Operating life	30 year	۰s
General inflation	8%	
Capital escalation	8%	
Plant start-up	1992	
*Debt fraction = 0.5 Debt cost = 11% Fraction preferred stock = 0.1	Fraction common stock = 0.4 Rate of return (before tax) = 15%	

TABLE III

ECONOMIC ASSUMPTIONS FOR INVESTOR-OWNED UTILITIES



Figure 2. Levelized energy cost of mature central receivers for electrical generation vs. capacity factor.

Figure 3 is a breakdown of the lower curve in Figure 2 into its component parts. The largest direct cost contributor to the levelized energy cost is the heliostats. In addition, 0&M and the add-on charges for contingency, indirects, and interest during construction comprise significant portions of the curve. Figure 3 also clearly indicates that the balance of plant is the source of the decline in energy costs as the capacity factor increases. The largest part of this category is the turbine/generator, which is a fixed capital cost item regardless of capacity factor. When this part of the capital cost is translated into an energy cost, its relative contribution will decrease with increasing capacity factor because the fixed investment is written off over the increase in annual energy production associated with increasing capacity factor.

The energy cost band of Figure 2 is duplicated on subsequent graphs where comparisons with conventional fossil fired technologies are made.

Fossil Fired Plants

The assumptions for conventional fossil fired plants are summarized in Table IV. Capital costs were obtained from the EPRI Technical Assessment Guide (ref. 18) and from conversations with a number of southwestern utilities concerning new plant costs for meeting mid 1980's emissions requirements (ref. 6). Initial fuel costs are typical of new contract prices for the delivered fuel. Uncertainties in fuel price escalation rates and geographic variations in coal plant construction costs are treated by considering a range on these parameters rather than a single value. The lower end of the range selected on fuel escalation rates represents the conservative assumption that fossil fuel prices will simply increase at the general inflation rate. The upper value of 3% above inflation is equivalent to a continuation of fuel price increases during the 1980's similar to those experienced in the previous decade (i.e., 4 to 8% annual increases over and above inflation), followed by a decline to meet general inflation in the 1990's. For illustration, such a variable fuel escalation rate scenario equivalent to the 3% above inflation case is presented in Appendix C.

FOSSIL FIRED PLANT ASSUMPTIONS FOR UTILITY APPLICATIONS				
	<u>0il</u>	Gas	Coal	
Fuel Cost (1981 \$/10 ⁶ BTU)	\$4.00	\$2.50	\$1.50	
Fuel escalation rate above inflation (%/yr)	0+3	0+3	0+3	
Capital cost (1981 \$/kW _e)	460	460	800-1600	
Heat rate (BTU/kw-hr)	8600	8600	10,250	

TABLE IV



Figure 3. Levelized energy cost breakdown of lower curve of Figure 2.

*Turbine/generator, land and site preparation, buildings, switchyard, etc.

Levelized Energy Cost Comparison for Electrical Generation

Figures 4-9 present the levelized energy cost range for central receivers from Figure 2 with the energy costs from oil, gas, and coal fired plants, respectively, at the lower and upper limits of fuel escalation rate considered here. An abbreviated note in the lower right hand corner identifies each comparison. The question of allowed capacity credit* for solar is handled by presenting the fossil curves representing the extremes of 0% capacity credit (fuel displacement value only) and 100% capacity credit (fuel plus full capital value). In reality, central receivers will probably be allowed an intermediate capacity credit (refs. 19, 20).

As an example, suppose that a solar plant of 25% capacity factor would be allowed 60% capacity credit in a particular grid and would be backed up with an oil fired plant. Simply stated, this means that an oil fired plant of 40% of the capacity of the solar plant would have to be built along with the solar plant in order to insure overall grid reliability. The value of the solar plant would then be the value of the fuel it displaces (i.e., the oil which is not burned because of the solar plant power production) plus the value of the oil fired plant capacity which did not have to be built (i.e., 60% of the solar plant capacity). Disregarding any considerations of cost scaling with capacity, then one can estimate the value of the solar plant from Figure 4 (or 5) as the sum of the "fuel only" line plus 60% of the difference between the "fuel only" and "capital + fuel" curves at 25% capacity factor. In Figure 4, this amounts to ~ 104 mills/kw-hr. This number should then be compared to the projected cost of energy from the solar plant, which is 89-111 mills/kw-hr at 25% capacity factor. The favorable comparison of the solar plant energy cost with its value for this example of intermediate capacity credit suggests that it is a reasonable economic choice for energy production.

As seen in Figures 4 and 5, the future competitiveness of solar central receivers with oil fired plants appears certain under the most conservative of assumptions; namely, little or no capacity credit and little or no fuel price escalation above inflation. Potential competitiveness with natural gas (Figures 6 and 7) is also likely given that solar plants are allowed some capacity credit and that there is a modest escalation of gas prices above inflation or the current price is higher than used here. (Significant escalation does, in fact, appear certain. Higher current gas prices are also a reality in some areas.)

In comparing central receivers to coal (Figures 8 and 9), several points must be considered. To begin with, fuel price can vary widely, depending primarily on the proximity of the generating plant to the mine. In addition, regional variations in environmental and licensing requirements, labor productivity, and construction practices combine to produce a wide range of capital cost projections. Only one utility contacted (ref. 20) asserts future costs below \$800/kWe, while another has estimated costs of \$2750/kWe for the

*Capacity credit is defined here as:

100% (1.0 - Backup capacity to meet system reliability) Solar plant capacity



.....

Figure 4. Energy cost comparison of central receivers and oil fired plants; 0% fuel escalation rate above inflation



Figure 5. Energy cost comparison of central receivers and oil fired plants; 3% fuel escalation rate above inflation







CAPACITY FACTOR, %

Figure 7. Energy cost comparison of central receivers and gas fired plants; 3% fuel escalation rate above inflation



Figure 8. Energy cost comparison of central receivers and coal fired plants; 0% fuel escalation rate above inflation



Figure 9. Energy cost comparison of central receivers and coal fired plants; 3% fuel escalation rate above inflation

1990 timeframe (ref. 21). The effect of capital cost is indicated in Figures 7 and 8. The comparison with coal is most likely at capacity factors > 50% -60% where most coal plants are designed to operate. In this case, central receivers become competitive under a scenario somewhat stricter than for oil or natural gas, but still plausible, i.e., the concurrence of some capacity credit with high real fuel price escalation rates and/or high coal plant construction costs.

Industrial Process Heat (IPH) Generation

Capital Costs of Central Receiver Plants

The molten salt receiver/storage system has been shown to be the most economic technology choice for a wide range of delivered process steam temperatures in IPH applications (ref. 22). Therefore, the same baseline system as the electrical case less the turbine/generator subsystem has been used and redesigned to 300 MW_{th} for the IPH comparison in this report. In comparing solar plants with fossil options for IPH, the most straightforward, but strictest comparison is on the basis of fuel displacement alone. The justification for this type comparision arises from the fact that most industrial processes are continuous with high (>95%) reliability factors, so that any solar plant will probably be built with a conventional backup system for process energy supply. The value of the solar plant will then be based on the fuel it displaces and no "capacity credit" will be allowed as in the electrical case.

While fuel displacement is probably a good basis for comparing central receivers with existing oil and gas burning facilities, the more plausible comparison with coal should include consideration of capital requirements. As discussed in reference 7, few existing facilities are equipped to burn coal. Therefore, the required investment in coal handling and burning equipment should be added to the fuel costs for comparison to the capital and operating expenses of a central receiver plant. New plant comparisons should be similarly treated; i.e., a coal plant designed specifically for the application. including backup equipment and fuel expenses, should be compared to the appropriate central receiver plant meeting the same operating and reliability requirements. (The likely central receiver plant concept is a hybrid with the most cost effective fossil option.) Unfortunately, the current lack of information on coal plant costs for industrial applications (i.e., smaller scale applications compared to utilities) has restricted the comparison here to fuel displacement alone. A solar plant with buffer storage only designed for a Barstow, CA location is used. Under the same assumptions as the electrical case, a capital cost range for central receivers of $245 - 380/kW_{th}$ (\$30 - $47/10^6$ BTU/yr), results.

Economic Assumptions

The economic assumptions are based on information about industrial financing practices (ref. 7) and the relation between the general inflation rate and rates of return outlined earlier. Table V gives the values of the parameters used.

ECONOMIC ASSUMPTIONS FOR INDUSTRIAL	PROCESS HEAT APPLICATIONS
Fixed charge rate (FCR)	22.9%
% Equity financing	100.0%
Rate of return (after tax)	15.0%
Income tax rate	48.0%
Property tax, insurance	2.5%
Investment tax credit	10.0%
Tax life (sum-of-years digits)	16 yrs
Operating life	20 yrs
General inflation	8.0%
Capital escalation	8.0%
Plant start-up	1992

TABLE V

Fossil Fired Plants

Table VI summarizes the assumptions on fossil fuels used in the IPH case. Since the comparison is based on fuel displacement only, capital costs of the fossil facilities do not enter into the caluclations. Note that the initial coal price is assumed somewhat higher than for the utility case. While few industries are currently burning coal, several have investigated the costs of retrofitting (ref. 7). Delivered coal prices are expected to be higher than

TABLE VI

FOSSIL FUEL ASSUMPTIONS FOR INDUSTRIAL	PROCESS	HEAT A	APPLICATIONS	
	0i1	Gas	s Coal	=
Fuel cost (1981 \$/10 ⁶ BTU)	4.00	2.50	2.00	
Fuel escalation above inflation (%/yr)	0+3	0*	3 0+3	
Boiler efficiency (%)	75	75	75	

for the utilities. The smaller average industrial plant size and the accompanying decreased capability for coal storage and handling mean smaller unit buys and, thus, higher prices. The same range on fuel escalation rates as in the utility analysis is used. Appendix C gives a comparable scenario with variable escalation rates.

Levelized Energy Cost Comparisons for Industrial Process Heat

Figure 10 compares the levelized energy cost from a central receiver plant with buffer storage only vs. the levelized fuel cost of conventional options. As indicated, the range on solar costs covers the baseline estimates plus the same allowed variations on solar component costs as used for the utility comparison. The range on fuel costs reflects the range on fuel escalation rates analyzed.

Similar to the utility case, the most conservative assumptions, i.e., negligible fuel escalation above inflation plus higher solar costs show that central receivers will be competitive with oil simply because of its high current prices. Substantial overlap of the natural gas and solar bands indicates the likelihood of central receiver competitiveness with this fuel, as well. Finally, the higher coal price in industrial applications results in the central receiver comparing favorably under the plausible scenario of higher coal escalation rates coupled to the attainment of baseline solar system costs. The addition of a capital cost contribution to the coal fuel value band will lead to an even more favorable comparison of central receivers with the coal option.



Figure 10. Energy Cost Comparison of Central Receivers and Fossil Fuels for Industiral Process Heat

ယ္သ

REFERENCES

- L. N. Tallerico, "A Description and Assessment of Large Solar Power Systems Technology," Sandia Laboratories, Livermore, SAND79-8015, August 1979.
- K. W. Battleson, et al., "1980 Solar Central Receiver Technology Evaluation," Sandia Laboratories, Livermore, SAND80-8235, October 1980.
- 3. J. W. Doane, et al., "The Cost of Energy from Utility Owned Solar Electric Systems," ERDA/JPL 1012-76/3.
- 4. J. M. Brune, "BUCKS Economic Analysis Model of Solar Electric Power Plants," Sandia Laboratories, Livermore, SAND77-8279, January 1978.
- 5. T. A. Dellin and M. J. Fish, "A User's Manual for DELSOL2: A Computer Code for Calculating the Optical Performance and Optimal System Design for Solar Thermal Central Receiver Plants," to be published as a Sandia Report, June 1981.
- 6. M. J. Fish, "Utility Views on Solar Thermal Central Receivers," Sandia Laboratories, Livermore, SAND80-8203, April 1980.
- 7. M. J. Fish, "User Views on Solar Thermal Central Receivers for Industrial Process Heat Applications," to be published as a Sandia Report, June 1981.
- 8. General Motors Corporation, "Heliostat Production Evaluation and Cost Analysis: Executive Summary," SERI/TR-8052-2, December 1979.
- 9. Solar Technology Division 8451, "Prototype/Second Generation Heliostat Evaluation and Recommendations: Executive Summary," Sandia Laboratories, Livermore, SAND78-8192, October 1978.
- 10. Martin Marietta, "Second Generation Heliostat Development," Sandia Laboratories, Livermore, SAND79-8192, September 1980.
- 11. McDonnell Douglas, "MDAC Second Generation Heliostat Program," MDCG9490, April 1980.
- 12. Stearns-Roger, "Tower Cost Data for Solar Central Receiver Studies," Final Report for Sandia (Contract No. 18-8446), June 1979.
- G. Oganowski and D. J. Muller, "EPGS Study for Advanced Water/Steam Receivers," Sandia Laboratories, Livermore, SAND80-8180 (prepared by General Electric), April 1980.

- 14. E. D. Eason, "The Credibility of Cost Estimates for Mass-Produced Heliostats," Sandia Laboratories, Livermore, SAND79-8222, October 1979.
- 15. K. W. Battleson, "Solar Power Tower Design Guide: Solar Thermal Central Receiver Power Systems, A Source of Electricity and/or Process Heat," Sandia Laboratories, Livermore, SAND81-8005, April 1981.
- 16. J. B. Woodard and G. J. Miller, "STEAEC Solar Thermal Electric Annual Energy Calculator Documentation," Sandia Laboratories, Livermore, SAND77-8278, January 1978.
- 17. E. D. Eason, "The Cost and Value of Washing Heliostats," Sandia Laboratories, Livermore SAND78-8813, June 1979.
- 18. Electric Power Research Institute, "Technical Assessment Guide," EPRI PS-1201-SR, July 1979.
- 19. Westinghouse Advaned Systems Technology Division, "Economic Assessment of Advanced Central Receiver Solar Thermal Power Systems," DOE/SF 10601-1, October 1980.
- 20. M. J. Fish, private communication from Southwestern Public Service, June 1980.
- 21. M. J. Fish and A. C. Skinrood, memo on visit with Pacific Gas and Electric, January 1980.
- 22. J. D. Fish, et al., "Central Receiver Steam Systems for Industrial Process Heat Applications," Sandia Laboratories, Livermore, SAND81-8223, April 1981.

APPENDIX A--CALCULATION OF THE FIXED CHARGE RATE

The fixed charge rate (FCR) is calculated according to the following relation:

$$FCR = PTI + \frac{(1.0-ITC) - (ITR X DEP)}{(1.0-ITR) f_{DIS}}$$
(A-1)

where PTI = annual property tax and insurance rate;

ITC = investment tax credit; ITR = income tax rate; DEP = depreciation allowance (see equation A-2); f_{DIS} = discount factor (see equation A-4).

The depreciation allowance will depend on the depreciation schedule used. The sum-of-years digits schedule gives:

$$DEP = \sum_{y=1}^{Y} \frac{2(Y_{DEP} - y + 1)}{Y_{DEP} (Y_{DEP} + 1) (1 + r_{DIS})^{y}}$$
(A-2)

where Y_{DEP} = depreciation life of the plant;

The discount rate is the effective cost of money to the plant owner and includes both debt costs and return on equity requirements according to:

$$r_{DIS} = [(1.0 - ITR) f_{D} + f_{PS}] i_{D} + f_{cs} i_{ROR}$$
 (A-3)

where f_D = debt fraction; i_D = debt cost; f_{PS} = fraction preferred stock; f_{CS} = fraction comon stock; i_{ROR} = rate of return (before - tax).

The discount factor is calculated from the discount rate:

$$f_{DIS} = \frac{Y_{OP}}{Y_{=1}} \frac{1.0}{(1.0 + r_{DIS})^y}$$

where $\boldsymbol{Y}_{\mbox{OP}}$ operating life of the plant.

APPENDIX B--RESULTS FOR A SCENARIO ASSUMING A HIGHER INFLATION RATE

Results for a different economic scenario in which the underlying inflation rate is assumed higher than in the main text are presented in this section. The relative ratios of the debt cost and rate of return to the inflation rate are kept the same as in the scenario of the main text. Table B-I gives the economic assumptions for the utility case. Figure B-1 is a plot of the levelized energy costs of central receivers based on the capital costs of Figure 1 in the main text and the economic parameters of Table B-I. Figures B-2 to B-7 are the corresponding comparisons with oil, gas, and coal fired plants at the lower and upper limits of the fuel escalation rate used throughout the analysis.

The economic assumptions for the industrial process heat case are found in Table B-II. The levelized energy cost comparison of central receivers with fossil fuels is presented in Figure B-8.

Qualitatively the conclusions of the main text still hold for this scenario; namely, central receivers can be cost-competitive with oil under the most conservative assumptions and with gas under assumptions of modest fuel escalation rates and allowed capacity credit (utility cases) coupled to attainment of the lower range of central receiver costs considered. Competitiveness with coal is also assured if high real fuel price escalations and/or high plant construction costs occur with some allowed capacity credit for central receivers. Quantitatively, the results emphasize the significant increases in energy costs (25-50%) which will accompany a sustained high inflation rate regardless of the energy source.

TABLE B-I

Fixed charge rate (FCR)	20.5%	
Discount rate		13.1%
Income tax rate		48.0%
Property tax, insurance		2.5%
Investment tax credit		10.0%
Tax life (sum-of-years digits)		24 yrs
Operating life		30 yrs
General inflation	12.0%	
Capital escalation	12.0%	
Plant start-up	1992	

ECONOMIC ASSUMPTIONS FOR INVESTOR OWNED UTILITIES HIGH INFLATION RATE SCENARIO

*	Debt fraction	=	0.5		
	Debt cost	Ξ	15.0%		
	Fraction preferred stock	=	0.1		
	Fraction common stock	=	0.4		,
	Rate of return (before tax)	=	19.25%		
_	المحجد كالكال كالمججى الكالمحصر منافلة فتداله بهندي متخدم بعد متدوره ودجا فيدخه بقومهمي ا				



Figure B-1. Levelized Energy Cost of Central Receivers vs. Capacity Factor; 12% Inflation Rate



Figure B-2. Energy Cost Comparison of Central Receivers and Oil Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation



Figure B-3. Energy Cost Comparison of Central Receivers and Oil Fired Plants; 12% Inflation, 3% Fuel Escalation Rate above Inflation



Figure B-4. Energy Cost Comparison of Central Receivers and Gas Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation



Figure B-5. Energy Cost Comparison of Central Receivers and Gas Fired Plants; 12% Inflation, 3% Fuel Escalation Rate above Inflation



Figure B-6. Energy Cost Comparison of Central Receivers and Coal Fired Plants; 12% Inflation, 0% Fuel Escalation Rate above Inflation



Figure B-7. Energy Cost Comparison of Central Receivers and Coal Fired Plants; 12% Inflation, 3% Fuel Escalation Rate above Inflation

TABLE B-II

HIGH INFLATION	RATE SCENARIO	
Fixed charge rate (FCR)	29.1%	
% Equity financing	100.0%	
Rate of return (after tax)	19.25%	
Income tax rate	48.0%	
Property tax, insurance	2.5%	
Investment tax credit	10.0%	
Tax life (sum-of-years digits)	16 yrs	
Operating life	20 yrs	
General inflation	12.0%	
Capital escalation	12.0%	
Plant start-up	1992	

ECONOMIC ASSUMPTIONS FOR INDUSTRIAL PROCESS HEAT APPLICATIONS HIGH INFLATION RATE SCENARIO



Figure B-8. Energy Cost Comparison of Central Receivers and Fossil Fuels for Industrial Process Heat; 12% Inflation Rate

49/50

*

*

APPENDIX C--EQUIVALENT SCENARIOS OF CONSTANT AND VARIABLE FUEL ESCALATION RATE

Continued real escalation of fuel costs above inflation throughout the 20 or 30 year life of a plant coming on line in 1992 seems unlikely. However, a variable escalation scheme equivalent to the constant scheme used in this report can be derived. High real fuel escalation rates (> 3%) are thought to be likely through the next decade with a gradual decline to meet general inflation in the 1990's. Two such schemes are presented in Figures C-1 and C-2 for electric utility and industrial applications, respectively, for the purpose of illustrating scenarios equivalent to the upper bound of 3% above inflation considered here. The 20 year life assumed for industrial applications compared to a 30 year economic life for utility plants leads to a correspondingly shorter period of real fuel escalation rates required for a variable scheme scenario following the same initial trend as used here. (Equivalently, lower real fuel escalation rates for industrial plants over the same period of time as a utility analysis would provide a second way of comparing the two markets.)



Figure C-1. Variable Fuel Escalation Rate Scenario Equivalent to a Constant Rate of 3% above Inflation - Utility Application



Figure C-2. Variable Fuel Escalation Rate Scenario Equivalent to a Constant Rate of 3% above Inflation - Industrial Process Heat Application

INITIAL DISTRIBUTION

UNLIMITED RELEASE

Arizona Public Service P. O. Box 21666 Phoenix, AZ 85036 Attn: Eric Weber

Salt River Project P. O. Box 1980 Phoenix, AZ 85001 Attn: Steve Chalmers

Tucson Gas and Electric Co. 2220 W. Sixth St. Tucson, AZ 85702 Attn: J. L. Davis

Arizona Electric Power Cooperative, Inc. P. O. Box 670 Benson, AZ 85602 Attn: Thomas Perrine

Pacific Gas and Electric Co. 77 Beale St. San Francisco, CA 94106 Attn: Glen Ikemoto

Pacific Gas and Electric 3400 Crow Canyon Road San Ramon, CA 94583 Attn: Harold Seielstad

Los Angeles Department of Water and Power 111 N. Hope Street Los Angeles, CA 90051 Attn: Norman Nichols

Pasadena Water and Power 100 N. Garfield Ave., Rm 301 Pasadena, CA 91109 Attn: J. T. Brodie

San Diego Gas and Electric Co. P. O. Box 1831 San Diego, CA 92112 Attn: Al Figueroa

Southern California Edison P. O. Box 800 Rosemead, CA 91770 Attn: Joe Reeves

Sacramento Municipal Utility District P. 0. Box 15830 Sacramento, CA 95813 Attn: Lee Keilman U.S. Water and Power Resources Service Bureau of Reclamation Code 1500 E P. O. Box 25007 Denver, CO 80225 Attn: Stanley Hightower Public Service of Colorado P. 0. Box 840 Denver, CO 80201 Attn: Ed Ellis Georgia Power Co. P. O. Box 4545 Atlanta, GA 30302 Attn: Jim Miller Nevada Power Co. P. 0. Box 230 Las Vegas, NV 89151 Attn: John Arlidge Sierra Pacific Power Co. P. 0. Box 10100 Reno, NV 89510 Attn: R. G. Richards Public Service Company of New Mexico P. 0. Box 2267 Albuquerque, NM 87103 Attn: D. J. Groves Public Serice Company of Oklahoma P. O. Box 201 Tulsa, OK 74102 Attn: F. J. Meyer Bonneville Power Administration P. O. Box 3621 Portland, OR 97208 Attn: Norman E. Fuller

Pacific Power and Light Co. 920 Sixth Ave., SW Portland, OR 97204 Attn: Bob Lisbakken Portland General Electric 121 SW Salmon St. Portland, OR 97204 Attn: Norman Sanesi Tennessee Valley Authority 1360 Commerce Union Bank Bldg. Chattanooga, TN 37401 Attn: Rebecca Aslinger Utah Power and Light Company P. O. Box 899 Salt Lake City, UT 84110 Attn: S. Kent Evans Texas Electric Service Co. P. O. Box 970 Fort Worth, TX 76101 Attn: Maurice Wendt Texas Power and Light Co, P. O. Box 6331 Dallas, TX 75222 Attn: U. Gibson El Paso Electric Co. P. 0. Box 982 El Paso, TX 7999 Attn: Jim Brown Gulf States Utilities P. 0. Box 2951 Beaumont, TX 77704 Attn: Aubrey Sprawls Houston Lighting and Power Company P. 0. Box 1700 Houston, TX 77001 Attn: Bell Sample Southwestern Public Service Company P. 0. Box 1261 Amarillo, TX 79170 Attn: W. R. Esler West Texas Utilities Company 1062 N. 3rd St. Abilene, TX 79604 Attn: Rick Stanaland

Kansas Power and Light Co. 818 Kansas Ave. Topeka, KS 66612 Attn: William E. Wall Kansas Gas and Electric Co. P. O. Box 208 Wichita, KS 67201 Attn: Bernard Ruddick Kansas Energy Office 214 W. 6th St. Topeka, KS 66603 Attn: Joseph King Electric Power Research Institute P. O. Box 10412 Palo Alto, CA 93403 Attn: John Bigger University of Kansas Center for Research 2291 Irving Hill Rd. Lawrence, KS 66045 Attn: Robert F. Riordan Gibbs and Hill, Inc. 393 7th Ave. New York, NY 10001 Attn: R. Prieto Foster Wheeler Corp. 12 Peach Tree Hill Rd. Livingston, NJ 07039 Attn: R. J. Zoschak Institute of Gas Technology, Suite 218 1825 K St., NW Washington, DC 25006 Attn: Donald Glenn National Rural Electric Cooperative Association 1800 Massachusetts Ave. NW Washington, DC 20036 Attn: Robert Partridge PFR Engineering 4676 Admiralty Way, Suite 832 Marina del Rey, CA 90291 Attn: J. M. Pundyk American Public Power Association 2600 Virginia NW Washington, DC 20037

Attn: Alex Radin

General Atomics P. 0. Box 81608 San Diego, CA 92138 Attn: John McNeill Bechtel National Inc. P. O. Box 3965 San Francisco, CA 94119 Attn: Ernie Lam McDonnell Douglas 5301 Bolsa Ave. Huntington Beach, CA 92647 Attn: Ray Hallet C. R. Easton Martin Marietta P. O. Box 179 Denver, CO 80201 Attn: H. C. Wroton A. E. Hawkins ARCO Power Systems 302 Nichols Dr. Hutchins, TX 75141 Attn: J. A. Pietsch Westinghouse Corp. P. O. Box 10864 Pittsburgh, PA 15236 Attn: R. W. Devlin Westinghouse Electric Corp. 77 Penn Center Blvd. Pittsburgh, PA 15235 Attn: John Day Boeing Engineering and Construction P. 0. Box 3707 Seattle, WA 98124 Attn: J. R. Gintz General Electric 1 River Rd. Schenectady, NY 12345 Attn: G. Oganowski Energy Systems Group Rockwell International 8900 De Soto Ave. Canoga Park, CA 91304 Attn: Ralph Balent

Solar Energy Research Institute 1536 Cole Blvd. Golden, Co 80401 Attn: John Thornton Bim Gupta PRC Energy Analysis Co. 7600 Old Springhouse Rd. McLean, VA 22101 Attn: J. V. Conopask Solar Thermal Test Facilities Users Association Suite 1204, First National Bank, East Albuquerque, NM 87108 Attn: Frank Smith Mitre Corporation 1820 Dolly Madison Blvd. McLean, VA 22102 Attn: Willard Fraize California Energy Commission 1111 Howe Ave, Sacramento, CA 95825 Attn: Robert Weatherwax, MS-40 Jet Propulsion Laboratory 4800 Oak Grove Dr. Pasadena, CA 91003 Attn: Mickey Alpert Lawrence Livermore Laboratory P. O. Box 808 Livermore, CA 94550 Attn: W. C. Dickinson L-393 Black and Veatch P. O. Box 8405 Kansas City, MO 64114 Attn: J. C. Grosskreutz Energy Advisory Council 411 W. 13th St. Austin, TX 78711 Attn: Alvin Askew Florida Solar Energy Center 300 SR 401 Cape Canaveral, FL 32920 Attn: C. D. Beach

4

*

Dynatherm Corp. 1 Industry Lane Cockeysville, MA 21030 Attn: W. B. Bienert Combustion Engineering 100 Prospect Hill Rd. Windsor, CT 06095 Attn: C. R. Bozzuto General Motors Transportation Systems Center GM Technical Center Warren, MI 48090 Attn: John Britt Arthur D. Little, Inc. 1 Maritime Plaza San Francisco, CA 94947 Attn: John Butterfield NASA Lewis Research Center 2100 Brook Park Rd. Cleveland, OH 44135 Attn: Jim Calogeras Battelle PNL P. O. Box 999 Richland, WA 99352 Attn: J. W. Currie Rocketdyne Div. Rockwell International 6633 Canoga Ave. Canoga Park, CA 93140 Attn: J. M. Friefeld Exxon Enterprises Inc. Solar Thermal Systems P. O. Box 592 Florham Park, NJ 07932 Attn: Murray Nadler Ford Aerospace 3939 Fabian Way, T33 Palo Alto, CA 94303 Attn: I. Earl Lewis Aerospace Corp. D-5, Rm 1110 2350 E. El Segundo Blvd. El Segundo, CA 90245 Attn: Prem Mathur

U. S. Gypsum Co., Dept. 176-2 101 S. Wacker Dr. Chicago, IL 60606 Attn: Raymond McCleary

Stanford Research Institute 333 Ravenswood Ave. Menlo Park, CA 94025 Attn: Art Slemmons

Babcock and Wilcox 1562 Beacon Alliance, OH 44601 Attn: George Grant

Stone and Webster P. O. Box 2325 Boston, MA 02107 Attn: Don Guild

Scientific Applications, Inc. 1546 Cole Blvd. Golden, CO 80401 Attn: Ken Brown

A. F. Hildebrandt University of Houston Solar Energy Laboratory Houston, TX 77004

Scientific Applications Inc. 1710 Goodrich Dr. McLean, VA 22102 Attn: Dr. Richard A. Moyle

Scientific Applications, Inc. 100 Mercantile Commerce Bldg. Dallas, TX 75291 Attn: J. W. Doane

Accurex Corp. 485 Clyde Ave. Mountain View, CA 94042 Attn: J. Vindum

Colorado WSUN Colorado Office of Energy Conservation 1600 Downing St. Denver, CO 80218 Attn: Dennis Bates

California Public Utilities Commission 350 McAllister St., Room 5040 San Francisco, CA 94102 Attn: Barbara Barkovich ARCO 911 Wilshire Blvd. Los Angles, CA 90017 Attn: J. H. Caldwell, Jr. AMFAC Sugar Co. P.O. Box 3230 Honolulu, HI 96801 Attn: George St. John Central Telephone and Utilities Corp. P. O. Box 170 Great Bird, KS 67530 Attn: Earl C. Rhodes Texasgulf Chemicals P.O. Box 488 Newgulf, TX 77462 Attn: W. Herrington Phelps Dodge Corp. P.O. Drawer 1233 Douglas, AZ 85607 Attn: W. J. Chen 0. Royce Hill Director Engineering Plans and Services Division AFZF-FE-EPS HQ. III Corps, Ft. Hood Ft. Hood, TX 76544 Col. P. G. Reynolds Civil Engineering Commander Robbins AFB, GA 31098 Major George Kastanos DCS/Engineering and Services Department of the Air Force HQ Air Force Logistics Command Wright Patterson AFB, OH 45930 Olin Chemicals Group 120 Long Ridge Road Stamford, CT 06904 Attn: R. E. Smith Department of Planning and Economic Development State of Hawaii P.O. Box 2359 Honolulu, HI 96804 Attn: H. Kono

Columbia Gas System Service Corp. 1600 Dublin Rd. Columbus, OH 43215 Attn: E. A. Reid, Jr. Greyhound Corp. Greyhound Tower Phoenix, AZ 85077 Attn: K. M. Ries Harrison Radiator Division General Motors Corp. Lockport, NY 14094 Attn: A. F. Stocker **IIT Research Institute** Division M 10 West 35th St. Chicago, IL 60616 Attn: R. F. Firestone General Electric Co. P.O. Box 8661 Philadelphia, PA 19101 Attn: W. Pijawka R. San Martin, DOE/HQ L. S. Levine, DOE/HQ G. W. Braun, DOE/HQ W. Auer, DOE/HQ C. T. Cherian, DOE/HQ J. Easterling, DOE/HQ J. E. Rannels, DOE/HQ M. U. Gutstein, DOE/HQ M. J. Katz, DOE/HQ W. Hochheiser, DOE/HQ Dan Ancona, DOE/HQ Cyril Draffin, DOE/HQ J. Gahimer, DOE/HQ R. Duval, DOE/SAN R. W. Hughey, DOE/SAN S. D. Elliott, DOE/SAN K. Rose, DOE/SAN J. Nevil, DOE/SAN J. Weisiger, DOE/ALO G. Pappas, DOE/ALO R. N. Schweinberg, DOE/STMPO G. Dacey, 1 A. Narath, 4000; Attn: J. H. Scott, 4700 G. E. Brandvold, 4710 B. W. Marshall, 4713 J. F. Banas, 4716

J. A. Leonard, 4717 D. G. Schueler, 4720 J. V. Otts, 4721 W. P. Schimmel, 4723 T. A. Dellin, 4723 T. B. Cook, 8000; Attn: A. N. Blackwell, 8200 D. M. Olson, 8100 W. E. Alzheimer, 8120 R. J. Gallagher, 8124 M. J. Fish, 8124 (25) B. F. Murphey, 8300; Attn: D. M. Schuster, 8310 G. W. Anderson, 8330 W. Bauer, 8340 R. L. Rinne, 8320 C. T. Yokomizo, 8326 R. E. Chang, 8326 J. Vitko, 8326 L. D. Brandt, 8326 L. Gutierrez, 8400 R. C. Wayne, 8430 P. J. Eicker, 8431 K. W. Battleson, 8431 R. W. Carling, 8431 L. G. Radosevich, 8431 C. S. Selvage, 8450 A. C. Skinrood, 8452 (25) T. T. Bramlette, 8452 W. G. Wilson, 8453 D. Hartley, 8500; Attn: C. W. Robinbson, 8510 Peter Dean, 8265 Publications Division, 8265, for TIC (27) Publications Division, 8265/Technical Library Processes Division, 3141 Technical Library Processes Division, 3141 (3) M. A. Pound, 8214, for Central Technical File (3)

Org.	Bldg.	Name	Rec'd by '	Org.	Bidg.	Name	Rec'd by *
1191							
-				12.74			
			- Carlo	16.2	17-1		
							W.C.
				1121 7			
1							
	50-50						
	f LE						
32							No.
		and the second second					
			135				Carta .
					1		BEA
5			1	12			
147		a surger a set	3 . S				

Recipient must initial on classified documents.