


1032

JIM BARTEL



Rockwell International

MIDTERM QUARTERLY REVIEW  
SOLAR CENTRAL RECEIVER HYBRID  
POWER SYSTEM  
MATERIALS TUTORIAL PORTION  
CONTRACT DE-AC03-78ET 20567  
JUNE 6-7, 1979

MIDTERM QUARTERLY REVIEW

SOLAR CENTRAL RECEIVER HYBRID POWER SYSTEM

CONTRACT DE-AC03-78ET 20567

MATERIALS TUTORIAL PORTION

JUNE 6-7, 1979

ENERGY SYSTEMS GROUP  
ROCKWELL INTERNATIONAL  
8900 DE SOTO AVENUE  
CANOGA PARK, CALIFORNIA 91304

## AGENDA

- JUNE 6
- I. 9:00 - 9:15 INTRODUCTION AND SUMMARY - T. SPRINGER
  - II. 9:15 - 9:45 SYSTEM MATERIAL REQUIREMENTS - L. GLASGOW
    - A. TEMPERATURE EXTREMES AND MEANS
    - B. STRAIN CYCLES
    - C. ENVIRONMENTAL EXPOSURES
      - 1. ATMOSPHERIC (RECEIVER)
      - 2. COMBUSTION CHAMBER (FOSSIL HEATER)
      - 3. FEEDWATER (STEAM GENERATOR)
  - III. 9:45 - 11:30 MATERIAL OPTIONS AND CONSIDERATIONS - J. PAGE
    - A. MATERIAL CHARACTERISTICS
      - 1. CARBON STEEL
      - 2. LOW-ALLOY STEEL
      - 3. AUSTENIC STAINLESS STEEL
      - 4. HIGH-NICKEL ALLOY STEEL
      - 5. TRANSITION WELDS AND JOINTS



AGENDA  
(CONTINUED)

B. MATERIALS IN THE ENVIRONMENT

1. AIR
2. STEAM
3. BURNER

C. MATERIALS AND SODIUM

1. GENERAL EFFECTS
2. CARBON TRANSPORT

IV. 11:30 12:00 SELECTED MATERIALS BY COMPONENT - W. WILLCOX

A. RECEIVER

B. FOSSIL-FIRED HEATER

1. FURNACE
2. HIGH-TEMPERATURE CONVECTION
3. LOW-TEMPERATURE CONVECTION

C. RISER

D. DOWNCOMER

AGENDA  
(CONTINUED)

E. STORAGE

F. STEAM GENERATOR COMPLEX

1. EVAPORATOR AND SEPARATOR
2. SUPERHEATER AND REHEATER

G. PUMPS

1. CASE AND IMPELLER
2. BEARINGS

H. VALVES

1. BODY
2. HARD FACING

I. TRANSITIONS

V. 12:00 - 1:00 LUNCH

VI. 1:00 - 1:45 BASIS OF MATERIAL SELECTION

A. HEATER (B&W)

AGENDA  
(CONTINUED)

B. BALANCE-OF-PLANT - J. PAGE

1. EQUIPMENT AND PLANT COMPONENTS
2. HEATER TUBE SODIUM ASPECTS
3. CHLORIDE STRESS

VII. 1:45 - 2:30 DESIGN FEATURES TO ACCOMMODATE THE MATERIAL - L. GLASGOW

A. BUFFERING

1. BUFFERED TANKS
2. MIXING T'S

B. ENVIRONMENTAL PROTECTION

COVERED RECEIVER (TEMPERATURE MAINTENANCE)

C. SODIUM PURITY

COLD TRAPS

D. HARD FACING, VALVES AND PUMPS

AGENDA  
(CONTINUED)

E. FEEDWATER

1. SEPARATOR TANK
2. H<sub>2</sub>O PURITY CONTROL

F. CYCLIC DRAINING OF RECEIVER

VIII. 2:30 - 5:00 REACTOR AND TEST LOOP EXPERIENCE

2:30 - 3:00 A. FOSSIL-FIRED HEATER (H1 AND H2) - W. WILLCOX

B. LIQUID METAL EXPERIENCE - W. WOLFE

3:00 - 3:30 BUS TO SPTF

3:30 - 3:40 VUGRAPH PRESENTATION OF SPTF

3:40 - 4:00 TOUR SPTF

4:00 - 4:45 A. SODIUM/WATER REACTION EXPERIMENTS - W. DEBEAR, B-38

B. SCTI VUGRAPH PRESENTATION

C. TOUR SCTI

AGENDA  
(CONTINUED)

SECOND DAY

JUNE 7      IX. 8:15 - 8:45      IMPACT OF SERI CONFERENCE - J. PAGE

A.    TOPICS PRESENTED AT SERI CONFERENCE

B.    DISCUSSION OF SPECIFIC AREAS

1.    SODIUM PURITY LEVELS
2.    HYDROGEN LEVELS
3.    OXYGEN LEVELS

C.    COMMENTS ON SLL ASSESSMENT DOCUMENT

X. 8:45 - 9:15      COAL PLANT STACK GAS CLEANUP - R. OLDENKAMP

A.    REMOVAL OF PARTICULATES


B.    SO<sub>2</sub> REMOVAL

INTRODUCTION AND SUMMARY

MID-TERM QUARTERLY REVIEW  
MATERIALS TUTORIAL SUMMARY

- USE OF SODIUM AS HEAT TRANSPORT FLUID IS NOT NOVEL
  - 30 YEARS OF EXPERIENCE AND \$3 BILLION ALREADY INVESTED IN DEVELOPMENT
  - 120 SODIUM LOOPS DESIGNED, BUILT, AND OPERATED IN U.S. AND WORLD
  - 9 SODIUM-COOLED POWER PLANTS CURRENTLY IN OPERATION (UP TO 350 MWE)
  - 14 SODIUM-COOLED POWER PLANTS UNDER CONSTRUCTION (UP TO 1200 MWE @ \$1 BILLION EACH)
- SODIUM SYSTEMS HAVE A SAFETY RECORD BETTER THAN U.S. INDUSTRY AS A WHOLE
- USE OF SODIUM AS A COOLANT IN THE SOLAR CENTRAL RECEIVER CONCEPT DOES NOT REPRESENT A DEPARTURE FROM THE ESTABLISHED STATE OF THE ART OF SODIUM TECHNOLOGY IN TERMS OF SIZE, TEMPERATURE, FLOW RATE, PRESSURE, AND MATERIALS OF CONSTRUCTION
- RECEIVER HAS UNIQUE AREAS OF CONCERN IN TERMS OF CYCLE LIFE

# WORLD LMFBF PLANTS (PROGRESS GROWTH)



1960 1965 1970 1975 1980 1985 1990 1995

STARTUP DATE

LEGEND  
 ● ACTUAL STARTUP  
 ○ ANTICIPATED STARTUP

SOLAR APPLICATIONS

REACTOR POWER MW

ESC Original  
 SCE Operated






SYSTEM MATERIAL REQUIREMENTS

# STRUCTURAL MATERIAL SELECTION FOR SODIUM SYSTEMS

THE USE OF SODIUM AS A HEAT TRANSFER FLUID HAS  
NO EFFECT ON STRUCTURAL MATERIAL SELECTION

# SOLAR CENTRAL RECEIVER HYBRID POWER SYSTEM

-29 (-20)  
 650 (1200 ± 50) TUBE WALL OUTSIDE  
 593 (1100 ± 50) N<sub>a</sub>




Furnace - Vol % [N<sub>2</sub>-69; CO<sub>2</sub>-14; H<sub>2</sub>O-15; O<sub>2</sub>-2; SO<sub>2</sub>-0.06]




Fly Ash - .001 #/ft<sup>3</sup>



Rockwell International  
 Energy Systems Group

# RECEIVER HEAT FLUX PROFILES (EQUINOX NOON)





TIME - t

TEMP - T

Rate of Temp

$$\left| \frac{dT}{dt} \right|_{max} \approx \frac{1}{L} \frac{OF}{SEC}$$

Thickness


$$St = \frac{F E \alpha \Delta T}{(1 - \mu)}$$

$$F_3 = f \left( \frac{1}{B_1} = \frac{K}{h_8} \right) (0, 1)$$

Caused by high thermal conductivity

Thermal Transient Stress

# RECEIVER TUBE TEMPERATURE PROFILE



Rockwell International  
Energy Systems Group

CONCLUSION:

THERE ARE NO ENVIONMENTS WHICH HAVE  
NOT BEEN ENCOUNTERED PREVIOUSLY.




Rockwell International  
Energy Systems Group

MATERIAL OPTIONS AND CONSIDERATIONS




SECTION III-A

MATERIALS CHARACTERISTICS




Changes in Pure Iron as it Cools from the Molten State to Room



*Ferrite*  
*( $\alpha$  Iron)*

Body-Centered Cubic Structure of Alpha Iron



(ASM)




*Austenite*  
*( $\gamma$  Iron)*

Face-Centered Cubic Structure of Gamma Iron


(ASM)




The Iron-Carbon Constitution Diagram (ASM)



70-MA1-48-375



70-MA1-48-375A




# NOMINAL COMPOSITION OF STRUCTURAL MATERIALS

MATERIAL	COMPOSITION, WT % (BALANCE FE)										
	CR	NI	MO	SI	MN	TI	AL	NB	C	S	P
AISI 304	18	9.6	-	0.5	1.1	-	-	-	0.07	0.008	0.03
AISI 316	17	12	2.8	0.5	1.7	-	-	-	0.05	-	-
AISI 321	18	9.5		0.7	1.1	0.4	-	-	0.07	-	-
2-1/4CR-1Mo	2.2	0.1	0.9	0.4	0.6	-	-	(1.0)	0.14	0.02	0.01
9CR-1Mo	9	-	1.0	0.7	1.0	-	-	-	0.15	0.03	0.03
ALLOY 800	20	32	0.04	0.3	0.8	0.4	0.4	-	0.06	0.007	0.008
16-8-2	15.5	8.5	1.5	0.5	2.5		(Cu		0.10	0.03	0.03
ERNiCr-3 (INCONEL 82)	20	67.0 (MIN)	(Fe 3.0)	0.5	3.0	0.75	0.5)	2.5	0.10	0.015	0.03



# ASME BOILER CODE ALLOWABLES FOR CANDIDATE MATERIALS

## SECTION VII, DIV 1



## CARBON STEEL

### ADVANTAGES

- VERY LOW COST
- READY AVAILABILITY
- GOOD FABRICABILITY

(EXCEPT WELD POROSITY)

- NO CHLORIDE SCC  
<sub>or Chloride / oxygen SCC</sub>

*depends upon  
heat quality*

### DISADVANTAGES

- RUSTS
- CAUSTIC <sup>CC</sup> \$\$\$
- ABOVE 800°F
  - GRAPHITIZES *cementite converts to carbon*
  - WEAK
  - OXIDIZES
  - WILL DECARBURIZE IN SODIUM
  - MAY EMBRITTLE AT LOW TEMPS

LOW - ALLOY STEEL  
(1 TO 9% CR)

ADVANTAGES

- LOW COST
- STRONG TO 1000°F
- OXIDATION OK
- WON'T GRAPHITIZE
- NO CHLORIDE SCC
- MUCH FOSSIL STEAM GENERATION EXPERIENCE
- MUCH SODIUM STEAM GENERATION EXPERIENCE
- REASONABLE AVAILABILITY

DISADVANTAGES

- MAY RUST
- MUST HEAT TREAT WELDS
- MAY HAVE HIGH NIL-DUCTILITY TEMP
- MAY DECARBURIZE 25%

75% Cr attract Carbon.

French: EM-12

~~19 Cr~~  
5 Cr

weaker than 2 1/2 Chrome  
USA,  
9 Cr - petrochemical

Modif 9 Cr - 1 Mo.  
CE + 0.02% N

Ar substitution  
strong as Nb, V. low Si

immune to el SCC  
Lower Thermal exp  
not as attractive as stainless steel  
to general corrosion

Not  
Common

except Steak knives

"400 - SERIES" STAINLESS  
12-14% Cr → 25%  
low Ni

(DARK HORSES - historically interstitials  
caused problems.)

Vacuum melt has helped minimize  
interstitials.

ADVANTAGES

- DOESN'T RUST
- LOWER COST
- NO CHLORIDE SCC

DISADVANTAGES

hard to weld

- HIGH-TEMP EMBRITTLEMENT
- DIFFICULT TO WELD
- CAUSTIC SCC?
- NO HIGH TEMP EXPERIENCE

## "300 - SERIES" STAINLESS

### ADVANTAGES

- MODERATE COST
- GOOD STRENGTH
- <sup>Very</sup> EASILY WELDED
- NO NIL-DUCTILITY
- DOESN'T RUST
- MUCH RESEARCH
- MUCH EXPERIENCE
- REASONABLE AVAILABILITY

### DISADVANTAGES

- SENSITIZES
- CAUSTIC SCC
- CHLORIDE SCC

*(result of temperature  
time exposure, not Na)*

## HIGH NICKEL ALLOYS

*deastically affected by  
Pb and Sulfur / form*

### ADVANTAGES

- RESISTS CHLORIDE SCC
- NO NIL-DUCTILITY
- RESISTS CAUSTIC SCC

### DISADVANTAGES

- HIGH COST
- LIMITED AVAILABILITY
- WEAKENED BY LEAD AND SULFUR

*readily weldable  
can mean small turbine  
blades, not large sections*

WELDABILITY VARIES


STRENGTH VARIES

*1-1 1/2 year to obtain plates*

TRANSITION JOINTS


LOW TEMPERATURE

( $T < 700^{\circ}\text{F}$ )




HIGH TEMPERATURE

( $T > 700^{\circ}\text{F}$ )



DISSIMILAR METAL WELDS - TRANSITION JOINTS PROGRAM  
(316 SS/2-1/4 CR - 1 Mo)

- CONDUCTED BY DOE AT ORNL
  - DESIGN ANALYSIS - GE
  - MECHANICAL PROPERTIES - ORNL
  - WELD & ISI PROCEDURES - ORNL
  - LIFE TESTS - ETEC/ESG
- 
- PROGRAM INCEPTION - 1976
  - BUDGET 1.25 M/YR.
  - COMPLETION - LATE 1980
  - TRANSITION JOINT SCHEMATIC:






### OTHER MATERIALS

- BRAZING - NI BASE ALLOYS
- ANTI GALL & SELF WELD - STELLITES
- SEAL MATERIALS - ELASTOMERS
- INERT GASES - HELIUM, ARGON
- COOLANTS - DOWTHERM, NAK, WATER


*as an industry can be faulted because  
have not utilized brazing as much as could*

SECTION III-B

MATERIALS IN THE ENVIRONMENT




STEAM CORROSION




OXIDATION IN AIR

# STRESS DISTRIBUTION IN A SHOT PEENED BEAM



a. DISTRIBUTION OF STRESS IN A SHOT-PEENED BEAM WITH NO EXTERNAL LOAD




b. RESULTANT DISTRIBUTION OF STRESS IN A SHOT-PEENED BEAM WITH EXTERNAL LOAD APPLIED  
SOLID LINE IS THE RESULTANT


71-014-59-6

Figure 86a


# EQUILIBRIUM CONCENTRATION OF NaOH AS A FUNCTION OF TEMPERATURE AND VAPOR PRESSURE OF H<sub>2</sub>O



# BOUNDARIES OF CAUSTIC SCC DANGER ZONES




# REPORTED CAUSTIC STRESS CORROSION IN 300 SERIES STAINLESS STEELS






V-A-86



# Ni ALLOY STRESS CORROSION




— Incoloy 800 Ni comp.  
Selected for resistance  
to SCC.

If you had to pick an  
alloy best for SCC.  
pick 8% Ni like 304  
316


71-01459-10

# PEENED TYPE 304 SS AFTER STRESS CORROSION TESTS



8X

SHOT-PEENED



8X

UNPEENED

Figure 86c

# STRESS CORROSION TEST U-BEND SPECIMEN

*Boeing Mg Al  
Sol 54*




Figure 86b

71-014-59-8

# STRESS CORROSION

9-N7-129-27

## **SENSITIZATION**

### **SENSITIZATION**


- HAS NO EFFECT ON STRENGTH
- HAS NEGLIGIBLE EFFECT ON DUCTILITY
- HAS MINOR EFFECT ON IMPACT STRENGTH AT LOW TEMPERATURES
- HAS NO EFFECT ON OXIDATION RESISTANCE
- HAS NO EFFECT ON SODIUM COMPATIBILITY

9-N7-129-26

**TO RESIST SENSITIZATION:**

- OPERATE ABOVE 1200°F
- SOLUTION ANNEAL AND OPERATE BELOW 800°F
- REDUCE CARBON (e.g. 304L) — LOSE STRENGTH
- ADD STRONG CARBIDE-FORMERS SUCH AS Ti(321) OR Cb(347) —
  - LESS WELDABLE
  - SUBJECT TO KNIFE-LINE ATTACK
  - WILL SENSITIZE EVENTUALLY

9-N7-129-24



NARROW REGION  
(2000 to 2600°F)

Nb, Ti CARBIDES  
DISSOLVED; DID  
NOT PRECIPITATE  
ON REHEATING

WIDER REGION  
(900 to 1400°F)

CHROMIUM CARBIDE  
PRECIPITATES:



STEEL IS SENSITIZED

70-MA1-48-359

*Mo provides pitting resistance  
stabilization doesn't help much if operate in water at hi T.*



# TIME-TEMPERATURE-SENSITIZATION DIAGRAMS FOR AUSTENITIC STAINLESS STEEL




70(724)48-374A

*low-C steels thus used  
bec. can weld on Fab.*

# How Sensitization Affects the Corrosion of Stainless Weld Metal

By **RUSSELL B. GUNIA**  
and **THOMAS J. MOORE\***



This three-dimensional drawing illustrates the time-temperature-sensitization relationship for 18-8 weld metal (0.036% C) which was aged in the as-welded condition before being corrosion tested in boiling nitric acid. (The vertical scale is logarithmic with the same base as the time scale.)

\*Mr. Gunia is manager, stainless steel metallurgy, United States Steel Corp., Pittsburgh, and Mr. Moore is assistant director of research, Arcos Corp., Philadelphia.

PEENED AND UNPEENED TYPE 304 SS AFTER  
SENSITIZING (1 hr AT 1200°F), AND TESTING FOR  
INTERGRANULAR CORROSION IN  $\text{HNO}_3$ -HF



a. Peened




b. Unpeened

41000-1274

NOTE INTERGRANULAR ATTACK IN UNPEENED SURFACE AND ABSENCE OF  
CORROSION IN THE COLD WORKED SURFACE OF THE PEENED SECTION (250X)

# SENSITIZATION



**SENSITIZATION**

SECTION III-C

MATERIALS AND SODIUM

## SODIUM "CORROSION" EFFECTS

### A. SOLUTION MASS TRANSFER

AKA TEMPERATURE GRADIENT MASS TRANSFER

- ESSENTIALLY INSIGNIFICANT IN NON-RADIOACTIVE SYSTEMS

### B. INTERSTITIAL MASS TRANSFER

AKA DISSIMILAR METAL MASS TRANSFER


AKA CARBON TRANSFER

- ESSENTIALLY INSIGNIFICANT BELOW 700°F
- PREDICTABLE ABOVE 700°F

### C. DISSOLUTION OF EXPOSED INCLUSIONS

- EASILY AVOIDED BY GRAIN FLOW CONTROL OR PURE METALS

# CORROSION OF 316 STAINLESS STEEL BY FLOWING SODIUM



## NOTES

- 1) FOR SODIUM VELOCITY >10 ft/s, LOWER CORROSION AT LOWER FLOW
- 2) OXYGEN ANALYZED BY VANADIUM WIRE; USUALLY 1/10 OF RESULTS BY OTHER METHODS
- 3) MULTIPLY BY 2 FOR HIGH  $dT/dt$  (i.e. CORE)


REFERENCE: NUCLEAR SYSTEMS MATERIALS HANDBOOK



Rockwell International  
Atomics International Division

76-S29-66-24






ALL COMMERCIAL ALLOYS  
USED IN HIGH-TEMPERATURE  
STRUCTURAL APPLICATIONS:

( IRON-CHROMIUM  
AND  
IRON-NICKEL-CHROMIUM)

ARE COMPATIBLE WITH SODIUM


## EFFECT OF TEMPERATURE ON SOLUBILITY



9-010-116-21



# SOLUBILITY - GRADIENT MASS TRANSFER

CASE "A" - TRANSFER OF ELEMENT - (e.g. Ni)



# SOLUBILITY - GRADIENT MASS TRANSFER


CASE "B" - TRANSFER OF COMPLEX - e.g.  $\text{Na}_2\text{O} \cdot \text{FeO}$



7-A15-184-10

*Fe, Cr go through  
complex formation  
Ni general solution*


# INITIAL CORROSION OF IRON-CHROME-NICKEL ALLOYS



9-010-116-16

*INFORMED DATA*


**EFFECT OF TIME  
ON SODIUM CORROSION  
OF IRON-CHROME-NICKEL ALLOYS**



TIME

9-010-116-18

# COMPOSITIONAL CHANGE IN SS ASSOCIATED WITH ELEMENTAL LEACHING IN Na




*ferite layer basis*

*Time = ?*

9-010-116-23





# ENVIRONMENTAL EFFECTS ON CLADDING CORROSION




8-024-155-7

# THE "HEAT FLUX EFFECT"



Fluid is becoming saturated as move down to lower temp.




Downstream Effect in ITF. 700°C


# ACTIVITY - GRADIENT MASS TRANSFER (e.g. CARBON TRANSPORT)

*INTERSTITIAL  
EFFECT*

*ENTROPY DRIVEN*




PHYSICAL REPRESENTATION



ACTIVITY PROFILE


# ACTIVITY OF CARBON FOR SEVERAL METAL CARBIDES




*Stainless will decarburize  
C-steel*

9-010-116-20

(2.4 MM)  
DECARBURIZATION OF 0.095-in. THICK 2¼Cr-1Mo STEEL  
BY SODIUM (ONE SIDE)





EFFECT OF DECARBURIZATION ON RUPTURE  
STRENGTH OF 2-1/4 Cr - 1 Mo STEEL STRUCTURES

STRENGTH DEGRADATION ALLOWANCES  
(2 1/4 Cr - 1 Mo)

GE. design  
Formula

Explains 9 hr  
reduction

- REDUCTION IN MAXIMUM ALLOWABLE STRESS INTENSITY ( $S_0$ )

EQUATION:

$$S_0^f = \frac{3.53 \times 10^5 \times t^{1/2} \times \exp\left(-\frac{13336}{T}\right)}{S_0 d}$$

$S_0^f$  : % REDUCTION OF  $S_0$  TO BE APPLIED

$S_0$  : ALLOWABLE STRESS INTENSITY, KSI (TABLE I-14.2; N-47)


$t$  : TIME OF EXPOSURE AT TEMPERATURE, HRS ( $2.5 \times 10^5$ )

$T$  : TEMPERATURE, °K

$d$  : THICKNESS OF FLAT MEMBER EXPOSED TO SODIUM, in.

T (°F)	$S_0$ (KSI)	$S_0^f$ inches		
		$d=0.1$	$d=0.25$	$d=0.5$
600	15.0	0.017	0.007	0.0034
700	15.0	0.120	0.048	0.024
800	15.0	0.557	0.223	0.111
900	13.1	2.886	1.554	0.577
950	11.0	6.418	2.567	1.284
1000	7.8	16.27	6.51	3.255
1100	4.2	86.57	34.63	17.32






Smiths

100  
1000

DECARBURIZATION OF 1020 STEEL  
Time (t), hour



← PRIMARY Na  
0.05 ppm C


SECONDARY Na →  
0.13 ppm C

FROM ANIL  
PRESENTATION  
@ SLL

# NUCLEAR SYSTEMS MATERIALS HANDBOOK

VOL 2 - SUPPORTING DOCUMENTATION

PART I - STRUCTURAL MATERIALS	GROUP 1 - HIGH ALLOY STEELS	SECTION 2 - 304 SS, SODIUM EXPOSED
REVISION: 0, 11-28-78		STRESS-RUPTURE STRENGTH, SODIUM EXPOSED




NOTE: The data are applicable for oxygen and carbon concentrations in sodium of ~1 and 0.3 to 0.6 wppm, respectively.

# NUCLEAR SYSTEMS MATERIALS HANDBOOK

VOL 1 - DESIGN DATA

PART I - STRUCTURAL MATERIALS	GROUP 1 - HIGH ALLOY STEELS	SECTION 2 - 304 SS, SODIUM EXPOSED
REVISION: 0, 11-28-78		CREEP EQUATION, SODIUM EXPOSED




NOTE: The data are applicable for carbon concentration in sodium in the range 0.3 to 0.6 wppm. *FAIRLY CARBURIZING.*

# NUCLEAR SYSTEMS MATERIALS HANDBOOK


VOL 2 - SUPPORTING DOCUMENTATION

PART I - STRUCTURAL MATERIALS	GROUP 1 - HIGH ALLOY STEELS	SECTION 2 - 304 SS, SODIUM EXPOSED
REVISION: 0, 11-28-78		TIME TO TERTIARY CREEP, SODIUM EXPOSED




NOTE: The data are applicable for oxygen and carbon concentrations in sodium of ~1 and 0.3 to 0.6 wppm, respectively.

# 12 PIN BIAxIAL CLADDING TEST RETORT FOR LMFBR




*Creep test data best ever  
 produced, no Na e-fuels  
 clean, highly instrumental*

# BIAXIAL STRESS-RUPTURE BEHAVIOR OF COLD WORKED TUBES OF 304 AND 316 SS IN STATIC SODIUM



*in 316,  
No prements  
break~~ing~~ observed  
in 304 curve.*


# CORRELATION OF STRESS STATE WITH RUPTURE LIFE USING VON MISES' YIELD THEORY-ANNEALED 304 STAINLESS STEEL





# UNIAXIAL CREEP OF ANNEALED TYPE 304 STAINLESS STEEL IN 1200°F SODIUM AND HELIUM ENVIRONMENTS—21,000 psi STRESS


3<sup>RD</sup> STAGE  
CREEP



9-AU12-091-15

CORROSION OF

NON METALLIC INCLUSIONS



STEEL CASTING

- CASTING IS CROPPED TO REMOVE "PIPE"
- CASTING IS HOT-WORKED  
CLOSES "VOIDS"
- INCLUSIONS WHICH HAVE HIGH MELTING POINTS
  - ALUMINIDES  
FRAGMENT & SEAL
- INCLUSIONS WITH LOW M.P. MAINTAIN AREA RELATIONSHIP -  
STAY AS STRINGERS

11

● STRINGERS RUN PARALLEL TO GRAIN FLOW

● NON-METALLIC STRINGERS ARE SUSCEPTIBLE TO Na CORROSION



## LIQUID METAL CONTAINERS

3. DESIGN CONSIDERATIONS (CONT)

3.2.5 All material selections for liquid metal containers shall be approved by the MLP Coordinator or assigned MLP Engineer.

3.2.6 Where grain direction is critical for designs utilizing bar, forgings, sheet or plate, it shall be indicated by a two-directional arrow and the word GRAIN on the field of the drawing.

3.2.6.1 Designs involving machining which leaves thin sections (1/8 inch or less) normal to the grain should be avoided. When this condition is unavoidable, adequate precautions should be taken to assure that the material does not contain laminations, stringers, or other flaws running parallel to the grain. Some appropriate precautions which may be specified include, but are not limited to:

- A) Surface etch followed by dye penetrant inspection.
- B) A thin specimen cut from surface and inspected for flaws.

3.2.6.2 In welded design the heat of welding may increase the size of internal flaws. For critical applications, forging or forming should be considered to avoid machining, as illustrated in Fig. 3.2.6.2.




Fig. 3.2.6.2

SELECTED MATERIALS BY COMPONENT

SOLAR CENTRAL RECEIVER  
HYBRID POWER SYSTEM

MATERIALS SELECTION



**Rockwell International**  
**Energy Systems Group**



## HYBRID POWER SYSTEM COMPONENTS

RECEIVER  
FOSSIL FIRED HEATER  
RISER  
DOWNCOMER  
STORAGE  
STEAM GENERATOR COMPLEX  
PUMPS  
VALVES  
TRANSITION POINTS  
HORIZONTAL PIPING



**Rockwell International**  
Energy Systems Group

RECEIVER

PANELS AND HIGH-TEMPERATURE HEADERS - 304 SS  
LOW-TEMPERATURE HEADERS AND VALVES - MILD STEEL -  
PANEL COATING PYROMARK



**Rockwell International**  
Energy Systems Group

## FOSSIL-FIRED HEATER MATERIALS

FURNACE MEMBRANE WALLS - 2 1/4 CR - 1 MO  
HIGH-TEMPERATURE CONVECTION - 304 SS  
LOW-TEMPERATURE CONVECTION - MILD STEEL




Fig. 19 Typical section through furnace wall (membrane design).

RISER AND DOWNCOMER MATERIALS

RISER - MILD STEEL  
DOWNCOMER - 304 SS



**Rockwell International**  
Energy Systems Group

JCS:65

STORAGE SUBSYSTEM MATERIALS

COLD TANK - MILD STEEL  
HOT TANK - 304 SS



**Rockwell International**  
Energy Systems Group

JCS:65

STEAM GENERATOR COMPLEX MATERIALS

EVAPORATOR AND SEPARATOR - 2 1/4 Cr - 1 Mo  
SUPERHEATER AND REHEATER - 304 SS



**Rockwell International**  
Energy Systems Group

PUMP MATERIALS

CASE AND IMPELLER - 316 SS  
BEARINGS - STELLITE 6,6B

*Common practice do to practice  
FFTF PUMPS FOR 10SD OF SERVICE  
USE THIS CONSTRUCTION*



Rockwell International  
Energy Systems Group

VALVE MATERIALS

BODY - LOW TEMPERATURE; MILD STEEL  
HIGH TEMPERATURE; 304 SS  
HARD FACING - STELLITE



Rockwell International  
Energy Systems Group



TRANSITION MATERIALS

INCO 82 WELD MATERIAL



**Rockwell International**  
Energy Systems Group

JCS:65

HORIZONTAL PIPING

HIGH TEMPERATURE - 304 SS  
LOW TEMPERATURE - MILD STEEL



Rockwell International  
Energy Systems Group

BASIS OF MATERIAL SELECTION

MATERIAL SELECTION

FOR

COAL-FIRED SODIUM HEATER

MATERIAL SELECTION

LOW-TEMP. CONVECTION SURFACE - CARBON STEEL

FURNACE TUBES - 2-1/4 CR - 1 Mo

HIGH-TEMP. CONVECTION SURFACE - TP304 SS\*

\*ACCEPTABLE ALTERNATE - 9CR - 1 Mo


## MATERIAL SELECTION - CONSIDERATIONS

- GAS-SIDE CORROSION
- SODIUM-SIDE DECARBURIZATION
- MECHANICAL STRENGTH — SIZED ON STRUCTURAL SUPPORT BASIS
- FABRICABILITY
- ECONOMICS


# FLUE GAS TEMPERATURES

HIGH-TEMP.  
CONVECTION

LOW-TEMP. CONVECTION



GAS-SIDE CORROSION



*SAFE DESIGN CURVE*

*BASIS  
FIELD OPERATION  
DATA USING  
HIGH FOULING  
FUEL*



SODIUM TEMPERATURE

	100%	20% HEATER LOAD
L.T. CONV. SURFACE	550-678°F	550-685°F
FURNACE	678-963	685-1050*
H.T. CONV. SURFACE	963-1100	1050-1100

*1000°F* ↗

\*BASED ON NO FLUE GAS RECIRCULATION

- ① TOP BURNERS
- ② FLUE GAS RECIRCULATION

CONCERN:  $2\frac{1}{2}$  Cr - 1 Mo

AT LOW LOADS, MORE OF THE TOTAL ABSORPTION OCCURS IN THE FURNACE  
RESULTING IN HIGHER TUBE METAL TEMPERATURES

ACTION:

CONTROL TEMPERATURE AT LOW LOAD BY:


- FLUE GAS RECIRCULATION
- HIGHER EXCESS AIR TO BURNERS (STILL BEING EVALUATED)
- FIRING ONLY THE TOP ROW OF BURNERS

TO REDUCE GAS TEMPERATURE IN BURNER ZONE AND EFFECTIVELY REDUCE SIZE OF FURNACE

DECARBURIZATION IN SODIUM

2-1/4 CR - 1 Mo FURNACE TUBE

30 YEARS



MEMBRANE PANEL FABRICATION

B&W HAS MANUFACTURED MEMBRANE PANELS OF 2-1/4 CR - 1 Mo ALLOY

- DEVELOPMENT PROGRAM ~ 1974
- USED IN COAL GASIFICATION UNIT

TRANSITION MATERIALS

- 2-1/4 CR - 1 Mo/TP304 SS - INCONEL 600
- 2-1/4 CR - 1 Mo/CARBON STEEL - NONE REQ'D

SECTION V-B

BALANCE OF PLANT

BALANCE-OF-PLANT MATERIALS  
SELECTION SUMMARY

A. HIGH TEMPERATURE REGION (~1100°F)

<u>COMPONENT</u>	<u>MATERIAL</u>	<u>DISCUSSION</u>	<u>BACK-UP</u>
RECEIVER DOWNCOMER HOT STORAGE TANK HOT VALVE BODIES	304 SS	ADEQUATE STRENGTH BEST WELDABILITY <i>WASH</i> MUCH RESEARCH MUCH EXPERIENCE LOWEST 3XXSS COST <i>1592</i>	<i>avoid metallic analysis</i> 316 SS (LOCAL, HIGHER STRENGTH) INCONEL 718 (LOCAL, MUCH HIGHER STRENGTH)
SUPERHEATER REHEATER	304 SS	ALSO: NO DECARB BUT: KEEP DRY	ALLOY 800 9 Cr - 1 Mo <i>Super.</i>
PUMP IMPELLER PUMP CASE	CF8M (CAST 316 SS) 316 SS	CURRENT PRACTICE	NONE NEEDED
VALVE HARDFACING PUMP BEARING	STELLITE	ADEQUATE MUCH EXPERIENCE	NONE NEEDED

BALANCE-OF-PLANT MATERIALS  
SELECTION SUMMARY

B. INTERMEDIATE TEMPERATURE REGION (700 - 1000<sup>o</sup>F)

<u>COMPONENT</u>	<u>MATERIAL</u>	<u>DISCUSSION</u>	<u>BACK-UP</u>
EVAPORATOR SEPARATOR	2-1/4 Cr-1 Mo	No CL-SCC MUCH EXPERIENCE STRENGTH OK DECARB OK COST OK	NONE NEEDED

C. LOW TEMPERATURE REGION (< 700<sup>o</sup>F)

RECEIVER HEADERS		MUCH EXPERIENCE	NONE NEEDED
RISER	CARBON STEEL	STRENGTH OK	
COLD STORAGE TANK		DECARB OK	
VALVE BODIES		LOW COST	
PUMP IMPELLER	CF8M (CAST 316 SS)	CURRENT	NONE NEEDED
PUMP CASE	316 SS	PRACTICE	
VALVE HARDFACING	STELLITE	MUCH EXPERIENCE	NONE NEEDED
PUMP BEARING			



BALANCE-OF-PLANT MATERIALS  
SELECTION SUMMARY

D. TRANSITION JOINTS

<u>COMPONENT</u>	<u>MATERIAL</u>	<u>DISCUSSION</u>	<u>BACK-UP</u>
INTERMEDIATE TEMP. ( $< 1000^{\circ}\text{F}$ )	INCO 82	INTENSIVE LMFBR R&D	16-8-2/ I-800/ INCO 82
LOW TEMP.	INCO 82	EXPERIENCE	NONE NEEDED

# STRENGTH DEGRADATION ALLOWANCES (3/4 Cr - 1 Mo)

- REDUCTION IN MAXIMUM ALLOWABLE STRESS INTENSITY ( $S_o$ )

EQUATION:

$$S_o^f = \frac{3.53 \times 10^5 \times t^{1/2} \times \exp\left(-\frac{13336}{T}\right)}{S_o d} \quad 2124$$

$S_o^f$  : % REDUCTION OF  $S_o$  TO BE APPLIED


$S_o$  : ALLOWABLE STRESS INTENSITY, KSI (TABLE I-14.2; N-47)

$t$  : TIME OF EXPOSURE AT TEMPERATURE, HRS ( $2.5 \times 10^5$ )  $t^{1/2} \leq 500$

$T$  : TEMPERATURE, °K

$d$  : THICKNESS OF FLAT MEMBER EXPOSED TO SODIUM, IN

T (°F)	$S_o$ (KSI)	$S_o^f$		
		d=0.1	d=0.25	d=0.5
600	15.0	0.017	0.007	0.0034
700	15.0	0.120	0.048	0.024
800	15.0	0.557	0.223	0.111
900	13.1	2.886	1.554	0.577
950	11.0	6.418	2.567	1.284
1000 <small>811K</small>	7.8	16.27	6.51	3.255
1050 <small>838K</small>	5.8	37.3	14.9	7.46
1100	4.2	86.57	34.63	17.32



EFFECT OF DECARBURIZATION ON RUPTURE STRENGTH OF 2-1/4 Cr - 1 Mo STEEL STRUCTURES

STRESS CORROSION CRACKING  
IN 304 SS PWR STEAM GENERATORS

<u>REACTOR</u>	<u>EQUIVALENT FULL-POWER DAYS</u>	<u>CUMULATIVE DEFECTS</u>
DRESDEN-1	2963	161
INDIAN PT-1	1750	265
KRB	2651	364
KWL LINGEN	1739	112
MZFR	2134	<del>0</del>
N-REACTOR		27
SENA (CHOOZ)	1956	20
TARAPUR-1	1317	2
TARAPUR-2	1304	143
TRINO	2428	<del>0</del>
YANKEE ROWE	4144	65

THRU DEC 31, 1976

*Chalk Review Review*

EXPERIENCE WITH TUBE MATERIALS  
TO DECEMBER 31, 1976


TUBE MATERIAL	NUMBER OF REACTORS	NUMBER OF TUBES	NUMBER OF TUBE FAILURES	TUBE FAILURE RATE	FAILURE MECHANISM
TYPE 304 SS	11	58 547	1159	2.0%	A,B
INCONEL-600	42	526 886	11 867	2.0%	A,B,C,D,E
MONEL-400	8	167 700	232	0.14%	A,D
INCOLOY-800		36 558	0	0	--

Water (Shell) side }  
 A SCC  
 B Phosphate Wasteage  
 C Denting  
 D Fretting  
 E Fatigue

No evidence of corrosion on Na side

DESIGN FEATURES TO ACCOMMODATE THE MATERIAL


# BELLOWS SEAL VALVES



2000 ~ Full open-close  
or 10000 ~ 15-90°  
oper.

66-3623-107-2

**8-INCH  
SECONDARY  
ISOLATION VALVE**




78-AU22-83-9

T.S.




# FREEZE SEAL TEMPERATURE PROFILE



L.T

**18-INCH  
BUTTERFLY VALVE**




*Control on rec'r  
thermal stripping  
is prevented  
by proper valve  
spacing*

78-AU22-83-8




T.J.

# HMPF TYPE PUMP




Bearings:  
Hard faced +  
pump will have  
pressurized at  
start up due to  
No head in tower.  
Hydrostatic bearing  
will be functioning

# HNPF PUMP BEARING





# CORROSION OF 316 STAINLESS STEEL BY FLOWING SODIUM




- NOTES:
- 1) FOR SODIUM VELOCITY > 10 FT/LOWER CORROSION AT LOWER FLOW
  - 2) OXYGEN ANALYZED BY VANADIUM WIRE USUALLY 1/10 OF RESULTS BY OTHER METHODS
  - 3) MULTIPLY BY 2 FOR HIGH FLUX (10<sup>6</sup> BTU/HR HEAT FLUX)
- REFERENCE: NUCLEAR SYSTEMS MATERIALS HANDBOOK

15

7057-201E-304


# SATURATION CONCENTRATION FOR OXYGEN IN NaK AND SODIUM





Alter  
30gpm  
Plant  
12,000  
gpm  
14 days  
to clean  
up

# SODIUM COLD TRAP



7-25-58 206-100

CONCLUSION:

THE MATERIAL ENGINEERING FOR HIGH TEMPERATURE  
SODIUM SYSTEMS HAS BEEN COMPLETED AND FIELD  
TESTED.



**Rockwell International**  
Energy Systems Group



REACTOR AND TEST LOOP EXPERIENCE

SODIUM HEATER EXPERIENCE

## SODIUM HEATER EXPERIENCE

- SODIUM COMPONENT TEST INSTALLATION
  1. TWO HEATERS
  2. 35 MWT EACH
  
- H-1
  1. BUILT 1954
  2. 50,000 HOURS AT 700<sup>0</sup>F OR GREATER
  
- H-2
  1. BUILT 1975
  2. INSTALLED AND OPERATING



Rockwell International  
Energy Systems Group

# SCTI H-1 HEATER SPECIFICATION

## GOVERNING SPECIFICATIONS

Knolls Atomic Power Laboratory Specification No. CTU-1 Revision 2, dated October 29, 1953.

## DESIGN CONDITIONS

		Operating Load		
		5%	100%	125%
Heat output	Btu/hr	5,000,000	100,000,000	125,000,000
Sodium outlet temperature	°F	740	850	1,200
Sodium inlet temperature	°F	470	580	870
Sodium Pressure Drop				
Tubes	psi	--	6.3	6.8
Inlet to outlet	psi	--	8.0	8.7
Fuel rate	gpm	.75	17.4	23.9
Excess Air leaving heater	%	25	25	25
Air Inlet Temperature	°F	80	80	80
Gas temperature leaving heater	°F	510	1,000	1,250
Wet gas flow	lb/hr	6,240	146,500	201,000
Air flow to burners	lb/hr	5,900	138,500	190,000
Furnace liberation	B/hr ft <sup>3</sup>	2,620	61,400	84,100
Dry gas loss	%	9.7	20.7	26.3
Water from AF fuel loss	%	6.3	7.5	8.1
Moisture in Air loss	%	0.2	0.5	0.7
Unburned combustion loss	%	0.0	0.0	0.0
Radiation loss	%	2.3	1.6	1.2
Unaccounted for loss	%	1.5	1.5	1.5
Total losses	%	20.0	31.8	37.8
Efficiency	%	80.0	68.2	62.2



Rockwell International  
Energy Systems Group


## SCTI H-1 HEATER

### GENERAL HEATER DATA

Weight of Heater	295,000 lbs
Volume	2,200 cu ft
Volume of Sodium (in heater)	168 cu ft
Convection Volume	1,890 cu ft
Tubes	1 $\frac{1}{4}$ OD x 0.095 thick minimum wall
Heating Surface	7,344 sq ft
Header Design Pressure	200 psi
Casing Design Pressure	18 in H <sub>2</sub> O




Rockwell International  
Energy Systems Group




SCTI H-1 SODIUM HEATER






Rockwell International  
Energy Systems Group








Rockwell International  
Energy Systems Group


2-1-61


00-57796




© 2005 78 3

Redwell International  
Engineering Systems Group




 Rockwell International  
Energy Systems Group






25276



7593-5439-B

Rockwell International  
Energy Systems Group

5-23-62




6424

nahont

4-3-62






7593 - 5949

 Rockwell International  
Energy Systems Group


6-8-66

## SATURATION CONCENTRATION FOR OXYGEN IN NaK AND SODIUM





Rockwell International  
Quality Systems Group




 Rockwell International  
Energy Systems Group

7593-5751





 Rockwell International  
Energy Systems Group






Rockwell International  
Energy Systems Group






SCTI  
H-2 SODIUM HEATER




Rockwell International  
Energy Systems Group











LMEC-P31733

P-75



91-621



# WORLD LIQUID-METAL-COOLED REACTOR FACILITIES

REACTOR	STARTUP DATE	YEAR															
		52	54	56	58	60	62	64	66	68	70	72	74	76	78	80	
<i>RET. USA.</i> EBR-I	8/24/51	x															
<i>A. I.</i> SRE	4/25/57			x													
BR-5,-10	1/ /59				x												
DFR	11/14/59				x												
LAMPRE	2/17/61					x											
HALLAM	8/25/62						x										
FERMI	8/23/63							x									
EBR-II	11/11/63								x								
RAPSODIE	1/28/67									x							
SEFOR	5/3/69										x						
BOR-60	12/14/69											x					
KNK	8/20/71												x				
BN-350	11/29/72													x			
PHENIX	8/31/73														x		
PFR	3/3/74															x	
JOYO	4/24/77																x

LIQUID METAL FAST BREEDER REACTOR PROJECTS THROUGHOUT THE WORLD


Name	Country	Type	Power		Initial Operation
			(MWt)	(MWe)	
<b>Operable</b>					
BR-10*	USSR	Loop	10	--	1973
DFR+	United Kingdom	Loop	60	14	1959
EBR-II	United States	Pool	62	20	1963
Rapsodie	France	Loop	40	--	1967
BOR-60	USSR	Loop	60	12	1969
BN-350	USSR	Loop	1000	350 (equiv)	1972
Phenix	France	Pool	567	250	1973
PFR	United Kingdom	Pool	600	250	1975
Joyo	Japan	Loop	100	--	1977
KNK-2	Germany (FRG)	Loop	58	20	1977#
<b>In Procurement/Construction</b>					
BN-600	USSR	Pool	1470	600	1980
FFTF	United States	Loop	400	--	1979
PEC	Italy	Loop	135	--	1981
Madras FBTR	India	Loop	42	17	1981
SNR-300	Germany (FRG)	Loop	762	327	1983
Super Phenix - 1	France <i>STARF Const. 74</i>	Pool	3000	1200	1983
CRBRP	United States	Loop	975	350	1986
<b>In Planning/Design</b>					
Monju	Japan	Loop	714	300	1986
CDFR-1	United Kingdom	Pool	3250	1300	1990
SNR-2	Germany (FRG)	Loop	3250	1300	1990
BN-1600	USSR	Pool	4000	1600	1990
Super Phenix - 2 and 3	France	Pool	2 X 3500	2 X 1500	1989-90
DFBR	Japan	--	2800	1000	1993
CDS	United States		2600	1000	1991

\*Following conversion from BR-5, which operated from 1959 to 1971.

+Decommissioned March 1977.

#Following conversion from the thermal neutron KNK-1, which operated from 1979 to 1974.






00-161

7-23-62




9-51-80

1218-2010







Lowell International  
Atomics International Division




Fig. 14. Construction schedule for the Creys-Malville power station



## LIST OF NATIONS WITH SODIUM HEAT TRANSFER LOOPS

USA

FRANCE

FEDERAL REPUBLIC OF GERMANY

JAPAN

USSR

NETHERLANDS

UNITED KINGDOM

ITALY

BELGIUM

CZECHOSLOVAKIA

SPAIN

INDIA

AUSTRIA

LUXEMBOURG

SOUTH AFRICA

DEMOCRATIC REPUBLIC OF GERMANY

EGYPT

PEOPLES REPUBLIC OF CHINA



COMMUNICATIONS SECTION


UNIVERSITY OF MICHIGAN LIBRARY

LMEC-P31230

Atomics International Division  
Rockwell International


1-30-74

(5,285,000)





## Some Highlights from Liquid Metal Nuclear Pump Manufacturing History



- 1950 Submarine "Seawolf" Prototype Pump
- 1956 "SRE" Primary and Secondary Pumps
- 1957 Enrico Fermi Test Pump
- 1958 "CANEL" Project Test Loop Pumps
- 1960 Enrico Fermi Primary and Secondary Pumps
- 1961 "SCTI" Primary Loop Pump
- 1962 Hallam Prototype, Primary and Secondary Pumps
- 1963 "EBR II" Primary Pumps
- 1964 "SRE" Power Expansion Primary, Secondary and Auxiliary Pumps
- 1964 Argonne National Laboratory Liquid Sodium Pump
- 1967 "SNR" Prototype Pump
- 1971 "PNC" Primary and Secondary Pumps
- 1975 "CRBRP" Prototype, Primary and Intermediate Pumps
- 1977 "L-S LMFBR" Preliminary Designs, Prototype Primary and Intermediate Pumps

# US "MILESTONE" LIQUID-SODIUM PRIMARY PUMPS

Designation	Manufacturer	Reactor Type	Capacity in GPM	Total Head in Feet	Temperature in F	RPM	HP	Operating * Hours	Pump type - number of stages and impeller type
SRE	BJ	LOOP	1200	80	1200	1160	30	21,400	Single stage, single suction
Fermi	BJ	LOOP	11,000	310	1000	900	1000	45,000	Single stage, single suction
Hallam	BJ	LOOP	7200	160	1000	870	350	20,000	Single stage, single suction
EBR II	BJ	POOL	5500	200	800	1075	300	72,000	Single stage, single suction
SCTI	BJ	LOOP	4000	160	1200	1750	200	45,000	Single stage, single suction
SNR 2 (W.Germany)	BJ	LOOP	7900	410	1022	1500	880	29,850	Single stage, single suction
PNC (Japan)	BJ	LOOP	4870	257	986	1425	500	12,000	Single stage, single suction
FFTF	West	LOOP	14,500	500	1050	1030	2200	3,000	Single stage, single suction
CRBR (proto)	BJ	LOOP	33,700	450	995	1116	5000	-----	Single stage, double suction

\*Per Pump

FIG 8a

# REPRESENTATIVE FOREIGN LIQUID-SODIUM PRIMARY PUMPS

Designation	Country	Reactor Type	Capacity in GPM	Total Head in Feet	Temperature in F	RPM	HP	Pump type - number of stages and impeller type
Rapsodie	France	LOOP	1670	105	1000	1100	72	Single stage, single suction
Phenix	France	POOL	18,700	250	1000	1000	1600	Single stage, single suction
Super Phenix	France	POOL	76,000	230	752	500	6000	Single stage, single suction
BN-350	USSR	LOOP	14,080	360	900	970	1400	Single stage, double suction
BN-600	USSR	POOL	42,800	312	770	970	4000	Single stage, double suction
SNR-300	W Ger	LOOP	22,000	279	1075	960	1600	Single stage, single suction
Joyo	Japan	LOOP	5,560	230	842	930	440	Single stage, single suction
Monju 300	Japan	LOOP	23,300	295	770	850	2400	Single stage, single suction
PFR	UK	POOL	20,900	317	932	960	1550	Single stage, double suction
CFR	UK	POOL	46,300	365	662	480	5500	Two stage, single suction

# HALLAM




FIG 3

# EBR II




FIG 5

# FERMI

MOTOR

MECHANICAL  
SHAFT SEAL

BIOLOGICAL AND  
RADIATION SHIELD

HYDROSTATIC  
BEARING

HYDROSTATIC  
BEARING

IMPELLER

DISCHARGE  
COLLECTOR

SUCTION  
NOZZLE

CHECK  
VALVE

STATIC  
SEAL

DISCHARGE  
NOZZLE




FIG 4

# FFTF





FIG 11



ETEC-P36189CN

Rockwell International  
Energy Systems Group

4-12-79



## SODIUM POWER STATISTICAL RECAP

141 REACTOR-YEARS OF SODIUM-COOLED REACTORS

1.8 MILLION MEGAWATT-DAYS OF NUCLEAR HEAT TRANSFERRED BY SODIUM

27-1/2 YEARS SINCE EBR-I FIRST PRODUCED ELECTRICITY (DECEMBER 1951)

21 YEARS OF EXPERIENCE ON SOVIET BR-5/10

16 CONTINUOUS YEARS OF SODIUM MECHANICAL PUMP SERVICE (EBR-II)

1200 MWe FRENCH SUPERPHENIX 1 NOW UNDER CONSTRUCTION

1600 MWe SOVIET BN-1600 NOW IN ADVANCED DESIGN

WBW JUNE 1979

14-22




Figure 4. Comparison of TRANSWRAP II Predicted Reaction Zone Bubble Pressure with Measurements from Transducer P612 in SWR-1



14-24




Figure 6. Comparison of TRANSWRAP II Predicted Reaction Zone Bubble Pressure with Measurements from Transducer P601 in SWR-3

14-25




Figure 7. Comparison of TRANSWRAP II Predicted Pressure at the Hockey Stick Elbow with Measurements from Transducer P603 in SWR-2

TABLE 1


LARGE LEAK SERIES I TEST RESULT SUMMARY

	TEST #1	TEST #2	TEST #3	TEST #4	TEST #5	TEST #6**
Injection Rate (Steady State)	2.4 lbs/sec (1.1 kg/sec)	2.5 lbs/sec (1.1 kg/sec)	8 lbs/sec (3.6 kg/sec)	4.2 lbs/sec (1.9 kg/sec)	4 lbs/sec* (1.8 kg/sec)	10 lbs/sec (4.5 kg/sec)
Peak Pressures Measured in Test Article at Different Locations	350-500 psia (2.4-3.5 MPa)	400-500 psia (2.8-3.5 MPa)	300-350 psia (2.1-2.4 MPa)	330-450 psia (2.3-3.1 MPa)	240-400 psia (1.6-2.8 MPa)	530-675 psia (3.7-4.7 MPa)
Maximum Temperatures Measured in Test Article	~1500°F (815°C)	~1700°F (927°C)	~1700°F (927°C)	~1500°F (815°C)	800°F (Na Temp) (427°C)	~1700°F (927°C)
Measured Wastage of Surrounding Tubes (By UT)	4-16 mils (.1-.4 mm)	4 mils max. (.1 mm)	4 mils max. (.1 mm)	no change	no change	no change
He Leak Indication After Test	7 Tubes @ 10 <sup>-4</sup> to 10 <sup>-7</sup> cc/sec	None	None	None	None	None
Deformation of Tubes by X-Ray	None	Bowing of Secondary Tubes Near Leak Site	None	None	None	None
Extent of Reaction Product Residual	Slight	Heavier Below Lower Window	Additional Buildup Below Lower Window + Above Lower Window	Slight Deposit on Tubes at Upper Window. No Significant Additional Buildup Below Lower Window.	no change	Slight Additional Deposit on Tubes at Upper Window. No Significant Additional Buildup Below Lower Window.
Agreement with TRANSWRAP Predictions	Good	Good	Code Over- Predicted	Code Over- Predicted	Code Over- Predicted	Code Over- Predicted



\*Nitrogen used in place of H<sub>2</sub>O for Test #5.

\*\*3-DEG Rupture Tube

# ISOTOPE SCANNING TEST (IST)







# SWR-IF DDAS PLOT 7-24-76







# SODIUM PRESSURE DUE TO SWR-1F




# LLTR SWR-IF 7-24-76






LARGE LEAK TEST RIG (LLTR) SERIES 1 TEST

# LARGE LEAK INJECTION DEVICE (LLID)



# LARGE LEAK TEST RIG (LLTR) SERIES II



# LLTR SERIES II TEST CONDITIONS


lower shroud.  
3) H<sub>2</sub>O inlet temp.

## GROUP A TESTS


TEST NO.	LEAK SIZE	RADIAL POSITION	H <sub>2</sub> O PRESS. PSIA	LEAK ORIENTATION	REMARKS
A-1a	1-DEG	CENTER	NITROGEN 2000	DNA	NON-REACTIVE TEST - DOUBLE MEMBRANE.
A-1b	1-DEG	CENTER	NITROGEN 2000	DNA	NON-REACTIVE TEST - SINGLE MEMBRANE.
A-2	1-DEG	CENTER	1700	DNA	LARGEST PRIMARY LEAK
A-3	TUBE WASTAGE LK. (0.1#/SEC)	CENTER	1700	BETWEEN ADJACENT TUBES	LEAK PROGRESSION FROM UNCONTROLLED NATURAL LEAK
A-4	TRANSITION SIZE LK. (0.8#/SEC)	CENTER	1700	BETWEEN ADJACENT TUBES	MAX. TUBE EXPOSURE TO REACTION PRODUCTS
A-5	MAX. W/O BURST DISC (2.0#/SEC)	CENTER	1700	BETWEEN ADJACENT TUBES	MAX. REACTION W/O RELIEF
A-6	1-DEG	BUNDLE EDGE	1700	TBD	CENTER VS. EDGE STRUCTURAL INTEGRITY CHECK.



# SWR-6 UT DATA = AVERAGED




# SODIUM COMPONENTS TEST INSTALLATION (SCTI) STEAM & FEEDWATER SYSTEM SCHEMATIC



79-A3-33-7



# SODIUM COMPONENTS TEST INSTALLATION



IMPACT OF SERI CONFERENCE

SECTION IX

IMPACT OF SERI  
CONFERENCE

SERI MATERIALS WORKSHOP - DECEMBER 1978

*Pohlman  
Royer Staely. OS4  
Corrosion report.*

CHRONOLOGY:

1ST AM INTRODUCTION, OBJECTIVE:  
"TO PROVIDE BALANCE TO DESIGN MOMENTUM"

1ST PM, TASK GROUPS MEET  
2ND DAY HEAR SCOPING PAPERS  
LIST ISSUES  
VOTE, PRIORITIZE  
WRITE-UP WINNERS

3RD AM RECONVENE MAIN GROUP  
REVIEW TASK GROUP REPORTS  
VOTE ON URGENCY OF WORK

LATER SERI SENDS OUT DRAFT REPORT FOR REVIEW AND COMMENT

SERI MATERIALS WORKSHOP - DECEMBER 1978

COMMENTS:

PARTICIPANTS WERE RESEARCH-ORIENTED, REPRESENTING GRANT - OR  
CONTRACT-FUNDED INSTITUTIONS

SOME ISSUES WERE PRESENTED MORE EFFECTIVELY THAN OTHERS

SOME PARTICIPANT'S OBJECTIVITY MAY HAVE BEEN CLOUDED BY:

LMFBR TECHNICAL BACKGROUND

LMFBR BUDGETARY PROGNOSIS

SALT VS. SODIUM

AFTER ALL, IT WAS DONE BY A COMMITTEE, IN A HURRY

SERI MATERIALS WORKSHOP - DECEMBER 1978

PRINCIPAL ISSUES  
IN ORDER OF PRIORITY

ESG COMMENT

1. CREEP/FATIGUE BEHAVIOR  
IN SODIUM AND SALT UNDER  
RECEIVER PROTOTYPICAL  
CONDITIONS

1. WE AGREE THAT MORE WORK IS  
NEEDED TO REDUCE THE CONSERVA-  
TISM IN HI-TEMP CODE CASE.

*95%  
OF WORK  
APPLICABLE TO  
Na can be done  
in air, performance  
better in Na* } MOST EXPERIMENTAL WORK TO  
SUPPORT SODIUM CAN BE DONE  
IN INERT ATMOSPHERE.

NO COMMENT ON WORK TO SUPPORT  
SALT TECHNOLOGY.

CREEP/FATIGUE PROBLEMS ARE  
COMMON TO ALL HIGH TEMPERATURE  
SOLAR SYSTEMS.

2. PHYSICOCHEMICAL DATA  
(427 - 593°C) ON ALKALI  
NITRATE SALT MIXTURES

2. WE AGREE THAT CURRENT DATA BASE  
IS INADEQUATE FOR CONFIDENT LONG-  
TERM SYSTEM DESIGN

SERI MATERIALS WORKSHOP - DECEMBER 1978 CONTD

<u>ISSUES</u>	<u>ESG COMMENT</u>
3. SODIUM CORROSION STUDIES AT OXYGEN CONCENTRATIONS GREATER THAN 1 PPM COUPLED WITH MASS TRANSPORT STUDIES	3. WE DO NOT AGREE: MAINTENANCE OF A CLEAN SYSTEM IS INEXPENSIVE
4. DEVELOP HIGH STRENGTH FERRITIC ALLOY	4. WE AGREE THAT SUCH AN (9 Cr - 1 Mo) WOULD BE USEFUL, ESPECIALLY IN STEAM GENERATOR.
5. THERMAL STRIPING AND THERMAL FATIGUE DAMAGE <u>TEMP CYCLING CAN BE AVOIDED THRU DESIGN</u>	5. WE DO NOT AGREE THAT THIS IS AS MUCH OF A CONCERN IN SOLAR AS IN LMFBR (UPPER INTERNALS) APPLICATIONS. WE DO AGREE THAT T MIXING DESERVES COMPETANT DESIGN/ ANALYSIS.
6. FORCED CONVECTION LOOP STUDIES OF MOLTEN NITRATE (DRAIN) SALT	6. WE AGREE

*ESG says  
low  
priority*

*ESG could test*

*ORNL  
CF.*

SERI MATERIALS WORKSHOP - DECEMBER 1978 CONTD

ISSUES

ESG COMMENT

7. DEVELOP AND/OR QUALIFY COOLANT CONTAINMENT ALLOYS FOR RECEIVER OPERATION TO 704°C (1300°F) FOR SECOND GENERATION PLANT DESIGNS

7. WE DO NOT AGREE THAT THERE IS ANY INCENTIVE IN EXCEEDING STEAM SYSTEM CONDITIONS DESIRED BY UTILITIES.

8. CAUSTIC CRACKING OF STEAM GENERATOR TUBES

8. WE DO NOT AGREE THAT CAUSTIC INTRUSION TO THE WATER/STEAM SYSTEM IS PROBABLE; WE DO AGREE THAT THE UNITS OF CAUSTIC SCC COULD BE MORE PRECISELY DEFINED

9. STRESS CORROSION CRACKING BY MOLTEN SALT

9. WE AGREE



CRITIQUE OF SODIUM  
SECTION OF ASSESSMENT  
REPORT

OVERALL

DOES NOT PROVIDE A BALANCED REPORT OF STATE-OF-THE-ART OF  
SODIUM TECHNOLOGY;

TOO MUCH ATTENTION TO RESEARCH (TREES) VIS A VIS COMPONENTS  
AND SYSTEMS (FOREST)

SELECTED CRITICISMS

NO COMMENT ON YEARS AND DOLLARS INVESTED IN SODIUM TECHNOLOGY.

"CORROSION" EFFECTS OVEREMPHASIZED. *2/3 of report, too negative*  
VALVE SECTION MUCH TOO NEGATIVE. *-uninformed - no hard facing etc.*

COAL PLANT STACK GAS CLEANUP

Bull Wall

FLUE GAS CLEANING SYSTEM

- TWO-STAGE DRY SCRUBBING SYSTEM
  
- SO<sub>2</sub> AND FLY ASH CONTROL
  - SPRAY DRYER SCRUBBER
  - FABRIC FILTER

**THIS NEW CONCEPT IS OFFERED BY**



**Wheelabrator-Frye Inc.**



**Rockwell International**


**A JOINT VENTURE**

**WHICH PROVIDES THE FOLLOWING ADVANTAGES —**

- **FULL CAPABILITIES AND SUPPORT OF TWO LARGE CORPORATIONS**
- **INTEGRATED SYSTEM APPROACH FOR ENTIRE AIR POLLUTION CONTROL SYSTEM**
- **SINGLE CONTRACTING ENTITY AND POINT OF CONTACT**
- **PERFORMANCE WARRANTEE PACKAGE FOR ENTIRE SYSTEM**

# SPRAY DRYER

- FINE ATOMIZATION PROVIDES GOOD GAS-LIQUID CONTACT
- EFFICIENT SO<sub>2</sub> REMOVAL WITH LOW LIQUID FLOW RATES
- HEAT FROM FLUE GAS DRIES LIQUID BEFORE CONTACTING CHAMBER WALLS
- OUTLET GAS TEMPERATURE ABOVE DEW POINT; NO REHEAT REQUIRED



# SCRUBBER CHEMISTRY AND TECHNOLOGY

- $\text{Ca(OH)}_2 + \text{SO}_2 \rightarrow \text{CaSO}_3 + \text{H}_2\text{O}$
- $\text{CaSO}_3 + 1/2 \text{O}_2 \rightarrow \text{CaSO}_4$
- SPRAY DRYER ATOMIZER PRODUCES FINE DROPS OF LIME SLURRY
- DROPS ARE DRIVEN THROUGH FLUE GAS STREAM
- $\text{SO}_2$  IS ABSORBED AND REACTS WITH LIME IN DROPS
- WATER EVAPORATES LEAVING DRY PARTICLES
- EXCELLENT GAS – LIQUID CONTACT GIVES HIGH  $\text{SO}_2$  REMOVAL
- FLUE GAS NOT SATURATED WITH WATER VAPOR



# SPRAY DRYER EXPERIENCE

- GENERAL

- MORE THAN 1200 UNITS CURRENTLY IN SERVICE WORLDWIDE
- MATURE TECHNOLOGY (~50 YEARS)

- SO<sub>2</sub> REMOVAL


- MORE THAN 600 TESTS OF SO<sub>2</sub> REMOVAL IN PILOT SPRAY DRYERS OVER 7-YEAR PERIOD
  - ▲ POWER PLANT BOILER FIRED WITH BLACK MESA COAL (MOHAVE)
  - ▲ IN-LINE GAS/OIL BURNER FOR HOT GAS GENERATION (BOWEN)
  - ▲ CYCLONE, BOILER FIRED WITH LIGNITE (LELAND OLDS)
  - ▲ CYCLONE ELECTROSTATIC PRECIPITATOR, AND FABRIC FILTERS USED FOR PRODUCT COLLECTION
  - ▲ SO<sub>2</sub> CONCENTRATIONS FROM 200 TO 8000 ppm
  - ▲ INLET GAS TEMPERATURES FROM 250° TO 500°F
  - ▲ DRYER GAS FLOWS FROM 800 TO 4000 acfm
  - ▲ SODA ASH, TRONA, SODIUM BICARBONATE, HYDRATED LIME, QUICKLINE, LIMESTONE, POTASH, FLY ASH, AND VARIOUS COMBINATIONS OF THESE USED AS SO<sub>2</sub> ABSORBENTS

## **FABRIC FILTER**


- **HIGH COLLECTION EFFICIENCY**
- **PROVEN APPLICATION IN MANY PROCESS INDUSTRIES**
- **GAINING WIDE ACCEPTANCE ON COAL FIRED BOILERS**
- **USED WITH SPRAY DRYER ON MOST SPRAY DRYER APPLICATIONS**
- **CAN EASILY BE MAINTAINED WHILE SYSTEM IS OPERATIONAL**
- **FLUCTUATIONS IN TEMPERATURE OR DUST LOAD HAVE LITTLE EFFECT ON PERFORMANCE OF COLLECTOR**



# FABRIC FILTER



# BAGHOUSES ON COAL FIRED UTILITY POWER PLANTS



REF. J. S. TROUPE, BECHTEL, PAPER PRESENTED AT 1978 APPA WORKSHOP,  
SAN FRANCISCO, CAL., FEB. 28, 1978


78-A4-54-15

# WFI'S FABRIC FILTER EXPERIENCE IN POWER INDUSTRY

- \*COYOTE STATION UNIT No. 1 440 MW
- SOUTHWESTERN PUBLIC SERVICE  
HARRINGTON No. 2 & No. 3 700 MW
- TEXAS UTILITIES  
MONTICELLO No. 1 & No. 2 880 MW
- \*PENNSYLVANIA POWER & LIGHT  
HOLTWOOD, PENNSYLVANIA 40 MW
- COLORADO-UTE  
NUCLA, COLORADO No. 1, No. 2, & No. 3 39 MW


\*TURNKEY INSTALLATIONS

# TYPICAL PERFORMANCE OF DRY FGD SYSTEM USING SODA ASH SOLUTION OR LIME SLURRY FOR ABSORBENT



(REACTANT ADDED/REACTANT THEORETICALLY REQUIRED TO REMOVE 100% OF THE SO<sub>2</sub>)

# PARTICULATE EMISSION CONTROL REQUIREMENTS



# SUMMARY OF KEY FEATURES

FEATURES		TECHNICAL ADVANTAGES	PAYOFF TO USER
SPRAY DRYER	<ul style="list-style-type: none"> <li>• WET CONTACT</li> <li>• DRY PRODUCT</li> <li>• LOW l/g</li> </ul>	<ul style="list-style-type: none"> <li>• HIGH SO<sub>2</sub> REMOVAL EFFICIENCY</li> <li>• NO PLUGGING OR SCALING</li> <li>• NO CORROSION OR EROSION</li> <li>• SMALL PIPES AND PUMPS</li> <li>• LOW POWER REQUIREMENTS</li> <li>• CAN USE BLOW DOWN WATER</li> </ul>	<ul style="list-style-type: none"> <li>• MEETS FGD REQUIREMENTS</li> <li>• HIGH AVAILABILITY</li> <li>• LOW MAINTENANCE COSTS</li> <li>• LOW CAPITAL AND OPERATING COSTS</li> <li>• REDUCED WATER USAGE</li> </ul>
BAGHOUSE	<ul style="list-style-type: none"> <li>• FABRIC FILTERS</li> <li>• MECHANICAL AND PNEUMATIC CLEANING</li> </ul>	<ul style="list-style-type: none"> <li>• HIGH PARTICULATE REMOVAL EFFICIENCY</li> <li>• PROVIDES ADDITIONAL SO<sub>2</sub> REMOVAL</li> <li>• HIGH PERFORMANCE WITH REDUCED FILTER AREA</li> <li>• LESS FREQUENT BAG CLEANING</li> </ul>	<ul style="list-style-type: none"> <li>• MEETS STRINGENT PARTICULATE AND SO<sub>2</sub> REQUIREMENTS</li> <li>• LOWER CAPITAL AND OPERATING COSTS</li> </ul>
THE SYSTEM	<ul style="list-style-type: none"> <li>• SIMPLICITY WITH PROVEN TECHNOLOGY</li> </ul>	<ul style="list-style-type: none"> <li>• HIGH RELIABILITY WITH LOW OPERATING AND MAINTENANCE REQUIREMENTS</li> </ul>	<ul style="list-style-type: none"> <li>• LOW CAPITAL AND OPERATING COSTS</li> </ul>

Friday

Meets new source performance standards

90% SO<sub>2</sub> removed

1.2 # SO<sub>2</sub> / 10<sup>6</sup> Btu burned.

2.6 # SO<sub>2</sub> / 10<sup>6</sup> Btu burned -1.2 after abatement  
if below must demo. removed 70% of SO<sub>2</sub>

# 75-80

KW installed  
ductwork from to  
less fan

78-JY3-54-14B

90-100KW  
in wet.

- Stearns-Roger  
- B&W Tech. BEV



# DRY SO<sub>2</sub> AND PARTICULATE REMOVAL SYSTEM

Through a joint venture, the Air Pollution Control Division of Wheelabrator-Frye Inc. and the Atomics International Division of Rockwell International have merged their respective resources and process knowledge to solve the problem of fossil-fuel boiler emissions.

The Wheelabrator/Rockwell dry-products SO<sub>2</sub> and particulate removal system relies on components which have proved their reliability in over 50 years of operation.

The Atomics International Division of Rockwell has developed the use of spray dryers for SO<sub>2</sub> removal.

Wheelabrator-Frye is a leader in air pollution control technology, specializing in applications of fabric filters and electrostatic precipitators for coal-fired boiler installations.

For additional information on this dry system, write: Marvin Long, Wheelabrator-Frye Inc./Rockwell International Joint Venture, P.O. Box 717, Pittsburgh, PA 15230. Or, call him at (412) 288-7290.



Wheelabrator-Frye Inc.



Rockwell International

A Joint Venture



### A dry-product system which removes both SO<sub>2</sub> and particulates

Wheelabrator-Frye Inc. and Rockwell International have developed a simple, economical, dry-product system\* for cleaning boiler flue gas. This system has application on utility and industrial boilers of virtually any size, fired with coal or oil. The system is an open-loop process which uses a spray dryer and a fabric filter collector for SO<sub>2</sub> and particulate removal. Alternately, an electrostatic precipitator can serve as the particulate collector.

\*Patent pending

### Key features and benefits

- Simple, reliable system with proven components
- High availability
- Meets emission standards
- Low capital costs

These features result in overall low annualized costs. In addition, here's what you avoid:

- Sludge ponds
- Water chemistry and pH control problems
- Flue gas reheat
- Scaling, erosion or corrosion problems

### Here's how the system works


1. Boiler flue gas is passed through a spray dryer where it reacts with a mist of a dilute sodium carbonate solution or calcium hydroxide slurry. Immediate chemical reaction removes the SO<sub>2</sub> from the flue gas and the sensible heat of the flue gas evaporates the water and dries the solution to form a dry powder. Since the flue gas does not become saturated, many of the operational problems associated with wet scrubbers cannot occur.
2. The flue gas leaving the spray dryer, containing dry powder and boiler fly ash, enters the collector. As the fly ash and powder are removed from the flue gas in the collector, additional reaction of the SO<sub>2</sub> takes place, increasing the efficiency of the system.
3. The clean gas is then exhausted through a stack to the atmosphere without reheat.
4. All particulates (fly ash and powder) are removed from the hoppers of the collector in a dry form for disposal.



A spray dryer installation



A power boiler fabric filter installation



### A tested system

Years of operating experience have proved fully the components of the system. The most recent demonstration testing was performed at the Leland Olds Station of Basin Electric Power Cooperative. Tests of operational characteristics were conducted with a number of sorbents and filter fabrics. The comprehensive test program demonstrated the ability of the system to achieve high SO<sub>2</sub> and particulate removal efficiencies under varied flue gas conditions.

Through a joint venture of Wheelabrator-Frye Inc. and Rockwell International, a 410 MW (1,890,000 ACFM) turnkey SO<sub>2</sub> and particulate removal system has been contracted for the North Dakota Coyote Station, owned by Otter Tail Power Company, Minnkota Power Cooperative, Inc., Montana-Dakota Utilities Company, Northwestern Public Service Company and Minnesota Power and Light Company.

Cleaned Air

Stack

### Flow Diagram Key:

- Fly Ash
- SO<sub>2</sub>
- Scrubbing Solution
- Spent Dry Salts
- Cleaned Air