

1095

CONTRACT NO.
DE - AC03 - 79SF10736

MARCH 1980
SF10736 - TR7

SOLAR INDUSTRIAL RETROFIT SYSTEM

NORTH COLES LEVEE NATURAL GAS PROCESSING PLANT

TOPICAL REPORT

An aerial photograph of an industrial facility, the North Coles Levee Natural Gas Processing Plant, situated in a flat, arid landscape. In the foreground, a large, rectangular array of solar collectors is arranged in neat rows. The plant itself consists of various structures, including tall distillation columns, storage tanks, and a prominent, tall, lattice-structured tower. The background shows a wide, flat plain extending to the horizon under a clear sky.

PREPARED FOR
THE U.S. DEPARTMENT OF ENERGY

BY
NORTHROP INCORPORATED

AND
ARCO OIL AND GAS COMPANY

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use or the results of such use of any information apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

March, 1978
SF-10736:TR7

SOLAR INDUSTRIAL RETROFIT SYSTEM

NORTH COLES LEVEE NATURAL
GAS PROCESSING PLAN

TOPICAL REPORT

Prepared for the
U. S. DEPARTMENT OF ENERGY
As part of

Contract No. DE-AC03-79SF10736

by
Northrup, Incorporated
and
ARCO Oil and Gas Co.

TABLE OF CONTENTS

<u>SECTION</u>	<u>TOPIC</u>	<u>PAGE</u>
1.	INTRODUCTION	1
1.1	PROJECT OBJECTIVE	1
1.2	APPLICATION DESCRIPTION	1
2.	SUBSYSTEM EVALUATION AND SELECTION	6
2.1	COLLECTOR SYSTEM	6
2.1.1	HELIOSTATS	6
2.1.2	HELIOSTAT CONTROL	7
2.1.3	FIELD CONFIGURATION	7
2.2	RECEIVER SYSTEM	17
2.2.1	RECEIVER SUBSYSTEM	19
2.2.2	RECEIVER SURFACE ANALYSIS	21
2.2.3	TOWER	21
2.3	SOLAR/FOSSIL INTERFACE	21
2.3.1	HEAT MEDIUM OIL SYSTEM INTERFACE	21
2.3.2	COLLECTOR FIELD	24
3.	CONCEPTUAL DESIGN	25
3.1	SOLAR SYSTEM PERFORMANCE REQUIREMENTS	25
3.2	RECEIVER	28
3.3	CONTROL SYSTEM	31
4.0	SYSTEM PERFORMANCE	44

LIST OF FIGURES

<u>FIGURE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
1.1	NORTH COLES LEVEE SOLAR RETROTIT PROJECT	4
1.2	NORTH COLES LEVEE PLANT FLOW DIAGRAM	5
2.1	PLAN VIEW OF RADIAL STAGGER AND TRIANGULAR MODULE CONFIGURATIONS	8
2.2	CANDIDATE COLLECTOR FIELD SITES FOR THE 23 MODULE FIELD CONFIGURATION	11
2.3	CANDIDATE COLLECTOR FIELD SITES FOR THE FOUR MODULE FIELD CONFIGURATION	12
2.4	CANDIDATE COLLECTOR FIELD SITES FOR THE DUAL MODULE FIELD CONFIGURATION	13
2.5	CANDIDATE COLLECTOR FIELD SITES FOR THE UNIT FIELD CONFIGURATION	14
2.6	CANDIDATE HEAT MEDIUM OIL INTERFACE CONNECTIONS	22
3.1	HEAT MEDIUM OIL FLOW DIAGRAM	26
3.2	RECEIVER SERIES VS. PARALLEL FLOW OPTIONS	30
3.3	RECEIVER DIMENSION AND PANEL ORIENTATION	32
3.4	RECEIVER FLOW PATH AND FLOW DISTRIBUTION	33
3.5	SELECTED PLATE COIL CONFIGURATION	34
3.6	RECEIVER PANEL PRESSURE LOSSES, ΔP , PSI	35

LIST OF FIGURES

<u>FIGURE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
3.7	HEAT TRANSFER ANALYSIS- ASSUMPTIONS	36
3.8	DETAILED FIN AND WET-WALL NETWORK ANALYSIS	37
3.9	SAMPLE COMPUTER PRINT-OUT ARCOLES ANALYZER	38
3.10	STEPPER MOTOR DRIVER DIAGRAM	41
3.11	LOGIC SWITCHING SEQUENCE	41
3.12	BLACK DIAGRAM-CONTROL ELECTRONICS	42
4.1	PROCESS HEAT ENERGY STAIRSTEPS FOR NOON ON WINTER, EQUINOX AND SUMMER SOLSTICES	45
4.2	ENERGY FLUX PROFILES ON THE TARGET PLANE AT THE NOON SUMMER SOLSTICE DESIGN POINT	46

LIST OF TABLES

<u>TABLE NO.</u>	<u>TITLE</u>	<u>PAGE</u>
2.1	TOWERLESS MODULE EVALUATION	9
2.2	STEEL TOWER COSTS	16
2.3	COLLECTOR FIELD EVALUATION DATA	18
2.4	RECEIVER APERTURE OPTIMIZATION DATA	20
3.1	RECEIVER DESIGN CRITERIA	29
3.2	RECEIVER ENERGY (KW) BALANCE AND EFFICIENCY	39

1. INTRODUCTION

This topical report was prepared by Northrup, Inc. to present a summary of the work completed under Department of Energy Contract DE-AC03-79SF10736 of the Solar Repowering/Industrial Retrofit System Program. This project encompasses the conceptual design and evaluation of a solar retrofit system for application in the petrochemical industry. The major efforts, to this point in the contract period, have been to establish the overall system requirements and evaluate subsystems and subsystem components and characteristics upon which a cost effective conceptual system design will be developed.

The design-user team formed to accomplish this project consists of two subsidiaries of Atlantic Richfield Company (ARCO); Northrup, Inc. (NI) as solar system design partner and the ARCO Oil and Gas Company as the industrial user partner.

1.1 PROJECT OBJECTIVE

The objective of the program is to develop a site-specific conceptual design of a solar energy retrofit system that will be practical and cost effective in producing process heat for a typical petrochemical industrial application.

1.2 APPLICATION DESCRIPTION

The solar powered process heat system is to be installed at the ARCO North Coles Levee Natural Gas Processing Plant No. 8, located 22 miles west of Bakersfield, California.

The plant is a refrigerated absorption oil plant that recovers propane, butane, and gasoline from raw natural gas. The process consists of the raw gas being bubbled through an oil that absorbs the hydrocarbons with molecular chains longer than methane. The process oil is then heated to drive off the absorbed hydrocarbons. These are selectively heated to separate ethane, propane, butane and gasoline. For safety reasons the entire process avoids the direct use of flame and is powered instead by a heat medium oil (HMO) that is heated remotely and circulated to the stripper, deethanizers, depropanizer and debutanizer reboilers. The system operates between 193°C (380°F) and 301°C (575°F). The process heat is supplied by a combination of two fired heaters and one heat recovery unit that operates on waste heat from a continuously operated gas turbine. Nominally, 2.1 million gallons of HMO are circulated through the system daily; 77% of which is heated by the fired heaters. These heaters consume 1.6×10^6 standard cubic feet per day of natural gas.

The solar retrofit system is being designed to provide a heat source for that portion of the HMO that is circulated through the fired heaters; thus directly replacing a portion of the natural gas fuel requirements.

The general arrangement shows a 35-acre array of 320 heliostats occupying a circular sector that has 304.8m (1000 ft.) radius and an included angle of 120°. It lies due north of a single cavity receiver positioned at the center of curvature, atop a 4-legged steel tower that will place the center of the target plane 200 feet above the ground surface. Figure 1.1 presents an artist's rendition of the collector field layout relative to the plant. The view is from the north "looking" south.

The collector used as a basis for the conceptual design is a second generation heliostat. Each heliostat contains 53.51 m^2 (576 ft.²) of reflective surface.

Direct current stepper motors are used to provide drivepower and maintain position accuracy. The field is controlled by a two-level open-loop system.

The receiver loop interfaces with the existing HMO system between the plant pump discharge and the fired heaters. A flow diagram of the process, HMO and solar system interface is shown in Figure 1. 2. During periods of sufficient insolation, the entire HMO that normally flows to the fired heaters is diverted through the receiver and back to the heaters. The heaters then "top-off" the heat required to maintain their outlet temperature of 301°C (575°F). Fuel flow to the heaters is automatically controlled to supply only enough heat to meet the ΔT requirement, or carry the entire plant load during periods of insufficient insolation. This method of interfacing the solar and non-solar HMO system offers several advantages: (a) All solar energy collected is used; (b) All heat supplied by heat recovery units is used; (c) Fired heaters are maintained at operating temperature and can respond rapidly to transient conditions; (d) System control is extremely simple; and (e) Minimum interruption of existing plant operation.

The solar system is sized to deliver 9,518 kW to the plant at noon, summer solstice. This supplies all the energy that is required, by that portion of the plant powered by the HMO, over and above energy that is available and would be wasted if replaced by solar energy. On this basis solar supplies 33% of the plant annual energy requirement and functions at an average efficiency of 58.2%.





Figure 1.1 North Ceres Levee Solar Retrofit Project

NORTH COLES LE INDUSTRIAL RETROFIT FLOW DIAGRAM



BPV1 BYPASS VALVE
 SOV1 SHUT OFF VALVE
 SOV2 SHUT OFF VALVE
 SOV3 SHUT OFF VALVE

Figure 1.2 North Cole Levee Industrial Retrofit Flow Diagram

2. SUBSYSTEM EVALUATION AND SELECTION

In order to develop the most efficient system for minimum cost and within land use and other site-specific constraints, it has been necessary to perform both system and subsystem parametric analyses and trade-studies. These included collector field configurations, receiver types, control strategies, heat augmentation temperatures, and site interfaces.

2.1 COLLECTOR SYSTEM

The key parametric analysis involved the evaluation and subsequent selection of a collector field configuration that would be economical, provide maximum collection efficiency and remain compatible with the site specific constraints imposed by an operating oil and gas field. The system design discussed in the proposal was based on a field composed of 23 modules, triangular in shape, each containing 19 heliostats focused on a ground level (towerless) receiver. The primary considerations were the savings due to the elimination of tower costs and the land use versatility and flexibility so important in retrofit applications. However, other central receiver tower modules and radial stagger flat field collector configurations were evaluated to establish the optimum.

2.1.1 Heliostats - The baseline heliostat selected as the basis of the North Coles Levee system design is the Northrup II. This heliostat is being developed under Department of Energy funding for second generation heliostats. Prototype testing is scheduled to be completed the latter part of 1980 and production and delivery can be scheduled to meet the requirements of the North Coles Levee project.

The heliostat is being designed to meet or exceed the structural and performance requirements of specification A10772. The basic configuration is a square array of mirror facets with a total area of 53.51 m² (576 ft.²) and a specular reflectivity of 0.87.

2.1.2 Heliostat Control - The heliostat control system is also being developed as a part of the work under the second generation heliostat development program. Here again, the tracking, slewing, and positioning capabilities will meet the requirements of specification A10772. However, complete control is derived from an open-loop, two-level (Array Controller & Heliostat Controller) system. Actual positioning is accomplished by stepper motors and calculated position based on step count rather than AC or DC motors with encoder position monitoring. Baseline position knowledge is derived from limit switches at the ends of travel.


2.1.3 Field Configuration - The selection of a suitable collector field configuration was the major thrust under this task. The 23 module towerless field configuration presented in the proposal utilized a triangular (two straight row) module arrangement composed of 19 heliostats each (Figure 2.1). Since this field configuration offered unique advantages (elimination of tower cost and land use flexibility) in retrofit situations, the initial effort was to determine if performance could be improved by placing the heliostats in a radial stagger configuration (Figure 2.1).

Evaluation and final selection between these two towerless fields was based on annual performance and land use considerations. Table 2.1 presents the performance comparison between the two configurations. The radial stagger module exhibits a higher peak performance while the triangular module shows a higher annual performance. This annual performance advantage is less than 0.5%.

RADIAL STAGGER FLAT FIELD LAYOUT

216 FT OUTER ROW, 166.5 FT INNER ROW

RADIAL LAYOUT NO. 3 FOR 19 - 53.51 M² HELIOSTATS



TRIANGULAR FLAT FIELD LAYOUT

224.8 FT OUTER ROW, 175.3 FT INNER ROW

LAYOUT NO. 8 FOR 19 - 53.51 M² HELIOSTATS




Figure 2.1 PLAN VIEW OF THE RADIAL STAGGER AND TRIANGULAR MODULE CONFIGURATIONS

TABLE 2.1

TOWERLESS MODULE EVALUATION

Straight Rows vs. Radial Stagger Rows

PARAMETER	STRAIGHT ROW - TRIANGULAR	RADIAL STAGGER ROW - SECTOR
I. PHYSICAL COMPARISON		
1.1 No. of Heliostats per Module	19	19
1.2 Mirror Area	53.51 m ² (576 ft ²)	53.51m ² (576 ft ²)
1.3 Module Size		
1.3.1 Width, E-W	143m (469 ft)	108m (353 ft)
1.3.2 Depth, N-S	68m (225 ft)	66m (216 ft)
1.3.3 Area	9803m ² (105,512 ft ²)	7094m ² (76,356 ft ²)
1.4 Packing Density	.0873	.1207
II. PERFORMANCE COMPARISON		
2.1 Peak Geometric Efficiency	.9084	.9239
2.2 Annual Geometric Efficiency	.7672	.7639
2.3 Annual Energy (19 Heliostats)	3.468 x 10 ⁷	3.457 x 10 ⁷
2.4 Peak Energy	734 MW	740 MW
2.5 Peak Flux	230 Kw/m ²	240 Kw/m ²

Table 2.1 also presents the physical comparison between the two modular configurations. The significance of this comparison is the much smaller land requirements of the radial stagger configuration. The triangular module requires about 10% more land area than does the radial stagger module.

Since land use is an important consideration in field layout, and annual performance is not significantly different, the radial stagger configuration was selected as the baseline flat field modular configuration for the remainder of the field selection effort.

After selection of the towerless module configuration, a cost/performance evaluation was conducted for four heliostat field configurations to provide a basis for selection of the collector field to be used in the conceptual design. These were of the modular field type and included the 23 module towerless field, the quad (4) module field, the dual (2) module field, and the unit or single module field. The 23 unit, quad, dual and unit module field configurations are shown in plan in Figures 2.2, 2.3, 2.4 and 2.5. As shown in the figures, all field layouts except the unit configuration are shown with extra modules. This was done to facilitate the selection of the best module placement considering the existing gas, oil and injection wells; pipe lines; and electrical and communication lines.

The collector field performance for each field configuration was evaluated by computer, which required the determination of the coordinates of the heliostats and the sun position as input. The code uses this information to calculate the cosine factors, shading, and blocking for each heliostat in the collector field. These values are averaged over the field reflector area and, combined with the tower shadow, produce an overall geometric performance efficiency matrix for 36 sun positions. The field performance is calculated by combining the hourly isolation data with the appropriate geometric performance, obtained from interpolation of the efficiency matrix and based on sun position, and summed

The heliostat is being designed to meet or exceed the structural and performance requirements of specification A10772. The basic configuration is a square array of mirror facets with a total area of 53.51 m² (576 ft.²) and a specular reflectivity of 0.87.

2.1.2 Heliostat Control - The heliostat control system is also being developed as a part of the work under the second generation heliostat development program. Here again, the tracking, slewing, and positioning capabilities will meet the requirements of specification A10772. However, complete control is derived from an open-loop, two-level (Array Controller & Heliostat Controller) system. Actual positioning is accomplished by stepper motors and calculated position based on step count rather than AC or DC motors with encoder position monitoring. Baseline position knowledge is derived from limit switches at the ends of travel.


2.1.3 Field Configuration - The selection of a suitable collector field configuration was the major thrust under this task. The 23 module towerless field configuration presented in the proposal utilized a triangular (two straight row) module arrangement composed of 19 heliostats each (Figure 2.1). Since this field configuration offered unique advantages (elimination of tower cost and land use flexibility) in retrofit situations, the initial effort was to determine if performance could be improved by placing the heliostats in a radial stagger configuration (Figure 2.1).

Evaluation and final selection between these two towerless fields was based on annual performance and land use considerations. Table 2.1 presents the performance comparison between the two configurations. The radial stagger module exhibits a higher peak performance while the triangular module shows a higher annual performance. This annual performance advantage is less than 0.5%.

RADIAL STAGGER FLAT FIELD LAYOUT

216 FT OUTER ROW, 166.5 FT INNER ROW

RADIAL LAYOUT NO. 3 FOR 19 - 53.51 M² HELIOSTATS



TRIANGULAR FLAT FIELD LAYOUT

224.8 FT OUTER ROW, 175.3 FT INNER ROW

LAYOUT NO. 8 FOR 19 - 53.51 M² HELIOSTATS




Figure 2.1 PLAN VIEW OF THE RADIAL STAGGER AND TRIANGULAR MODULE CONFIGURATIONS

TABLE 2.1

TOWERLESS MODULE EVALUATION

Straight Rows vs. Radial Stagger Rows

PARAMETER	STRAIGHT ROW - TRIANGULAR	RADIAL STAGGER ROW - SECTOR
I. PHYSICAL COMPARISON		
1.1 No. of Heliostats per Module	19	19
1.2 Mirror Area	53.51 m ² (576 ft ²)	53.51m ² (576 ft ²)
1.3 Module Size		
1.3.1 Width, E-W	143m (469 ft)	108m (353 ft)
1.3.2 Depth, N-S	68m (225 ft)	66m (216 ft)
1.3.3 Area	9803m ² (105,512 ft ²)	7094m ² (76,356 ft ²)
1.4 Packing Density	.0873	.1207
II. PERFORMANCE COMPARISON		
2.1 Peak Geometric Efficiency	.9084	.9239
2.2 Annual Geometric Efficiency	.7672	.7639
2.3 Annual Energy (19 Heliostats)	3.468 x 10 ⁷	3.457 x 10 ⁷
2.4 Peak Energy	734 MW	740 MW
2.5 Peak Flux	230 Kw/m ²	240 Kw/m ²

Table 2.1 also presents the physical comparison between the two modular configurations. The significance of this comparison is the much smaller land requirements of the radial stagger configuration. The triangular module requires about 10% more land area than does the radial stagger module.

Since land use is an important consideration in field layout, and annual performance is not significantly different, the radial stagger configuration was selected as the baseline flat field modular configuration for the remainder of the field selection effort.

After selection of the towerless module configuration, a cost/performance evaluation was conducted for four heliostat field configurations to provide a basis for selection of the collector field to be used in the conceptual design. These were of the modular field type and included the 23 module towerless field, the quad (4) module field, the dual (2) module field, and the unit or single module field. The 23 unit, quad, dual and unit module field configurations are shown in plan in Figures 2.2, 2.3, 2.4 and 2.5. As shown in the figures, all field layouts except the unit configuration are shown with extra modules. This was done to facilitate the selection of the best module placement considering the existing gas, oil and injection wells; pipe lines; and electrical and communication lines.

The collector field performance for each field configuration was evaluated by computer, which required the determination of the coordinates of the heliostats and the sun position as input. The code uses this information to calculate the cosine factors, shading, and blocking for each heliostat in the collector field. These values are averaged over the field reflector area and, combined with the tower shadow, produce an overall geometric performance efficiency matrix for 36 sun positions. The field performance is calculated by combining the hourly isolation data with the appropriate geometric performance, obtained from interpolation of the efficiency matrix and based on sun position, and summed




Figure 2.2




Figure 2.3




Figure 2.4




Figure 2.5.

over the entire year. Since the atmospheric attenuation does not vary significantly over the range of field dimensions, it was only considered in calculations of the annual energy collected.

To compare the cost of the four solar collector subsystem configurations, it is necessary to normalize the costs for performance variations. The collector subsystems and tower costs were analyzed by use of the algorithm:

$$C_{CN} = \frac{C_H + C_T + C_R + C_W + C_P}{\eta}$$

where:

C_{CN} = the normalized collector subsystem cost

C_H = installed cost of heliostats

C_T = tower cost

C_R = receiver cost

C_W = field wiring cost

C_P = piping cost

η = field efficiency

The input and variations of the terms of the algorithm were defined as follows:

- * Heliostats costs (C_H) were established by placing the results of all performance calculations on the basis of a field size of 437 heliostats; each containing 53.51 m^2 , reflective surface area. An installed cost of \$230.0 per m^2 , recommended in Reference 1, was used in the calculation.
- * The tower costs (C_T) were calculated using the SLL steel tower cost algorithm recommended in Reference 1 and are presented in Table 2.2.
- * The receiver costs (C_R) were based on using flat plate design for the towerless field and adapting a scaled up version of this receiver to develop the single cavity configuration for the tower receivers.

TABLE 2.2

STEEL TOWER COST
(Dollars-1978)

FIELD CONFIGURATION	TOWER HEIGHT	RECEIVER WEIGHT	TOWER COST	FOUNDATION COST	ACCESSORY COST	ENG. & FEE	TOTAL (1 TOWER)
SINGLE	200 ft.	48,000	73,525	210,358	215,000	124,720	623,606
DUAL	174 ft.	23,520	52,815	182,591	209,800	111,301	556,507
QUAD	135 ft.	12,000	37,288	164,854	202,000	101,000	505.178

- * The wiring costs (C_w) were estimated from the requirements of supplying each heliostat 115 VAC drive power and control signals.
- * Piping costs (C_p) were estimated from visually optimized layouts superimposed on each field, and include the riser and downcomer.
- * The field efficiency (η) is the integrated average of the geometric efficiency taken hourly from 6 a.m. to 6 p.m. for the year 1976 at Barstow, Ca., for times when the isolation was above 500 W/m^2 .

A complete cost and performance comparison is presented in Table 2.3.

Other considerations included; (1) operations and maintenance costs should not differ significantly between the field configurations, (2) piping losses would be minimum for the single module, and (3) the single tower module is more efficient relative to the total land utilization.

As a result of the evaluation of the above data, Northrup has selected the single module field for the design of North Coles Levee solar process heat system.

The design point that has been established (Section 3.1) is for the solar system to deliver to the heat medium oil system at the plant interface, 9.518 kW_t at noon on the summer solstice. This design point is based on less energy production than originally proposed and as a result, the collector field has been re-sized to meet the revised requirement. The most recent calculations showed that a field size of 320 heliostats would be adequate to meet this design requirement.

2.2 RECEIVER SYSTEM - The receiver system consists of the receiver proper, tower, and riser/downcomer pipes. The original concept incorporated modules that contained receivers near ground level, hence no towers were required. Based on subsequent analyses, the field configuration has been revised to a single collector array with the receiver positioned at an optical height of 61 m (200 ft.) above ground level. The system design has therefore been expanded to include the tower and riser/downcomer piping.

TABLE 2.3

SOLAR INDUSTRIAL RETROFIT SYSTEM
NORTH COLES LEVEE PROJECT

COLLECTOR FIELD SELECTION EVALUATION DATA

SELECTION CRITERIA	23 MODULE "FLAT" FIELD (Proposal)	QUAD MODULE TOWER FIELD (Towers-135')	DUAL MODULE TOWER FIELD (Towers-174')	SINGLE MODULE TOWER FIELD (Tower-200')
I. COST (1979 Dollars)				
1.A HELIOSTATS	5,378,500	5,378,500	5,378,500	5,378,500
1.B TOWERS	-0-	2,020,712	1,113,016	623,603
1.C RECEIVERS	344,712	179,506	213,698	188,054
1.D PIPING	495,364	301,587	164,005	81,698
1.E WIRING	29,179	33,731	28,706	27,817
TOTAL	6,247,750	7,914,036	6,897,925	6,299,671
II. ACTUAL PERFORMANCE				
2.A ANNUAL EFFICIENCY	0.763899	0.83312	0.83144	0.829824
2.B ANNUAL ENERGY TO RECEIVER (Kw/Hr)	3.457 (7)	3.762 (7)	3.754 (7)	3.7422 (7)
III. RELATIVE EVALUATION				
3.A NORMALIZED COST $\left\{ \frac{\text{Cost}}{\text{Efficiency}} \right\}$	8,178,771	9,499,264	8,296,359	7,591,575
3.B SPECIFIC CAPITAL COST (\$/Kw Hr)	.18073	.21036	.18373	.16834
IV. EFFECTIVE RELATIVE COST (Single Tower Basis)	1.07735	1.2496	1.0914	1.000

Prior to the final field selection for this project, the conceptual design of a flat-plate type ground-level receiver had been developed. It is possible that a pilot project or other retrofit projects with severe land use constraints will dictate a return to the smaller towerless collector module. Also, it is conceivable that this receiver will be used in the pilot unit for this project. A description of this receiver was presented in the October Monthly Report (TPR-2) and will be included as an appendix to the final report.

2.2.1 Receiver Subsystem - As a result of the selection of a field configuration using a tall tower 61 m (200 ft.) an appropriate receiver is being designed. The receiver will be a north-facing cavity type. The flow rate through the receiver has been established at 63,750 gal/hr of heat medium oil. The normal operating range will be 215.5° to 293°C (420°F to 560°F). The receiver is being sized to deliver $9,518 \text{ MW}_t$ at the point of interface with the existing plant system.

In general, the receiver geometry will be a circular arc segment; 120° included angle on a 7.3 m (24 ft.) radius; approximately 10 m (39 ft.) in height; with the aperture centerline 61 m (200 ft.) above ground level. The conceptual design and analysis is currently in progress.

Initial work has included the optimization of the size of the receiver aperture. The optimization is based on the combined efficiencies of four fundamental properties of a receiver; the spillage, the absorptivity, the radiation and convection. The efficiencies were calculated for winter and summer solstices and spring equinox for three aperture sizes. The results of these calculations are tabulated in Table 2.4. The results show that the $6.4 \times 6.4 \text{ m}$ (21 ft x 21 ft) aperture provides the overall highest efficiency.

TABLE 2.4
RECEIVER APERTURE OPTIMIZATION

DAY NO.	APERTURE (FT)	SPILLAGE	ABSORPTIVITY	RADIATION	CONVECTION	COMBINATION
80	27 x 27	.9907	.9787	.9756	.9258	.8758
80	21 x 21	.9698	.9777	.9849	.9541	.8910
80	15 x 15	.8716	.9769	.9915	.9740	.8222
173	27 x 27	.9850	.9787	.9734	.9190	.8624
173	21 x 21	.9506	.9777	.9833	.9492	.8675
173	15 x 15	.8204	.9767	.9902	.9701	.7699
355	27 x 27	.9932	.9787	.9766	.9288	.8818
355	21 x 21	.9776	.9777	.9854	.9562	.9008
355	15 x 15	.8948	.9769	.9920	.9756	.8460

2.2.2 Receiver Surface Analysis - During the design of the receiver for the "towerless" field module, an analysis related to the utilization of selective surface vs. black paint was conducted. The analysis demonstrated that for the ground level receivers, the problem is really one of selective surface availability; if selective surface finish is available which can withstand the thermal environment (204°C - 371°C) it should be used on this type receiver. The benefit of a selective surface vs. a non-selective, black painted surface will produce a system performance improvement of about 5%. The radiation problem is less critical for the cavity receiver and black paint will suffice. Analysis are continuing.

2.2.3 Tower - The tower design has only recently been initiated as a result of the single module field configuration selection. Initial costs estimates used in the field selection were based on using a four legged steel tower and the cost algorithms recommended by SLL. More detailed tower design and evaluation and selection is in progress.

2.3 SOLAR/FOSSIL INTERFACE

The interface between the solar system and the existing HMO system includes several areas. The most prominent of these are the interface of the receiver fluid loop with the heat medium oil system and the collector field interface with the available land.

2.3.1 Heat Medium Oil System Interface - The interface of the existing plant heat medium oil system with the solar system has been evaluated. Three points were selected for analysis. Thses are shown schematically in Figure 2.6. In all cases the oil flows through the fired heaters in the usual manner.






Figure 2.6 Candidate Heat Medium Oil Interface Connections

The hook-up shown in schematic C would provide the maximum ΔT across the solar system because the heat medium outlet from the debutanizer is the lowest in the system (approximately 320°F). Unfortunately, this process requires less than 5% of the heat produced by the fired heaters.

The hook-up shown in schematic B would permit a much larger flow through the solar system but would raise the temperature in the heat medium surge tank, thereby reducing the ΔT across the solar system. Also, the HMO system pumps would be required to operate at much higher temperatures.

Schematic A shows the interface selected. Here all the heat medium oil that flows through the fired heaters would be routed through the solar system (after the solar system oil has been brought up to the average surge tank operating temperature - approximately 215.5°C, 420°F) and return to the inlet of the fired heaters which will raise the temperature to the required 570°F. Solar would supply all heat collected until the input to the fired heaters dropped below the surge tank temperature. At this time the solar system would be blocked out and the plant would return to normal operation. The maximum solar return temperature would be limited to approximately 560°F. This is necessary because the fired heaters cannot be completely extinguished during solar operation. The remaining ΔT of 5.6°C (10°F) will be furnished by the heaters operating at minimum level.

This method of interfacing the solar and non-solar HMO systems offer several advantages:

1. All solar energy collected is used,
2. All heat supplied by heat recovery units is used.
3. Fired heaters are maintained at operating temperature and can respond rapidly to transient conditions.
4. System control is extremely simple.
5. Minimum interruption of existing plant operations.

2.3.2 Collector Field Installation - The site proposed for the collector field is relatively flat and level and is clear of major obstructions. However, it is a producing oil and gas field and, as such, contains numerous oil and gas wells, with associated transport and injection pipelines and unimproved access roads. There is also a telephone and power line and a 30 in. water main that traverse portions of the field, Figure 2.5. The well sites require an unobstructed area 30.5 m (100 ft) x 73.2 m (240 ft) for placement of workover platforms and redrilling equipment when that type of well maintenance is required. These restrictions were not considered of sufficient severity to prohibit installation. Once the collector field configuration had been selected and sized, it was possible to analyze the placement to minimize both the interference with oil field operations and collector field integrity. Figure 2.5 shows a plan view of the final field placement. In this position only two wells fall within the field perimeter and one well pad intersects the outer row of heliostats on the extreme eastern edge. All power and telephone lines and the 30 in. water main lie outside. Other small pipelines still remain within the field. Minor position adjustments to a small number of heliostats should adequately eliminate any interference with those existing lines. With the construction of two short access roads and relocation of a materials storage area, the collector field installation should be completely compatible with the existing land use plan.

3. CONCEPTUAL DESIGN

3.1 SOLAR SYSTEM PERFORMANCE REQUIREMENTS

The heat medium oil (HMO) system is illustrated in the temperature/flow diagram in Figure 3.1. Total daily HMO circulation through the system averages 2,100,000 gal. The system capacity is approximately 20,000 gal., divided almost evenly between the surge tank (10,000 gal.) and the piping system. The system level is maintained at approximately 18,000 gal. which requires that each segment of the fluid circulate through the system 117 times each day.

There are various inlet and outlet temperatures maintained at the several processes by system by-pass valves and loops. All HMO outlets from the process reheaters and reboilers return to the surge tank, which remains at an average temperature of 216°C (420°F). The HMO is pumped from the surge tank to a Nordberg Heat Recovery Unit (HRU) and two natural gas fired heaters where each of these units raises the HMO temperature to 305°C (575°F). The 2.1×10^6 gal./day flow rate combined with the T of 68.3°C (155°F) results in a calculated energy production of 4.94×10^7 Btu/hr or 1.45×10^4 Kwt.

Of this total energy production, approximately 33% is furnished by the HRU which utilizes the heat rejected from the one 5500 hp Nordberg Gas Turbine that is used as prime mover for the compressor used in a water flood project. This rejected heat is available 24 hrs per day and would be wasted if not utilized in the heat medium system. For this reason, this energy was not considered as replacable by solar as no fossil fuel displacement would result.

The flow rate through the HRU averages 560,000 gal. per day. This flow, combined with the $68.3^{\circ}\text{C} \Delta T$ produces 1.31×10^7 Btu/hr or 3.858×10^3 Kwt.

The remainder, 3.631×10^7 Btu/hr or 1.06×10^4 Kwt is delivered to the system by the fired heaters.




Figure 3.1

7a

HEAT MEDIUM OIL FLOW DIAGRAM		PLANT 8		AMERICAN FERTILIZER COMPANY	
11-07-045 D		11-07-045 D		11-07-045 D	
NO. 1	NO. 2	NO. 3	NO. 4	NO. 5	NO. 6
NO. 7	NO. 8	NO. 9	NO. 10	NO. 11	NO. 12
NO. 13	NO. 14	NO. 15	NO. 16	NO. 17	NO. 18
NO. 19	NO. 20	NO. 21	NO. 22	NO. 23	NO. 24
NO. 25	NO. 26	NO. 27	NO. 28	NO. 29	NO. 30
NO. 31	NO. 32	NO. 33	NO. 34	NO. 35	NO. 36
NO. 37	NO. 38	NO. 39	NO. 40	NO. 41	NO. 42
NO. 43	NO. 44	NO. 45	NO. 46	NO. 47	NO. 48
NO. 49	NO. 50	NO. 51	NO. 52	NO. 53	NO. 54
NO. 55	NO. 56	NO. 57	NO. 58	NO. 59	NO. 60
NO. 61	NO. 62	NO. 63	NO. 64	NO. 65	NO. 66
NO. 67	NO. 68	NO. 69	NO. 70	NO. 71	NO. 72
NO. 73	NO. 74	NO. 75	NO. 76	NO. 77	NO. 78
NO. 79	NO. 80	NO. 81	NO. 82	NO. 83	NO. 84
NO. 85	NO. 86	NO. 87	NO. 88	NO. 89	NO. 90
NO. 91	NO. 92	NO. 93	NO. 94	NO. 95	NO. 96
NO. 97	NO. 98	NO. 99	NO. 100	NO. 101	NO. 102
NO. 103	NO. 104	NO. 105	NO. 106	NO. 107	NO. 108
NO. 109	NO. 110	NO. 111	NO. 112	NO. 113	NO. 114
NO. 115	NO. 116	NO. 117	NO. 118	NO. 119	NO. 120
NO. 121	NO. 122	NO. 123	NO. 124	NO. 125	NO. 126
NO. 127	NO. 128	NO. 129	NO. 130	NO. 131	NO. 132
NO. 133	NO. 134	NO. 135	NO. 136	NO. 137	NO. 138
NO. 139	NO. 140	NO. 141	NO. 142	NO. 143	NO. 144
NO. 145	NO. 146	NO. 147	NO. 148	NO. 149	NO. 150
NO. 151	NO. 152	NO. 153	NO. 154	NO. 155	NO. 156
NO. 157	NO. 158	NO. 159	NO. 160	NO. 161	NO. 162
NO. 163	NO. 164	NO. 165	NO. 166	NO. 167	NO. 168
NO. 169	NO. 170	NO. 171	NO. 172	NO. 173	NO. 174
NO. 175	NO. 176	NO. 177	NO. 178	NO. 179	NO. 180
NO. 181	NO. 182	NO. 183	NO. 184	NO. 185	NO. 186
NO. 187	NO. 188	NO. 189	NO. 190	NO. 191	NO. 192
NO. 193	NO. 194	NO. 195	NO. 196	NO. 197	NO. 198
NO. 199	NO. 200	NO. 201	NO. 202	NO. 203	NO. 204
NO. 205	NO. 206	NO. 207	NO. 208	NO. 209	NO. 210
NO. 211	NO. 212	NO. 213	NO. 214	NO. 215	NO. 216
NO. 217	NO. 218	NO. 219	NO. 220	NO. 221	NO. 222
NO. 223	NO. 224	NO. 225	NO. 226	NO. 227	NO. 228
NO. 229	NO. 230	NO. 231	NO. 232	NO. 233	NO. 234
NO. 235	NO. 236	NO. 237	NO. 238	NO. 239	NO. 240
NO. 241	NO. 242	NO. 243	NO. 244	NO. 245	NO. 246
NO. 247	NO. 248	NO. 249	NO. 250	NO. 251	NO. 252
NO. 253	NO. 254	NO. 255	NO. 256	NO. 257	NO. 258
NO. 259	NO. 260	NO. 261	NO. 262	NO. 263	NO. 264
NO. 265	NO. 266	NO. 267	NO. 268	NO. 269	NO. 270
NO. 271	NO. 272	NO. 273	NO. 274	NO. 275	NO. 276
NO. 277	NO. 278	NO. 279	NO. 280	NO. 281	NO. 282
NO. 283	NO. 284	NO. 285	NO. 286	NO. 287	NO. 288
NO. 289	NO. 290	NO. 291	NO. 292	NO. 293	NO. 294
NO. 295	NO. 296	NO. 297	NO. 298	NO. 299	NO. 300

There is an additional limitation on the amount of energy to be supplied by the solar system. The heat supplied by the fired heaters is controlled relative to system demand by control of fuel gas to the heater burners. Adequate control is accomplished quite easily and automatically, within the narrow limits of the normal operating range, by a TRC valve in the fuel line which is controlled by the HMO outlet temperature. However, complete start-up from a cold or complete fuel shut-off condition is a somewhat complicated and lengthy process involving safety systems, alarm systems, flame provers, pilot burners, torch lighters and main burners. In order to eliminate the daily (or even more often in the case of cloud transients) burner shut-down and start-up process or a complete redesign of the existing control system, it was decided that the heaters would remain in service, but operating at a maximum turndown of 10 to 1. In order that the remaining heat not be wasted during periods of high solar insulation, the decision was made to design the solar system such that the constant flow of HMO through the heaters would be retained and the solar system sized to return the HMO to the system at a maximum temperature that would still allow the fired heaters operating at maximum turndown level to utilize the energy produced to "top-off" the HMO to meet the 301°C (575°F) process temperature requirement. This design criteria will greatly simplify the control system and minimize installation and operational interference with routine plant operations while remaining compatible with the existing safety system and associated procedures.

In order to fully utilize the energy produced when the fossil system is operating at minimum, the solar system was sized to supply sufficient energy to increase the HMO temperature from 216 C (420 F) to 293 C (560 F) and return it to the inlet of the fired heaters where the temperature is increased to the required 301 C (575 F).

Based on the above, a system rating value has been established for solar system sizing and design as follows:

2,100,00	Gal./Day	heat medium flow for plant
-570,000	"	to heat recovery unit
<hr/>		
1,530,000		to fired heaters

flow rate = 63,750 Gal./ Hr.

$T = 560^{\circ}F - 420^{\circ}F = 140^{\circ}F$

Specific Heat = .60 Btu/lb. $^{\circ}F$

Specific Gravity = .731

Heat Requirement = 32.49×10^6 BTU/Hr.
= 9,518 KWT

3.2 RECEIVER

With the energy requirements of the solar system established and the flux distributions incident upon the receiver calculated, the actual design began. The analysis work is being done using the Northrup Arcoles Receiver Analyzer computer program. The criteria established to define the philosophy as well as the parameters that govern the operational limits of the receiver systems are presented on page 28..

The receiver design incorporates standard size Platecoil panels produced by the Tratner Manufacturing Co. (Figure 3.2). The panels are available in a wide variety of metals, sizes, flow patterns, manifold connections, pass sizes and embossing patterns.

The Arcoles Analyzer was used to evaluate the system parameters for a number of panel sizes, physical arrangements, and flow patterns to establish an **optimum** balance and efficiency within the above design criteria.


TABLE 3.1 RECEIVER DESIGN CRITERIA

- * USE COMMERCIALY AVAILABLE STANDARD HARDWARE TO THE MAXIMUM EXTENT POSSIBLE.
- * USE LOW COST CARBON STEEL PANELS, PIPE, AND FITTINGS. AVOID STAINLESS STEEL AND SUPER ALLOYS.
- * MINIMIZE THE USE OF CONTROL VALVES, PUMPS, AND OTHER "ACTIVE" COMPONENTS.
- * DESIGN FOR MINIMUM METAL AND OIL TEMPERATURES AND MINIMUM RECEIVER PRESSURE LOSS:
 1. LIMIT PEAK OIL TEMPERATURE TO 600^oF.
 2. LIMIT PEAK TUBE WALL TEMPERATURE TO 650^oF.
 3. LIMIT PEAK NON-WETTED METAL TEMPERATURE TO 675^oF.
 4. LIMIT RECEIVER PRESSURE LOSS TO 50 PSI.
 5. LIMIT PEAK THERMAL STRESS TO 25,000 PSI.


FIGURE 3.2 SERIES VS PARALLEL FLOW OPTION

1/4" MPT for double embossed and 1/2" MPT for single embossed typ


1 1/4" typ



SERIES (SERPENTINE) FLOW



PARALLEL FLOW



SERIES-PARALLEL FLOW

30

The receiver model used for the calculations was composed of 52 plate coil panels; three stacked rows of 14 each and 10 horizontal or cross-panels for return bend protection (Figure 3.3). The flow pattern was established to be a series/parallel arrangement - basically parallel through each row and serpentine through each panel. The Platecoil panel selected is shown in figure 3.5. Flow rates and associated pressure losses relative to each panel were calculated. The pressure drop results are shown in figure 3.6.

For the heat transfer analysis, each of the vertical panels was divided into three modal zones and each cross panel remained a single zone for a total of 136 zones. The assumptions used in the transfer analysis are summarized in figure 3.7. The basis for the panel fin and wet-wall network analysis is shown in figure 3.8. Combining these inputs with the receiver configuration previously described, the Arcoles Analyzer then characterized each modal zone and summed the results over the entire receiver. A sample computer printout for a typical zone is shown in figure 3.9.

A summary of the results for the selected receiver is as follows:

- * MAXIMUM FIN TEMPERATURE 659°F
- * MAXIMUM TUBE TEMPERATURE 628°F
- * MAXIMUM OIL TEMPERATURE 600°F
- * MAXIMUM THERMAL STRESS 21.484 PSI

The receiver energy balances and efficiencies are summarized in Table 3.1.

3.3 CONTROL SYSTEM:

The controls at each heliostat will consist of two stepper motor drive electronics and the microprocessor controls to interface with the

FIGURE 3.3 RECEIVER DIMENSIONS AND PANEL ORIENTATION






FIGURE 3.4 RECEIVER FLOW PATH & FLOW DISTRIBUTION



33

FIGURE 3.5

SELECTED PLATECOIL CONFIGURATION



34

Width vs Number of Passes

No. of Passes	1	2	3	4	5	6	7	8	9	10	11
Actual Width	5 ³ / ₈	9 ³ / ₁₆	13	16 ⁷ / ₈	20 ³ / ₄	24 ⁹ / ₁₆	28 ³ / ₈	32 ¹ / ₄	36 ¹ / ₈	39 ¹⁵ / ₁₆	43 ³ / ₄

Furnished as standard
in the following lengths:

23"	59"	107" ✓
29"	71"	119" ✓
35"	83"	131"
47"	95"	143" ✓

OPERATING PRESSURES CARBON ✓ AND 300 SERIES STAINLESS STEEL AND MONEL ASME AND STANDARD

GA.	DOUBLE EMBOSSED	SINGLE EMBOSSED COMPANION PLATE (GA.)										
		16	14	12	11	10	9	8	3/8	1/4	3/16	3/8
16	25	10	20	30	40	50	60	65	70	70	70	70
14	30		20	30	40	50	60	70	90	90	90	90
12	60			40	50	70	70	80	110	110	110	110
11	80				50	80	80	90	120	120	120	120
10 ✓	120					90	90	100	130	130	130	130





QTY	SIZE	PASS	FITTING
7	43"x143"	11	L.H.
7	43"x143"	11	R.H.
7	43"x119"	11	L.H.
7	43"x119"	11	R.H.
7	43"x107"	11	L.H.
7	43"x107"	11	R.H.
2	13"x107"	3	L.H.
8	13"x143"	3	R.H.

FIGURE 3.6 RECEIVER PANEL PRESSURE LOSSES, ΔP , PSI

2.0	2.0	2.0	1.9	1.9	1.9	2.0	2.0	1.9	1.9	1.9	2.0	2.0	2.0	
0.5			0.5			0.9			0.5			0.5		
8.1	16.2	24.3	33.1	35.3	40.0	40.8	40.8	40.0	35.3	33.1	24.3	16.2	8.1	
1.1			6.0 *			1.9			6.0			1.1		
4.1	4.1	4.1	4.3	4.3	4.3	4.1	4.1	4.3	4.3	4.3	4.1	4.1	4.1	

* These series panels dictate total receiver pressure loss = 46.8 psi
 Assuming 70% motor-pump efficiency, pump power = 30.7 KW

FIGURE 3.7 HEAT TRANSFER ANALYSIS - ASSUMPTIONS

SURFACE PROPERTIES	ABSORPTIVITY LOSSES
 <p>$\alpha = 0.95$ $\epsilon = 0.95$ BLACK PAINT</p> <p><u>Assumption:</u> Non-Selective black paint with moderate optical properties.</p>	 <p><u>Assumption:</u> 50% of the reflected energy striking the cavity walls is absorbed by those walls.</p>
WEATHER	CONVECTION LOSSES
 <p>$V_{wind} = 11.07 \text{ mph}$ $T_{amb} = 50^\circ\text{F}$ 200' $V_{wind} = 8.33 \text{ mph}$ 30'</p>	 <p>Forced Convection: $h = 0.931 (R_{cp} V_{\infty}) Re^{-1/2} Pr^{-2/3} *$</p> <p><u>Assumption:</u> Receiver panels are exposed to the full wind velocity. Natural and forced convection effects are additive.</p> <p>Natural Convection: $h = 1.0 \text{ BTU/ft}^2\text{-hr-}^\circ\text{F}$</p> <p>* Sparrow & Tien, Journal of Heat Transfer, Nov. 1977, Vol 99, pg. 507-512.</p>

36

figure 3.8 DETAILED FIN & WET-WALL NETWORK ANALYSIS





FIGURE 3.9 SAMPLE COMPUTER PRINT-OUT: "ARCOLES" ANALYZER

DAY 355 : 12:00 NOON

NODE # = 67
VIEW FACTOR TO APERTURE= .01519
INCIDENT Q, KW = 207.55
ABSORP.LOSS, KW = 5.98
CONV.LOSS, KW = 2.77
RAD.LOSS, KW = .75
Q INTO FLUID, KW = 198.04
MAXIMUM THERMAL STRESS, PSI= 15534
TEMP OF FIN, DEG-F= 567
TEMP OF FRONT, DEG-F= 497
TEMP OF BACK, DEG-F= 443
TEMP OIL, AVG, DEG-F= 436
TEMP OIL IN, DEG-F= 420
TEMP OIL OUT, DEG-F= 452
AVG OIL DENSITY, LB/CU-FT= 46.011
AVG OIL VISCOSITY, LB/FT-HR= .718
AVG OIL CONDUCTIVITY, BTU/FT-HR-F= .07013
PANEL FLOW RATE, GPM = 95
PANEL FLOW VELOCITY, FT/SEC= 14.68
PASSAGE FILM COEFFICIENT, BTU/SQ-FT-HR-F= 886.83

TABLE 3.2 RECEIVER ENERGY, KW, BALANCE & EFFICIENCY

PARAMETER	Day 355 (Winter Solstice)			Day 80 (Equinox)			Day 173 (Summer Solstice)		
	8:00	10:00	12:00	8:00	10:00	12:00	8:00	10:00	12:00
Energy Available	10256	12669	13021	10925	12119	12512	9971	11118	11509
Energy Losses:									
1. Aperture	416.8	305.6	239.5	593.0	415.0	327.0	733.8	579.0	495.1
2. Panel Miss	88.6	143.9	164.0	70.8	124.0	146.4	39.6	91.1	113.9
3. Absorptivity	277.2	343.8	353.5	294.1	327.2	338.0	265.9	297.1	307.6
4. Convection	385.2	408.0	411.0	390.5	401.9	405.9	381.0	391.5	395.7
5. Radiation	77.9	88.2	89.7	80.5	85.4	87.2	76.0	80.6	82.1
TOTAL LOSSES	1246	1290	1258	1429	1354	1305	1496	1439	1394
ENERGY TO FLUID	9010	11380	11763	9496	10766	11208	8475	9679	10115
EFFICIENCY, %	87.85	89.82	90.34	86.92	88.83	89.57	85.00	87.05	87.88

39

motor drive electronics, limit switches, and the communications buss to the master control. Each heliostat will receive solar vector cosines, target coordinates and heliostat coordinates. The heliostat coordinates and target coordinates will be down-loaded once per day, the solar vector cosines will be sent periodically.

The processor at each heliostat will recognize mode commands that will cause the heliostat to return to stow positions or to slew to a commanded position. The master control can also interrogate each heliostat as to the status of its limit switches and position registers.

The master control will communicate to the heliostats on a serial data buss with a maximum of 64 heliostats on each buss. The communications will be a duplex data transmission at the rate of approximately 9600 baud.

The output of the master control computer will be buffered so that the data can be transmitted on 6 separate data busses to a maximum of 6x64 heliostats. If redundancy is a requirement, the data will be transmitted on separate lines.

The drive for the stepper motors will consist of solid state power switches in each of the four motor legs (see figure 3.10). The processor will drive the motor through the step sequence shown in figure 3.11. The motor will be powered down by going into the sleep mode. Sufficient friction in the system will provide the holding torque during the sleep mode.

The microprocessor system is shown in figure 3.12 and consists of a 6504 CPU, 6522 versatile interface adapter, 6532 RAM/timer I=O and 4K ROM chip. The CPU outputs stepper motor commands to the 6532 I=O ports. Eight ports are required to control the two stepper motors. The outputs of the 6532 are buffered and amplified to switch the stepper motor windings.





Figure 3.10 Stepper Motor Driver Diagram

<u>STEP</u>	<u>SW 1</u>	<u>SW 2</u>	<u>SW 3</u>	<u>SW 4</u>
1	ON	OFF	ON	OFF
2	ON	OFF	OFF	ON
3	OFF	ON	OFF	ON
4	OFF	ON	ON	OFF

Figure 3.11 Logic Switching Sequence



42

Figure 3.12 Block Diagram — Control Electronics

Limit switches are read by the 6522 and the data put into the 6532 RAM. Each electronics unit is equipped with dip switches that identify the address of the unit to the master control.

These switch inputs are also read by the 6522. Serial communications is handled by two ports on the 6522 that are used for incoming data. One port is an interrupt input for the 6522 and the other is a data input port. The interrupt port detects the start bit of the data word and the actual data is read from the data port. The outgoing status data comes from another data line of the 6522. The software for the communications is interrupt driven so that calculations can be accomplished while data is being received. Internal timers in the 6522 allow hardware timing during the communications process.


4. SYSTEM PERFORMANCE

As discussed in Section 3, the design point was established to be a system that would deliver to the existing system $9,518 \text{ KW}_t$ at noon, summer solstice. This effectively supplies all the plant's process heat requirements except the heat, furnished by other sources, that would be wasted if additional heat was supplied by solar. Using this criteria for system rating, the collector field was sized at 320 heliostats.

The stairstep energy accounting technique was used to establish the solar system performance at noon on winter solstice, spring equinox, and summer solstice (design point). These energy stairsteps are presented in Figure 4.1. The average annual energy delivered is 94.56×10^9 Btu which is approximately 33% of the annual amount (285×10^9) furnished by the fired heaters.


These energy stairsteps are preliminary to the extent that the conceptual design of the receiver and the actual piping layout and sizing has not been completed, hence, the cycle efficiencies for these components are subject to change as the design progresses.

Profiles of the flux incident on the target plane and on the receiver surface (cavity - 24 ft. radius) have been calculated. These profiles were calculated for morning, noon and afternoon times at the summer and winter solstices and the spring equinox. Examples of the flux profiles calculated for noon, summer solstice are presented in graphic form in Figure 4.2. The profiles are being employed in the design and evaluation of the receiver.



[1] - NET CYCLE EFFICIENCY AT EACH POINT [2] - EFFICIENCY OF EACH CONVERSION STEP

Figure 4.1 PROCESS HEAT STAIRSTEPS FOR NOON ON WINTER, EQUINOX AND SUMMER SOLSTICES



VERTICAL FEET
ON TARGET PLANE

HORIZONTAL FEET
ON TARGET PLANE




Figure 4.2 ENERGY FLUX PROFILES INCIDENT ON THE TARGET PLANE AND RECEIVER AT THE NOON, SUMMER SOLSTICE DESIGN POINT