

1097

GENERAL ELECTRIC

SPACE DIVISION
PHILADELPHIA

PIR NO.	STEP	OPERATION	PROGRAM	SEQUENCE NO.	REV. LTR.
			PHIV	270	
*USE "C" FOR CLASSIFIED AND "U" FOR UNCLASSIFIED					

PROGRAM INFORMATION REQUEST / RELEASE

FROM E. Kelly	TO A. J. Poché		
DATE SENT 11/19/79	DATE INFO. REQUIRED	PROJECT AND REQ. NO.	REFERENCE DIR. NO.

SUBJECT
EXTENDED COLUMN THERMAL ENERGY STORAGE TEST RESULTS

INFORMATION REQUESTED/RELEASED

Attached are the results of the tests run at the G.E. Evendale Plant using a 100 inch long thermal energy storage bed with SylthermTM 800 fluid and Hanna Mining Company iron ore pellets as the storage media.

The report is sectioned as follows:

1. Summary
2. Introduction
3. Description of Test Setup
4. Test Program
- 5.0 Static and Dynamic Holdup and Void Fraction
- 5.1 Charging Tests
- 5.2 Discharging Tests
- 5.3 Holding Tests
- 5.4 Inversion Test
- 5.5 Heat Transfer Coefficients
- 5.6 Fluid Distributor
- 5.7 Conclusions

Appendix A - Syltherm Properties

RETURN TO:
SCOTT FAAS

Copies To: W. Mertz J. Bledsoe A. Saydah R. Laessig R. Allred V. Haley	PAGE NO. OF	RETENTION REQUIREMENTS	
		COPIES FOR	MASTERS FOR
		<input type="checkbox"/> 1 MOS.	<input type="checkbox"/> 3 MOS.
		<input type="checkbox"/> 3 MOS.	<input type="checkbox"/> 6 MOS.
		<input type="checkbox"/> 6 MOS.	<input type="checkbox"/> 12 MOS.
		<input type="checkbox"/> MOS.	<input type="checkbox"/> MOS.
		<input type="checkbox"/>	<input type="checkbox"/> DO NOT

1. Summary

An experiment has been performed at the General Electric Evendale Plant to gain knowledge of the performance of high temperature trickle mode thermal energy storage using a silicone oil as the working fluid. The incentive for considering trickle operation in a large system is the minimization of fluid inventory since high temperature heat transfer fluid costs are typically \$20 per gallon.

The test program included measurement of static and dynamic fluid hold-ups, axial and radial temperature distributions during charging and discharging, holding tests and an inversion test.

Dow-Corning SylthermTM 800 was the working fluid; the storage material was Hanna Mines iron ore with a primary particle size of 3/8". The test temperature range was 350^oF (177^oC) to 450^oF (232^oC) whereas the actual system will operate at 500^oF (260^oC) to 750^oF (399^oC). Test flow rates were chosen to cover the range of the Reynolds number of the full scale system, 1.8 to 28.1 for fluid dynamic and thermal simulation.

The storage bed was 22.5 inches in diameter and 100 inches deep, with a void fraction of 40%.

Analysis of the data showed good agreement of static and dynamic hold-up with correlations available in the literature. Static holdups in the range of 5 to 8% of bed volume are predicted for the full scale system. Dynamic holdups in the range of 2 to 10% are projected.

Charge/discharge data shows that large radial temperature gradients develop during initial charging, but go through a maximum and then diminish as charging/discharging proceeds. For the Shenandoah STEP program, series charging and

discharging will be used, consequently, these gradients will persist only at the bottom of the last tank. From the data analysis, in conjunction with a computer model, effective heat transfer coefficients in the range of 15 to 25 BTU/Ft²hr⁰F were deduced over the flow rate range from 550 to 2400 lbs/Ft²hr. The tests showed the adequacy of the model to predict average thermocline shapes over the primary flow range of the full scale system, when the model heat transfer coefficient is reduced by a factor of 4. A previous test in a 28-inch long column, using water/glycerine solution as the fluid had indicated a reduction factor of eleven was needed. The sensitivity of charge/discharge efficiency to the heat transfer is not great; e.g., a reduction factor of 4 results in an 83% charge while a factor of 8 results in a 79% charge in the last large tank.

Holding test results indicate that serious distortion of the thermoclines will not occur in the full scale system with tanks of 10 to 20 feet in diameter.

The inversion test (moving the hot zone from the top to the bottom of the bed), showed that this process, although only of secondary importance in the full scale system, is feasible.

Difficulties in the test, which made analysis of the data less rigorous than desired, were primarily due to inlet fluid distributor problems, heat losses in the fluid exit line, and an insufficient batch fluid inventory to achieve full charges and discharges.

The overall conclusion is that the trickle mode of operation has a high probability of meeting the primary goals of the full scale system.

2. Introduction

The incentive for trickle mode operation is the reduction in fluid inventory required in comparison to dual media operation where the bed is completely filled with fluid. This is a significant consideration with high temperature heat transfer fluid costs at \$20 per gallon.

The choice of fluids for high temperature operation is extremely limited and silicone oil was judged to offer the best potential for the STEP system. No data existed in the literature for high temperature silicone oil trickle mode operation. In order to confirm feasibility, an experiment was designed to obtain data in a small scale system. Of primary interest were the shapes of the thermoclines in the charging and discharging modes, along with void fraction measurement, static and dynamic fluid holdups, holding, and inversion (moving the hot zone of a partially charged bed from the top to the bottom of the bed). The comparison of measured thermocline shapes with a computer model would enable evaluation of effective heat transfer coefficients which would be used to size and predict the performance of the full scale system with a higher degree of confidence.

A previous test had been run on a short bed (28 inches deep) using a water/glycerine solution to simulate the viscosity of the silicone oil. This test was run over a temperature range of 80^oF (27^oC) to 180^oF (82^oC) with granite rock particles of large and irregular shapes (characteristic dimensions 3/8" to 1"). To match measured thermocline shapes with the model, the theoretical heat transfer coefficient as calculated in the model had to be reduced by a factor of 11. The short length of the bed did not allow

fully developed thermoclines to be established and in addition the large and irregular shaped particles were thought to have contributed to poor wetting with reduced heat transfer and channeling. Post test inspection of the fluid distributor showed clogging of some outlet holes which affected initial fluid distribution. In addition, a holding test of a partially discharged bed showed extreme distortion of the thermocline.

Because of the empirical inconclusiveness of these tests a second test described herein was designed. This test included the following changes and characteristics: 1) the column height was extended from 28 inches to 100 inches to allow measurement of full thermocline shape development as it proceeded through the bed, 2) spheroidal iron ore particles (3/8" diameter) as bed material (Granite was eliminated because compatibility tests showed high fluid degradation rates), 3) SylthermTM 800 silicone oil as the working fluid. It was recognized that fluid viscosity matching might not be sufficient, particularly as related to the question of fluid foaming which could reduce heat transfer rates. The surface tension of the fluid is believed to be an important parameter with regard to foaming. Consequently, the actual working fluid was used in these tests. The test temperature range was 350⁰F (177⁰C) to 450⁰F (232⁰C) compared to the actual system range of 500⁰F (260⁰C) to 750⁰F (399⁰C). Existing equipment limitations, schedules and costs precluded operation at 500⁰F to 750⁰F. It was judged that this range would provide an acceptable degree of simulation of fluid dynamics and heat transfer characteristics so that fitting the model to test data at these temperatures would not result in significant error when the model was

used for full scale predictions. (See Appendix A for SylthermTM 800 properties as a function of temperature.)

Other changes included a redesign of the fluid distributor with the intent of obtaining a more uniform initial distribution, the addition of view ports at the top and bottom of the bed, re-design of the column support structure and insulation to control heat losses, and the use of a higher speed (13 channels per second) data acquisition system.

Table 1 summarizes the general operating conditions of the Phase 3 conceptual tests, the phase 4 extended column test and the STEP field installation.

TABLE 1

COMPARISON OF THE GENERAL OPERATING CONDITIONS OF THE TRICKLE OIL TES TESTS WITH THE SHENANDOAH FIELD APPLICATION

	<u>Trickle Oil TES Tests</u>		
	<u>Phase III Conceptual Test</u>	<u>Phase IV Extended Column Test</u>	<u>STEP Shenandoah * Design</u>
Heat Transfer Fluid	Water	S-800	S-800
Heat Storage Media	Granite	Iron Ore	Iron Ore
Temperature Range	80-180 ⁰ F	350-450 ⁰ F	500-750 ⁰ F
Bed Height	28 in	100 in.	192 in. large 144 in. small
Cover Gas	N ₂ (0 and 1 psig)	N ₂ (5 psig and 1 psig)	N ₂ (10 psig)

* Original 140 X 10⁶ BTU design, 60 X 10⁶ BTU System

Predictions not included in this report.

3. Description of Extended Column Test Setup

A 100-inch high iron ore column, 22-1/2" diameter was used with SylthermTM 800 oil in the temperature range for 350^oF to 450^oF at flows between 0.9 and 17.2 gpm.

Iron ore pellets approximately 3/8" in diameter were supported on a screen inside a 3 section stainless steel tank. The temperature profile of the bed was measured using sheathed thermocouples inserted into pellets located to provide both axial and radial data. The axial profile was measured along the column centerline at 2-inch intervals throughout the 100-inch depth. Radial profiles were measured on five selected planes.

Charging-discharging tests were accomplished by pre-establishing the desired temperature of a fixed inventory of oil and then pumping that oil through the ore tank. Separate source and sink tanks are used. By utilizing separate source and sink tanks, the need for a fast response facility temperature regulation system was eliminated.

Two centrifugal pumps were used in the test setup. One pump transferred oil from the source or sink tank to the fluid distributor at the top of the thermal storage tank. The second pump scavenged the oil from the bottom of the thermal storage tank and pumped it to the desired sink or source tank.

Both pumps are constant speed devices. The variable flow rates required for testing was achieved by "by-pass" regulation wherein part of the pump outlet flow was allowed to by-pass back to the pump inlet through an adjustable control valve.

Stainless steel (304) was used for the external storage tank, the source

and sink tanks and several other components but plain carbon was used extensively for piping, valves, etc. (The Shenandoah setup will use plain carbon steel almost exclusively).

The source and the sink tanks are actually a set of three 100 gal. tanks connected in parallel. Each of the three 100 gal. hot (source) tanks is equipped with clamp-around drum heaters with thermostatic controls to maintain a 450⁰F environment around the tanks, minimize heat losses, and achieve a nearly constant source temperature. The three "cold" tanks were not equipped with clamp-around drum heaters since in general their function was to cool the oil prior to a "discharge" run. All tanks and piping were insulated.

Two parallel electric immersion heaters each rated at 6 KW are the means by which circulating oil was heated prior to a test run.

Fluid flow in and out of the thermal storage tank was measured with turbine type flow meters. The fluid flows and all temperatures are automatically recorded using an Acurex A-900 Data Logger. A magnetic tape cassette recording capability enabled data acquisition at approximately 13 channels/second and the use of a digital computer for fast, accurate and versatile data reduction and evaluation.

A nitrogen cover gas was used at all interior locations. The pressure level was established at approximately 5 psi by a nitrogen regulating valve connected through the ore tank. Vapor boil off below 450⁰F was expected to be minimal and elaborate fluid pre-conditioning was not required.

Table 2 summarizes the significant thermal/mechanical characteristics of the extended column test.

Figure 1 (Dwg. No. 147D4026) shows the test setup flow schematic, detailing all valves, piping, gage locations, etc. By appropriate valve manipulation, various flow loops and paths required for the test (reference Table 3) were achieved.

Figure 2 is the top level assembly drawing for the test setup. The parts list defines all sub-tier drawings and equipment. Some features of the setup are:

An angle iron structure supports six 100 gallon tanks utilized for fluid storage. A separate structure supports the ore tank and provides a mid-height walk-on level.

The ore tank is supported at mid-flange location with 4 point structural contact in an effort to minimize heat conduction losses from the rock tank.

All tanks and pipes are insulated to control thermal loss. Filters have been installed at appropriate locations to prevent particulate matter from plugging critical flow paths.

Welded pipe joints were utilized as much as possible to avoid leakage problems with SylthermTM 800.

Figure 3 (Dwg. No. 147D4020) shows details of the fluid distribution manifold. It was intended to uniformly distribute the fluid over the upper cross sectional area of the tank. The manifold consists of five concentric circular tubes with 0.043 inch diameter holes drilled on the side facing the

TABLE 1

THERMAL CHARACTERISTICS OF TES EXTENDED COLUMN TEST SET-UP

Thermal Storage

Storage Media	Hanna Mines Iron Ore Pellets
Characteristic Diameter	3/8" dia.
Bulk Density	137.1 lb/ft ³
Specific Heat @ 350,400,450 ^o F	0.2 Btu/lb- ^o F
Pounds - Mass in Tank	3154 lbs.
Tank Weight (Total)	915 lbs.
Distributor System Wt.	122 lbs.
Upper Section Wt.	243 lbs.
Middle Section Wt.	187 lbs.
Bottom Section Wt.	363 lbs.
Tank Material	304 SS
Specific Heat	.11 Btu/lb- ^o F

Fluid System

Fluid	Syltherm 800
Viscosity at 400 ^o F	1 CP = 2.5 lb/ft-hr
Density @ 400 ^o F	48 lb/ft ³
Specific Heat @ 400 ^o F	0.46 Btu/lb- ^o F
Oil Inventory	1730 lbs. (270) gallons
Hot Tank System	
Number of Tanks in Set	3 each
Individual Tank Capacity	100 gallons
Individual Tank Material	304 SS
Individual Tank Wt.	280 lbs.
Individual Tank Specific Heat	.11 Btu/lb- ^o F

TABLE 1 (CONT'D.)

Individual Tank I.D. x Ht.	22.5" x 40"
Total Capacity	300 gallons
Total Weight	840 lbs
Cold Tank System	
Identical to Hot Tank System	
Pumps (Inlet & Scavenge Pump Identical)	Burks Turbine Pump
Rated Flow/Pressure (H ₂ O)	20 gpm/200 ft.
Max. Recommended Operating Temp.	550 ^o F
NPSH (estimated)	2 ft.
Drive HP/Speed	3 HP/3450 RPM
In-line Heaters (Two in Parallel)	Chromalox
Each Heater Rated Capacity	6 KW
Thermal Density	13 watts/in ²
Design Range	150-550 ^o F
Cooler Heat Exchanger	Graham
Shell Side Fluid/Pressure	H ₂ O/100 psi
Tube Side Fluid/Tube Dia.	Syltherm TM 800/0.5 inch
Heat Transfer Surface Area	9.63 ft ²

thermal storage bed. At 17 gpm the pressure head required at the shower inlet is 35 ft. of water (14.4 psi).

The major components and other system elements which make up the assembly are listed as follows:

Tanks. Six 100-gallon, Type 304 SS tanks detailed in Drawing No. 12808633.

Pumps. One circulating pump, and a scavenge pump. Both Burks Co. Model 330CS8MJ close coupled turbine pumps. 3 HP, 3450 RPM, 3 phase, 20 gpm at 200 ft. head, water jacketed mechanical face seal designed for 550⁰F maximum fluid temperature.

Tank Heaters. Three Drum Tec Co. Model VHDR-55-460-3, 3.2 KW, 460 volts, 3 phase, 55 gal. drum heaters with 100⁰-450⁰F thermostat. Will cover only lower part of tank.

Circulation Heaters. Two Chromalox Co. Cat. No. MWH0-30615, 6.0 KW, 480 volts, 3 phase watt density 13 watts/in², with 150⁰-550⁰F thermostat.

Cooler Heat Exchanger. Graham Manufacturing Co., Heliflow Model 5X4C-14S, 1/2 inch Type 304 SS tubes, 9.63 ft² surface area, cast iron shell 100 psi rating (water side).

Flow Meters. Two Flow Technology Inc., Turbine Type Model FT-8N10-LB, 1-10 gpm max, fluid temp. 450⁰F. Two Model FT-12N20-LB, 2-20 gpm max, fluid temp. 450⁰F. Model PRI-102A frequency to analog converter. Cox Model 950-D-A converter.

Valves. Gate-Vogt Model SW-12111 with socket weld connections, forged steel, max. temp. 850⁰F. Glove-Vogt Model SW-12141 with socket weld connections, forged steel. Max. Temp. 850⁰F.

Filter. Two 100 μ filter elements, CUNO Model 2710-150 with AEP shop supplied S/S casings.

Piping. 3/4", 1", 1-1/2" Sch. 40, black steel with forged steel socket weld fittings.

Insulation.

Oil Tanks - Celotamp 1500 block for base, 4 inch thick; Type ETR Forty-Eight blankets on both sides and top 4 inch thick. Finish with 1 inch thick aluminum covered Armstrong "Rig-Flex."

Pipeline - Jim Micro-Lok Fiber Glass, 2 inch thick

Fittings - ETR Forty-Eight 2 inch thick covered with Textoglass cloth

Thermal Storage - ETR Forty-Eight 8 inch thick, with 1 inch thick Armstrong "Rig-Flex" on the outside.

Fluid. 270 gallons of SylthermTM 800 (Dow Corning experimental fluid X2-1162).

Instrumentation

This section presents the instrumentation details for the extended column test setup.

An Acurex Autodata Logger Model A900 was utilized to record key HTS tank data. This recorder (with its auxiliaries) has the capability of scanning up to 140 input channels and printing the value of each channel on a paper tape at 2.5 channels/second. The A932-01 serial output interface provided an ASCII formatted serial output and enabled storage on a GE Magnetic Tape Terminal (MTT) cassette recorder. The logger records the following parameters:

Temperature

- Thermal storage tank inlet and outlet fluid temperature
- 88 temperatures in the iron ore bed

Flow

- Thermal storage tank inlet flow rate
- Thermal storage tank outlet flow rate

The Temperature readings associated with the tank were determined from Type T (copper constantan) sheathed thermocouples located in the iron ore bed along the axial centerline and radially at the five selected sections. Figure 4 (Dwg. No. 707E931) shows the mechanical design of the tank and identifies the thermocouple locations in the test bed as does Figure 4-A.

Figure 5 shows an instrumentation schematic diagram for the overall test setup and indicates the temperature and flow recording and monitoring equipment.

Due to the wide range of test flow requirements (.9 to 17.2 gpm) two overlapping flowmeters (in parallel) were used. Flow Technology Turbine Type Model FT-8N10-LB meter covers the 1-10 gpm range, while a Model FT-12N20-LB meter can measure flows up to 20 gpm. This is done at both the inlet and outlet of the storage tank. The flowmeters were calibrated with a fluid having a viscosity similar to SylthermTM 800 at 400°F.

Strip Chart Recorders and Additional Temperature Instrumentation

Thermal storage tank inlet and outlet flow and temperature were recorded on separate single channel strip charts (Elektronik Model 19 recorders). These charts were used to monitor the test progress and were useful for indicating break-out conditions.


Thirty (30) additional Type K T/C's were used primarily for control of the test and to provide test bed heat loss and other related data.

Pressure Instrumentation

Pressure gages required for control of the facility were located throughout the facility and were not included in the automatic data logging system. The following list identifies the gages required.

LIST OF FACILITY PRESSURE GAGES

P1	Circulation Pump Inlet Pressure
P2	Circulation Pump Discharge
P3	N ₂ Cover Gas Pressure
P4	Scavenge Pump Inlet Pressure
P5	Scavenge Pump Discharge
ΔP1	Flow Distributor to Rock Tank Diff. Press.
ΔP2	Filter ΔP



REVISIONS				
ZONE	LTN	DESCRIPTION	DATE	APPROVED
A		DESIGN CHANGES	11/27/78	GAJ

BURKE TURBINE PUMP 17 GPM @ 200' HD # 330CSBMJ (CIRCULATION PUMP)

Hx GRAHAM HELIFLOW HEAT EXCHANGER

BURKE TURBINE PUMP 17 GPM @ 200' HD # 330CSBMJ (SCAVENGE PUMP)

* INDICATES GLOBE VALVES

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES - TOLERANCES ON:	ALL
3-PLACE DECIMALS ±	FRAC.
ANGLES ±	
MATERIAL	

DESIGNED	BY	DATE
P. ELLIS	A. S. 78	
PR. PFL.	24. 8. 78	
CHK. H. H.	24. 8. 78	

GENERAL ELECTRIC AEP MIL. EVENDALE OHIO	
SCHEMATIC	
3X HEAT STORAGE TANK	
SIZE	CODE IDENT NO.
D	17237 147D4026
SCALE	NGNE
	SHEET

147D4026	707E933 G1
IDENT N°	NEXT ASSY

FIGURE 1

APPENDIX A

SYLTHERM™ PROPERTIES

750°F	μ = .6292 lb/Fthr	450°F	μ = 1.98
	ρ = 37.02 lbs/Ft ³ (.593 gm/cc)		ρ = 47 (.753 gm/cc)
	k = .06375 BTU/Fthr°F		k = .070
	C _p = .525 BTU/lb°F		C _p = .465
	P _r = 5.18		P _r = 13.75
	σ = 3.5 dyne/cm		σ = 9.4 dyne/cm
500°F	μ = 1.585	350°F	μ = 3.27
	ρ = 45.26 (.725 gm/cc)		= 50 (.801 gm/cc)
	k = .0691		k = .0718
	C _p = .475		C _p = .445
	P _r = 10.9		P _r = 20.27
	σ = 8 dyne/cm		σ = 12 dyne/cm
625°F	μ = .97	400°F	μ = 2.52
	ρ = 41.2 (.66 gm/cc)		ρ = 48.4 (.775 gm/cc)
	k = .0668		k = .0709
	C _p = .50		C _p = .455
	P _r = 7.33		P _r = 16.17
	σ = 5.5 dyne/cm		σ = 10.6 dyne/cm
Room Temp.	μ = 21.8 lb/Fthr		
	ρ = 58.3 lbs/Ft ³ (.934 gm/cc)		
	k = .078		
	C _p = .395		
	P _r = 110.4		
	σ = 20 dyne/cm		

REV NO. 1

TITLE

295A8040

REQUIREMENTS FOR STEAM GENERATOR UNIT

CONT ON SHEET 5

SH NO. 4

FIRST MADE FOR STE-LSE

REVISIONS

OPERATION

Steam Generator operating ranges, limits, setpoints, and setpoint tolerances are as follows:

- a. Steam Flow 0 - 10500 lb/hr
- b. Steam Temperature (Superheated Mode) 720°F (+25°, - 70°)
- c. Steam Pressure Setpoint/ Tolerance (Saturated Mode) 700 psig/ ± 2 psig
- d. Steam Pressure Setpoint/ Tolerance (Saturated Mode) 110 psig/ ± 2 psig
- e. Steam Purity 99.5%
- f. Maximum total solids carryover 1ppm
- g. S-800 Inlet Pressure 50 psig { + 15
- 5
- h. S-800 Inlet Temp. 685° - 750°F
- i. S-800 Outlet Temp. 475°-525°F.
- j. S-800 ΔT 200°F Minimum
- k. S-800 Pressure Drop 12 psi Max.
- l. Feedwater Inlet Temp. 338°F + 4°F
- m. Feedwater Inlet Pres. 850 psig (max)
- n. Blowdown Flow 1-5% of Feedwater Flow (+ 1/4%)
- o. Blowdown Water Discharge Temp. 80°F. (max)
- p. Flash Tank Operating Pressure 105 psig + 5
- q. Shell Side Fouling Resistance .001 Water/.0005 Steam (max)
- r. Tube Side Fouling Resistance .001 (max)
- s. Tube Side Design Pres./Temp 150 psig/750°F
- t. Shell Side Design Pres./ Temp. Preheater & Steam Generator 750 psig/550°F
- u. Superheater. 750 psig/750°F
- Nitrogen Supply Pressure 1-5 psig

2.2.2 PHYSICAL

All components comprising the steam generating unit shall be mounted on a common steel skid base. Maximum envelope dimensions are 20'L x 10'H x 4'W. S-800 valves shall be mounted with stems horizontal to prevent leakage from soaking into insulation.

7/11/79 PCER
1 INC EWA 79-07-110 LSE

STE/PC
PRINTS TO

MADE BY R. ALLRED/A. SCHNACKE

APPROVALS

AEP

DIV OR DEPT.

295A8040

ISSUED

PHILA, PA

LOCATION

CONT ON SHEET 5

SH NO. 4

REV NO. 1

TITLE

295A8040

REQUIREMENTS FOR STEAM GENERATOR UNIT

CONT ON SHEET 5

SH NO. 4

FIRST MADE FOR STE-LSE

REVISIONS

OPERATION

Steam Generator operating ranges, limits, setpoints, and setpoint tolerances are as follows:

- a. Steam Flow 0 - 10500 lb/hr
- b. Steam Temperature (Superheated Mode) 720°F (+25°, - 70°)
- c. Steam Pressure Setpoint/ Tolerance (Saturated Mode) 700 psig/ ± 2 psig
- d. Steam Pressure Setpoint/ Tolerance (Saturated Mode) 110 psig/ ± 2 psig
- e. Steam Purity 99.5%
- f. Maximum total solids carryover 1ppm
- g. S-800 Inlet Pressure 50 psig { + 15
- 5
- h. S-800 Inlet Temp. 685° - 750°F
- i. S-800 Outlet Temp. 475°-525°F.
- j. S-800 ΔT 200°F Minimum
- k. S-800 Pressure Drop 12 psi Max.
- l. Feedwater Inlet Temp. 338°F + 4°F
- m. Feedwater Inlet Pres. 850 psig (max)
- n. Blowdown Flow 1-5% of Feedwater Flow (+ 1/4%)
- o. Blowdown Water Discharge Temp. 80°F. (max)
- p. Flash Tank Operating Pressure 105 psig + 5
- q. Shell Side Fouling Resistance .001 Water/.0005 Steam (max)
- r. Tube Side Fouling Resistance .001 (max)
- s. Tube Side Design Pres./Temp 150 psig/750°F
- t. Shell Side Design Pres./ Temp. Preheater & Steam Generator 750 psig/550°F
- u. Superheater. 750 psig/750°F
- Nitrogen Supply Pressure 1-5 psig

2.2.2 PHYSICAL

All components comprising the steam generating unit shall be mounted on a common steel skid base. Maximum envelope dimensions are 20'L x 10'H x 4'W. S-800 valves shall be mounted with stems horizontal to prevent leakage from soaking into insulation.

7/11/79 PCER
1 INC EWA 79-07-110 LSE


STE/PC-
PRINTS

MADE BY
R. ALLRED/A. SCHNACKE
ISSUED


APPROVALS

AEP
PHILA, PA

DIV OR DEPT. 295A8040
LOCATION CONT ON SHEET 5 SH NO. 4
CODE IDENT NO.



REV.	DATE	DESCRIPTION	BY	APP.
1	1/14/51	ISSUED FOR FABRICATION	J. J.
2	1/14/51	REVISIONS	J. J.
3	1/14/51	REVISIONS	J. J.
4	1/14/51	REVISIONS	J. J.



ITEM NO.	DESCRIPTION	QUANTITY	UNIT
1	ACQUICEL 2" x 2" SINOQ	304	SIT F
2	TACONITE	304	SHOULDR
3	THERMOCOUPLES 18 1/2"	317	SIT
4	THERMOCOUPLES 18 1/2"	317	SIT
5	PIPE RING 1/2" DIA.	204	SIT
6	MALE COUPLINGS 1/2" DIA.	204	SIT
7	FLAT WASHERS 1/2"	204	SIT
8	FLAT WASHERS 1/2"	204	SIT
9	FLAT WASHERS 1/2"	204	SIT
10	FLAT WASHERS 1/2"	204	SIT
11	FLAT WASHERS 1/2"	204	SIT
12	FLAT WASHERS 1/2"	204	SIT
13	FLAT WASHERS 1/2"	204	SIT
14	FLAT WASHERS 1/2"	204	SIT
15	FLAT WASHERS 1/2"	204	SIT
16	FLAT WASHERS 1/2"	204	SIT
17	FLAT WASHERS 1/2"	204	SIT
18	FLAT WASHERS 1/2"	204	SIT
19	FLAT WASHERS 1/2"	204	SIT
20	FLAT WASHERS 1/2"	204	SIT
21	FLAT WASHERS 1/2"	204	SIT
22	FLAT WASHERS 1/2"	204	SIT
23	FLAT WASHERS 1/2"	204	SIT
24	FLAT WASHERS 1/2"	204	SIT
25	FLAT WASHERS 1/2"	204	SIT
26	FLAT WASHERS 1/2"	204	SIT
27	FLAT WASHERS 1/2"	204	SIT
28	FLAT WASHERS 1/2"	204	SIT
29	FLAT WASHERS 1/2"	204	SIT
30	FLAT WASHERS 1/2"	204	SIT
31	FLAT WASHERS 1/2"	204	SIT
32	FLAT WASHERS 1/2"	204	SIT
33	FLAT WASHERS 1/2"	204	SIT
34	FLAT WASHERS 1/2"	204	SIT
35	FLAT WASHERS 1/2"	204	SIT
36	FLAT WASHERS 1/2"	204	SIT
37	FLAT WASHERS 1/2"	204	SIT
38	FLAT WASHERS 1/2"	204	SIT
39	FLAT WASHERS 1/2"	204	SIT
40	FLAT WASHERS 1/2"	204	SIT
41	FLAT WASHERS 1/2"	204	SIT
42	FLAT WASHERS 1/2"	204	SIT
43	FLAT WASHERS 1/2"	204	SIT
44	FLAT WASHERS 1/2"	204	SIT
45	FLAT WASHERS 1/2"	204	SIT
46	FLAT WASHERS 1/2"	204	SIT
47	FLAT WASHERS 1/2"	204	SIT
48	FLAT WASHERS 1/2"	204	SIT
49	FLAT WASHERS 1/2"	204	SIT
50	FLAT WASHERS 1/2"	204	SIT
51	FLAT WASHERS 1/2"	204	SIT
52	FLAT WASHERS 1/2"	204	SIT
53	FLAT WASHERS 1/2"	204	SIT
54	FLAT WASHERS 1/2"	204	SIT
55	FLAT WASHERS 1/2"	204	SIT
56	FLAT WASHERS 1/2"	204	SIT
57	FLAT WASHERS 1/2"	204	SIT
58	FLAT WASHERS 1/2"	204	SIT
59	FLAT WASHERS 1/2"	204	SIT
60	FLAT WASHERS 1/2"	204	SIT
61	FLAT WASHERS 1/2"	204	SIT
62	FLAT WASHERS 1/2"	204	SIT
63	FLAT WASHERS 1/2"	204	SIT
64	FLAT WASHERS 1/2"	204	SIT
65	FLAT WASHERS 1/2"	204	SIT
66	FLAT WASHERS 1/2"	204	SIT
67	FLAT WASHERS 1/2"	204	SIT
68	FLAT WASHERS 1/2"	204	SIT
69	FLAT WASHERS 1/2"	204	SIT
70	FLAT WASHERS 1/2"	204	SIT
71	FLAT WASHERS 1/2"	204	SIT
72	FLAT WASHERS 1/2"	204	SIT
73	FLAT WASHERS 1/2"	204	SIT
74	FLAT WASHERS 1/2"	204	SIT
75	FLAT WASHERS 1/2"	204	SIT
76	FLAT WASHERS 1/2"	204	SIT
77	FLAT WASHERS 1/2"	204	SIT
78	FLAT WASHERS 1/2"	204	SIT
79	FLAT WASHERS 1/2"	204	SIT
80	FLAT WASHERS 1/2"	204	SIT
81	FLAT WASHERS 1/2"	204	SIT
82	FLAT WASHERS 1/2"	204	SIT
83	FLAT WASHERS 1/2"	204	SIT
84	FLAT WASHERS 1/2"	204	SIT
85	FLAT WASHERS 1/2"	204	SIT
86	FLAT WASHERS 1/2"	204	SIT
87	FLAT WASHERS 1/2"	204	SIT
88	FLAT WASHERS 1/2"	204	SIT
89	FLAT WASHERS 1/2"	204	SIT
90	FLAT WASHERS 1/2"	204	SIT
91	FLAT WASHERS 1/2"	204	SIT
92	FLAT WASHERS 1/2"	204	SIT
93	FLAT WASHERS 1/2"	204	SIT
94	FLAT WASHERS 1/2"	204	SIT
95	FLAT WASHERS 1/2"	204	SIT
96	FLAT WASHERS 1/2"	204	SIT
97	FLAT WASHERS 1/2"	204	SIT
98	FLAT WASHERS 1/2"	204	SIT
99	FLAT WASHERS 1/2"	204	SIT
100	FLAT WASHERS 1/2"	204	SIT

- F-FLOWLINE CORP., NEW CASTLE, PA. OR EQUAL
- E-ERNST GAGE CO., 250 SO. LIVINGSTON AVE., LIVINGSTON, N.J.
- D-SWAGelok CRAWFORD FITTING CO., 29500 SOLON RD., CLEVELAND, OHIO
- C-MICHELAN WIRE CLOTH DIV. OF MICHIGAN-DYNAMICS, INC., 2100 HOWARD ST., DETROIT, MICHIGAN
- B-McMASTER-CARR SUPPLY CO., CHICAGO, ILL. OR EQUAL
- A-BRIGHTON CORP., 11811 MOSTELLER RD. CINTI, OHIO
- FURNISHED BY DEV. ENG.

ITEM NO.	DESCRIPTION	QUANTITY	UNIT
1	ACQUICEL 2" x 2" SINOQ	304	SIT F
2	TACONITE	304	SHOULDR
3	THERMOCOUPLES 18 1/2"	317	SIT
4	THERMOCOUPLES 18 1/2"	317	SIT
5	PIPE RING 1/2" DIA.	204	SIT
6	MALE COUPLINGS 1/2" DIA.	204	SIT
7	FLAT WASHERS 1/2"	204	SIT
8	FLAT WASHERS 1/2"	204	SIT
9	FLAT WASHERS 1/2"	204	SIT
10	FLAT WASHERS 1/2"	204	SIT
11	FLAT WASHERS 1/2"	204	SIT
12	FLAT WASHERS 1/2"	204	SIT
13	FLAT WASHERS 1/2"	204	SIT
14	FLAT WASHERS 1/2"	204	SIT
15	FLAT WASHERS 1/2"	204	SIT
16	FLAT WASHERS 1/2"	204	SIT
17	FLAT WASHERS 1/2"	204	SIT
18	FLAT WASHERS 1/2"	204	SIT
19	FLAT WASHERS 1/2"	204	SIT
20	FLAT WASHERS 1/2"	204	SIT
21	FLAT WASHERS 1/2"	204	SIT
22	FLAT WASHERS 1/2"	204	SIT
23	FLAT WASHERS 1/2"	204	SIT
24	FLAT WASHERS 1/2"	204	SIT
25	FLAT WASHERS 1/2"	204	SIT
26	FLAT WASHERS 1/2"	204	SIT
27	FLAT WASHERS 1/2"	204	SIT
28	FLAT WASHERS 1/2"	204	SIT
29	FLAT WASHERS 1/2"	204	SIT
30	FLAT WASHERS 1/2"	204	SIT
31	FLAT WASHERS 1/2"	204	SIT
32	FLAT WASHERS 1/2"	204	SIT
33	FLAT WASHERS 1/2"	204	SIT
34	FLAT WASHERS 1/2"	204	SIT
35	FLAT WASHERS 1/2"	204	SIT
36	FLAT WASHERS 1/2"	204	SIT
37	FLAT WASHERS 1/2"	204	SIT
38	FLAT WASHERS 1/2"	204	SIT
39	FLAT WASHERS 1/2"	204	SIT
40	FLAT WASHERS 1/2"	204	SIT
41	FLAT WASHERS 1/2"	204	SIT
42	FLAT WASHERS 1/2"	204	SIT
43	FLAT WASHERS 1/2"	204	SIT
44	FLAT WASHERS 1/2"	204	SIT
45	FLAT WASHERS 1/2"	204	SIT
46	FLAT WASHERS 1/2"	204	SIT
47	FLAT WASHERS 1/2"	204	SIT
48	FLAT WASHERS 1/2"	204	SIT
49	FLAT WASHERS 1/2"	204	SIT
50	FLAT WASHERS 1/2"	204	SIT
51	FLAT WASHERS 1/2"	204	SIT
52	FLAT WASHERS 1/2"	204	SIT
53	FLAT WASHERS 1/2"	204	SIT
54	FLAT WASHERS 1/2"	204	SIT
55	FLAT WASHERS 1/2"	204	SIT
56	FLAT WASHERS 1/2"	204	SIT
57	FLAT WASHERS 1/2"	204	SIT
58	FLAT WASHERS 1/2"	204	SIT
59	FLAT WASHERS 1/2"	204	SIT
60	FLAT WASHERS 1/2"	204	SIT
61	FLAT WASHERS 1/2"	204	SIT
62	FLAT WASHERS 1/2"	204	SIT
63	FLAT WASHERS 1/2"	204	SIT
64	FLAT WASHERS 1/2"	204	SIT
65	FLAT WASHERS 1/2"	204	SIT
66	FLAT WASHERS 1/2"	204	SIT
67	FLAT WASHERS 1/2"	204	SIT
68	FLAT WASHERS 1/2"	204	SIT
69	FLAT WASHERS 1/2"	204	SIT
70	FLAT WASHERS 1/2"	204	SIT
71	FLAT WASHERS 1/2"	204	SIT
72	FLAT WASHERS 1/2"	204	SIT
73	FLAT WASHERS 1/2"	204	SIT
74	FLAT WASHERS 1/2"	204	SIT
75	FLAT WASHERS 1/2"	204	SIT
76	FLAT WASHERS 1/2"	204	SIT
77	FLAT WASHERS 1/2"	204	SIT
78	FLAT WASHERS 1/2"	204	SIT
79	FLAT WASHERS 1/2"	204	SIT
80	FLAT WASHERS 1/2"	204	SIT
81	FLAT WASHERS 1/2"	204	SIT
82	FLAT WASHERS 1/2"	204	SIT
83	FLAT WASHERS 1/2"	204	SIT
84	FLAT WASHERS 1/2"	204	SIT
85	FLAT WASHERS 1/2"	204	SIT
86	FLAT WASHERS 1/2"	204	SIT
87	FLAT WASHERS 1/2"	204	SIT
88	FLAT WASHERS 1/2"	204	SIT
89	FLAT WASHERS 1/2"	204	SIT
90	FLAT WASHERS 1/2"	204	SIT
91	FLAT WASHERS 1/2"	204	SIT
92	FLAT WASHERS 1/2"	204	SIT
93	FLAT WASHERS 1/2"	204	SIT
94	FLAT WASHERS 1/2"	204	SIT
95	FLAT WASHERS 1/2"	204	SIT
96	FLAT WASHERS 1/2"	204	SIT
97	FLAT WASHERS 1/2"	204	SIT
98	FLAT WASHERS 1/2"	204	SIT
99	FLAT WASHERS 1/2"	204	SIT
100	FLAT WASHERS 1/2"	204	SIT


ITEM NO.	DESCRIPTION	QUANTITY	UNIT
1	ACQUICEL 2" x 2" SINOQ	304	SIT F
2	TACONITE	304	SHOULDR
3	THERMOCOUPLES 18 1/2"	317	SIT
4	THERMOCOUPLES 18 1/2"	317	SIT
5	PIPE RING 1/2" DIA.	204	SIT
6	MALE COUPLINGS 1/2" DIA.	204	SIT
7	FLAT WASHERS 1/2"	204	SIT
8	FLAT WASHERS 1/2"	204	SIT
9	FLAT WASHERS 1/2"	204	SIT
10	FLAT WASHERS 1/2"	204	SIT
11	FLAT WASHERS 1/2"	204	SIT
12	FLAT WASHERS 1/2"	204	SIT
13	FLAT WASHERS 1/2"	204	SIT
14	FLAT WASHERS 1/2"	204	SIT
15	FLAT WASHERS 1/2"	204	SIT
16	FLAT WASHERS 1/		

FIG. 4A T.C. LOCATIONS IN 5 PLANES


AXIAL LOCATION

↓


1"




25"




50"



75"



99"






Figure 5. Instrumentation Schematic for Extended Column TES Experiment

4. Test Program

The primary objectives of the test were (1) to obtain axial and radial temperature distributions through the bed as a function of time for a range of flow rates to simulate the full scale system, (2) to determine static and dynamic liquid holdups, (3) to obtain temperature distribution during the holding and inversion modes.

To accomplish the best simulation, it was judged that the Reynolds number was the most significant parameter that should be matched. The test flow rates were then selected to cover the Reynolds number range of the full scale system. This matching is shown in Table 1 for the charging and discharging tests. It is also seen from the Table that the Reynold matching combined with the selected operating temperature range provides a good simulation of the heat flux parameter $\left(\frac{MC_p\Delta T}{A}\right)$. From this comparison, the specific points for the planned test program to cover the required range were selected and shown in Table 2. The actual tests deviated only slightly from the plan, as follows: test run #2, the actual flow rate was 4 GPM (determined by recalibration of the flow meter after this test) instead of 3.5 GPM, and the charging temperature was 430⁰F; run #4, the actual flow rate was 17.2 GPM instead of 16.5 GPM (increased to extend the upper range since later inputs indicated flow rates slightly over 400 GPM were possible in the full scale system), the inversion test was run at 8 GPM. In addition full charge and discharges were not achieved because of insufficient fluid capacity in the batch holding tanks. The procedure for the operation is shown in Table 3.

TABLE 1

REYNOLDS NUMBER SUMMARY FOR EXTENDED COLUMN TEST POINTS AT MAX & MIN. STEP FLOW CONDITIONS

Shenandoah STE-LSE				REYNOLDS NUMBER	Extended Column Test				
Flow Rate (gpm)	Inlet Temp. (°F)	Mass Flux lb/hr ft ² M/A	Heat Flux Btu/hr ft ²		Flow Rate (gpm)	Inlet Temp. (°F)	Mass Flux lb/hr ft ² M/A	Heat Flux Btu/hr ft ²	
<u>Charging</u>				$\frac{M}{A} C_p \Delta T$	<u>Storage Tank (Dia = 22.5")</u>				$\frac{M}{A} C_p \Delta T$
Small Tank (Dia = 13.0')					Storage Tank (Dia = 22.5")				
50	750	112	14,000	3.6	2.1	450	283	13,200	
198	750	443	55,400	14.3	8.4	450	1144	52,600	
387 (403)	750	877	109,000	28.1	16.5 (17.2)	450	2248	103,400	
Large Tank (Dia = 20.6')									
50	750	44.5	5,560	1.4	.84	450	114	5,260	
198	750	176	22,000	5.7	3.3	450	456	21,000	
387 (403)	750	347	43,400	11.2	6.6	450	896	41,200	
<u>Discharging</u>									
Small Tank									
50	500	137	17,100	4.4	2.4	350	352	16,200	
198	500	542	67,800	17.4	9.6	350	1400	64,400	
Large Tank									
50	500	54	6,800	1.8	.96	350	140	6,400	
198	500	216	27,000	7.0	3.8	350	557	25,600	

$\bar{\mu}$, viscosity, @625°F = .97 lb/Ft hr
 @400°F = 2.5

TABLE 2
EXTENDED COLUMN TEST PROGRAM SUMMARY

Activity

Comments

Static Holdup Evaluation

Room Temperature Test
accomplished after initial
filling of bed

Dynamic Hold-up Tests

Hot circulation tests at .9,
8, and 16.5 gpm

Charging-Discharging and
Holding Loss

	<u>CHARGING</u>		<u>DISCHARGING</u>	
	<u>Run No.</u>	<u>Rate (gpm)</u>	<u>Rate (gpm)</u>	<u>Holding Time</u>
Full charge/discharge	1	0.9	0.9	Minimum
Full charge/discharge	2	3.5(4.0)	3.5	"
Full charge/discharge	3	8.0	9.6	"
Full charge/discharge	3(a)	8.0	9.6 at 1 psig	
Full charge/discharge	4	16.5(17.2)	9.6	6 hours
50% Discharge/hold	5	3.5	3.5	6 hours
50% Charge/hold	6	3.5	3.5	6 hours
Inversion	7	3.5 (8 gpm)		

TABLE 3
OPERATIONAL PROCEDURE FOR CHARGING-DISCHARGING EVALUATION

PROCEDURE SEQUENCE	COMMENTS	FLOW SCHEMATIC
PRELIMINARY WARM-UP 1. BATCH OIL HEAT UP TO 350°F	OIL CIRCULATES IN SOURCE TANK - HEATER LOOP	
2. ORE TANK HEAT UP TO 350°F	OIL CIRCULATES IN SOURCE TANK - HEATER - ORE TANK LOOP. BOTH PUMPS REQUIRED	
3. BATCH OIL HEAT UP TO 450°F	OIL CIRCULATES IN SOURCE TANK - HEATER LOOP	
CHARGING RUN	ENTIRE HOT OIL INVENTORY PUMPED THRU ORE BED AT DESIRED RATE. SCAVENGE PUMP TRANSFER OIL TO COLD TANKS	
HOLDING LOSS EVALUATION	AUTOMATIC DATA LOGGER WILL RECORD KEY ORE BED AND TEST FACILITY TEMPERATURES	STATIC TEST
PRE-DISCHARGE STABILIZATION 6. BATCH OIL TEMPERATURE STABILIZATION AT 350°F	OIL CIRCULATES FROM SINK TANK THRU HEATER OR COOLER AS NECESSARY TO ESTABLISH 350°F	
DISCHARGE RUN	ENTIRE OIL INVENTORY PUMPED THRU ORE BED AT DESIRED RATE. SCAVENGE PUMP TRANSFERS OIL TO HOT TANKS	

STATIC HOLDUP

VOID FRACTION

DYNAMIC HOLDUP

5.0.1 STATIC HOLDUP AND VOID FRACTION

Static Holdup

Knowledge of the bed static holdup is necessary to calculate system fluid inventory requirements and to calculate fluid make-up rates due to fluid degradation. The static holdup consists of (1) fluid clinging to the surface of individual particles, (2) fluid held at the inter-particle contact areas, and (3) fluid held in the particle pore structure.

The static holdup was determined at room temperature by filling the dry bed with a measured quantity of Syltherm oil and then draining the bed and measuring the quantity drained. The calculated holdup was 4.8% of the bed weight. This was translated into a fluid volume per unit of bed volume and is plotted in figure 1 along with a correlation from Ref. (1). The value is in good agreement with the extrapolated curve for porous particles. From independent measurements made on single bed particles the internal particle porosity is known to be 15%. The EÖTVÖS number, which contains the fluid density, surface tension and particle diameter, was calculated at 500°F and 750°F and the extrapolated curve used to determine the static holdup for the full scale system. These correspond to 7.6% at 500°F and 4.6% at 750°F for particles in the range from 3/8 to 1/2".

Void Fraction


At the same time the static holdup was measured the bed void fraction was also determined from the known quantity of fluid input and drained from the bed. The void fraction was determined to be 40%. Details of the static holdup and void fraction determination are in Ref. (2).

Ref. (1) Int. Chem. Eng., Vol 17, No. 1, Jan. 1977

Ref. (2) S. Abujawdeh - U-LSE PhIV-193(VIF) PIR 79-1-3 (Evendale)

FIG. 1 STATIC HOLDUP

359 - 125



$$EÖTVÖS \text{ NUMBER} - EÖ = \frac{\rho g d^2}{\gamma_L}$$

Dynamic Holdup

Dynamic holdup is that portion of the total fluid holdup in the bed under flow conditions which drains from the bed after flow is stopped. Dynamic holdup is a function of flow rate and is needed to enable calculations of required fluid inventories, fluid residence time in the bed, and fluid make-up rates. Dynamic holdup was measured by circulating fluid through the bed at a constant flow rate; simultaneously closing the fluid inlet and outlet valves; then measuring the fluid level rise in the reservoir at the tank bottom. Dynamic holdup is defined as the fraction of bed voids filled and is correlated with the Reynold's number, Galileo number, surface area per unit volume, particle size and bed void fraction. Figure 2 shows the measured data in comparison with the values predicted from the correlation of reference (3). Agreement between theory and model is good at the higher flow rates and diverges at the lower rates. This is due to poorer fluid distribution at the lower flow rates which is discussed later. The dynamic holdup predictions for the large scale system are shown in figure 3.

From the dynamic holdup, the fluid residence time in the bed can be predicted as shown in figure 4. Direct observation of residence time was made at 3.5 and 15 GPM and is shown in figure 4. Residence time predictions for the full scale system are shown in figure 5.

FIG. 2 DYNAMIC HOLDUP - 100 INCH COLUMN TEST




FIG. 3 DYNAMIC HOLDUP - STEP




FIG. 4 100" COLUMN RESIDENCE TIME





FIG. 5



CHARGING TESTS

5.1 Charging Tests

Charging tests were run at flow rates of 17.2, 8, 4 and 0.9 GPM. This section shows the measured temperature profiles at the bed centerline as well as the radial temperature distributions which were measured at 5 locations in the bed. Also shown are the measured fluid exit temperatures as a function of time.

5.1.1 17.2 GPM Charge

Fig. 5.1 shows the temperature profiles measured along the bed centerline initially and for three times during the test, 5, 11 and 16 minutes. (The numbers along the top of the plot are the thermocouple identification numbers.)

Fig. 5.2 shows the initial radial temperature distribution. The initial radial gradient are 10°F to 15°F from the centerline to wall.

Fig. 5.3 shows the bed centerline temperature profile and the radial temperatures measured at the midpoint between the centerline and the wall ($r=\frac{R_0}{2}$). Also shown are a family of predicted curves from the model for heat transfer coefficients in the range from $\frac{h}{4}$ to $\frac{h}{8}$. h is the theoretical heat transfer coefficient calculated in the model. A good fit to the data is shown in figure 5.4 for $\frac{h}{4} = 25 \text{ BTU/Ft}^2\text{hr}^{\circ}\text{F}$. Fig. 5.5 again shows the bed centerline but also the temperature measured 1.4 inches ($r=9.8''$) from the wall. It is seen that $h=25$ is a reasonable duplication of the temperature axial gradient and off centerline temperature levels.

Fig. 5.6 shows the bed centerline profile and temperature at $\frac{R_0}{2}$ for $t=11$ minutes, as well as the family of theoretical curves for a

range of heat transfer coefficients. Again $\frac{h}{4}$ or 25 BTU/Ft²hr⁰F is a good fit to the slope at the thermoclines, as shown in figure 5.7. Figure 5.8 shows the radial temperatures measured 1.4 inches from the wall along with the centerline temperatures. The slope of the $\frac{h}{4}$ curve is a reasonable fit. The limited number of thermocouples in the radial positions make it difficult to define the off centerline slopes with great certainty. But the charge efficiency is not a strong function of h in this flow rate range. For example, in charging a large tank, if h is in the range $\frac{h}{4}$ to $\frac{h}{8}$ the charge efficiency varies from 83% to 79%.

Figures 5.9 and 5.10 show the centerline and radial temperatures measured at $\frac{R_0}{2}$ and near the wall, respectively for $t=16$ minutes. Again $\frac{h}{4}$ is a reasonable fit to the slope of the thermoclines.

It has been seen in the plots presented, that there exist large radial temperature gradients in the bed during charging. Radial gradients to some degree are inherent in a trickle charge operation with a finite number of fluid distributor sources. In these tests the situation was aggravated by the fact that the fluid distribution rings tended to allow a greater flow per unit area in the outer rings. (See Section 5.6 for details.) This condition became more severe as the flow rate decreased till at 1 GPM the flow was almost entirely out of the outer rings. Consequently, as the fluid moves axially down the bed and spreads radially it's cooler fluid reaches the centerline, resulting in the lag in centerline temperatures which becomes more severe at the lower flow

rates. However, these radial gradients are washed out with time. Figure 5.11 shows the radial distribution at the plane near the top of the bed as a function of time. At $t=0$ the spread in temperature was 14°F , after 29 seconds the spread increased to 60°F then diminished till after 5 minutes the spread was only 5°F . Figures 5.12 and 5.13 show the spreads along the bed after charging at position $\frac{R_0}{2}$ and near the wall. (Complete charging of the bed was not achieved because of insufficient capacity in the 3 fluid holding tanks. In the charge runs a second smaller batch of fluid was heated to obtain a more fully charged bed for the discharge runs, however, complete charging was not achieved because of the time involved in reheating the entire batch back up to 450°F .) It is seen that the radial gradients diminish as charging proceeds. Figure 5.14 shows this phenomena at the 5 planes as a function of time. It is seen that the radial temperature spread goes through a maximum at each plane, and large gradients do not persist. This is particularly important because it means that in the trickle mode of operation, the series charging of the tanks will result in gradients in only the end of the last tank.

5.25 MIN
11.25
16.25






FIG. 5.1

0 12 24 36 48 60 72 84 96 100
TOP BED POSITION, INCHES Bottom

17.2 GPM CHARGE INITIAL RADIAL TEMPERATURE DISTRIBUTION



BED TEMPERATURE, °F



E/G. 5.3
17.2 GPM CHARGE

BED CENTERLINE AND
LOCATIONS


$\frac{R_0}{2}$


NOTE
CENTERLINE TEMPERATURES
O, T, D, X R/2 TEMPERATURES

BED POSITION, INCHES

TOP


BOTTOM






BED TEMPERATURE, °F

17.25 GPM





BED TEMPERATURE, °F

17.25 GPM




FIG. 5.8

17.2 GPM CHARGE

t = 11 MIN.


BED CENTERLINE AND LOCATIONS r = 9.8"

NOTE

• CENTERLINE TEMPERATURES

○, □, X R/2 TEMPERATURES

BED POSITION, INCHES








FIG. 5.11

RADIAL PROFILES IN TOP PLANE VS. TIME





TOP

BOTTOM





FIG. 5.14

17.2 GPM RADIAL GRADIENTS (T_{MAX} - T_{MIN}) FOR THE FIVE PLANES



← 2ND BATCH

5.1.1.1 Fluid Exit Temperature

Figure 5.15 shows the measured fluid exit temperature and the model prediction for $\frac{h}{4}$. The model was run using the measured fluid inlet temperature and the integrated average bed temperature at the 5 planes as shown in figure 5.16.

The measured fluid exit temperature starts at 156^oF. This is due to cooling of outlet pipe by the coolant loop used to protect the outlet pump from overheating. The coolant pump was located only a few feet downstream from the tank bottom. In 3 minutes the fluid exit rises to a near steady state value, however, there is still a heat loss to the pipe which results in the measured fluid exit temperature being lower than the average temperature of the bottom of the bed. This effect becomes more pronounced at the lower flow rates. The measured fluid exit temperature rise slope after breakthrough is in good agreement with the predicted curve but displaced in time by 2 minutes.

Fig. 5.15

17.2 GPM

FLUID EXIT TEMPERATURE




FIG. 5.16


17.2 GPM.

5

INITIAL AXIAL

PROFILE

FROM RADIAL AVERAGE IN 5 PLANES



5.1.2 8 GPM Charge

Two tests were run at 8 GPM to determine if there was an effect on the shape of the thermocline due to system pressure. Theoretically, a more dense gas phase might have an effect on the fluid-solid heat transfer rate. Tests were run at 1 psig and 5 psig. Higher pressures could not be achieved due to safety considerations.


5.1.2.1 5 psig Charge


Figure 5.17 shows the initial bed centerline profile and the profiles measured at 13, 26, and 36 minutes. Figure 5.18 shows the bed centerline temperatures and the radial profiles measured a $\frac{R_0}{2}$ along with the model prediction for $\frac{h}{4}$. Figure 5.19 is a similar plot where the radial temperatures measured near the wall are shown. The model fit $\frac{h}{4}$ is again a good fit to the slope of the measured temperature profiles. As at 17 GPM, it is seen that the radial gradients do not persist as charging proceeds.


Figure 5.20 shows the initial radial temperature profiles, from which the integrated average profile shown in figure 5.21 was calculated. This profile along with the inlet fluid temperature history were used as the initial conditions in the model.

5.1.2.1.1 Fluid Exit Temperature

Figure 5.22 shows the measured and model fluid exit temperature for $\frac{h}{4}=t$. The measured temperature, as at 17.2 GPM, lags the model, however, the slopes are in good agreement.












FIG. 5.21

INITIAL AXIAL PROFILE
86PM SP516 CHARGE

5



14
FIG. 5.22 FLUID EXIT TEMPERATURE 8 GPM CHARGE 5 PSIG



TIME, Min.

5.1.2.2 8 GPM, 1 psig Charge

Figure 5.23 shows the initial bed centerline temperature and the bed temperatures measured at 13, 26 and 36 minutes. Figures 5.24 and 5.25 show the 26 minute profiles at $\frac{R_0}{2}$ and near the wall for $\frac{h}{4} = 20$. The model, $\frac{h}{4}$, again fits the measured thermocline slopes. The initial bed radial profiles are shown in figure 5.26. The integrated average profile was not calculated because the only effect is to shift the model curve slightly to the left but not change the slope. Consequently, the input to the model was the bed centerline profile and the measured fluid inlet temperature history.


5.1.2.2.1 Fluid Exit Temperature

Figure 5.27 shows the measured and model fluid exit temperatures. These show the same characteristics as the previous profiles.

5.1.2.2.2 Thermocline Comparison at 1 and 5 psig

Figure 5.28 shows the thermoclines measured at the centerline for both test pressures. There is no significant difference between the slopes of the thermoclines at the two pressures as they progress through the bed.

BED TEMPERATURE, °F




800PM CHARGE 11PSIG CENTERLINE PROFILES


FIG. 5.2.3

BED POSITION, INCHES

TOP

BOTTOM





NOTE -
• CENTERLINE TEMPERATURES
○, □, X R/2 TEMPERATURES

FIG. 5.25 8 GPM CHARGE IPSIG

t = 26 MM

BED CENTERLINE AND LOCATIONS t = 9.8"

BED POSITION, INCHES

Top

FIG. 5.26

INITIAL RADIAL PROFILE
86PM CHARGE 1PS16





FIG. 5.27



TEMPERATURE IN BED

BED TEMPERATURE, °F




FIG. 5.28

Bottom

Top

5.1.3 4 GPM Charge

Figure 5.29 shows the initial centerline profile and the profiles at 15, 47 and 72 minutes. The initial radial profiles and the integrated average axial profiles are shown in figures 5.30 and 5.31 respectively. The temperatures from figure 5.31 and the fluid inlet temperature* histories were used as inputs to the model.

Figures 5.32 and 5.33 show the model results in comparison to the measured profiles at $\frac{R_o}{2}$ and near the wall along with the measured centerline profiles. At this flow rate, the effects of fluid mal-distribution are becoming evident. Here the centerline slope is showing the effect of lean direct flow with considerable flow inward and cooler fluid reaching the centerline. The model and measured slopes are in better agreement at the $\frac{R_o}{2}$ and near wall position.

5.1.3.1 Fluid Exit Temperature

Figure 5.34 shows the measured and radial fluid exit temperatures. The agreement is poorer at this flow rate primarily due to the greater heat loss in the tank bottom and exit line due to the previously mentioned pump coolant effect. At this flow rate there is a 5 minute residence time in the tank bottom (capacity ~ 20 gallons).

*The fluid inlet temperature for this test was 430°F.

FIG. 5.29







FIG. 5.30




5

FIGS. 31 INITIAL AXIAL PROFILE
4 GPM CHARGE





BED TEMPERATURE, °F



NOTE
 • CENTERLINE TEMPERATURES
 O, □, X R/2 TEMPERATURES


FIG. 5.33 4 GPM CHARGE
 t = 47 MIN.
 CENTERLINE AND LOCATIONS F = 9.8"

BED POSITION, INCHES

0 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100
 TOP BOTTOM


FIG. 5.34

FLUID EXIT TEMPERATURE 4 GPM CHARGE



5.1.4 1 GPM Charge

At a flow rate of 1 GPM it was not possible to charge the bed uniformly. The preferential flow to the outer ring(s) (see Section 5.6) was so great that the bed temperature profiles shown in figure 5.35 resulted. It is seen that after 5 hours the bed centerline temperature had risen only a few degrees in the top half of the bed, and the temperatures at $\frac{R_o}{2}$ and near the wall are progressively higher in the higher flow regions. Visual observation through the view port at the top of the tank confirmed that flow was from the outer periphery though it was not possible to discern whether the flow was through the outer ring only or the outer two rings. Assuming predominant flow in the outer ring, the test shows that the space between fluid outlet ports must be considerably less than 20 inches at this flow rate ($140 \text{ lbs/ft}^2\text{hr}$). The test was not repeated because of lack of funding and the judgement that very little charging would be done at this very low flow rate in the actual system.



DISCHARGING TESTS

5.2 Discharging Tests

Discharge tests were run at 4.0 and 9.6 GPM. The planned discharge test at 1 GPM was not run because of the failure to charge the bed at 1 GPM due to the fluid distributor problem. The 9.6 GPM discharges were performed following the 17.2 GPM charge, and the two 8 GPM charges at 5 psig and 1 psig.


5.2.1 9.6 GPM Discharge Following 8 GPM Charge at 5 psig

Figures 5.36 and 5.37 show the initial bed centerline profile and the temperatures measured at $\frac{R_0}{2}$ and $r=9.8$ inches, respectively. Figure 5.38 is a plot of the radial distribution in the 5 planes at $t=0$. Figure 5.39 shows three centerline thermoclines at 12, 16, and 20 minutes. The model fit for $t=20$ minutes is shown in figures 5.40 and 5.41 for $\frac{R_0}{2}$ and $r=9.8$ inches. It is seen in discharging as in charging that the centerline temperature lags the temperature at $\frac{R_0}{2}$ and $r=9.8$ due to the outer ring preferential flow. The slope of the $\frac{h}{4}$ curve is seen to be a reasonable fit to data. It is also seen, as in the charging mode, that large radial gradients do not persist but are washed out as discharging proceeds.

5.2.1.1 Fluid Exit Temperature

Figure 5.42 shows the model and measured fluid exit temperature profiles. The model was run using the measured centerline temperature and the fluid inlet temperature history. The effect of using the integrated average temperature profile would be to lower the model temperature level but not change the slope. This is shown in section 5.2.3 where both temperature profiles were used.

BED TEMPERATURE, °F



NOTE

• CENTERLINE TEMPERATURES
 O, □, X R/2 TEMPERATURES


FIG. 5.36

9.6 GPM DISCHARGE 5 P.S.I.G.

INITIAL DISTRIBUTION
 BED CENTERLINE AND LOCATIONS R₀

BED POSITION, INCHES

0 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100
 TOP BOTTOM











FIG. S. 38 9.6 GPM DISCHARGE 5 PSIG


INITIAL AXIAL
PROFILE



RADIAL POSITION, INCHES


10 5 0 5 10





$t = 20 \text{ min.}$


BED TEMPERATURE, °F



TOP

BOTTOM

FIG. 5.42 9.6 GPM DISCHARGE SP516 FLUID EXIT TEMP.



TIME, MINUTES

5.2.2 9.6 GPM Discharge Following 8 GPM Charge at 1 psig

Figures 5.43 and 5.44 show the initial bed centerline temperature profile and the temperatures measured at $\frac{R_0}{2}$ and $r=9.8$ ", respectively. Figure 5.45 shows the radial temperature distribution in the 5 planes at $t=0$. Figure 5.46 shows the centerline profiles measured at 12, 16 and 20 minutes. The model fit for $t=20$ minutes is shown in figures 5.47 and 5.48 for $\frac{R_0}{2}$ and $r=9.8$ inches. The model slope and the measured slopes are in good agreement and the steep radial gradients are again washed out as discharging proceeds.

5.2.2.1 Fluid Exit Temperatures

The measured and model fluid exit temperatures are shown in figure 5.49. The same comments apply as given in section 5.2.1.1.

5.2.2.2 Thermocline Comparison at 1 and 5 psig

Figure 5.50 shows the measured thermocline at the centerline for both pressures. There is no significant difference in the slopes of the curves.





FIG. 5.45 9.6 GPM DISCHARGE 1 PSIG

INITIAL RADIAL PROFILES







FIG. 5.46

9.6 GPM DISCHARGE IPSIG
CENTERLINE PROFILES

TOP BOTTOM



12 X 12 INCHES (30 CM X 30 CM)
NEPHELIUM GLASS CO. MADE IN U.S.A.





FIG. 5.48 9.6 GPM DISCHARGE 11 PSIG $t = 2.0$ MIN
CENTERLINE AND LOCATIONS $r = 2.8$
(DOTS) (SQUARES)

0 TOP 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100 BOTTOM

FIG. 5.49


9.6 GPM DISCHARGE 1PSIG

FLUID EXIT TEMPERATURE ¹⁴



BED TEMPERATURE, °F

460
450
440
430
420
410
400
390
380
370
360
350
340
330
320
310
300



● = 5 PSIG

X = 1 PSIG

FIG. 5.50 9.6 GPM DISCHARGE
1 AND 5 PSIG
t = 20 MIN.
CENTERLINE PROFILES

BED POSITION, INCHES

0 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100

BOTTOM

5.2.3 9.6 GPM Discharge Following 17.2 GPM Charge


Prior to this discharge test, the bed was charged at 17.2 GPM. It was then held for $5\frac{1}{2}$ hours, and discharged.

Figures 5.51 and 5.52 show the centerline and radial temperature distributions at $\frac{R_0}{2}$ and $r=9.8"$ at the beginning of the discharge test as a function of axial position. Figure 5.53 shows the radial distribution in the 5 planes. From these profiles, the area weighted average temperature was calculated for each plane as plotted in figure 5.54. This profile was used as the initial condition in the model.

The model results and the measured data are shown in Figures 5.55 and 5.56 for $t=16$ minutes. As usual the centerline lags the outer temperatures. The slope of the model, however, is in good agreement with the off centerline profiles.

5.2.3.1 Fluid Exit Temperature

The measured and model fluid exit temperature are shown in figure 5.57. Model profiles are shown for two initial bed temperature profiles, one, the radial area weighted profile of figure 5.54 and the other, the bed centerline profile.






FIG. 8.52 9.6 GPM DISCHARGE
INITIAL DISTRIBUTION
CENTERLINE AND 1/8"
(DOTS) (SYMBOLS)

BED TEMPERATURE, °F

BED POSITION, INCHES

0 TOP

100 BOTTOM

FIG. 5.53

9.6 GPM DISCHARGE - INITIAL RADIAL PROFILES






FIG. 5.54

5



BED TEMPERATURE, °F


100.0000
change



TOP

BOTTOM

F1C



Time, Minutes

5.2.3 4 GPM Discharge

Figures 5.58 and 5.59 show the initial centerline and temperatures at $\frac{R_o}{2}$, and near the wall. Figure 5.60 is a plot of initial temperature versus radial position. The integrated average profile was not calculated. The bed centerline temperature and inlet fluid temperature history was used as input to the model.

Figure 5.61 shows the measured centerline profiles at 16, 30, 46, and 60 minutes. Figure 5.62 shows the 46 minute profile in comparison with the model at the centerline and $\frac{R_o}{2}$. Figure 5.63 shows the near wall profiles. It is seen that the slopes are generally in good agreement with the model. This was not the case in the 4 GPM charge mode, indicating that the mal-distribution effect is more severe in the charge mode.

4 GPM Fluid Exit Temperature

The measured and model fluid exit temperatures are shown in figure 5.64. As in the 4 GPM charge the slope of the fluid temperature change is less steep than the model.

BED TEMPERATURE, °F

460
450
440
430
420
410
400
390
380
370
360
350
340
330
320
310
300




FIG. 5.58

BED POSITION, INCHES

BED TEMPERATURE, °F

460 450 440 430 420 410 400 390 380 370 360 350 340 330 320 310 300




FIG. 5.59

BED POSITION, INCHES


0 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100

TOP

BOTTOM

FIG. 5.60

4 GPM DISCHARGE - INITIAL TEMPERATURE



BED TEMPERATURE, °F




FIG. 5.61 4 GPM DISCHARGE
CENTERLINE PROFILES

BOTTOM

TOP

46 min (12:41)




FIG. 5.62 4 GPM DISCHARGE
 t = 46 MIN.
 CENTERLINE AND LOCATIONS
 (DOTS) (SYMBOLS)

46 min (12:41)





FIG. 5.64 FLUID EXIT TEMPERATURE
4 GPM DISCHARGE



HOLDING TESTS

5.3 Holding Tests

Two holding tests were run to observe the changes in the bed temperature profiles. The first test consisted of partially charging the bed at a 3.5 GPM flow rate, then holding for 11 hours.

In the 2nd test the bed was partially discharged, then held for 10 hours.

5.3.1 1/2 Charge Hold

The centerline profiles are shown in figure H-1. It is seen that there is appreciable cooling only in the top 5 inches of the bed due to convective losses. $t=0$ is defined as the time at which flow is stopped. Part of the rise in centerline temperature down the bed is due to the drainage of the dynamic holdup and in part due to radial inward conduction as well as axial conduction. All temperature levels drop as a function of time but even after 8 hours the thermocline shape is not significantly distorted. It is concluded that the bed thermal conductance in the full scale system will be sufficiently low that thermoclines will not be severely distorted and that the 14" of insulation will maintain heat losses at 4% over a 24 hour period. It is evident that radial conduction inward is occurring because the energy content at the centerline is greater after 6 hours than at $t=0$. The present bed model is one-dimensional; i.e., it handles only axial temperature variations. It is therefore not possible to separate the complex heat flow into components due to dynamic holdup drain, radial and axial conduction. Between 4 and 6 hours it is seen that there is very little temperature change in the bulk of the bed along the centerline. Beyond 6 hours all temperatures start to fall due to radial conduction outward, and axial conduction. The heat


flow pattern is seen by observing the radial temperature changes shown in figure H-2 and H-3. The centerline (439°F) is cooler than position $\frac{R_0}{2}$ and $r=9.8"$, at $t=0$ heat flows inward raising the centerline to a peak of 445°F which prevails till 8 hours where it drops to 444°F and then continues to drop slowly (441°F after 11 hrs.) During this time temperature at $\frac{R_0}{2}$ and $r=9.8"$ are continually dropping.

The full scale system is 20Ft in diameter with 14" of insulation; the test is 2Ft in diameter with 8" of insulation. The ratio of $(\frac{T_{\text{bed}} - T_{\text{ambient}}}{L_{\text{insulation}}})$ is the same for both, therefore, the surface heat flux is the same (insulation conductivity being equal). However, the area to volume ratio of the test is 7 times as large as the full scale system. Consequently, the observed drops in temperature are representative of less than the outer foot near the wall of the full scale system. Figure H-4 shows the axial profile at a location of $\frac{R_0}{2}$ as a function of time.

BED TEMPERATURE, °F

FIG. H-1
1 CHARGE HOLD
2

FOLLOWING 3.5 GPM CHARGE
CENTERLINE PROFILES



BED POSITION, INCHES

ToP

BOTTOM

FIG. H-2

1/2 charge hold - radial profiles at





FIG. H-3

1/2 Charge hold - radial profiles at Plane 2







FIG. H-4 ~ 1/2 CHARGE HOLD

PROFILES AT R0/2

AXIAL POSITION INCHES

5.3.2 1/2 Discharge Hold

The centerline profiles are shown in figure H-5. In the discharge mode the centerline temperature was always hotter than the outer temperatures. Consequently, there is radially flow outward, as well as axial conduction upward and hot air convection currents upward. It was postulated that upward convection currents might be severe enough to flatten the thermocline. In the previous column test, run on a 2 foot long bed, these forces, combined with significant tank bottom heat losses, were large enough to drastically distort the thermocline as shown in figure H-6. In this 8 foot column test, the results clearly show that severe thermocline degradation will not occur.



THE KNOCKLINES
 HOLDING TEST # 3
5-31-78




Figure 3.

5.4 Inversion Test


Prior to inversion the bed was charged to approximately the 1/2 charge condition at a flow rate of 3.5 GPM. The bed centerline temperature at the end of charging is shown in figure I-1. Initial radial distributions in the five planes are shown in figure I-2. The area weighted average temperatures were calculated for the 5 planes resulting in the average plane temperature as a function of axial position shown in figure I-3. This profile was used as the initial bed condition in the model.

Figure I-4 shows the fluid exit temperature, which should equal the fluid inlet temperature, but is reduced by the heat loss in the tank exit line. (As previously mentioned this loss is primarily due to the water cooled exit pump.) The temperature loss is typically 10⁰F between the exit and inlet. The present model cannot account for this loss and assumes that the inlet temperature is equal to the calculated exit temperature. Consequently, the agreement between model and measured performance would be expected to become increasingly poor with time as energy is drained from the system. This is shown in figures I-5 and I-6 at t=10 minutes, and 20 minutes. At 10 minutes the agreement between model and measured (measured is calculated from measured radial profile) is good except at the bed top, as here the temperatures are lower than predicted. As inversion progresses to the end, at 20 minutes, the agreement is poorer reflecting the energy loss; the top 2 feet of the bed being 15 to 20⁰F cooler than predicted.

Considering the limitations of the model, and the heat loss problem, the only conclusion reached from test is that the inversion process appears feasible but only a re-test with minimal line losses could confirm this. Systems studies have shown that only a small fraction (10%) of the energy stored will require inversion, consequently the inversion process is of secondary importance.

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION

FIG. 1-1 BED CENTERLINE BEFORE INVERSION



0 6 12 18 24 30 36 42 48 54 60 66 72 78 84 90 96 100
TOP BOTTOM

FIG. 2-2 INITIAL RADIAL PROFILES BEFORE INVERSION




FIG. I-3

AXIAL PROFILE FROM RADIAL AVERAGE TEMPERATURES




FIG. I-4 INVERSION TEST - FLUID INLET AND OUTLET TEMPERATURES




FIG. I-5 INVERSION PROCESS $t = 10$ MINUTES





FIG. I-6 INVERSION PROCESS $t = 20 \text{ MIN.}$

⊗ = MEASURED POINTS
CALCULATED FROM MEASURED
RADIAL TEMPS.



5. Heat Transfer Coefficients


The model calculates a theoretical heat transfer coefficient based on variable fluid properties with temperature, the mass flow rate, and particle size. As seen in the charge and discharge test these theoretical values had to be reduced by a factor of 4 to provide a reasonable fit to the test data.

The magnitude of the heat transfer coefficient and its variation with mass flow rate is shown in figure C-1. The mass flow rate is defined in terms of the total bed cross sectional area. Values varied from 15 to 25 BTU/Ft²hr⁰F over the test range.

Figure C-2 shows the heat transfer coefficients in terms of Reynolds number, where the characteristic dimension in the Reynolds number is the particle diameter.

A more general correlation is shown in Figure C-3 where the Nusselt number is shown as a function of Reynolds number.

FIG. C-1



$$G = \frac{\dot{m}}{A}, \quad \text{SUPERFICIAL MASS FLOW RATE, lb/FE}^2 \text{hr}$$

FIG. C-2





FIG. C-3

NUSSELT NUMBER VS. REYNOLDS NUMBER



Reynolds Number, $\frac{d_p G}{\mu}$ (d_p = particle diameter)

5.6 Fluid Distributor Problem

The fluid distributor design was intended to provide uniform flow over the range of flow rates planned. This, however, did not turn out to be the case. At the lower flow rates, fluid preferentially flowed out the outer rings leaving the inner region fluid poor. The post test plot of the bed temperature profiles at the 1 GPM flow rate, showed that even after 5 hours of charging the bed centerline rose only a few degrees.

Prior to the start of testing, a test was run to check fluid distribution. This was accomplished by placing a series of cups of 2" diameter under the distributor. The test was run at 4 GPM. Fluid levels in the cups were compared and the deviation was approximately $\pm 20\%$ from the mean level. This was judged at the time to be acceptable with the intent of re-running tests if the thermoclines were poor. It is possible to vary the flow in each individual ring by means of a valve in each ring inlet line, although it would be a time consuming operation.


The first charge/discharge runs were made at 8GPM, since thermocline spreading was expected to be most severe at the higher flow rates. When the 1 GPM temperature distributions were analyzed, detailed calculations were made of the pressure-flow relationships as shown in figure F-1. This showed that a head of only $\sim 9"$ was required to allow all fluid to flow out of the outer ring at 1 GPM. This was confirmed by a careful post test observation through the top view port at a flow of 1 GPM. This showed no flow from the inner rings. As the test data was being reduced, it became evident that a heat transfer coefficient of $\frac{h}{4}$ theoretical was a reasonable

fit to the thermocline slopes at the higher flow rates, compared to $\frac{h}{T}$ from the previous column test, and that acceptable full scale performance could be expected. These higher rates are representative of the great majority of rates for charging/discharging in the full scale system. Consequently, in the interest of cost economy, the decision was made not to fine tune the distributor and re-run the test at the lower flow rates.

FIG. F-1

COLUMN TEST DISTRIBUTOR FLOW

N = 102 HOLES
D = 0.043 INCHES



volume ratio of a small scale test compared to the full scale system. When this is considered, the holding tests indicate that significant distortion of the thermoclines will not result radially. Also, axial dispersion, (inherently lower in a trickle system), was seen to be small; convective losses at the top of the bed distort only the first 5 inches and holding tends to smooth out internal radial (not near the wall) gradients.

The inversion test results were distorted by the heat losses in the fluid exit line, but do indicate that the process is feasible.

In summary, the results of the Extended Column Test have established a rational engineering basis for the design of the trickle oil storage systems. The Extended Column Tests provide a higher degree of confidence than was provided by the previous short column test. It must be born in mind that the true criteria for judgement of trickle versus dual media mode lies not just in a direct comparison of thermocline shapes but in the overall system economics. With this in mind, it is a wise decision to carry the capability for both modes of operation into the Shenandoah system so that the economics and performance of both approaches can be comprehensibly evaluated.

volume ratio of a small scale test compared to the full scale system. When this is considered, the holding tests indicate that significant distortion of the thermoclines will not result radially. Also, axial dispersion, (inherently lower in a trickle system), was seen to be small; convective losses at the top of the bed distort only the first 5 inches and holding tends to smooth out internal radial (not near the wall) gradients.

The inversion test results were distorted by the heat losses in the fluid exit line, but do indicate that the process is feasible.

In summary, these test with due consideration to their limitations, do not provide an indictment against trickle mode operation nor do they provide the highest degree of confidence. They do provide a higher degree of confidence than provided by the previous short column test. It must be born in mind that the true criteria for judgement of trickle versus dual media mode lies not just in a direct comparison of thermocline shapes but in the overall system economics. With this, in mind it is a wise decision to carry the capability for both modes of operation into the Shenandoah Large Scale experiment.