

SOLAR-ONE
10 MWe PILOT PLANT
ULLAGE MAINTENANCE UNIT (UMU)

DESCRIPTION
OPERATION &
ANALYSIS

13 MARCH 1981

REVISED

5 NOVEMBER 1982

INTRODUCTION

Solar One is a 10MWe Solar Thermal Central Receiver Pilot Plant which generates electricity exclusively from solar energy. The pilot plant is a joint undertaking between the U.S. Department of Energy and the Utility Associates composed of the Southern California Edison Company, the Los Angeles Department of Water and Power, and the California Energy Resources Conservation and Development Commission. The pilot plant consists of several major systems (shown in Figure 1) including the Thermal Storage System.

The Thermal Storage System is designed to absorb and store thermal energy by condensing receiver generated steam and to serve as a source of thermal energy for a simultaneous or subsequent steam generation process (see Figure 2.) The thermal energy is absorbed into the subsystem (charging process) by circulating low temperature (nominally 425⁰F) Caloria HT-43 (heat transfer oil) through charging heat exchangers which condenses receiver steam and exits from the heat exchangers at an elevated temperature (580⁰F). The high temperature Caloria flows to either the storage tank (thermal storage unit) or on to the inlet of the steam generating heat exchangers.

The thermal storage unit (TSU) is a vertical cylindrical tank filled with a sand/rock mixture through which the Caloria passes. Hot Caloria is introduced at the top of the TSU through a distribution manifold and passes downward through the tank. As the oil passes through the rock/sand mixture, it transfers its heat to the sand and rock and is cooled to the low temperature (425⁰F) condition. The zone of heat transfer within the tank (thermocline) occurs over a small fraction of the entire tank height. As energy is added to the TSU, the thermocline moves downward thereby increasing the thermal charge of the system.





Figure 1. Pilot Plant System Schematic

FIGURE 2

SOLAR ONE THERMAL STORAGE SUBSYSTEM



379-190



Rockwell
International
Rocketdyne Division

During the energy extraction process, high temperature Caloria is circulated to the steam generators either flowing directly from the outlet of the charging heat exchangers or from the top manifold in the TSU. The steam generators produce steam at a nominal condition of 420 psia and 530⁰F. Caloria leaves the steam generators at a nominal temperature of 425⁰F and flows to either the TSU bottom manifold where it is reintroduced into the tank or directly to the charging heat exchangers where it absorbs additional charging energy.


The Caloria introduced into the TSU bottom manifold flows upward through the sand/rock mixture. As the Caloria passes through the thermocline region, it absorbs heat from the high temperature rock and continues to flow upward until it passes out of the top of the tank at a nominal temperature of 575⁰F. During this period, the thermocline is moving toward the top of the TSU which results in a net energy extraction from the TSU. Charging and extraction functions for the TSU must be terminated when the thermocline begins to pass out of the bottom or top manifold respectively.

The ullage maintenance unit (UMU) (See Figure 3) controls the pressure in the TSU to a safe level and removes volatile degradation products generated by the Caloria at high temperature (See Table 1). The design ullage vapor flow rate (due to oil degradation plus volume change) is shown in Figure 4 and the expected daily vapor production is shown in Figure 5. The UMU also controls nitrogen flow to the TSU. At all times, the TSU is maintained at a slightly positive pressure to prevent air from leaking into the tank. The presence of oxygen in the tank will significantly increase the degradation rate of the Caloria and could produce a combustible mixture if sufficient free oxygen existed inside the TSU.

The configurational details of the UMU are shown in Figure 6, and a photo of the unit is shown in Figure 7. The remaining sections of this report describe the operation of the UMU, and provide analyses in support of these operational details.

FIGURE 3

THERMAL ENERGY STORAGE



- COMPLETELY ENCLOSED – OXYGEN FREE
- SLIGHT POSITIVE PRESSURE AT ALL TIMES
- CONDENSIBLE VAPORS RECYCLED
- NON CONDENSIBLES BURNED

379-191



Rockwell
International
Rocketdyne Division

TABLE 1
 CALORIA HT43 DEGRADATION PRODUCTS AT 575°F

COMPONENT	MOLECULAR WEIGHT LB/LB _{mole}	VOL, %	BOILING PT °F
N ₂	28	* 2.0	- 320
CO	28	2.4	- 312
CO ₂	44	* 2.0	- 109
H ₂	2	20.8	- 423
O ₂	32	0.2	- 297
CH ₄	16	20.5	- 263
C ₂ H ₆	30	19.3	- 128
C ₂ H ₄	28	0.5	- 155
C ₃ H ₈	44	12.3	- 43.6
C ₃ H ₆	42	2.0	- 57
n C ₄ H ₁₀	58	8.1	31
i C ₄ H ₁₀	58	2.4	31
n C ₅ H ₁₂	72	6.0	97
i C ₅ H ₁₂	72	0.4	82
H ₂ O	18	* 1.0	212
AVE	28.9	100	

* INERT CONSTITUENTS = 5%

FIGURE 4
ULLAGE VAPOR FLOW RATE

TOTAL OUTFLOW = OIL DEGRADATION + ULLAGE VOLUME CHANGE
MAXIMUM AT END OF CHARGING CYCLE





FIGURE 5
TSU DAILY FUEL VAPOR PRODUCTION






FIGURE 6

ULLAGE MAINTENANCE UNIT



379-192



Internal Letter



Rockwell International

Date: .28 July 1980

No. IL 141-42-8352

TO: (Name, Organization, Internal Address)
.G. R. Morgan *GRM*
.D/585-139 AA95

FROM: (Name, Organization, Internal Address, Phone)
.R. H. Morrison (4)
.D/585-141 AC35
.3431

Subject: .10 MWe Pilot Plant - Ullage Maintenance Unit (UMU),
Description, Operation, and Analysis

SUMMARY

This memo contains a general description, operational description and analysis of the Ullage Maintenance Unit (UMU) which controls the venting, supply and disposal of the gas in the ullage space of the thermal storage unit (TSU).

The UMU provides an oxygen free environment in the ullage space of the TSU. Air, which can cause rapid deterioration of the heat transfer oil, is excluded by using non-oxygen bearing fuel vapors. Gaseous nitrogen is available for backup when necessary. Air is excluded by keeping the ullage space and UMU makeup system at a slight positive pressure, 7 to 11 inches of water, at all times. The oil level in the TSU changes continually as a result of heating and cooling during the charging and extraction cycles. The UMU compensates by removing and supplying gas to keep the ullage pressure in an established band. Fuel vapors, resulting from oil decomposition, that do not condense are disposed of through the UMU combustor/flare stack.

GENERAL DESCRIPTION

The UMU is a service unit to the TSU and provides the following 3 important functions:

- 1) Pressurization of the ullage space to a continuous and positive pressure, selected to be between 5.5 and 10.5-inches of water.
- 2) Venting or charging the ullage space with oxygen free gas to keep the pressure within the desired range as the liquid level changes during charging and extraction cycles.
- 3) Disposal of excess gas and water vapor through a combustion and drain system.

It is essential that the UMU retain the oxygen free integrity of the TSU ullage space at all time. The TSU is a sealed, closed system. Excess pressure will rupture the TSU. A pressure below atmospheric in the TSU may allow air to leak in and if too low will lead to collapse of the roof.

The UMU is contained in skid assembly SA311, Dwg, GA000-90907-M29, and is connected to the TSU ullage space by a 6" vapor line (6-UG-1-BBA), a 1" liquid line (1-HP-1-BBA) and numerous control lines. The UMU skid consists of a 300 gallon condensate storage and water separator, US; a pump to transfer liquid pressurant to the TSU, P308; a burner stack and associated blowers and controls to dispose of the waste gases; and a gaseous nitrogen supply (2-UC-2-BBA) that provides backup service when gas from the recirculating liquid phase system is inadequate to meet TSU pressure requirements.

The working fluid for pressurizing the TSU is heptane. It is stored in tank US as a liquid well below its boiling point of 209F. When returned to the TSU ullage space it vaporizes, since the ullage environment is at a temperature over 400F. When returning to tank US through line 6-UG-1-BBA the vapors condense. Tests have shown that the oil decomposition products of Caloria HT43 are a mixture of fuel vapors, some of which condense at room temperature and pressure. Thus the working fluid will be a mix of heptane and other hydrocarbon vapors. Condensed liquids remain in tank US and non-condensibles go to the burner stack through line 6-UG-1-BBA.

Waste gas blower FA-301 and air blower FA-302 provide a positive pressure to the burner stack where the fuel gases are mixed with air and burned. A pilot gas supply services a pilot flame to assure combustion at all mixture ratios. Pilot gas supply is from a pressure bottle on the UMU pad. Nitrogen for inert gas purging is supplied through line 1/2-N-4-BBD and is controlled by the flame safety control center through valve SOV-4009.

The ullage pump P-308 returns condensed liquid to the TSU through line 1-HP-1-BBA when the ullage volume is increasing. The liquid consisting of Heptane and some condensed fuel vapors revaporizes upon entering the TSU and fills the ullage space as needed.

Each day prior to operating in the extraction mode, the level of liquid in US will be checked using sight gage LG4020A, and makeup heptane will be added as necessary. Line 1-HP-2-BBA is the heptane fill line. Liquid heptane is delivered and stored on the UMU pad in 50 gallon barrels and transferred to the US storage container with a commercial, air or electrically powered, barrel pump.

Tank US, Figure 1, is a combined gas receiver, gas liquid separator and storage tank. Ullage gases and condensed vapors from the TSU enter near the top of the tank. The condensed vapors settle out and the non-condensable fraction is diverted to the burn stack. Approximately 120 gallons of heptane is required to fill the TSU ullage space during a complete extraction cycle. If none is lost the 120 gallons can be used repeatedly. However, it is expected that some will be lost and makeup heptane will be added as needed.

Tank US acting as a liquid gas separator provides an indication if water is leaking into the oil system. Water will be turned to steam which will ultimately find its way to the TSU ullage space and then into the UMU system. Steam will condense in the 6 inch vent line between the TSU and the UMU and settle to the bottom of US. Liquid level gage LG 4020B is placed in the lower region of the tank to monitor water level for drainage purposes. It is desirable that the water level remain below the connection to line 1-HP-2-BBA. Small amounts of water can be returned as a pressurizing gas for the ullage space in the TSU but repeated useage of large amounts of water may lead to oxidation of the oil. Water is drained from the bottom of the tank through manual control valve UHDV. A pad of nitrogen is available through valve PCV 4023. The pressure setting will be determined by the skid manufacturer in relation to the waste disposal system.

The gaseous nitrogen system serves as a backup and provides an independent, inert, positive pressure in the ullage space during activation before operating temperature conditions are reached. Gaseous nitrogen is supplied from the main supply at 130 psig through a 1-1/2 inch line and enters the UMU skid at interface U71. The gaseous nitrogen flows through a series of regulators, shutoff valves, and flowmeters, line UG-2-BBA, and into the TSU at interface U101. Final regulation into the TSU is by valve PCV-4006 and PCV-4007. The GN_2 system is completely mechanical. Line 1/2-UG-3-BBA provides sensing to valve PCV-4006 from TSU interface U111.

OPERATION

Reference drawing GA000-90907-M29

The UMU has 4 principal operating circuits. These are:

1. Vapor inlet and condensing
2. Condensate return
3. Waste gas disposal
4. Gaseous nitrogen supply

These fluid circuits are interconnected and controlled by a network of valves with signals from pressure sensors mounted on the TSU. Pressures, temperatures, liquid levels and flows are monitored with sight gages and electrical recording transducers.

Vapor Inlet and Condensing

During the charging mode the fluid level rises in the TSU (V303) and a high pressure signal opens valve AOV-4014 venting excess gases in the ullage space through line 6-UG-1-BBA to the receiver and storage vessel US. Condensible vapors collect in tank US and non-condensibles pass through into the waste gas disposal system through valve MOV-4015.

Condensate level in tank US is established by sight gage LG4020A and LG4020B. When the TSU is near or in the fully discharged state the water and excess condensate will be drained from tank US through valve UHDV and/or makeup heptane will be added to bring the condensate to the correct operating level (200 gallons of condensate). Heptane filling is through line 1-HP-2-BBA and valve UHIS-1. Heptane is stored in 50 gallon (type) barrels and is transferred to tank US through a portable electric or pneumatic barrel pump.

Condensate Return

During the extraction mode, and whenever more gas is needed in the TSU ullage space, a low pressure signal activates ullage pump P308 and condensate is injected into the TSU ullage space through line 1-HP-10BBA. The condensate vaporizes when heated to the operating temperature of the top of the TSU bed (500F or higher). The pump cycles on and off to meet the ullage

gas demand. When the pump is off liquid is prevented from returning to Tank US by check valve UHCK. Isolation of the pump for maintenance is provided by valves UHIS-2 and USIS-3. Approximately 120 gallons of condensate is required to supply vapor during a full extraction.

Waste Gas Disposal

Gases and vapors that do not condense into tank US are transferred to the waste gas disposal system through line 6-UC-1-BBA and valve MOV-4015. Valve MOV-4015 actuates simultaneously with valve AOV-4014. Waste gas blower FA301 and air blower FA302 are synchronized with controls in the burner stack and pilot gas supply to provide controlled ignition and combustion of the waste gases.

Pilot gas supply is controlled through SOV-4016 and PCV-4012 to insure combustion during all operating conditions. The flow and ignition of waste and pilot gas is controlled through the flame safety control network that will be supplied by the manufacturer of the UMU skid assembly.

The principal purpose of burning the non-condensable gases is for safety and ease of disposal. Emission regulations do not require that every fuel molecule entering the system be burned. When the waste gas is mostly nitrogen it may be beyond the lean ignition limits and a mixture containing unburned fuel vapors may leave the stack. However, the pilot will operate at all times to insure that mixtures beyond the combustion lean limit will burn.

Gaseous Nitrogen Supply

Gaseous nitrogen at 130 ± 20 psig is supplied to the skid at interface U71. Valve PCV-4004 provides 1st stage regulation to 25 ± 5 psig. Final regulated pressure is controlled by PCV-4006 which is set for 5 in. WC and PCV-4007 set at 3 in. WC. Feedback of ullage gases to the GN_2 system is prevented by check valve UNCK-1. Valves PCV-4006 and PCV-4007 are externally sensed, spring loaded regulators that sense TSU ullage pressure.

Control

The operating set points for the UMU (and TSU) are shown in Figure 2. The "normal" operating range for the pressure in the TSU is between 5.5 and 10.5 inches water column (WC). Above 10.5 in. WC of pressure the UMU venting is activated to remove gases from the TSU. Below 5.5 in. WC pressure the UMU is activated to supply gas to the TSU.

When the ullage volume is decreasing and/or pressure is increasing, valves AOV-4014 and MOV-4015 are opened and the waste gas disposal system is activated. Ullage gas flows through line 6-UG-1-BBA into tank US. Vapors that can condense form liquid in the line and are tapped in tank US. Noncondensable vapors flow into the waste gas disposal system and out the burner stack.

If the pressure reaches 13 in. WC, the upper limit of the operating band, a high pressure alarm is activated and personnel are alerted to an excessive pressure condition.

As ullage pressure increases the redline unit terminates operation of the extraction and charging loops at 16 in. WC. At 18 in. WC low flow relief valve PSV-4018 opens. The high flow relief valve on the TSU opens at 20 in. WC. With decreasing pressure the ullage pump, P308, is activated at 5.5 in. WC. The low pressure alarm is activated at 5 in. WC. and the low flow GN₂ supply becomes active. The high flow GN₂ supply becomes active at 3 in. WC. Continually decreasing pressure activates the redline unit which shuts down the charging and extraction flow loops at 2 in. WC.

Instrumentation

Monitoring of the TSU is accomplished by remote sensors and in-situ sight gages. Sensors for control steps shown in Figure 2 are mounted on the thermal storage unit V303. Venting of the TSU is controlled by ullage pressure sensor PT4008 thru the ILS. The ILS is set to actuate the venting and waste gas disposal system at 10.5 in. WC. In the decreasing pressure mode it terminates venting at 8.5 in. WC. Control of liquid condensate flow to the TSU is also determined by PT-4008 thru the ILS. When pressure is decreasing the ILS activates the condensate pump at 5.5 in. WC. When increasing in pressure, operation is terminated at 6.5 in. WC. TSU ullage pressure is monitored in

the control center by PT4008. Sight gage PI4013 provides reading of the TSU ullage pressure at the tank.

Gaseous nitrogen supply and operating pressures are monitored by sight gages PI 4003, PI 4005, and PI 4007. Pressure of gaseous nitrogen is monitored for the control center by PTX 4052.

Open/close position switches are provided for valves AOV-4014 and MOV-4015 for control center monitoring of these main venting valves.

Operation of components in the waste disposal system is controlled by the flame safety control subsystem. These will be interlocked in a manner that will assure safe operation at all times. The interlock network and operation will be established by the manufacturer of the UMU skid.

ANALYSIS

The analyses of the UMU gases, vapors, and liquid flows are contained in the following pages. Fifteen different sets of calculations have been included. Table 1 is a summary of the results of these calculations. Included are comments on the impact of specific calculated values on the sizing and operation of the UMU. The numbers in the left column refer to specific conditions in the calculations that follow. Discussions of techniques and assumptions are included with the calculations.

R. H. Morrison

R. H. Morrison
Valves & Controls

RHM:cc

- REFERENCES: (1) Burolla, V.P., "Prediction of Yearly Fluid Replenishment Rates for Hydrocarbon Fluids in Thermal Energy Storage Systems," Sandia Laboratories, Report SAND79-8209, April 1979
- (2) Hallet, R.W. and Gervais, R.L., "Central Receiver Solar Thermal Power System, Preliminary Design Report, Thermal Storage Subsystem," McDonnell Douglas Company, Report MDC G6776, October 1977

cc: E. G. Spence *ES* AC35
D. G. Landy AC35
J. G. Absalom AA95
A. Djordjevic SS11

PREPARED BY:
R. MORRISON
CHECKED BY:
DATE:



Rocketdyne Division
Rockwell International

PAGE NO.
REPORT NO.

CONCEPTUAL SCHEMATIC OF
HEPTANE TANK (US)




Figure 1





FIGURE 2. OPERATIONAL PRESSURE SETPOINTS FOR ULLAGE MAINTENANCE UNIT

TABLE 1. UMU DESIGN CALCULATIONS SUMMARY

NO.	DESCRIPTION	CALCULATED VALUE *	COMMENT
1	Max. rate of thermal contraction or expansion of HT43	741 ft ³ /hr	Oil level rises and falls at a max. rate of 0.262 ft/hr
2	Density of oil degradation products at 580°F	0.0388 lb/ft ³	Based on vapor analysis from Reference 1
3	Max. rate of oil degradation product formation	1560 ft ³ /hr	Based on tests from Reference 1 and 2
4	Max. flowrate of ullage gases out of TSU	2300 ft ³ /hr	End of charging, 1 + 3
5	Max. flowrate of degradation products to burner	24.3 SCFM	Same as 4, no vapors condensing
6	Max. flowrate of Heptane leaving TSU	0.933 gpm	Beginning of charging, bed at 425 F
7	Max. flowrate of Heptane into TSU	0.356 gpm	Heptane pump flow selected to be 1.5 gpm
8	Volume of Heptane req'd for one day of operation	122 gal	Heptane tank capacity to be 300 gal.
9	Max. req'd flowrate of GN ₂ req'd to back up Heptane	7.69 SCFM	GN ₂ flow capacity selected to be 30 SCFM
10	Volume of GN ₂ req'd for 1 day of operation	2640 SCFD	Based on 1 complete extraction, GN ₂ only, no Heptane
11A	Drainage rate of 70°F TSU with 30 SCFM GN ₂ supply	224 gpm	Density of GN ₂ dependent on bed temperature ↓
11B	Drainage rate of 425°F TSU with 30 SCFM GN ₂ supply	367 gpm	
12A	Time to drain 70°F TSU	17.8 hrs	
12B	Time to drain 425°F TSU	12.9 hrs	
13A	Volume GN ₂ to drain 70°F TSU	32,000 SCF	
13B	Volume GN ₂ to drain 425°F TSU	23,000 SCF	

* Gallons refer to liquid state, ft³ to gaseous state

PREPARED BY: <u>R. MORRISON</u>	 Rocketdyne Division Rockwell International	PAGE NO. <u>1</u>
CHECKED BY:		REPORT NO.
DATE: <u>7-24-80</u>	<u>UMU CALCULATIONS</u>	

DATA SHEET

ULLAGE PRESSURE = 15.0 PSIA, STD. = 147 PSIA

CALORIA HTA3

$$\rho_{925^{\circ}\text{F}} = 49.91 \text{ lb/ft}^3 \quad \rho_{580^{\circ}\text{F}} = 40.85 \text{ lb/ft}^3$$

TOTAL MASS = 1,709,000 LBS

$$C_{p_{925}} = 0.61 \text{ BTU/lb}^{\circ}\text{F} \quad C_{p_{580}} = 0.69 \text{ BTU/lb}^{\circ}\text{F}$$

ROCK/SAND

$$C_{p_{925}} = 0.23 \text{ BTU/lb}^{\circ}\text{F} \quad C_{p_{580}} = 0.25 \text{ BTU/lb}^{\circ}\text{F}$$

$$\rho = 169. \text{ lb/ft}^3$$

n-HEPTANE

$$\rho_{70^{\circ}\text{F}} = (0.68376_{64}^{\text{lb}})(62.4) = 42.7 \text{ lb/ft}^3$$

Z FACTOR RANGES FROM 0.95 TO 1.0 IN OPERATING RANGE
 ASSUME VAPOR BEHAVES AS PERFECT GAS. AT 15 PSIA AND GREATER THAN 100°F SUPERHEAT.

$$\rho_{391} = \frac{(15.0)(100.21)}{(10.73)(851)} = 0.1646 \text{ lb/ft}^3$$

$$\rho_{925} = 0.1646 \left(\frac{851}{885} \right) = 0.1583 \text{ lb/ft}^3$$

$$\rho_{580} = 0.1646 \left(\frac{851}{1090} \right) = 0.1397 \text{ lb/ft}^3$$

GASEOUS NITROGEN

$$\rho_{\text{LN}_2} = 50.4 \text{ lb/ft}^3$$


(-320°F)

$$\rho_{70^{\circ}\text{F, STANDARD}} = \frac{(14.7)(28.02)}{(10.73)(530)} = 0.0774 \text{ LB/ft}^3$$

$$\rho_{925^{\circ}\text{F}} = \frac{(15)(28.02)}{(10.73)(885)} = 0.0443 \text{ LB/ft}^3$$

$$\rho_{580^{\circ}\text{F}} = \frac{(15)(28.02)}{(10.73)(1090)} = 0.0377 \text{ LB/ft}^3$$

$$C_{p_{\text{GN}_2}} = 0.24 \text{ BTU/lb}^{\circ}\text{R}$$

PREPARED BY: <u>R. MORRISON</u>		PAGE NO. <u>1-1</u>
CHECKED BY:		REPORT NO.
DATE: <u>7.29-80</u>	<u>UMU CALCULATIONS</u>	

1. WHAT IS THE MAXIMUM RATE OF VOLUME CHANGE IN THE ULLAGE SPACE DUE THERMAL CONTRACTION AND EXPANSION OF FLUID?

DISCUSSION: THE TSU CAN FULLY CHARGE OR FULLY DISCHARGE AT ITS MAXIMUM RATE OF FLOW IN FOUR HOURS. ASSUME THAT IN THIS TIME ALL OF THE ROCKS & SAND BETWEEN THE UPPER & LOWER MANIFOLD CHANGE TEMPERATURE FROM 580 TO 425 AND VICE VERSA. ALSO, A NET QUANTITY OF OIL EQUAL TO THAT OCCUPYING THE VOID SPACE IN THE BED AT 425°F UNDERGOES THE SAME CHANGE. ALL FLOWING OIL GOES INTO THE ROCK/SAND (I.E. THERE IS NO OPERATION IN WHICH HOT OIL ENTERS THE UPPER MANIFOLD WITHOUT SIMULTANEOUS COOLING OF OTHER OIL AT SOME POINT IN THE TSU).

GIVEN: FROM TSS ANALYSIS REPORT (9-12)

VOID SPACE IN ROCK/SAND BED = 28,373 ft³
 VOID SPACE IN 10 3/4" GRADED BED = 836 ft³
 ABOVE LOWER MANIFOLD
 VOID SPACE IN 6 1/2" OF ROCK ABOVE = 589 ft³
 BOTTOM OF UPPER MANIFOLD

29,798 ft³

TOTAL VOID SPACE IN ACTIVE PORTION OF TSU = 29,800 ft³

TIME = 4 HRS

PREPARED BY:
R. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.
1-2

CHECKED BY:

REPORT NO.

DATE:
7-29-80

UMU CALCULATIONS

DENSITY OF 580 °F OIL = 40.85 lb/ft³
DENSITY OF 475 °F OIL = 49.91 lb/ft³

CALCULATION:

$$\dot{V} = \frac{M_{OIL} (lb)}{t (hr)} \left(\frac{1}{\rho_1} - \frac{1}{\rho_2} \right) \frac{(ft^3)}{(lb)}$$

$$M_{OIL} = \rho_{OIL} V_{VOID} = 49.91 \frac{(lb)}{(ft^3)} 29,800 (ft^3)$$

$$M_{OIL} = 1.39 \times 10^6 \text{ lb}$$

$$\dot{V} = \frac{1.39 \times 10^6}{4} \left(\frac{1}{40.85} - \frac{1}{49.91} \right)$$

$$\dot{V} = 791 \frac{ft^3}{hr}$$

CONCLUSION: THE MAXIMUM RATE OF VOLUME CHANGE DUE TO THERMAL EXPANSION OR CONTRACTION OCCURS DURING MAX. FLOWRATE CONDITIONS IN CHARGING OR EXTRACTION AND IS NO GREATER THAN 791 FT³/HR IN EITHER CASE.

THIS CALCULATION IS CONSERVATIVE BECAUSE DURING THE ACTUAL CHARGING AND EXTRACTION CYCLES, THE CYCLE IS TERMINATED BEFORE THE ENTIRE BED IS BROUGHT TO TEMPERATURE.

PREPARED BY:
R. MORRISON
 CHECKED BY:
 DATE:
7-24-80



PAGE NO.
2-1
 REPORT NO.

UMJ CALCULATION

2. DETERMINE THE DENSITY OF THE OIL DEGRADATION PRODUCTS.


ASSUME: GAS BEHAVES AS AN IDEAL SOLUTION WITH PERFECT GAS PROPERTIES, ULLAGE PRESSURE = 15.0 PSIA

GIVEN:

COMPONENT	M.W. (LB/LBmole)	VOL %	BOILING PT. (°F)
N ₂	28	2.0	-320
CO	28	2.4	-312
CO ₂	44	2.0	-109
H ₂	2	20.8	-423
O ₂	32	0.2	-297
CH ₄	16	20.5	-263
C ₂ H ₆	30	19.3	-128
C ₂ H ₄	28	0.5	-155
C ₃ H ₈	44	12.3	-43.6
C ₃ H ₆	42	2.0	-59
n-C ₄ H ₁₀	58	8.1	31
i-C ₄ H ₁₀	58	2.4	31
n-C ₅ H ₁₂	72	6.0	97
i-C ₅ H ₁₂	72	0.4	82
H ₂ O	18	1.0	212
TOTAL		99.9	

CALCULATION:
$$\text{AVG. M.W.} = \frac{\sum \text{LBmole COMPONENT}}{\text{LBmole TOTAL}} = \frac{\text{LB COMPONENT}}{\text{LBmole COMPONENT}}$$

$$\frac{\text{LBmole COMPONENT}}{\text{LBmole TOTAL}} = \frac{\text{VOL. COMPONENT}}{\text{VOL. TOTAL}} = \frac{\text{VOL \%}}{100}$$

PREPARED BY: <u>R. MORRISON</u>	 Rocketdyne Division Rockwell International	PAGE NO. <u>2-2</u>
CHECKED BY:		REPORT NO.
DATE: <u>4. 29. 80</u>	<u>UMU CALCULATION</u>	

$$M.W. COMPONENT = \frac{LB COMPONENT}{LB MOLE COMPONENT}$$

$$AVG. M.W. = \sum \left(\frac{VOL\%}{100} \right) (M.W. COMPONENT)$$

COMPONENT	$\frac{VOL\%}{100}$	$\frac{VOL\%}{100} (M.W.)$
N ₂	0.020	0.560
CO	0.024	0.672
CO ₂	0.020	0.880
H ₂	0.208	0.416
O ₂	0.002	0.064
CH ₄	0.205	3.280
C ₂ H ₆	0.193	5.790
C ₂ H ₄	0.005	0.190
C ₃ H ₈	0.123	5.912
C ₃ H ₆	0.020	0.840
n-C ₉ H ₁₀	0.081	4.698
i-C ₉ H ₁₀	0.024	1.392
n-C ₅ H ₁₂	0.060	4.320
i-C ₅ H ₁₂	0.009	0.288
H ₂ O	0.010	0.180
TOTAL		28.9

DENSITY IS A FUNCTION OF TEMPERATURE. ACCORDING TO THE TSS ANALYSIS REPORT (P. 4-67) THE TEMPERATURE OF THE CEILING VARIES FROM 490°F AT THE WALL TO 282°F 1.45 FL. RADially INWARD AT A FLUID SURFACE TEMPERATURE OF 500°F

PREPARED BY:
R. MORRISON



PAGE NO.
7-3

CHECKED BY:

REPORT NO.

DATE:
7-25-80

UMU CALCULATION


ASSUME AN AVERAGE ULLAGE TEMPERATURE
OF $\frac{500 + 282}{2} = 391 \text{ } ^\circ\text{F}$.

$$\rho_{D.P. \text{ } 391^\circ\text{F}} = \frac{(15.0) \text{ PSIA } \text{LBmol}^\circ\text{R} (28.9) \text{ LB}}{(10.73) \text{ PSIA } \text{ft}^3 \text{ LBmol } (851)^\circ\text{R}}$$

$$\rho_{D.P. \text{ } 391^\circ\text{F}} = 0.0975 \text{ LB/ft}^3$$

AT MAX. TEMP. (580°F)

$$\rho_{D.P.} = \frac{(15.0) (28.9)}{(10.73) (1090)} = 0.0388$$

PREPARED BY: <u>R. MORRISON</u>		PAGE NO. <u>3-1</u>
CHECKED BY:		REPORT NO.
DATE: <u>7-24-80</u>	<u>UNMU CALCULATIONS</u>	

3. DETERMINE THE MAXIMUM RATE OF OIL DEGRADATION PRODUCT FORMATION.

DISCUSSION: THE MAXIMUM RATE OF DEGRADATION PRODUCT FORMATION OCCURS WHEN THE MAXIMUM QUANTITY OF OIL IS AT ITS MAXIMUM TEMPERATURE

ASSUME: ALL THE OIL IN THE TSU IS AT 580°F.

GIVEN: RATE OF PRODUCT FORMATION IN BED AT 580°F = 0.000092 LB/LB_{oil}HR = R₁

RATE OF PRODUCT FORMATION ABOVE BED AT 580°F = 0.00001375 LB/LB_{oil}HR = R₂

TOTAL VOID SPACE IN BED = 32,084 FT³

TOTAL MASS OF OIL = 1,709,000 LB

DENSITY OF OIL AT 580°F = 40.85 $\frac{LB}{FT^3}$

DENSITY OF DEGRADATION PRODUCTS = 0.0388 $\frac{LB}{FB}$ AT 580°F

CALCULATIONS:

M₁ = MASS OF OIL IN BED

$$M_1 = (32,084 \text{ FT}^3) (40.85 \text{ LB/FT}^3) = 1.311 \times 10^6 \text{ LB}$$

M₂ = MASS OF OIL ABOVE BED

$$M_2 = (1.709 - 1.311) \times 10^6 = 0.393 \times 10^6 \text{ LB}$$

PREPARED BY:
R. MORRISON
CHECKED BY:
DATE:
7-29-80



PAGE NO.
3-2
REPORT NO.

UMU CALCULATION

$$M_1 R_1 + M_2 R_2 = \text{RATE OF DEGRADATION} = \dot{M}$$

PRODUCT FORMATION

$$\dot{M} = (1.311 \times 10^6)(4.2 \times 10^{-5}) + (0.393 \times 10^6)(1.375 \times 10^{-5})$$

$$\dot{M} = 55.062 + 5.409 = 60.47 \frac{\text{LB}}{\text{HR}}$$

$$\dot{V} = \frac{\dot{M}}{\rho} = \frac{60.47 \text{ LB}}{\text{HR}} \frac{\text{FT}^3}{0.0288 \text{ LB}} = 1559 \frac{\text{FT}^3}{\text{HR}}$$

$$\frac{\dot{M}}{M} = \frac{60.47}{1,704,000} = 0.0000353 \text{ LB/LB HR}$$

PREPARED BY:
R. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.
4-1

CHECKED BY:

REPORT NO.

DATE:
7-29-80

UMU CALCULATIONS


4. DETERMINE THE MAXIMUM FLOWRATE OF ULLAGE GASES OUT OF THE TSU.

DISCUSSION: THE MAXIMUM FLOWRATE OF ULLAGE GASES OUT OF THE TSU OCCURS NEAR THE END OF THE CHARGING CYCLE WHEN THE MAXIMUM RATE OF DEGRADATION PRODUCT FORMATION COMBINES WITH THE MAXIMUM RATE OF ULLAGE CONTRACTION DUE TO THERMAL EXPANSION OF THE CALORIA HT93.

GIVEN: MAX. RATE OF DEGRADATION PRODUCT FORMATION = $1559 \frac{FL^3}{HR}$
MAX. RATE OF ULLAGE CONTRACTION = $741 \frac{FL^3}{HR}$

CALCULATIONS:

MAX. RATE OF ULLAGE GAS FLOW OUT OF TSU = $1559 + 741 = 2300 \frac{FL^3}{HR}$

PREPARED BY: E. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. 5-1
CHECKED BY:		REPORT NO.
DATE: 7-29-80	UML CALCULATIONS	

5. DETERMINE THE MAXIMUM FLOWRATE OF DEGRADATION PRODUCTS TO BURNER.

DISCUSSION: IF THE TSU IS ALLOWED TO SIT FOR A LONG PERIOD OF TIME WITH SOME MINIMUM QUANTITY OF ITS CONTENTS ABOVE 580°F, DEGRADATION PRODUCTS WILL EVENTUALLY OCCUPY ALL OF THE ULLAGE SPACE. NEARLY ALL OF THE n-HEPTANE WILL HAVE BEEN REMOVED BY THE PERIODIC PURGES NECESSARY TO MAINTAIN ULLAGE PRESSURE. IF CHARGING IS THEN RESTARTED AND BROUGHT TO ITS MAXIMUM FLOWRATE THEN THE MAXIMUM FLOWRATE OF DEGRADATION PRODUCTS OUT OF THE ULLAGE SPACE IS EQUAL TO THE MAXIMUM FLOWRATE OF ULLAGE GASES.

ASSUME: FLOWRATE AND ENVIRONMENTAL CONDITIONS IN THE WORST CASE ARE SUCH THAT NO PART OF THE DEGRADATION PRODUCTS ARE ABLE TO CONDENSE BEFORE REACHING THE BURNER.

GIVEN: THE MAXIMUM FLOWRATE OF ULLAGE GASES = 2300 $\frac{FL^3}{HR}$
 DENSITY OF D.P. = 0.0475 $\frac{LB}{FL^3}$

CALCULATION:


$$P_{D.P. @ STD.} = \frac{PM}{RT} = \frac{(14.7)(28.9)}{(10.73)(530)} = 0.075 \frac{LB}{FL^3}$$

14.7 PSIA
70°F

$$V_{STD} = V_{580°F} \frac{P_{580°F}}{P_{STD}}$$

$$V_{STD} = 2300 \frac{FL^3}{HR} \left(\frac{0.0475}{0.075} \right) \frac{HR}{60 MIN.}$$

$$V_{STD} = 29.3 \text{ SCFM}$$

PREPARED BY: P. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. 6-1
CHECKED BY:		REPORT NO.
DATE: 7-29-80	UMJ CALCULATIONS	

6. DETERMINE THE MAXIMUM FLOWRATE OF n-HEPTANE OUT OF TSU.


DISCUSSION: AT 425°F THE RATE OF DEGRADATION PRODUCT FORMATION IS NEGLIGIBLE. ASSUMING THE TANK HAS BEEN BROUGHT TO 425°F AND HAS REMAINED AT THAT TEMPERATURE FOR A LONG PERIOD OF TIME, THE ULLAGE SPACE WILL BE FILLED WITH ONLY n-HEPTANE VAPORS. FURTHERMORE, THE AVERAGE TEMPERATURE OF THE ULLAGE SPACE WILL DROP BY 75° FROM THAT WHEN THE TOP LAYER OF OIL IS AT 500°F. THE NEW AVERAGE TEMPERATURE IS 299°F. SOME n-HEPTANE MAY EVEN BE CONDENSING ON THE ROOF WHEN CHARGING IS AGAIN STARTED, AT ITS MAXIMUM FLOWRATE, THE HEPTANE VAPORS WILL BE FORCED OUT OF THE TANK BY THERMAL EXPANSION OF THE FLUID. ASSUME ALSO THAT THE AVERAGE TEMPERATURE OF THE ULLAGE GASES RISES AT A MAXIMUM RATE OF 75°/¼ HR. = 5°/MIN. THE MAXIMUM FLOW OF n-HEPTANE OCCURS WHEN THE MAXIMUM RISE IN ULLAGE GAS TEMPERATURE IS OCCURRING.

GIVEN: RATE OF FLUID VOLUME CHANGE = 791 ft³/HR

$$P_{n\text{-HEPTANE @ } 299^{\circ}\text{F}} = 0.1696 \frac{(851)}{(709)} = 0.1990 \text{ lb/ft}^3$$

$$P_{n\text{-HEPTANE @ } 299^{\circ}\text{F}} = 0.1696 \frac{(851)}{709} = 0.1976 \text{ lb/ft}^3$$

ROOF EDGE HEIGHT - 425°F FLUID HEIGHT = 31 INCHES


PREPARED BY: R. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. 6-2
CHECKED BY:		REPORT NO.
DATE: 7-29-80	UMU CALCULATION	

TANK DIAMETER = 60 ft.
 ROOF IS A SEGMENT OF A SPHERE
 WITH AN 18" RISE FROM TANK EDGE
 TO CENTER & SPHERICAL RADIUS OF
 301.58 FT.

CALCULATION:

ULLAGE VOLUME

VOLUME OF DOME ROOF = VOLUME OF
 ZONE AND SEGMENT OF ONE BASE



R = RADIUS OF SPHERE

$$V = \frac{1}{3} \pi h^2 (3R - h)$$

$$h = \frac{18}{12} \text{ ft}$$

$$R = 301.58 \text{ ft}$$

$$V = \frac{1}{3} \pi \left(\frac{18}{12}\right)^2 \left(3(301.58) - \frac{18}{12}\right)$$

$$V = 2128 \text{ ft}^3$$

VOLUME OF CYLINDER FROM FLUID SURFACE
 TO EDGE OF ROOF.

$$V = \frac{\pi D^2}{4} h = \frac{\pi (60)^2}{4} \left(\frac{31}{12}\right) = 7,309 \text{ ft}^3$$

$$\text{MAXIMUM ULLAGE VOLUME} = 9,432 \text{ ft}^3$$

CHANGE IN VOLUME DUE TO HEATING OF
 GASES

$$M_1 = P_1 V_1 = \left(0.1990 \frac{\text{lb}}{\text{ft}^3}\right) (9432 \text{ ft}^3) = 1877 \text{ lb}$$

$$M_2 = P_2 V_2 = \left(0.1976 \frac{\text{lb}}{\text{ft}^3}\right) (9432 \text{ ft}^3) = 1864 \text{ lb}$$

PREPARED BY:
R. M. ...
CHECKED BY:
DATE:
7-75-80



PAGE NO.
6-3
REPORT NO.

UMU CALCULATION

$$\Delta M = 1877 - 1864 = 13 \text{ lb}$$

$$\dot{m} = \left(\frac{13 \text{ lb}}{5 \text{ min}} \right) \left(\frac{60 \text{ min}}{\text{hr}} \right) = 156 \text{ lb/hr}$$

$$\rho_{\text{avg}} = 0.1983 \text{ lb/ft}^3$$

$$\Delta V = \frac{156 \text{ lb}}{\text{hr}} \frac{\text{ft}^3}{0.1983 \text{ lb}} = 787 \frac{\text{ft}^3}{\text{hr}}$$

TOTAL FLOWRATE OF ULLAGE GASES OUT OF TSU

$$\dot{Q} = 791 + 787 = 1528 \text{ ft}^3/\text{hr}$$

THE FIRST n-Heptane FLOWING OUT OF THE TSU WILL BE AT THE TEMPERATURE OF THE ROOF & 210 °F


$$\rho = \frac{(15.0)(10021)}{(10.73)(670^\circ\text{F})} = 0.2091 \text{ lb/ft}^3$$

LIQUID FLOW BACK TO UMU

$$\left(1528 \frac{\text{ft}^3}{\text{hr}} \right) \left(\frac{0.2091}{92.7} \right) = 7.482 \frac{\text{ft}^3}{\text{hr}}$$

$$Q = \left(7.482 \frac{\text{ft}^3}{\text{hr}} \right) \frac{7.48052 \text{ HR GAL}}{60 \text{ MIN. FT}^3}$$

$$Q = 0.933 \text{ GPM}$$

PREPARED BY: R. MORRISON		PAGE NO. 7-1
CHECKED BY:		REPORT NO.
DATE: 7-25-80	UMC) CALCULATIONS	

7. DETERMINE THE MAXIMUM FLOWRATE OF n-HEPTANE NECESSARY TO COMPENSATE FOR THERMAL CONTRACTION.

DISCUSSION: AT THE BEGINNING OF THE EXTRACTION CYCLE PRODUCTION OF DEGRADATION PRODUCTS IN THE BED COMPENSATES FOR THERMAL CONTRACTION. THE MAXIMUM REQUIRED FLOW OF n-HEPTANE OCCURS NEAR THE END OF THE EXTRACTION CYCLE WHEN THERMAL CONTRACTION OF THE HT43 IS STILL AT ITS MAXIMUM RATE AND NO DEGRADATION ^{PRODUCTS} ARE BEING FORMED.

ASSUME: AVG. TEMP. OF ULLAGE SPACE IS 391°F

GIVEN:

$$\rho_{n\text{-HEPTANE } 391^{\circ}\text{F}} = 0.1696 \text{ lb/ft}^3$$

$$\rho_{n\text{-HEPTANE } 70^{\circ}\text{F}} = 42.7 \text{ lb/ft}^3$$


CONTRACTION RATE OF ULLAGE: 741 FT³/HR

CALCULATION:

$$\dot{V}_{70^{\circ}\text{F}} = \dot{V}_{391^{\circ}\text{F}} \frac{\rho_{391^{\circ}\text{F}}}{\rho_{70^{\circ}\text{F}}} = 741 \frac{(0.1696)}{(42.7)} = 2.856 \frac{\text{ft}^3}{\text{hr}}$$

$$Q = 2.856 \frac{\text{ft}^3}{\text{hr}} \frac{7.48052 \text{ GAL}}{\text{ft}^3} \frac{1 \text{ hr}}{60 \text{ min.}}$$

$$Q = 0.356 \text{ GPM}$$

PREPARED BY: D. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. 8-1
CHECKED BY:		REPORT NO.
DATE: 7-25-80	UMU CALCULATION	

8. DETERMINE THE VOLUME OF n-HEPTANE NECESSARY FOR 1 DAY OF OPERATION.

DISCUSSION: MAXIMUM HEPTANE REQUIREMENT IS BASED ON THE ASSUMPTION THAT NO MORE WILL BE REQUIRED THAN IS NECESSARY TO FILL THE CHANGE IN ULLAGE VOLUME FROM THE FULLY CHARGED TO THE FULLY DISCHARGED CONDITION

ASSUME: THE CHANGE IN FLUID LEVEL IS 18" (NEARLY ALL OF FLUID GOES FROM 580°F TO 425 °F) AND THERE IS NO CONTRIBUTION FROM DEGRADATION PRODUCT FORMATION. TOP LAYER OF FLUID IS AT 500°F, AVG. ULLAGE TEMP. IS 391 °F

GIVEN

$$P_{n\text{-HEPTANE } 70^{\circ}\text{F}} = 42.7 \text{ lb/ft}^3$$

$$P_{n\text{-HEPTANE } 391^{\circ}\text{F}} = 0.1696 \text{ lb/ft}^3$$

CALCULATION:

$$\Delta V = \frac{\pi D^2}{4} h = \frac{\pi (60)^2}{4} \frac{18}{12} = 4291 \text{ FL}^3$$

$$V_{70^{\circ}\text{F}} = \Delta V \frac{P_{391}}{P_{70}} = 4291 \left(\frac{0.1696}{42.7} \right) = 16.35 \text{ FL}^3$$

$$V = (16.35 \text{ FL}^3) \left(7.48052 \frac{\text{GAL}}{\text{FL}^3} \right) = 122 \text{ GAL.}$$

PREPARED BY:
P. MORRISON
CHECKED BY:
DATE:
7-25-80



Rocketdyne Division
Rockwell International

PAGE NO.
9.1
REPORT NO.

UMU CALCULATIONS

9. DETERMINE THE MAXIMUM FLOWRATE OF GN₂ NECESSARY TO BACK-UP THE N-HEPTANE ULLAGE MAINTENANCE SYSTEM

GIVEN: VOLUME FLOW REQUIREMENT = 791 $\frac{\text{ft}^3}{\text{hr}}$

$$\rho_{\text{GN}_2 \text{ STD}} = 0.0724 \text{ LB/ft}^3$$

$$\rho_{\text{GN}_2 \text{ 391}} = 0.0724 \left(\frac{530}{851} \right) = 0.0451 \frac{\text{LB}}{\text{ft}^3}$$

CALCULATION:

$$\dot{V}_{70} = \dot{V}_1 \frac{\rho_1}{\rho_{70}} = 791 \left(\frac{0.0451}{0.0724} \right) = 461.6 \frac{\text{ft}^3}{\text{hr}}$$

$$\dot{V} = \frac{461.6}{60} = 7.69 \text{ SCFM}$$

PREPARED BY:
R. Morrison
 CHECKED BY:
 DATE:
7-7-80



PAGE NO.
10-1
 REPORT NO.

JMD CALCULATIONS

10. DETERMINE THE VOLUME OF LN₂ NECESSARY FOR 1 DAY OPERATION!

ASSUME: FULL EXTRACTION OCCURS ONCE IN A DAY WITH NITROGEN REQUIRED ONLY TO FILL THE CHANGE IN ULLAGE VOLUME BETWEEN FULL CHARGE AND FULL DISCHARGE. AVG TEMP IS 391 °F IN ULLAGE SPACE

GIVEN: CHANGE IN ULLAGE VOLUME = 4291 FL³

$$P_{\text{GN}_2 \text{ STD.}} = 0.0729 \text{ LB/FL}^3$$

$$P_{\text{GN}_2 \text{ 391}} = 0.0951 \text{ LB/FL}^3$$

$$P_{\text{LN}_2} = 50.9 \text{ LB/FL}^3$$

$$V_{\text{STD}} = V_i \frac{P_i}{P_{\text{STD}}} = 4291 \text{ FL}^3 \frac{0.0951}{0.0729}$$

$$V_{\text{STD}} = 2692 \text{ SCF}$$

$$V_{\text{LN}_2} = V_{\text{STD}} \frac{P_{\text{STD}}}{P_{\text{LN}_2}} = 2692 \left(\frac{0.0729}{50.9} \right)$$

$$V_{\text{LN}_2} = 3.80 \text{ FL}^3 (7.48052) \frac{\text{gal}}{\text{FL}^3}$$

$$V_{\text{LN}_2} = 28.4 \text{ gallons LN}_2$$

PREPARED BY:
R. MORRISON
 CHECKED BY:
 DATE:
7.28.80



PAGE NO.
11-1
 REPORT NO.

UMU CALCULATIONS

11. DETERMINE THE RATE THAT OIL MAY BE REMOVED FROM THE TSS ASSUMING A MAXIMUM FLOWRATE OF $Q_{N_2} = 30$ SCFM WITH OIL AT BOTH $70^\circ F$ & $425^\circ F$

ASSUME: Q_{N_2} IN THE PORE SPACE OF THE ROCK/SAND BED IS AT THE SAME TEMPERATURE AS THE ROCK/SAND BED. ALSO, THE TEMPERATURE PROFILE OF THE TANK REMAINS CONSTANT THROUGHOUT THE DRAINING PROCEDURE.


GIVEN: $\rho_{N_2 70^\circ F} = 0.0729 \text{ LB/FE}^3$

$\rho_{N_2 425} = 0.0993 \text{ LB/FE}^3$

$\dot{V}_{70^\circ F} = 30 \frac{\text{FE}^3}{\text{MIN}} \frac{7.48052 \text{ GAL}}{\text{FE}^3} = 229 \text{ GPM}$

$\dot{V}_{425^\circ F} = 30 \frac{\text{FE}^3}{\text{MIN}} \left(\frac{0.0729}{0.0993} \right) \frac{7.48052 \text{ GAL}}{\text{MIN}}$

$\dot{V}_{425^\circ F} = 367 \text{ GPM}$

PREPARED BY: <u>R. MORRISON</u>	 Rocketdyne Division Rockwell International	PAGE NO. 12-1
CHECKED BY:		REPORT NO.
DATE: 7-25-80	UMU CALCULATIONS	

12. DETERMINE THE TIME REQUIRED TO EMPTY THE TSU WHEN THE OIL IS AT 70°F AND WHEN IT IS AT 425°F

GIVEN: $\rho_{OIL\ 70^\circ F} = 53.1 \frac{LB}{ft^3}$

$\rho_{OIL\ 425^\circ F} = 44.91 \frac{LB}{ft^3}$

$M_{OIL} = 1,700,000 \text{ LB}$

$\dot{V}_{OIL\ 70^\circ F} = 224 \text{ GPM}$

$\dot{V}_{OIL\ 425^\circ F} = 367 \text{ GPM}$

$$V_{70^\circ F} = \frac{(1,700,000) \text{ LB } ft^3}{(53.1) \text{ LB}} \frac{(7.48052) \text{ GAL}}{ft^3}$$


$V_{70^\circ F} = 239,500 \text{ GAL.}$

$$t = \frac{V}{\dot{V}} = \frac{239,500 \text{ GAL}}{224 \text{ GPM}} \frac{hr}{60 \text{ min}}$$

$t_{70^\circ F} = 17.8 \text{ hrs.}$

$$V_{425} = \frac{1,700,000 (7.48052)}{(44.91)} = 283,200 \text{ GAL.}$$

$$t = \frac{V}{\dot{V}} = \frac{283,200}{(367)(60)} = 12.9 \text{ hrs.}$$

PREPARED BY: <u>R. MORRISON</u>		PAGE NO. <u>13-1</u>
CHECKED BY:		REPORT NO.
DATE: <u>7-25-80</u>	<u>UMU CALCULATIONS</u>	

13. DETERMINE THE MAXIMUM VOLUME OF GN₂ NECESSARY TO EMPTY THE THERMAL STORAGE ^{UNIT} _{GEN}, IN EXCESS OF THAT REQUIRED FOR NORMAL ULLAGE MAINTENANCE

GIVEN: VOLUME OF 70°F OIL TO BE DISPLACED = 239,500 GAL.
 VOLUME OF 425°F OIL TO BE DISPLACED = 283,200 GAL.
 $P_{GN_2 \ 70^\circ F} = 0.0729 \text{ LB/ft}^3$
 $P_{GN_2 \ 425^\circ F} = 0.0943 \text{ LB/ft}^3$
 $P_{LN_2} = 50.4 \text{ LB/ft}^3$

CALCULATIONS:


$$V_{LN_2} = V_{OIL \ 70^\circ F} \frac{P_{GN_2 \ 70^\circ F}}{P_{LN_2}} = 239,500 \left(\frac{0.0729}{50.4} \right)$$

$$V_{LN_2} = 349 \text{ GAL. FOR } 70^\circ F \text{ TSU}$$

$$V_{STD} = 32,016 \approx 32,000 \text{ SCF}$$

$$V_{LN_2} = 283,200 \left(\frac{.0943}{50.4} \right) = 249 \text{ GAL. FOR } 425^\circ F \text{ TSU}$$

$$V_{STD} = 37,858 \frac{.0943}{.0729} = 23,000 \text{ SCF}$$

PREPARED BY: R. Mark 15001		PAGE NO. 19-1
CHECKED BY:		REPORT NO.
DATE: 7-28-80	n-HEPTANE DENSITY	

$$T_c = 540.2 \text{ K} \qquad T = 282 - 580^\circ\text{F}$$

$$P_c = 27.0 \text{ ATM} \qquad = 912.09 - 577.6^\circ\text{K}$$

$$\omega = 0.351 \qquad P = 1.02 \text{ ATM}$$

$$T_r = 0.763 - 1.070$$

$$P_r = 0.038$$

USE GENERALIZED VIRIAL COEFFICIENTS (1)

$$Z = 1 + \frac{BP}{RT} = 1 + \left(\frac{BP_c}{RT_c} \right) \frac{P_r}{T_r}$$

$$\frac{BP_c}{RT_c} = B^0 + \omega B^1$$


$$B^0 = 0.083 - \frac{0.422}{T_r^{1.6}}$$

$T_r = 0.763$	$T = 282^\circ\text{F}$	$B^0 = -0.5675$
$T_r = 1.070$	$T = 580^\circ\text{F}$	$B^0 = -0.2957$

$$B^1 = 0.139 - \frac{0.172}{T_r}$$

$T_r = 0.763$	$T = 282^\circ\text{F}$	$B^1 = -0.3967$
$T_r = 1.070$	$T = 580^\circ\text{F}$	$B^1 = 0.0095$

(1) REF. INTRODUCTION TO CHEMICAL ENGINEERING THERMODYNAMICS, 3RD EDITION, SMITH AND VAN NESS, 1959, P. 87

PREPARED BY: <i>D. H. ...</i>	 Rocketdyne Division Rockwell International	PAGE NO. 14-2
CHECKED BY:		REPORT NO.
DATE: 7-28-80	<i>n-Heptane Density</i>	

$$\left(\frac{BP_c}{RT_c}\right)_{282^\circ F} = -0.5675 + (.351)(-.3967)$$

$$= -0.7067$$

$$\left(\frac{BP_c}{RT_c}\right)_{580^\circ F} = -.2957 + (.351)(.0095)$$

$$= -.2929$$

$$Z_{282^\circ F} = 1 - .7067 \left(\frac{0.038}{0.763}\right) = 0.965$$

$$Z_{580^\circ F} = 1 - 0.2929 \left(\frac{0.038}{0.763}\right) = 0.985$$

ASSUMPTIONS: n-Heptane is relatively non-polar and non-associating

$$P_{282} = \frac{PM}{ZRT} = \frac{(15.0)(100.21)}{(10.73)(742)(.965)} = 0.196 \frac{lb}{sq\ in}$$

$$P_{580} = \frac{(15.0)(100.21)}{(10.73)(1090)(.985)} = 0.137 \frac{lb}{sq\ in}$$

PREPARED BY:

R. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.

15-1

CHECKED BY:

REPORT NO.

n-HEPTANE CRACKING RATE

DATE:

7-28-70

REF. PETROLEUM REFINERY ENGINEERING, 3RD EDITION, W.L. NELSON, MCGRAW-HILL BOOK CO., INC., 1949, pp. 581-585

Cracking may be described as a first order reaction if the decomposition is limited to a low conversion per pass (< 20 to 25%)

$$K_1 = \frac{1}{t} \ln \frac{a}{a-x} \quad \text{or} \quad = \frac{1}{t} \ln \frac{100}{100-x}$$

K_1 = reaction velocity constant (Fig. 220)

t = time, sec.

a = % of material in feedstock
for a pure feedstock $a = 100$

x = percentage of material that disappears during the reaction time, t .

for heptane x is a mole (gas volume percentage)

$$e^{K_1 t} = \frac{100}{100-x}$$

$$x = 100 - \frac{100}{e^{K_1 t}}$$

PREPARED BY:
R. MORRISON



PAGE NO.
15-2

CHECKED BY:

DATE:
7-28-80

HEPTANE CRACKING RATE

REPORT NO.





Fig. 220.—Reaction velocity constants for the decomposition of hydrocarbons and petroleum fractions into gasoline (except as noted in the text).

T = 1050 K = .006
 T = 1000 K = .002
 T = 850 K = .00004

$K \approx 7.55 \times 10^{-75} T^{23.8}$

PREPARED BY: R. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. 15-3
CHECKED BY:		REPORT NO.
DATE: 7-28-80	2 HEPTANE CRACKING RATE	

FOR CONSERVATISM - ASSUME ALL HEPTANE
AT TEMPERATURE OF TOP LAYER OF FLUID -

ASSUME: TOP LAYER OF FLUID AT 580°F
24 HRS / DAY.

$$K_1 = 4.5 \times 10^{-9} \text{ (T=580°F)}$$

$$24 \times 3600 = 8.64 \times 10^4 \text{ SEC}$$

$$X = 100 - \frac{100}{e^{(4.5 \times 10^{-9})(8.64 \times 10^4)}}$$

$$X: 0.039 \%$$

CRACKING RATE OF HEPTANE SHOULD
BE MUCH LESS THAN 0.1% / DAY.

10 MW PILOT PLANT
THERMAL STORAGE SYSTEM
ULLAGE MAINTENANCE UNIT
SUPPORTING DETAILED ANALYSIS

ROCKETDYNE

26 NOVEMBER 1980

REV. 1: 26 FEBRUARY 1981

F O R E W O R D

This document contains supporting detail analysis for the thermal storage unit (TSU) and ullage maintenance unit (UMU). This material provides supplementary information for the supporting detailed analysis dated 8/6/80.

Included are relief valve calculations for the TSU, nitrogen supply line size to the TSU from the UMU, heptane supply line size to the TSU from the UMU, the vent line routed from the TSU to the UMU, and the heptane concentration in the ullage space of the TSU.

Revision 1 includes the relief valve calculations for tank US on the UMU skid, p. 57 & 58, and a summary sheet for the TSU relief valve sizing, p. 1A.


Questions concerning the contents should be addressed to:

Art Moore

or

(213) 884 - 3324

Dick Morgan

PREPARED BY: W. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 1
CHECKED BY: K. TEO		REPORT NO.
DATE: 23 FEB 80	SOLAR	
	TSU RELIEF VALVES	

SUMMARY

STORAGE AND VENTING OF CALORIA HT 43.

CALCULATIONS PRESENTED HEREIN DETERMINE THE SIZE AND CAPACITY OF THE VENT VALVES SELECTED. THE APPLICATION OF THE VENT VALVES WILL MINIMIZE THE PROBLEMS THAT COULD OCCUR IN THE EVENT OF OVER FILLING, THERMAL CHANGE, EQUIPMENT MALFUNCTION OR EXTERNAL FIRE. IN NORMAL OPERATION THE ULLAGE MAINTENANCE UNIT WILL PROVIDE LEADOFF OF FLAMMABLE VAPORS TO A CONDENSER AND FLARE FOR SAFE DISPOSAL. VENT VALVE SELECTION IS BASED UPON REQUIREMENTS OUTLINED IN THE AMERICAN PETROLEUM INSTITUTE BULLETIN RP-2000.

PREPARED BY:

W. KNIPPEL



Rocketdyne Division
Rockwell International

PAGE NO.

1

CHECKED BY:

REPORT NO.

DATE:

11 DEC 80

SOLAR

TSU RELIEF VALVES

REVIEW OF CALCU.

TOTAL RATE OF EMERGENCY VENTING REQUIRED FOR FIRE EXPOSURE VERSUS WETTED SURFACE AREA, REF. TABLE 2, PAR. 1.5.2, API STANDARD 2000

$$\text{WETTED AREA} = 60\pi 30 = 5655 \text{ SQ FT}$$

VENTING REQ'D, $V = 742,000 \text{ CFH}$, FROM TABLE FLOW CAPACITY OF RELIEF, REF. NFC, PARA. 2-2.5.9 (b)

$$\text{CFH} = 1667 C_f A \sqrt{P_t - P_a}$$

$$C_f = \frac{293,000}{1667 \sqrt{6} 113.1} = 0.634 \text{ REF. 12" GROTH VALVE}$$

$$C_f = \frac{133,000}{1667 \sqrt{6} 50.03} = 0.651 \text{ REF. 8" GROTH VALVE}$$

$$\text{CFH}_{12" \text{ GROTH}} = 1667 (0.634) (113.1) \sqrt{20} = 534567$$

$$\text{CFH}_{8" \text{ GROTH}} = 1667 (0.651) (50.03) \sqrt{20} = 242808$$


TOTAL VENT CAPACITY AVAIL. 777375 CFH

$$777375 > 742000 \text{ CFH}$$

$$\text{ALSO } \text{CFH} = \sqrt{\frac{1337}{L \sqrt{M}}} \text{ REF. NFC, PARA. 2-2.5.5}$$

$$\text{CFH} = 742,000 \frac{(1337)}{65.3 \sqrt{415}} = 745758 < 777375$$

REV.
1
49
1A

PREPARED BY: W. D. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 2
CHECKED BY: K. YED		REPORT NO.
DATE: 23 FEB 80	SOLAR	
	TSU RELIEF VALVE	

STORED PRODUCT, EXXON CALORIA HT 43

- * MOLECULAR WEIGHT, 415
- * HEAT OF VAPORIZATION, 65.3 $\frac{BTU}{LB}$ @ B.P. OF 800°F.
- FLASH POINT 400°F.

AUTOIGNITION TEMPERATURE 759°F

TYPE OF VESSEL VERTICAL CYLINDER

OIL CAPACITY 254 000 GALLONS (W/ROCK)

DIA. OF VESSEL 60'-0

HEIGHT OF VESSEL 44'-0

WORKING PRESSURE 10 TO 12 INCHES W.C.

DESIGN PRESSURE 20.0 INCHES W.C.

LOW FLOW RELIEF SETTING 18.0 INCHES W.C.

HIGH FLOW RELIEF SETTING 20.0 INCHES W.C.


OPERATING TEMPERATURE 580°F.

HIGH PRESSURE/VOLUME RATE 1,330,000 SCFH (NO INSULATION)

HIGH PRESSURE/VOLUME RATE 99,750 SCFH (INSULATED)

GROTH EQUIPMENT CORP, HOUSTON TEXAS, HERB PARKER 713-675-6151

EXXON CRIS BYLOW 552-5595 * INFO REL'D PHONE

PREPARED BY: W. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 3
CHECKED BY: K YEO		REPORT NO.
DATE: 17 JAN 80	SOLAR	
	TSU RELIEF VALVE	

DETERMINE INDIVIDUAL RELIEVING RATES

1. INADVERTENT VALVE OR PUMP FLOW INLET MAXM

1.28 x 10⁶ LB/HR @ 575°F

$$1.28 \times 10^6 \frac{\text{LBS}}{\text{HR}} \times \frac{\text{CU FT}}{41.0 \text{ LBS}} = 31219.5 \text{ CFH} = 520 \text{ SCFM}$$

2. STEAM GENERATION RATE IN TSU, WATER LEAK ETC

$$32 \frac{\text{MW}}{\text{DAY}} \times \frac{\text{DAY}}{20 \text{ HR}} \times 0.056 \frac{\text{LBS BTU}}{\text{MIN WATT}} \times \frac{\text{LB OF STEAM}}{1000 \text{ BTU}} =$$

$$91 \text{ LBS OF STEAM/MIN} \quad \text{OR} \quad 26.8 \frac{\text{CU FT}}{\text{LB}} \times \frac{60 \text{ MIN}}{\text{HR}} \times \frac{91 \text{ LBS}}{\text{MIN}} =$$

$$146,328 \text{ CFH} \quad 1.517 \frac{\text{LBS}}{\text{SEC}}$$

3. FIRE

REF. API 2000

$$A = 60 \pi \times 30 = 5655 \text{ SQFT}$$

$$\text{CFH} = 1107 A^{0.82}$$


$$\text{CFH} = 1,321,729$$

$$\text{ALSO} \quad \text{CFH} = \frac{V(1,337)}{L \sqrt{M}}$$

$$\text{CFH} = \frac{1,321,729 (1,337)}{65.3 \sqrt{415}} = 1,328,424$$

USE CFH = 1,330,000 FOR LARGE EMERGENCY RELIEF

$$\text{CFH} = 1,330,000 (1.075) = 99750 \text{ (INSULATION FACTOR)}$$

PREPARED BY: W. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 4
CHECKED BY: K. YEO		REPORT NO.
DATE: 23 FEB 80	SOLAR	
	TSU RELIEF	

4. STEAM LEAK

$$65,500 \text{ LBS/HR} \times \frac{26.8 \text{ CUFT}}{\text{LB}} = 1,755,400 \text{ CFH}$$

I. PRESSURE DROP THRU HIGH FLOW RELIEF SYSTEM

IS 20 INCHES W.C., FLOW (2.) = 1.517 $\frac{\text{LBS}}{\text{SEC.}}$

ASSUME 12" GROTH VALVE & 4'-0 LG PIPE

REF. CRANE, PIPE LOSS

$$\Delta f = f \frac{L}{DP} \left[\frac{W}{0.525 Y d^2} \right]^2$$

$$Re = 22716 \frac{W}{d \mu} = \frac{22716 (1.517)}{(12) 0.0205} = 140,082$$

$$f = 0.0138$$

$$\Delta f = 0.0138 \left(\frac{4}{1} \right) \frac{26.8}{1} \left[\frac{1.517}{0.525 (1) (12)^2} \right]^2 (27.72)$$


$$\Delta f = 0.0165 \text{ INCHES W.C.}$$

ENTRY LOSS

$$k = 0.5 \text{ REF. CRANE}$$

$$\Delta f = k V \left[\frac{W}{0.525 Y d^2} \right]^2$$

$$\Delta f = 0.5 (26.8) \left[\frac{1.517}{0.525 (1) 144} \right]^2 (27.72) = 1.496 \text{ INCHES W.C.}$$

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 5
CHECKED BY: K. YEO		REPORT NO.
DATE: 23 FEB 65	SOLAR	
	TSU RELIEF VALVE.	

ORIFICE LOSS

$$\Delta p = \left[\frac{W}{0.525 Y d^2 C} \right]^2 \frac{1}{V_1}$$

$$\Delta p = \left[\frac{1.5167}{0.525(1)(144)(.59)} \right]^2 (26.8) 27.72$$

$$\Delta p = 0.86 \text{ INCHES W.C.} \quad \text{OK}$$

II. HIGH FLOW RELIEF SYSTEM, FLOW (3) = 99,705 CFH

$$P_1 = \frac{MP}{10.72T} = \frac{415(14)}{10.72(1040)} = 0.5211 \frac{\text{LBS}}{\text{CUFT}} \quad \text{CALORIA}$$

$$P_2 = \frac{29}{415} P_1 = 0.0364 \frac{\text{LBS}}{\text{CUFT}} \quad \text{AIR}$$

$$S_G = 14.309 \quad \text{VALVE SET} = 11.540Z/\text{SQIN}$$

12" GROTH VALVE CAPACITY FROM CHART = 542000 SCFH

$$\frac{542000}{(14.309)^{\frac{1}{2}}} \left(\frac{520}{1040} \right)^{\frac{1}{2}} = 101316 \text{ CFH} > 99705 \text{ REQ'D}$$

OK

III. LOW FLOW RELIEF SYSTEM

FLOW = 65.5 LBS/HR (ULLAGE MAINT. SYS.)
HEPTANE


$$P_1 = \frac{MP}{10.72} = \frac{100.20(14)}{10.72(1040)} = 0.1258 \frac{\text{LBS}}{\text{CUFT}}$$

$$S_G = \frac{.1258}{.0364} = 3.46 \quad \text{VALVE SET} = 10.39Z/\text{SQIN}$$

8" GROTH VALVE CAPACITY = 235000 SCFH

$$\frac{235000}{(3.46)^{\frac{1}{2}}} \left(\frac{520}{1040} \right)^{\frac{1}{2}} = 89334 \text{ CFH} > 520 \text{ CFH (HEPTANE)}$$

ASSUME 8" PLUS 12" RELIEF CAPACITY ALLOW FOR INCREASE OF TEMP. ABOVE 580°F FOR FIRE.


PREPARED BY: W. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 6
CHECKED BY: K. TEO		REPORT NO.
DATE: 23 FEB 80	SOLAR	
	TSV RELIEF VALVE	

FLOW CAPACITY OF 12 INCH GROTH FLAME ARRESTOR

@ 10.39 OZ/SQ IN IS 200,000 SCFH

$$\frac{200,000}{(3.46)^{1/2}} \left(\frac{520}{1040} \right)^{1/2} = 76,029 \text{ CFH (HEPTANE)}$$


NOTE FINAL VALVE SELECTION OF GROTH RELIEF
HAS INCREASED CAPACITY ABOVE THOSE SPECIFIED
HEREIN. (17 OCT 80 W.O.K.)

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 1
CHECKED BY: K. YEO		REPORT NO.
DATE: 11 NOV 80	10 MWe PILOT PLANT	
	ULLAGE MAINTENANCE SYSTEM	

THERMAL STORAGE UNIT VENT PIPE

SUMMARY

CALCULATIONS ATTACHED WERE MADE TO DETERMINE THE HEAT TRANSFER CAPACITY OF THE PIPE LINE PROVIDED TO VENT THE THERMAL STORAGE UNIT TO THE ULLAGE MAINTENANCE SYSTEM. THE PIPE LINE PROVIDES ABOUT 200 LINEAL FEET OF AIR COOLED STEEL PIPE SURFACE. THE UMU DISPOSES OF THE NON-CONDENSIBLE FRACTION OF WASTE PRODUCT LEAVING THE TSU AND COLLECTS AND RETURNS CONDENSIBLES TO THE TSU. THIS PIPE LINE PROVIDES THE COOLING REQUIRED BY THE CONDENSIBLES. THE PRESSURE LOSS CALCULATED ILLUSTRATES THAT THE POSITIVE PRESSURE WITHIN THE TSU WILL ADEQUATELY DISCHARGE THE GASES AND VAPOR. A BLOWER FURNISHED ON THE UMU SKID WILL MAINTAIN A CONSTANT FLOW TO THE FLARE SYSTEM.

PREPARED BY: W.O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 2
CHECKED BY: K. YEO		REPORT NO.
DATE: 26 SEPT 79	ULLAGE MAINTENANCE SYSTEM	
	HEAT TRANSFER, 6" DIA PIPE LINE	

REV. 10 NOV 80

GIVEN DATA

1. THERMAL STORAGE UNIT OPERATING TEMP.
DAILY CYCLE 425° TO 580°F.
2. MAXIMUM FLOW RATE OF ULLAGE GAS = 2300 $\frac{\text{CUFT}}{\text{HR}}$
3. LENGTH OF 6" DIA PIPE, AIR COOLED, 200 FT
4. MAXIMUM AMBIENT TEMP. OF STEEL PIPE ASSUMED TO BE 140°F

5. DENSITY OF ULLAGE GAS @ 580°F = 0.0388 $\frac{\text{LBS}}{\text{CUFT}}$

MAXIMUM $\Delta T = T_{g1} - T_{g2} = 580 - 150 = 430^\circ\text{F}$.

AVERAGE TEMP OF GAS = $\frac{580 + 150}{2} = 365^\circ\text{F}$

$\rho = \frac{580 + 460}{365 + 460} (0.0388) = 0.04891 \frac{\text{LBS}}{\text{CUFT}}$

$Q = 2300 \frac{\text{CUFT}}{\text{HR}} \times 0.04891 \frac{\text{LBS}}{\text{CUFT}} \times 1.170 \frac{\text{BTU}}{\text{LB}} \times 430^\circ\text{F} = 56595 \frac{\text{BTU}}{\text{HR}}$

SURFACE AREA OF PIPE = $200(1.73) = 346 \text{ SQFT}$

LMTD

ASSUME AIR ENTERS @ TEMP. OF 120° AND LV 130°F

ASSUME GAS ENTERS @ 580° AND LV @ 150°F

REF, ROCKETDYNE IL 141-42-B352, DRAWING NO. 40P7005132020
 Δ , 3250 Δ , 2021 Δ , 2027 Δ

PREPARED BY:
W. O. KNIPPEL



Rocketdyne Division
Rockwell International

PAGE NO.
3

CHECKED BY:
K. YEO


REPORT NO.

DATE:
26 SEPT 79

ULLAGE MAINTENANCE SYSTEM

HEAT TRANSFER, 6" DIA PIPE LINE

REV 11 NOV 80



$$\text{LMTD} = \frac{450 - 30}{\text{LOG}_E \frac{450}{30}} = \frac{420}{2.708} = 155^{\circ}\text{F}$$

$$\text{AREA OF PIPE } 200 \times 1.73 = 346 \text{ SQ FT}$$

$$U = \frac{Q}{A \times \text{LMTD}} = \frac{56595}{346 \times 155} = 1.055 \frac{\text{BTU}}{\text{SQ FT-HR-}^{\circ}\text{F}} \text{ REQUIRED}$$

$$\text{REF. ASHREA CHART "U" AVAILABLE} \leq 3.94 \frac{\text{BTU}}{\text{SQ FT-HR-}^{\circ}\text{F}}$$

CHECK PRESSURE DROP

$$R_e = 22716 \frac{8^{\rho}}{d^4} \quad \text{REF. CRANE TECH. BUL. 410}$$

$$R_e = 22716 \frac{2300 (0.04891)}{3600 (6.065)^2} = 0.013898$$

$$R_e = 8421 \quad f = 0.032$$

$$\Delta f = f \frac{L}{D} \left(\frac{1}{\rho} \right) \left[\frac{W}{0.525 Y d^2} \right]^2 \quad W = \frac{2300 (0.04891)}{3600}$$


$$\frac{L}{D} \approx (12) 90^{\circ} \text{EL} + 1 \text{ CHECK} + 1 \text{ VALVE} = 460 \quad K = 14.72$$

$$K \approx (3) \text{ ENTRANCE} (3) \text{ EXIT} \quad K = (1.5)^3 = 4.5$$

$$\frac{L}{D} \approx \text{PIPE} = 400 \quad K = 12.80$$

$$K = 32.02$$

$$\Delta f = 32.02 \left(\frac{1}{0.04891} \right) \left[\frac{0.03125}{0.525 (1) (36.78)} \right]^2 = 0.001714 \text{ PSI}$$
$$= 0.0475 \text{ IN H}_2\text{O}$$

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 4
CHECKED BY: K. TED		REPORT NO.
DATE: 26 SEPT 79	ULLAGE MAINTENANCE SYSTEM	
	WASTE PRODUCTS	

REV 10NOV80


PROPERTIES OF UMU WASTE PRODUCT, TEMP = 391°F

	M.W.	VOL%	C_p BTU/FT ³ °F	M CENTIGRASE	
	H ₂	2	20.8	3.50	0.0120
	N ₂	28	2.0	0.252	0.0247
	CO	28	2.4	0.252	0.0247
	CO ₂	44	2.0	0.240	0.0214
	O ₂	32	0.2	0.233	0.0275
METHANE	CH ₄	16	20.5	0.670	0.0155
ETHANE	C ₂ H ₆	30	19.3	0.600	0.0140
ETHYLENE	C ₂ H ₄	28	0.5	0.540	0.0150
PROPANE	C ₃ H ₈	44	12.3	0.534	0.0118
PROPYLENE	C ₃ H ₆	42	2.0	0.473	0.0128
ISOBUTANE	n C ₄ H ₁₀	58	8.1	0.535	0.0128
	i C ₄ H ₁₀	58	2.4	0.535	0.0128
PENTANE	n C ₅ H ₁₂	72	6.0	0.529	0.0102
	i C ₅ H ₁₂	72	0.4	0.529	0.0102
	H ₂ O	18	1.0	0.4650	0.0160

$C_{p\text{ AVE.}} = 1.1700$

$M_{\text{AVE.}} = 0.013898$

REF. TEMA

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 5.
CHECKED BY: K. YEO		REPORT NO.
DATE: 14 NOV 80	10 MW _e PILOT PLANT	
	ULLAGE MAINTENANCE SYSTEM	

THERMAL STORAGE UNIT CONDENSATE RETURN

SUMMARY

THE UMU DISPOSES OF THE NON-CONDENSIBLE FRACTION OF WASTE AND COLLECTS AND RETURNS THE CONDENSIBLES TO THE TSU. A 1.5 GPM CAPACITY PUMP RETURNS THE CONDENSATE FROM THE RECEIVER ON THE UMU SKID VIA A 1 1/2 IN. DIA. PIPE LINE APPROXIMATELY 200 FEET LONG. THE ATTACHED CALCULATIONS WERE MADE TO DETERMINE THE PRESSURE LOSS OF THE PIPE LINE. THE PUMP TO BE FURNISHED ON THE UMU SKID WILL PROVIDE A 1.5 GPM FLOW AGAINST A TOTAL HEAD OF 100 FEET. THE CALCULATED HEAD IS 25 1/2 FEET AND IS THEREFORE ADEQUATE.

PREPARED BY:
W. O. KNIPPEL



Rocketdyne Division
Rockwell International

PAGE NO.

6

CHECKED BY:
K. YEO

REPORT NO.

ULLAGE MAINTENANCE SYSTEM

DATE: REV.
12 NOV. 80

TSU HEPTANE RETURN

GIVEN:

- 1- MAXIMUM FLOW RATE OF HEPTANE INTO TSU = 0.356 GPM
(REQ'D)
- 2- PUMP FLOW RATE OF HEPTANE = 1.5 GPM
- 3- LENGTH OF PIPE = 200 LINEAL FEET, 1 1/2" DIA.
- 4- (16) 90° ELBOWS, (1) REDUCER, 1 1/2" DIA.
- 5- ELEVATION IS 40 FEET
- 6- LENGTH OF PIPE = 10 LINEAL FEET, 1" DIA
- 7- (4) 90° ELBOWS, (1) TEE, (1) CHECK, (1) VALVE, 1" DIA

VELOCITY IN 1 1/2" DIA PIPE

$$V = \frac{1.5 \text{ GAL}}{\text{MIN.}} \times \frac{\text{CUFT}}{7.48 \text{ GAL}} \times \frac{1}{0.01414 \text{ SQFT}} \times \frac{\text{MIN}}{60 \text{ SEC}} = 0.24 \text{ FPS}$$

VELOCITY IN 1" DIA PIPE

$$V = \frac{1.5 \text{ GAL}}{\text{MIN.}} \times \frac{\text{CUFT}}{7.48 \text{ GAL}} \times \frac{1}{0.0060 \text{ SQFT}} \times \frac{\text{MIN}}{60 \text{ SEC}} = 0.56 \text{ FPS}$$

$$R_E = 123.9 \frac{d \nu \rho}{\mu} \quad \text{TEMP} = 150^\circ \text{F HEPTANE}$$

$$R_{E1\frac{1}{2} \text{ IN PIPE}} = 123.9 \left(\frac{1.610}{0.28} \right) (0.24) 39.87 = 6817$$

$$R_{E1 \text{ IN PIPE}} = 123.9 \left(\frac{1.049}{0.28} \right) (0.56) 39.87 = 10364$$

$$f_{1\frac{1}{2}} = 0.035$$


$$f_1 = 0.033$$

REF. CRANE TECH. BUL. 410, TEMA

PREPARED BY:
W. O. KNIPPEL

CHECKED BY:
K. YEO

DATE: REV.
14 NOV 80



PAGE NO.
7

REPORT NO.

ULLAGE MAINTENANCE SYSTEM
TSU HEPTANE RETURN

1 1/2 IN. DIA., K

$$K = f \frac{L}{D} = 0.035 \frac{(200)}{0.1342} = 52.16 \quad (\text{PIPE})$$

(16) 90° EL $30 \times 16 \times 0.035 = 16.80$

(1) REDUCER $K = 0.25$

$$K_{1\frac{1}{2}"}_{\text{TOTAL}} = 69.21$$

$$\Delta P = \left[\frac{Q}{236d^2} \right]^2 K P = \left[\frac{1.5}{236(2.59)} \right]^2 (69.21)(39.87) = 0.0166 \text{ PSI}$$

1 IN. DIA., K

PIPE $K = 0.033 \frac{(10)}{0.0874} = 3.78$

(4) 90° EL = $30 \times 4 \times 0.033 = 3.96$

VALVES (2) = $100 \times 0.033 = 3.30$

TEE (1) = $20 \times 0.033 = 0.66$

$$K_{1"}_{\text{TOTAL}} = 11.7$$

$$\Delta P = \left[\frac{1.5}{236(1.1)} \right]^2 (11.7)(39.87) = 0.0156 \text{ PSI}$$


40' ELEVATION

$$40 \times 0.433103 \times \frac{39.87}{62.4} = 11.069 \text{ PSI}$$

$$\text{TOTAL } \Delta P_0 = 11.10 \text{ PSI}$$

REF. ROCKETDYNE IL 141-42-8352, DRAWING


NO. 40P7005/32020 Δ , 3250 Δ , 2021 Δ , 2027 Δ

PREPARED BY: W. D. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 8.
CHECKED BY: K. YEO KHL		REPORT NO.
DATE: 14 NOV 80	10 MG _e PILOT PLANT	
	ULLAGE MAINTENANCE SYSTEM	

THEMAL STORAGE UNIT NITROGEN SUPPLY

SUMMARY

THE ULLAGE MAINTENANCE UNIT PROVIDES AN OXYGEN FREE ULLAGE GAS OVER THE TSU HEAT TRANSFER OIL. AIR IS EXCLUDED FROM THE ULLAGE SPACE IN THE TSU BY MAINTAINING A SLIGHT POSITIVE PRESSURE WITH VAPORS RESULTING FROM OIL DECOMPOSITION OR AN EMERGENCY BACKUP SUPPLY OF GASEOUS NITROGEN. THE ATTACHED CALCULATIONS ILLUSTRATE THE FLOW AND PRESSURE LOSS IN THE 2 INCH PIPE SUPPLY LINE OF GN₂. THE UPSTREAM PRESSURE REGULATOR FURNISHED ON THE UMU SKID LOCATED AT THE INLET TO THE SUPPLY WILL BE SET TO REGULATE THE DOWNSTREAM PRESSURE AT 25 PSIG. THIS PRESSURE AT THE PIPE INLET IS ADEQUATE COMPARED TO 2 1/2 PSI PRESSURE LOSS CALCULATED AND GN₂ FLOW TO THE TSU WILL EXCEED THE MINIMUM REQUIRED 30 SCFM.

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 9
CHECKED BY: K. YEO		REPORT NO.
DATE: REV 14 NOV 80	ULLAGE MAINTENANCE SYSTEM	
	GN ₂ SUPPLY	

GIVEN:

- 1- GN₂ REQUIRED FLOW CAPACITY = 30 SCFM MINIMUM
- 2- ACTIVATION PRESSURE = 3.5 IN. W.C. IN TSU
- 3- DEACTIVATE @ 7.0 IN. W.C. IN TSU
- 4- 2 IN DIA PIPE LINE, 200 FT LG
- 5- (16) 90° ELBOWS, 2 IN. DIA.
- 6- (1) 2 IN TO 1 IN REDUCER
- 7- (1) VALVE, 1 IN. DIA.
- 8- 1" PIPE, 10 FT LG
- 9- UP STREAM LINE PRESSURE 3 TO 13 PSIG

ASSUME MINIMUM FLOW = 50 SCFM

$$W = \frac{50 \text{ CUFT}}{\text{MIN}} \times \frac{0.07274 \text{ LBS}}{\text{CUFT}} \times \frac{\text{MIN}}{60 \text{ SEC}} = 0.0606 \frac{\text{LBS}}{\text{SEC}}$$


$$Re = 22716 \frac{W}{d \mu}$$

$$Re_{1 \text{ IN. DIA}} = \frac{22716 (0.0606)}{(1.049) 0.0175} = 74988 \quad f = 0.025$$

$$Re_{2 \text{ IN. DIA}} = \frac{22716 (0.0606)}{(2.067) 0.0175} = 38056 \quad f = 0.025$$

REF. CRANE TECH. BUL. 410, ROCKETDYNE IL 141-42-8352,

DRAWING NOS. 40PT005132020 Δ , 3250 Δ , 2021 Δ , 2027 Δ

PREPARED BY: W. O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 10.
CHECKED BY: K. YEO		REPORT NO.
DATE: 14 NOV 80	ULLAGE MAINTENANCE SYSTEM GN ₂ SUPPLY	

K, 2 IN. DIA

$$K = f \frac{L}{D} = \frac{0.025(200)}{0.1722} = 29.04 \text{ (PIPE)}$$

(16) 90° EL 30x16x0.025 = 12.0

(1) REDUCER K = 0.33

$$K_{2" \text{ TOTAL}} = 41.37 \quad Y = 0.925 \frac{\Delta P}{P_1} = 0.23 \text{ (ASSUMED)}$$

$$\Delta P = K \frac{1}{\rho} \left[\frac{W}{0.525 Y d^2} \right]^2$$

$$\Delta P_{2" \text{ DIA}} = \frac{41.37}{0.07274} \left[\frac{0.0606}{0.525(0.925)4.272} \right]^2$$

$$\Delta P_{2" \text{ DIA}} = 0.485 \text{ PSI}$$

K, 1 IN DIA

$$K = f \frac{L}{D} = \frac{0.025(10)}{0.0874} = 2.86 \text{ (PIPE)}$$

$$K = 0.025(340) = 8.5 \text{ (GLOBE VALVE)}$$

$$\Delta P_{1" \text{ DIA}} = \frac{11.36}{0.07274} \left[\frac{0.0606}{0.525(0.925)1.10} \right]^2$$

$$\Delta P_{1" \text{ DIA}} = 2.01$$

$$\text{TOTAL } \Delta P = 2.495 \text{ PSI}$$

Internal Letter



Rockwell International

Date: . 4 November 1980

No: . IL 141-42-8458

TO: (Name, Organization, Internal Address)

. D. G. Landy
. D/585-141
. AC35

FROM: (Name, Organization, Internal Address, Phone)

. R. H. Morrison
. D/585-141
. AC35
. 3232

Subject: . 10 MWe PILOT PLANT - HEPTANE CONCENTRATION IN ULLAGE SPACE OF TSU

- References: 1) IL 141-43-8352, "10 MWe Pilot Plant - Ullage Maintenance Unit (UMU), Description, Operation, and Analysis", R. H. Morrison to G. R. Morgan.
- 2) Lipscomb, T. G., Correspondence, Exxon Co. USA., Houston, 25 September 1980.

INTRODUCTION

Attached to this letter (Appendix A) is the analysis of heptane concentration in the ullage space of the TSU. This analysis has been performed to assist definition of the requirements for a system to monitor the oxygen concentration in the TSU ullage space.

SUMMARY OF RESULTS

Heptane concentration vs. time of day and the corresponding thermal charge in the TSU are depicted in Figs. 1A and 1B. The lower curve in Fig. 1A shows the heptane concentration when the rate of oil degradation (fresh oil) is at the maximum reported in Ref. 1. The heptane concentration varies from 5 to 26 percent by mass. The upper curve shows heptane concentration when the rate of oil degradation (weathered oil) is one half the maximum. In this case the heptane concentration varies from 32 to 55 percent by mass.

The thermal charge cycle of Fig. 1B is a nominal cycle assumed as the basis for this analysis. A charge of 0 percent corresponds to the condition when all of the rock/sand bed and the oil in its void space are at 425°F. The TSU is at 100 percent charge when all of the rock/sand bed and the oil in its void space are at 580°F. The thermocline between hot and cold oil is assumed to have negligible thickness. The TSU is charged in four hours from 9 AM to 1 PM and discharged in 4 hours from 5 PM to 9 PM.

DISCUSSION

The assumptions and data used in the solution of this problem are presented in Appendix A. The primary source of data and operating characteristics was Ref. 1. The heptane concentration vs. time of day is described by the curves in Fig. 1A

DISCUSSION (CONT'D)

after at least four days of continuous operation with the TSU undergoing the assumed thermal cycle described by Fig. 1B. This cycle represents ideal system operation but not necessarily normal system operation. Extremes in system operation can be envisioned (Ref. 1) where heptane concentration in the TSU ullage space will reach 100 percent or 0 percent.

The rationale for selecting a minimum oil degradation rate equal to one-half the maximum was based on data received in Ref. 2. No experimental data on the rate of oil degradation in weathered oil was available. Observation suggests, however, that weathered oil will degrade at a slower rate than fresh oil as evidenced by the lower vapor pressure. The vapor pressure of weathered oil has been reported to be approximately one-half that of fresh oil, therefore a minimum oil degradation rate of one-half has been assumed for the purposes of this calculation.


R. H. Morrison

R. H. Morrison
Valves & Controls

1w

cc: E. G. Spencer AC35
G. F. Tellier *422* AC35
G. R. Morgan AA95
J. G. Absalom AA95
A. E. Moore AA95

FIGURE 1



PREPARED BY:



Rocketdyne Division
Rockwell International


PAGE NO.

CHECKED BY:

REPORT NO.

DATE:

APPENDIX A

PREPARED BY: P. M. HARRISON	 Rocketdyne Division Rockwell International	PAGE NO. A1
CHECKED BY:		REPORT NO.
DATE: 10-27-80		

DETERMINE: CONCENTRATION OF γ -HEPTANE (C_7) AS A FUNCTION OF TIME IN THE ULLAGE SPACE.

ASSUME: THE INITIAL CONCENTRATION OF C_7 IN THE ULLAGE SPACE IS ZERO

ALL OF THE OIL IN THE ROCK BED OF THE TANK IS AT 425 °F IN THE FULLY DISCHARGED STATE.

NO HEAT IS LOST THROUGH THE WALLS OF THE TANK.

ALL OF THE OIL ABOVE THE ROCK BED IS ALWAYS AT 580 °F

ALL OF THE OIL IN THE TANK IS AT 580 °F IN THE FULLY CHARGED STATE

THE THERMOCLINE HAS NO THICKNESS →
i.e. ALL OIL IN THE TANK IS EITHER AT 425 °F OR 580 °F

PREPARED BY:
R. H. Morrison






PAGE NO.
A 2

CHECKED BY:

REPORT NO.

DATE:
10-27-80

ASSUME : - CONT. -



→ CHARGING

DISCHARGING ←

EACH CHARGING AND DISCHARGING
CYCLE REQUIRES 4 HRS.

AVG. DAY →

START CHARGING	AT 9 AM.
STOP CHARGING	AT 1 PM.
START DISCHARGING	AT 5 PM.
STOP DISCHARGING	AT 9 PM.

PREPARED BY:



Rocketdyne Division
Rockwell International

PAGE NO.

A3

CHECKED BY:

REPORT NO.

DATE:

ASSUME: - CONT. -

C₂ AND DEGRADATION PRODUCTS (GAS)
BEHAVE AS AN IDEAL GAS AT THE
AVERAGE TEMPERATURE AND PRESSURE OF
THE UMU

THE AVERAGE MOLECULAR WEIGHT OF
THE GAS IS 28.9 LB/LBMOL.

ULLAGE PRESSURE IS MAINTAINED
CONSTANT AT ITS AVERAGE VALUE

PREPARED BY:

F. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.

A 4

CHECKED BY:

REPORT NO.

DATE:

10-27-80

GIVEN: OIL DEGRADATION RATE AT 580 °F:
 IN ROCK BED = 42×10^{-6} LB / LB-HR = $R_{GAS RB}$
 ABOVE ROCK BED: 13.75×10^{-6} LB / LB-HR = $R_{GAS ABS}$

OIL DEGRADATION RATE AT 425 °F = 0

EXPANSION AND CONTRACTION RATE OF
 OIL DURING A HR. CHARGING AND DISCHARGING
 PERIOD = 741 FL³ / HR = ΔV

TOTAL MASS OF OIL IN TSU = M_{OIL}
 $M_{OIL} = 1,640,000$ LBS.


DENSITY OF OIL AT 580 °F = $\rho_{580°F} = 40.85$ $\frac{LB}{FL^3}$

DENSITY OF OIL AT 425 °F = $\rho_{425°F} = 49.91$ $\frac{LB}{FL^3}$

VOLUME OF VOID SPACE IN ROCK BED = V_v
 $V_v = 29,800$ FL³

AVERAGE TEMP OF ULLAGE SPACE =
 (CENTER CEILING TEMP. + CENTER OIL SURFACE
 TEMP.) / 2 = $(282 + 580) / 2 = 431$ °F

AVERAGE ULLAGE PRESSURE = P
 $P = 9$ in. W.C. = 0.325 PSIG = 14.13 PSIA
 $P_{atm} = 13.8$ PSIA.

PREPARED BY: R. MORRISON	 Rocketdyne Division Rockwell International	PAGE NO. A5
CHECKED BY:		REPORT NO.
DATE: 10-27-80		

GIVEN: - CONT. -

SPECIFIC GAS CONSTANT OF GASEOUS
 $C_g = 1596 \text{ (ft}^2 \text{ lbf / lbmol}^{\circ}\text{R)} / 100 \text{ (lb / lbmol)}$
 $R_g = 15.96 \text{ ft}^2 / \text{OR}$

SPECIFIC GAS CONSTANT OF THE GAS = R_{GAS}
 $R_{GAS} = 1596 / 28.9 = 53.49 \text{ ft}^2 / \text{OR}$

VOLUME OF ULLAGE SPACE WHEN ALL
 OIL IS 425°F = $V_{425} = 9932 \text{ ft}^3$

PREPARED BY:

R. HARRISON



Rocketdyne Division
Rockwell International

PAGE NO.

A's

CHECKED BY:

REPORT NO.

DATE:

10-27-70

CALCULATION:

FROM 9 P.M. TO 5 P.M. (NEXT DAY), NO C_7 NEED EVER BE ADDED TO THE ULLAGE SPACE. THE OIL NEVER CONTRACTS AND THERE IS ALWAYS A POSITIVE RATE OF FORMATION OF GAS.

FROM 5 P.M. TO 9 P.M. THE OIL IS CONTRACTING AND THE ULLAGE SPACE IS EXPANDING. ALSO, THE RATE OF GAS FORMATION IS DECREASING. AT SOME POINT THE RATE OF GAS FORMATION BECOMES INSUFFICIENT TO COMPENSATE FOR THE EXPANSION OF THE ULLAGE SPACE. AT THIS POINT PRESSURE DROPS AND C_7 MUST BE ADDED TO THE ULLAGE SPACE TO MAINTAIN PRESSURE.

LET F = FRACTION OF ROCK BED AT 925°F

9 P.M. TO 9 A.M. : $F = 1$

9 A.M. TO 1 P.M. : $F = 1 - \frac{1}{4}t$ t (hours)

1 P.M. TO 5 P.M. : $F = 0$

5 P.M. TO 9 P.M. : $F = \frac{1}{4}t$

LET $M_{B, 580}$ = MASS OF OIL IN BED AT 580°F

$$M_{B, 580} = (1-F) V_v \rho_{580} = (1-F)(29800)(40.85) \frac{lb_m}{ft^3}$$

PREPARED BY:
R. MORRISON
 CHECKED BY:
 DATE:
10-27-80



PAGE NO. A-7
 REPORT NO.

LET M_A = MASS OF OIL ABOVE ROCK BED

$$M_A = 1,640,000 - F(29,800)(49.91) - (1-F)(29,800)(40.85)$$

$$M_A = 1,640,000 - 29,800 [49.91 F + (1-F)(40.85)]$$

$$M_A = 1,640,000 - 29,800 [40.85 + F(49.91 - 40.85)]$$

$$M_A = 1,640,000 - 29,800 [40.85 + 9.06 F]$$

$$M_A = 422,670 - 120,988 F$$

$$M_{B,520} = (1-F) 1,217,330$$

RATE OF DEGRADATION PRODUCT FORMATION

$$R = R_{GAS RB} M_{B,520} + R_{GAS A22} M_A$$

$$R = (1-F)(1,217,330)(42 \times 10^6) + (422,670 - 120,988 F)(13.75 \times 10^6)$$

9 PM TO 9 AM, $F=1$ $R = 4.148$ lb/hr

9 AM TO 1 PM, $F = 1 + 1/4 t$

$$R = (1 - 1 + 1/4 t)(1,217,330)(42 \times 10^6) + (422,670 - 120,988 + 120,988(1/4)t)(13.75 \times 10^6)$$

$$R = 4.148 + 13.198 t$$

PREPARED BY:
 R. MOORESON
 CHECKED BY:
 DATE:
 10-27-70



Rocketdyne Division
 Rockwell International

PAGE NO.
 A 5
 REPORT NO.

1 P.M. TO 5 P.M. $F=0$ $R=56.940$ lb/hr

5 P.M. TO 9 P.M. $F = 1/4t$

$$R = (1 - 1/4t) (1,217,330) (42 \times 10^{-6}) + (422670 - \frac{120,988}{4} t) (13.75 \times 10^{-6})$$

$$R = 56.940 - 13.198 t$$

ULLAGE VOLUME FROM 9 P.M. TO 9 A.M. = V_{MAX}
 TOTAL TANK VOID VOLUME - VOLUME OF OIL ABOVE BED - VOLUME OF BED VOID SPACE

$$V_{MAX} = (V_{U_{925}} + \frac{M_T}{44.91}) - \frac{M_{A.F.1}}{40.85} - 29800$$

$$V_{MAX} = (9932 + \frac{1,640,000}{44.91}) - \frac{301682}{40.85} - 29800$$

$$V_{MAX} = 8769 \text{ ft}^3$$

ULLAGE VOLUME FROM 1 P.M. TO 5 P.M. = V_{MIN}

$$V_{MIN} = (V_{U_{925}} + \frac{M_T}{44.91}) - \frac{M_{A.F.0}}{40.85} - 29800$$

$$V_{MIN} = (9932 + \frac{1,640,000}{44.91}) - \frac{422,670}{40.85} - 29800$$

$$V_{MIN} = 5803 \text{ ft}^3$$

PREPARED BY:
K. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.

A 9

CHECKED BY:

REPORT NO.

DATE:

12-27-80

ULLAGE VOLUME FROM 9 A.M. TO 1 P.M.

$$V_{U_{DEC.}} = 8769 - 740.3 t \quad t \text{ (hours)}$$

ULLAGE VOLUME FROM 5 P.M. TO 9 P.M.

$$V_{U_{INC.}} = 5803 + 740.3 t$$

CONSIDER THE TIME INTERVAL FROM
9 P.M. TO 9 A.M.

$$V = V_{U_{MAX}} = 8769 \text{ Ft}^3$$

$$Q = 4.148 \text{ lb/hr}$$


CHOOSE A TIME INCREMENT, Δt , SUCH THAT

$$C_{C_1} = \frac{M_{C_1}}{M_T} \Big|_{t=t_0} \approx \frac{M_{C_1}}{M_T} \Big|_{t=t_0 + \Delta t}$$

M_{C_1} is known

M_{GAS} is known

LET PRESSURE INCREASE
OVER TIME INTERVAL, FIND
NEW CONCENTRATION, C_1 .
ASSUME GAS AT CONCENTRA-
TION C_1 IS RELEASED UNTIL
SET POINT PRESSURE IS
REACHED. DETERMINE NEW
MASSES OF C_1 AND GAS
IN ULLAGE SPACE

PREPARED BY: E. M. ...	 Rocketdyne Division Rockwell International	PAGE NO. A10
CHECKED BY:		REPORT NO.
DATE: 10-27-80		

$$\rightarrow M_{GAS_1} = M_{GAS_0} + R \Delta t$$

$$\rightarrow M_{C_1} = M_{C_0}$$

$$R_G = 15.46 \text{ ft}^2 / \text{°R}$$

$$R_{GAS} = 53.49 \text{ ft}^2 / \text{°R}$$

$$\rightarrow R_{mix} = \frac{(M_{GAS_1})(53.49) + (M_{C_1})(15.46)}{(M_{GAS_1} + M_{C_1})}$$

$$P_{mix} = 14.13 \text{ PSIA} = \frac{M_T R_{mix} T_{mix}}{144 V}$$

$$\rightarrow M_T = \frac{(14.13)(8769)(144)}{R_{mix}(891)} \frac{\text{lb}}{\text{m}^2} \frac{\text{ft}^3 \text{m}^2}{\text{ft}^2 \text{°R ft}} \frac{\text{°R}}{\text{ft}}$$

$$\rightarrow \Delta M_{UMU} = M_{GAS_1} + M_{C_1} - M_T$$

$$\Delta M_{UMU} = M_{GAS_0} + R \Delta t + M_{C_0} - M_T$$

$$\rightarrow M_{GAS_2} = M_{GAS_0} + R \Delta t - \frac{M_{GAS_1} \Delta M_{UMU}}{M_{GAS_1} + M_{C_1}}$$

$$\rightarrow M_{C_2} = M_{C_0} - \frac{M_{C_1} \Delta M_{UMU}}{M_{GAS_1} + M_{C_1}}$$

NEXT TIME INCREMENT \rightarrow

$M_{C_0} = M_{C_2}$ from previous increment
 $M_{GAS_0} = M_{GAS_2}$ from previous increment

PREPARED BY:
E. MORRIS-A



Rocketdyne Division
Rockwell International

PAGE NO.
A 11

CHECKED BY:

REPORT NO.

DATE:
10-27-80

CONCENTRATION OF C_7 AT THE
END OF EACH TIME INCREMENT

$$= C_{C7} = \frac{M_{C7_1}}{M_{C7_2} + M_{GAS_2}}$$

CONSIDER TIME INTERVAL FROM 9 A.M.
TO 1 P.M.

$$V = V_{U DEL} = 8769 - 740.3t$$

$$R = 4.148 + 13.198t$$

M_{C7_0} is known

M_{GAS_0} is known

$$M_{GAS_1} = M_{GAS_0} + R \Delta t$$

$$M_{C7_1} = M_{C7_0}$$

$$R_{mix} = \frac{(M_{GAS_1})(53.49) + (M_{C7_1})(15.46)}{(M_{GAS_1} + M_{C7_1})}$$

$$M_T = \frac{(14.13)(8769 - 740.3t)(144)}{R_{mix} (891)}$$

$$\Delta M_{UMU} = M_{GAS_1} + M_{C7_1} - M_T$$

PREPARED BY:
F. M. ...



PAGE NO.
A 12

CHECKED BY:

REPORT NO.

DATE:
10-28-80

$$M_{GAS_2} = M_{GAS_1} - \frac{M_{GAS_1}}{M_{GAS_1} - M_{C_7}} \Delta M_{UMU}$$

$$M_{C_7_2} = M_{C_7_0} - \frac{M_{C_7_1}}{M_{GAS_1} + M_{C_7_1}} \Delta M_{UMU}$$

$$C_7 = \frac{M_{C_7_2}}{M_{C_7_2} + M_{GAS_2}}$$

$$M_{C_7_2} \rightarrow M_{C_7_0}$$

$$M_{GAS_2} \rightarrow M_{GAS_0}$$

RETURN → decrement time

CONSIDER TIME INTERVAL FROM 1 A.M.
TO 5 P.M.

$$V = V_{UMIN} = 5803 \text{ Ft}^3$$

$$Q = 56.940 \text{ lb/hr}$$

$M_{C_7_0}$ is known

M_{GAS_0} is known

PREPARED BY:
R. Morrison



Rocketdyne Division
Rockwell International

PAGE NO.
A 13

CHECKED BY:

REPORT NO.

DATE:

10-28-80

$$M_{GAS_1} = M_{GAS_0} + R \Delta t$$

$$M_{C_1} = M_{C_0}$$

$$R_{mix} = \frac{(M_{GAS_1})(53.49) + (M_{C_1})(15.46)}{(M_{GAS_1} + M_{C_1})}$$

$$M_T = \frac{(19.13)(5803)(194)}{R_{mix} (891)}$$

$$\Delta M_{UMU} = M_{GAS_1} + M_{C_1} - M_T$$

$$M_{GAS_2} = M_{GAS_1} - \frac{M_{GAS_1}}{M_{GAS_1} + M_{C_1}} \Delta M_{UMU}$$

$$M_{C_2} = M_{C_1} - \frac{M_{C_1}}{M_{GAS_1} + M_{C_1}} \Delta M_{UMU}$$

$$C_{C_1} = \frac{M_{C_2}}{M_{C_2} + M_{GAS_2}}$$

$$M_{C_2} \rightarrow M_{C_0}$$

$$M_{GAS_2} \rightarrow M_{GAS_0}$$

increment time
RETURN

PREPARED BY:
R. MORRISON
 CHECKED BY:
 DATE:
10-28-80



PAGE NO.
419
 REPORT NO.

CONSIDER TIME INTERVAL FROM
 5 P.M. TO 9 P.M.

$$V = V_{U, INC.} = 5803 + 740.3 t$$

$$R = 56.94 - 13.19 t$$

AT SOME POINT DURING THIS TIME
 INTERVAL R BECOMES INSUFFICIENT TO
 MAINTAIN P

M_{C70} is known

$M_{GAS.}$ is known

$$M_{GAS.1} = M_{GAS.0} + R \Delta t$$

$$M_{C71} = M_{C70}$$

$$R_{mix} = \frac{(M_{GAS.1})(53.49) + (M_{C71})(15.46)}{(M_{GAS.1} + M_{C71})}$$

$$M_T = \frac{(14.13)(5803 + 740.3 t)(144)}{R_{mix} (891)}$$

$$\Delta M_{UND} = M_{GAS.} + M_{C71} - M_T$$

IF ΔM_{UND} IS NEGATIVE, HEPTANE
 MUST BE ADDED → GO TO **A**

PREPARED BY:
R. MORRISON
 CHECKED BY:
 DATE:
10-28-80



PAGE NO.
A 5
 REPORT NO.

$$M_{GAS2} = M_{GAS1} - \frac{M_{GAS1}}{M_{GAS1} + M_{C71}} \Delta M_{UMU}$$

$$M_{C72} = M_{C70} - \frac{M_{C71}}{M_{GAS1} + M_{C71}} \Delta M_{UMU}$$

$$C_{C7} = \frac{M_{C72}}{M_{C72} + M_{GAS2}}$$

$$M_{C72} \rightarrow M_{C70}$$

$$M_{GAS2} \rightarrow M_{GAS0}$$

RETURN \rightarrow decrement time


A

$$P_T = P_{GAS} + P_{C7}$$

$$P_T = 14.13 \text{ PSIA}$$

$$P_{GAS} = \frac{M_{GAS1} (53.49)(891)}{144 (5803 + 740.3t)}$$

$$P_{C7} = P_T - P_{GAS}$$

PREPARED BY: R. M. GREGG	 Rocketdyne Division Rockwell International	PAGE NO. A 16
CHECKED BY:		REPORT NO.
DATE: 10-28-70		

$$P_G = \frac{M_{C7} (15.46) (891)}{144 (5803 + 740 t)}$$

$$M_{C72} = \left[14.13 - \frac{M_{GAS_1} (53.49) (891)}{(144) (5803 + 740 t)} \right] \times \left[\frac{144 (5803 + 740 t)}{(15.46) (891)} \right]$$

$$M_{GAS_2} = M_{GAS_1}$$

$$C_{C7} = \frac{M_{C72}}{M_{GAS_2} + M_{C72}}$$

$$M_{C72} \rightarrow M_{C70}$$

$$M_{GAS_2} \rightarrow M_{GAS_0}$$

RETURN \rightarrow decrement time

$$M_{C70} = 0$$

$$M_{GAS_0} = \frac{14.13 (144) (891)}{(53.49) (891)} = 362.76 \text{ lbs.}$$

PREPARED BY:
F. M. ...



PAGE NO. A 17

CHECKED BY:

REPORT NO.

DATE:
12-27-80

DETERMINE: CONCENTRATION OF η -HEP-TANE (C_1) AS A FUNCTION OF TIME IN THE ULLAGE SPACE WHEN THE RATE OF DEGRADATION PRODUCT FORMATION IS $1/2$ THE MAXIMUM RATE.

GIVEN: SAME AS BEFORE EXCEPT:

OIL DEGRADATION RATE AT 580°F :
IN ROCK BED = 21×10^{-6} LB/LB-HR = $R_{\text{GAS RB}}$
ABOVE ROCK BED = 6.875×10^{-6} LB/LB-HR = $R_{\text{GAS AB}}$

CALCULATION: SAME AS BEFORE EXCEPT

RATE OF DEGRADATION PRODUCT FORMATION

$$R = R_{\text{GAS RB}} M_{B, 580} + R_{\text{GAS AB}} M_A$$

$$R = (1-F)(1217,330)(21 \times 10^{-6}) + (422,670 - 120,988 F)(6.875 \times 10^{-6})$$

9 P.M. TO 9 A.M. $F=1$ $R = 2.074$ LB/HR

PREPARED BY:

K. YAGGER



Rocketdyne Division
Rockwell International

PAGE NO.

A 18

CHECKED BY:

REPORT NO.

DATE:

10-29-80

9 AM TO 1 P.M. $F = 1 - \frac{1}{4}t$


$$R = (1 - \frac{1}{4}t)(1,217,330)(21 \times 10^{-6}) +$$

$$+ (422,670 - 120,988 + \frac{120,988t}{4}) 6875 \times 10^{-6}$$

$$R = 2.079 + 6.599t$$

1 P.M. TO 5 P.M. $F = 0$ $R = 28.470$

5 P.M. TO 9 P.M. $F = \frac{1}{4}t$ $R = 28.470 - 6.599t$

PREPARED BY:	 Petroleum Division Shell International	PAGE NO. A 19
CHECKED BY:		REPORT NO.
DATE:		

PROGRAM NAME :

STEP	DESCRIPTION	ENTER	PRESS	READ	PRINT	
					VALUE	LABEL
1	ENTER PROGRAM		CMS			
2	ENTER TIME INCREMENT IN HRS. TO BE USED IN CALCULATION (0.1)	Δt (HR.)	A'	Δt		
3	ENTER TIME INCREMENT BETWEEN DATA PRINTOUTS IN HOURS (0.5)	Δt (HR.) PRINT	B'	-		
4	ENTER INITIAL MASS OF GAS LBS (365.611)	M_{GAS_0} (LBS)	C'	M_{GAS_0}		
5	ENTER INITIAL MASS OF HEPTANE LBS (0)	M_{C_7} (LBS)	D'	M_{C_7} (LBS)		
6	START CALCULATING PRESS A TO START AT 5 P.M. PRESS B TO START AT 9 P.M. PRESS C TO START AT 9 A.M. PRESS D TO START AT 1 P.M.		A		t (hr)	C
7	STOP		E/S			

PREPARED BY:
E. MORRISON
 CHECKED BY:
 DATE:
10-28-80




Pocketdyne Division
 Fockwell International

PAGE NO.
A 20
 REPORT NO.

00		0
01		1
02		2
03		3
04	M _{GAS0.2} (lb)	4
05	M _{C70.2} (lb)	5
06	M _{GAS1} (lb)	6
07	M _{C71} (lb)	7
08	R (lb/m)	8
09	Δt (hr)	9
10	R _{mix} (Σ+10R)	0
11	M _t (lb)	1
12	V (ft ³)	2
13	ΔM _{sum} (lb)	3
14	C _{GAS2} (lb/lb _t)	4
15	C _{C72} (lb/lb _t)	5
16	M _{C71} + M _{GAS1} (lb)	6
17	Δt PRINT (hr)	7
18	# Δt BETWEEN PRINTS	8
19	± (hr)	9
20	L _{TOTAL}	0
1		1
2		2
3		3
4		4
5		5
6		6
7		7
8		8
9		9

PREPARED BY:
K. J. ...



PAGE NO.
A 21

CHECKED BY:

REPORT NO.

DATE:

0	LBL	SPM TO 9AM	0	=	0	SUBR
1	A		1	STO	1	PRT
2	CLR		2	08	2	A
3	STO		3	5	3	XZT
4	19		4	8	4	RCL
5	LBL		5	0	5	19
6	-		6	3	6	INV
7	0		7	+	7	X=T
8	XZT		8	7	8	1
9	RCL		9	4	9	19
0	09		0	0	0	LBL
1	SUM		1	.	1	√X
2	19		2	3	2	SUBR
3	SUM		3	X	3	XZT
4	20		4	RCL	4	SUBR
5	5	2	5	19	5	PRT
6	6	8	6	=	6	A
7	.	.	7	STO	7	XZT
8	9	4	8	12	8	RCL
9	4	7	9	SUBR	9	19
0	1	1	0	RCL	0	INV
1	1	6	1	SUBR	1	X=T
2	3	.	2	SUM	2	1
3	.	5	3	RCL	3	NOP
4	1	9	4	13	4	
5	9	9	5	INV	5	
6	8	0	6	XZT	6	
7	X		7	√X	7	
8	RCL		8	SUBR	8	
9	19		9	STO	9	

PREPARED BY:
 K. H. GREGG
 CHECKED BY:
 DATE:
 10-28-70



Rocketdyne Division
 Rockwell International

PAGE NO.
 A 22
 REPORT NO.

0	LEL	777	777	0	ECL
1	B			1	SUBC
2	CLR			2	SUM
3	S/O			3	SUBC
4	19			4	STO
5	1			5	SUBC
6	2			6	PRT
7	XET			7	ECL
8	LEL			8	19
9	+			9	INV
0	ECL			0	XET
1	09			1	+
2	SUM			2	NOP
3	19			3	
4	SUM			4	
5	20			5	
6	4	2		6	
7	.			7	
8	1	0		8	
9	4	7		9	
0	8	4		0	
1	S/O			1	
2	08			2	
3	8			3	
4	7			4	
5	6			5	
6	4			6	
7	STO			7	
8	12			8	
9	SUBC			9	


PREPARED BY:
 CHECKED BY:
 DATE:
 10-27-30



Rocketdyne Division
 Rockwell International

PAGE NO.
 A 23
 REPORT NO.

0	LEL	9 AM TO 1 PM	0	=	
1	C		1	STO	
2	CLC		2	OR	
3	STO		3	X	
4	19		4	1	
5	9		5	6	
6	X 2t		6	1	
7	LEL		7	1	
8	X		8	7	
9	RCL		9	4	
0	09		0	0	
1	SUM		1	.	
2	19		2	3	
3	SUM		3	v	
4	20		4	RCL	
5	9	2	5	19	
6	.	.	6	=	
7	1	0	7	STO	
8	4	7	8	12	
9	8	4	9	SUBR	
0	+	+	0	RCL	0 v=t
1	1	6	1	SUBR	1 X
2	2	.	2	SUM	2 NOP
3	.	5	3	SUBR	3
4	1	9	4	STO	4
5	9	9	5	SUBR	5
6	8	0	6	RET	6
7	X		7	RCL	7
8	RCL		8	19	8
9	19		9	IRV	9

PREPARED BY: F. [unclear]		PAGE NO. A 29
CHECKED BY:		REPORT NO.
DATE: 10. 28. 70		

		1PM TO 5PM		
0	LEL		0	SUBE
1	D		1	SUM
2	CLR		2	SUBR
3	STO		3	STO
4	19		4	SUBR
5	4		5	PRT
6	XZT		6	RCL
7	LEL		7	19
8	:		8	HALV
9	RCL		9	XZT
0	09		0	+
1	SUM		1	NOP
2	19		2	GTO
3	SUM		3	A
4	20		4	
5	5	2	5	
6	6	8	6	
7	.	.	7	
8	9	4	8	
9	4	7	9	
0	STO		0	
1	08		1	
2	5		2	
3	8		3	
4	0		4	
5	3		5	
6	STO		6	
7	12		7	
8	SUBR		8	
9	RCL		9	

PREPARED BY:
R. Morrison



Rocketdyne Division
Rockwell International

PAGE NO.

A 25

CHECKED BY:

REPORT NO.

DATE:
10-28-80

0	LEL	SUBROUTINE	0	LEL	SUBROUTINE
1	RCL	RCL	1	SUM	SUM
2	RCL	$M_{GAS1} = M_{GAS0} + RAT$	2	RCL	$R_{mix} = [M_{GAS1}(5349)$
3	04	$M_{G1} = M_{G20}$	3	06	$+ (M_{G21}(1546)]$
4	+		4	X	
5	RCL		5	5	$(M_{GAS} - M_{G21})$
6	08		6	3	
7	X		7	.	$M_{T} = (14.13)(.1)$
8	RCL		8	4	(144)
9	09		9	9	$R_{mix} (391)$
0	=		0	+	
1	STO		1	RCL	$\Delta M_{MUN} = M_{GAS1} +$
2	06		2	07	$M_{G21} - M_T$
3	RCL		3	X	
4	05		4	1	
5	STO		5	5	
6	07		6	.	
7	INV		7	4	
8	SER		8	6	
9			9	=	
0			0	÷	
1			1	(
2			2	RCL	
3			3	06	
4			4	+	
5			5	RCL	
6			6	07	
7			7)	
8			8	=	
9			9	STO	

PREPARED BY:
R. MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.
A 26

CHECKED BY:

REPORT NO.

DATE:
10-28-80

0 10
1 RCL
2 12
3 v
4 2
5 .
6 2
7 8
8 3
9 6.
0 4
1 ÷
2 RCL
3 10
4 =
5 STO
6 11
7 RCL
8 06
9 +
0 RCL
1 07
2 -
3 RCL
4 11
5 =
6 STO
7 13
8 INV
9 SUBR

0 LBL SUBROUTINE
1 STO STO
2 RCL $C_{GAS_2} = \frac{M_{GAS_1}}{M_{GAS_2} + M_{CH_4}}$
3 06
4 +
5 RCL $C_{CH_4} = \frac{M_{CH_4}}{M_{CH_4} + M_{GAS_2}}$
6 07
7 =
8 STO $M_{GAS_2} = M_{GAS_1}$
9 16
0 1/x $- C_{GAS_2} \Delta M_{GAS}$
1 x
2 RCL $M_{CH_4} = M_{CH_4}$
3 06
4 = $- C_{CH_4} \Delta M_{GAS}$
5 STO
6 14
7 RCL
8 07
9 ÷
0 RCL
1 16
2 =
3 STO
4 15
5 RCL
6 06
7 -
8 RCL
9 14

PREPARED BY:
E. Morrison



Rocketdyne Division
Frickwell International

PAGE NO.
A 27

CHECKED BY:

REPORT NO.

DATE:

10-28-80

0	Y	0	LEL	SUBROUTINE
1	RLL	1	XZT	XZT
2	13	2	1	
3	=	3	4	$M_{c_2} = [14.13 -$
4	STO	4	.	
5	09	5	1	$- \frac{M_{GAS} (330.97)}{V}]$
6	RLL	6	3	
7	07	7	-	X 0.010959 V
8	-	8	RLL	
9	RLL	9	06	$C_{c_2} = \frac{M_{c_2}}{M_{c_2} - M_{GAS}}$
0	15	0	X	
1	X	1	3	
2	RLL	2	3	$C_{GAS} = \frac{M_{GAS}}{M_{c_2} - M_{GAS}}$
3	13	3	0	
4	=	4	.	
5	STO	5	9	
6	05	6	7	
7	INV	7	÷	
8	SUBR.	8	RLL	
9		9	12	
0		0	=	
1		1	X	
2		2	.	
3		3	0	
4		4	1	
5		5	0	
6		6	4	
7		7	5	
8		8	4	
9		9	X	

PREPARED BY:
 F. MOORE
 CHECKED BY:
 DATE:
 10-28-50



Rocketdyne Division
 Rockwell International

PAGE NO.
 A 28
 REPORT NO.

0	RCL
1	12
2	=
3	STO
4	05
5	RCL
6	06
7	STO
8	04
9	RCL
0	04
1	-
2	(
3	RCL
4	04
5	-
6	RCL
7	05
8)
9	STO
0	16
1	=
2	STO
3	14
4	RCL
5	05
6	-
7	RCL
8	16
9	=

0	STO
1	15
2	11/1
3	SUAC.
4	
5	
6	
7	
8	
9	
0	
1	
2	
3	
4	
5	
6	
7	
8	
9	
0	
1	
2	
3	
4	
5	
6	
7	
8	
9	

PREPARED BY:
R MORRISON



Rocketdyne Division
Rockwell International

PAGE NO.
A 29

CHECKED BY:

REPORT NO.

DATE:

0	LBL	0	LBL	SUBROUTINE
1	A'	1	PRT	PRINT
2	STO	2	DSE	
3	09	3	0	
4	R/S	4	CLR	
5		5	RCL	
6		6	ZO	
7		7	PRT	
8	LBL	8	RCL	
9	B'	9	IS	
0	STO	0	PRT	ADN
1	17	1	RCL	
2	X	2	IS	
3	RCL	3	STO	
4	09	4	00	
5	1/x	5	LBL	
6	=	6	CLR	
7	STO	7	INV	
8	18	8	SUBR	
9	STO	9		
0	00	0		
1	R/S	1		
2		2		
3		3		
4	LBL	4	LBL	
5	C'	5	D'	
6	STO	6	STO	
7	09	7	05	
8	R/S	8	R/S	
9		9		

HIGH RATE OF DEGRADATION PRODUCT FORMATION

A 30

		16.5
0.5 PM	8.5 0.221870572	.2048397622
	9. 0.220837262	.2012125431
	9.5 .2198078715	.1958210442
	10. .2187823939	.1886193487
	10.5 .2177608226	.1796013161
	11. .2167431509	.1688108076
	11.5 .2157293721	.158332573
	12. .2147194793	.1424037264
	12.5 .2137134656	.1285070114
	13. .2127113241	.1158422393
	13.5 .2117130478	.1043237343
	14.5 .2097280621	.0938672497
	15. .2087413385	.0843909089
	15.5 .2077584512	-----
	16. 0.222907808	.0680675136
		.0610745917

9 PM

1 PM

9 AM

5 PM

HIGH RATE OF DEGRADATION
PRODUCT FORMATION

A 31

24.5
0.055317068

25.
.0509590017

25.5
.0476666802

26.
.0462872352

26.5
0.068610994

27.
.1168889712

27.5
.1825766425

28.
.2578267222

28.5
.2566622405

29.
.2555018435

29.5
.2543455323

30.
.2531933031

30.5
.2520451518

31.
.2509010743

31.5
.2497610665

32.
.2486251241

32.5
.2474932427

33.
.2463654179

33.5
.2452416451

34.
.2441219197

34.5
.2430062369

35.
.2418945919

35.5
.2407869797

36.
.2396833955

36.5
.2385838341

37.
.2374882903

37.5
.2363967589

38.
.2353092345

38.5
.2342257117

39.
0.233146185

39.5
.2320706488

40.
.2309990974

40.5
.2288756213

41.
~~0.224902442~~

41.5
.2189915024

42.
.2110862395

42.5
.2011714762

43.
.1892849587

43.5
.1755301511

44.
.1600893618

44.5
.1446642717

45.
.1305698347

45.5
0.117720491

46.
.1060305689

46.5
.0954155418

47.
.0857931095

47.5
0.077084024

48.
.0692126906

9 A.M.

1 P.M.

9 A.M.

5 P.M.

HIGH RATE OF DEGRADATION
PRODUCT FORMATION

A 32

48.5
.0627237508

49.
.0578071252

49.5
.0540900195

50.
.0523800238

50.5
.0742219776

51.
.1218635013

51.5
.1868612677

52.
.2614425768

9 P.M.

52.5
.2602654642

53.
.2590924474

53.5
.2579235277

54.
.2507007010

LOW RATE OF DEGRADATION
PRODUCT FORMATION

0.0 SPM

0.5
.0280131122

1.
.0748667627

1.5
.1302162237

2.
.1900455656

2.5
.2513663682

3.
.3120932926

3.5
.3708623768

4.
.4268494883

4.5
.4260261691

5.
.4252037331

5.5
.4243822035

6.
0.423561576

6.5
.4227418524

7.
.4219230343

7.5
.4211051232

8.
.4202891209

9 PM

8.5
0.419472029

9.
0.418252020

9.5
.4178425825

10.
.4170292312

10.5
.4162167967

11.
.4154052804

11.5

12.
.4137850088

12.5
.4129762566

13.
.4121684289

13.5
.4113615271

14.
.4105555527

14.5
.4097506079

15.
.4089463923

15.5
.4081432092

16.
.4073409694

9 AM

16.5
.4057445744

17.

17.5
.3981975972

18.
.3920187319

18.5
.3840770301

19.
.3742501197

19.5
.3624166588

20.
.3484609682

20.5
.3337019648

21.
.3182704788

21.5
.3054966674

22.

22.5
.2790552435

23.
.2664955728

23.5
0.254373649

24.
.2426837309

1 PM

5 PM

LOW RATE OF DEGRADATION
PRODUCT FORMATION

A34

24.5
.2535281547

25.
.2763288043

25.5
.3578557953

26.
0.345209017

26.5
.3862410792

27.
.4288878049

27.5
.4718668258

28.
.5142124331

28.5
.5133088909

29.
.5124060205

29.5
.5115032287

30.
.5106023182

30.5
.5097014918

31.
.5088013521

31.5
.5079019018

32.
.5070031435

32.5
.5061050798

33.
.5052077135

33.5
.5043110472

34.
.5034150834

34.5
.5025198248

35.
0.501625274

35.5
.5007314335

36.
0.499838306

36.5
0.498945894

37.
.4980542001

37.5
.4971632268

38.
.4962729767

38.5
.4953834523

39.
.4944940562

39.5
.4936065908

40.
.4927192586

40.5
.4909326807

41.
.4876179458

41.5
.4825850603

42.

42.5
.4668575418

43.
.4558569399

43.5
0.44254937

44.
0.426769237

44.5
0.4100000000

45.
.3935834445

45.5
.3775954382

46.
.3620247737

46.5
.3468797245

47.
.3321667682

47.5
.3178906495

48.
.3040544536

9PM

1 PM

9AM

5 PM

LOW RATE OF DEGRADATION
PRODUCT FORMATION

A35

48.5
.3103541508

49.
0.328032485

49.5
.3542789884

50.
.3865374428

50.5
.4226439416

51.
0.460667915

51.5
0.499886337

52.
.5387348835

52.5
0.537814223

53.
0.536094150

53.5
.5359746959

54.
.5350558396

54.5
0.534137392

55.
.5332199561

55.5
.5323029347

56.
.5313865308

56.5
.5304707472

57.
.5295555868

57.5
.5286410526

58.
.5277271473

58.5
.5268138739

59.
.5259012351

59.5
.5249892338

60.
.5240778729

60.5
.5231671551

61.
.5222570833

61.5
.5213476602

62.
.5204388888

62.5
.5195307716

63.
.5186233117

63.5
.5177165115

64.
.5168103741

64.5
.5150061008

65.
0.511599279

65.5
.5064552945

66.
0.499428622

66.5
.4903627165

67.
.4790906448

67.5
0.465436891

68.
.4492209649

68.5
.4319364997

69.
.4150288706

69.5
.3985124451

70.
.3823998024

70.5
.3667016299

71.
.3514267563

71.5
.3365821976

72.
.3221732166

9PM

1PM

9AM

5PM

LOW RATE OF DEGRADATION
PRODUCT FORMATION

72.5
.3272107841

73.
.3434437435

73.5
.3681790142

74.
.3989476172

74.5
.4336435817

75.
.4705691424


75.5
.5084181214

76.
.5462269207

9 PM

76.5
.5453015022

77.
.5443766551

PREPARED BY: <i>W.O. KNIPPEL</i>	 Rocketdyne Division Rockwell International	PAGE NO. <i>1 OF 2</i>
CHECKED BY: <i>K. YEO</i>		REPORT NO.
DATE: <i>18 FEB 81</i>	<i>SOLAR</i>	
	<i>ULLAGE MAINTENANCE UNIT</i>	


*CONDENSATE RECOVERY TANK
300 GAL. 50 PSIG*

SUMMARY

THE ATTACHED CALCULATIONS WERE MADE TO ASCERTAIN THE RELIEF VALVE CAPACITY REQUIREMENT OF THE TANK IN THE EVENT OF FIRE ON THE SKID. THE TANK IS PIPED TO A SYSTEM CONTAINING A BLOWER DESIGNED TO OPERATE AT 5 PSIG MAXIMUM. A NITROGEN SUPPLY TO THE TANK IS NOT A CONSIDERATION SINCE FIRE ACCOUNTS FOR THE MAXIMUM FLOW THRU A RELIEF. A 4" RELIEF VALVE IS RECOMMENDED TO ACCOMMODATE THE RELIEF CAPACITY REQUIREMENTS AS SPECIFIED BY API STANDARD 2000 AND NFC. THE RELIEF VALVE SHALL BE LOCATED IN THE 6" PIPE LINE ROUTED BETWEEN THE TSU AND THE RECOVERY TANK AT A SAFE ELEVATION FOR RELIEF VALVE DISCHARGE.

*REV
1*

*105
57*

PREPARED BY: W.O. KNIPPEL	 Rocketdyne Division Rockwell International	PAGE NO. 2 OF 2
CHECKED BY: K. YEO		REPORT NO.
DATE: 18 FEB 81	SOLAR	
	ULLAGE MAINTENANCE UNIT	

CONDENSATE RECOVERY TANK

RELIEF VALVE SIZING (REF API STANDARD 2000)

$$Q = 20,000 A \quad (\text{APPENDIX})$$

$$A = 75 \text{ SQ FT}$$

$$Q = 1,500,000 \text{ BTU/HR}$$

$$\text{SCFH} = \frac{70.5 Q}{L \sqrt{M}} \quad (\text{FREE AIR, } 14.7 \text{ PSIA @ } 60^\circ \text{F})$$

$$\text{SCFH} = \frac{70.5 (1,500,000)}{133 \sqrt{100}} \quad (\text{HEPTANE})$$

$$\text{SCFH} = 79511 \quad (\text{AIR})$$

USE 4" GROTH MODEL 2301, SET TO OPEN AT 5 PSIG

PRESSURE, REMAIN CLOSED WITH VACUUM, STAINLESS

STEEL TRIM, VITON SEAT, CARBON STEEL BASE

AND COVER 4" 150 LB FLANGE

REV.
1

106
58

APPENDIX A

UMU OPERATING MANUAL

APPENDIX A

UMU OPERATING MANUAL

The UMU provides an oxygen free environment in the ullage space of the TSU. Air, which can cause deterioration of the heat transfer oil, is excluded by using non-oxygen-bearing fuel vapors. Gaseous nitrogen is available for backup when necessary. Air is excluded by keeping the ullage space and UMU makeup system at a slight positive pressure, 5.5 to 10.5-inches of water, at all times. The oil level in the TSU changes continually as a result of heating and cooling during the charging and extraction cycles. The UMU compensates by removing and supplying gas to keep the ullage pressure in an established band. Fuel vapors, resulting from oil decomposition, that do not condense are disposed of through the UMU combustor.

GENERAL DESCRIPTION

The UMU is a service unit for the TSU and provides the following two functions:

- 1) Pressurization of the ullage space to a continuous and positive pressure, selected to be between 5.5 and 10.5-inches of water, by adding or removing oxygen free gas to keep the pressure within the desired range as the liquid level changes during TSU charging and extraction cycles.
- 2) Disposal of excess gas and water vapor through a combustion and drain system.

It is essential that the UMU retain the oxygen free integrity of the TSU ullage space at all times. The TSU is a sealed, closed system. Excess pressure will result in operation of the TSU relief valves. A pressure below atmospheric in the TSU may allow air to leak in and, if too low, will lead to the collapse of the roof. The UMU is contained in skid assembly SA311, and is connected to the TSU ullage space by a 6-inch vapor line (6-UG-1-BBA), a 1-inch liquid line (1-HP-1-BBA) and a 2-inch nitrogen line (2-N-5-BBA). The UMU skid consists of a 300 gallon condensate storage and water separator tank; a pump to transfer liquid pressurant to the TSU; a burner stack and associated blowers and controls to dispose of combustible gases; and a gaseous nitrogen supply that provides TSU pressurant when gas from the condensate system is inadequate to meet TSU pressure requirements.

The working fluid for pressurizing the TSU is a mixture of heptane and other hydrocarbon vapors. It is stored in the tank TK-302 as a liquid well below its boiling point. When returned to the TSU ullage space it vaporizes, since the ullage environment is at a temperature above 400°F. When returned to tank TK-302 through line 6-UG-1-BBA the vapors condense. Tests have shown that the oil decomposition products of Caloria HT43 are a mixture of fuel vapors, some of which condense at room temperature and pressure. Condensed liquids remain in tank TK-302 and non-condensibles go to the burner stack through line 6-UG-1-BBA.

Waste gas blower FA-301 and air blower FA-302 provide a positive pressure to the burner stack where the fuel gases are mixed with air and are burned. A pilot gas supply services a pilot flame to assure combustion at all mixture ratios. Pilot gas supply is from a pressure bottle on the UMU pad.

The ullage pump P-308 returns condensed liquid to the TSU through line 1-HP-1-BBA when the ullage volume is increasing. The liquid consisting of Heptane and some condensed fuel vapors revaporizes upon entering the TSU and fills the ullage space as needed.

Each day at the end of the charging mode, the level of liquid in TK-302 shall be checked using sight gage LG4020A, and makeup heptane shall be added as necessary. Line 1/2-inch-HP-2-BBA is the heptane fill line. Liquid heptane is delivered and stored on the UMU pad in 50 gallon barrels and transferred to the U S storage container with a commercial, air or electrically powered barrel pump.

Tank TK-302 is a combined gas receiver, gas-liquid separator and storage tank. Ullage gases and condensed vapors from the TSU enter near the top of the tank. The condensed vapors settle out and the non condensible fraction is diverted to the burn stack. Approximately 120 gallons of condensate or heptane is required to fill the TSU ullage space during a complete extraction cycle. If none is lost, the 120 gallons can be used repeatedly. However, it is expected that some will be lost and makeup condensate or heptane will be added as needed.

Tank TK-302, acting as a liquid-gas separator, provides an indication if water is leaking into the oil system. Water will be turned to steam, which will ultimately find its way to the TSU ullage space and then into the UMU system. Steam will condense in the 6-inch vent line between the TSU and the UMU and settle to the bottom of TK-302. Liquid level gage LG4020B is placed in the lower region of the tank to monitor water level for drainage purposes. It is desirable that the water level remain below the connection to line 1-HP-2-BBA. Small amounts of water can be returned as a pressurizing gas for the ullage space in the TSU but repeated usage of large amounts of water may lead to oxidation of the oil. Water is drained from the bottom of the tank through manual control valve UHDV.

Nitrogen is available through pressure regulator PCV-4023 to maintain a positive pressure in V-304 to prevent condensate flashing into vapor. A gaseous nitrogen system serves as a UMU backup and provides an independent source of inert pressurant for the TSU ullage space.

OPERATION

Reference Drawings

UMU Skid Assembly	GA000-90907-M8
Skid Assembly SA-311 Flow Diagram	GA000-90907-M77
UMU Electrical Diagram	GA000-90907-E20
UMU Termination Boxes	GA000-90907-E17

The UMU has four (4) principal operating circuits. These are:

- (1) Vapor inlet and condensing (storage vessel)
- (2) Condensate return
- (3) Waste gas disposal (thermal oxidizer)
- (4) Gaseous nitrogen supply

These fluid circuits are interconnected and controlled by a network of valves with signals from pressure switches mounted on the TSU. Pressures, temperatures, liquid levels and flows are monitored with sight gages and electrical recording transducers.

Powering of the UMU

The operation of the UMU can start after the unit is powered. To power the UMU, the following actions are required:

- (1) The main UMU power switch has to be in the ON position.
- (2) Breakers 10 and 12 in LP4 (Building 712) in ON position.
- (3) The thermal oxidizer power switch has to be in the ON position.
This will be indicated by the lit POWER lamp on the thermal oxidizer control panel.
- (4) The ullage pump disconnect switch has to be in the ON position.

When these five switches are in the ON position all circuits of the UMU are ready for operation.

In addition to the above, the AUTO-MANUAL switch on the thermal oxidizer control panel shall be turned to AUTO.

Vapor Inlet and Condensing

During the charging mode the fluid level in the TSU (V303) rises. At the same time, due to the high temperature, a certain amount of oil vapors are being released from the oil into the ullage space. The combination of those two factors causes the pressure in the ullage space to increase. When the pressure in the TSU reaches 10.5-inches H₂O on PI-4008, the ILS closes the circuit, energizing the solenoid valve SOV-4014 in the instrument air supply line to valve AOV-4014 and the relay ICR in the control system of the thermal oxidizer. Subsequently, valve AOV-4014 opens, venting gases from the ullage space of the TSU, through line 6-inch-UG-1-BBA, to the UMU tank TK-302. Condensible vapors condense in the 6-inch line and collect in the UMU tank, while non-condensable gases (fumes) pass through the tank into the thermal oxidizer. (Non-condensable gases passing through the thermal oxidizer will be referred to as fumes). Limit switches mounted on valve AOV-4014 transmit signals to the master controller, indicating whether the valve is open or closed.

The level of the condensate in the UMU tank can be monitored at the sight gage LG-4020A. Gage LG-4020B shows the level of water in the tank if there is an accumulation of water.

The volume of condensate in the UMU tank required to maintain the ullage pressure in the TSU during the transition from the fully charged (with heat) to the fully discharged state of the TSU, has been calculated to be 122 gallons. This figure has to be verified in the field. Upon verification a scale shall be fastened to the sight gage LG-4020A. The scale shall be graduated in such a manner to show the maximum volume of condensate required for the transition from the fully charged to the fully discharged TSU with increments of 1/10 of the maximum volume, down to zero volume. The scale shall be set in such a way that the point of zero volume coincides with the level of the lower connection of sight gage LG-4020A. This will then coincide with the midpoint of gage LG-4020B. The level of the condensate has to be checked every evening after the end of the charging cycle. The condensate level in the UMU tank shall correspond to the state of the TSU heat charging, i.e., for maximum TSU charging, the UMU tank shall contain the maximum volume of condensate; for 40% TSU charging the UMU tank shall contain 40% condensate. If the condensate is below the required level, heptane shall be pumped to the UMU tank from one of the barrels located at the pad adjacent to the UMU. Heptane is added through valve UHIS-1 located at the east side of the UMU. In order to prevent air from entering the UMU tank during the adding of heptane, the following procedure shall be used:

- (1) Place pump suction hose into heptane barrel and make sure that the hose is submerged in heptane. Make sure that air can enter the heptane barrel.
- (2) Attach hose from pump discharge to valve UHIS-1.
- (3) Open valve UHIS-1. Wait one minute (or as long as required) for the condensate from the tank to displace the air in the hoses and the pump.
- (4) Start the pump. Observe the sight gage LG-4020A and add only the amount of heptane required. Stop pump before the heptane level in the barrel drops below the suction hose inlet to prevent pumping air.
- (5) After the required level of condensate in the UMU tank is reached, close valve UHIS-1 and stop the pump

If the presence of water is observed in the UMU tank, the water shall be drained before the reading of the condensate tank is made.

An appreciable amount of water will be noticeable in the UMU tank by a dividing line in the sight gage separating water and the lighter hydrocarbon liquids. Water shall be drained as soon as such a dividing line appears in the lower sight gage LG-4020B. Water shall be drained by opening the valve UHDV and observing the water level in the sight gage LG-4020B. After the water level reaches the lowest point of the sight gage LG-4020B, another 30 gallons of water shall be drained. Those 30 gallons of water are accumulated in the tank below the lowest level of the sight gage LG-4020B.

If, during the normal course of plant operation an unusually high water volume is observed in the UMU tank, the heat exchangers in the thermal storage subsystem shall be checked for leakage between the steam/water and the oil side.

Waste Gas Disposal

Fumes that do not condense in the UMU tank TK-302 are transferred to the thermal oxidizer system, through line 6-inch-UG-2-BBA. The operation of the thermal oxidizer system is controlled by the pressure transmitter PI-4008 located on the TSU and the ILS. In the automatic mode of the thermal oxidizer operation, the ILS closes the circuit when the pressure in the TSU rises to 10.5-inch H_2O , opening the valve AOV-4014 and energizing relay 1CR in the thermal oxidizer control system. In the manual mode of operation the setting of the AUTO-MANUAL switch on MANUAL performs the same action as the closing of the circuit by the ILS. After relay 1CR becomes energized, the following steps will take place:

- (1) The air fan FA-302, and timer 1TDR (set at 2 minutes) and the purge timers (set at 30 seconds) are energized. The purging of the burner starts, indicated by the lit amber light tagged PURGING.
- (2) At the end of 30 seconds, if the pressure switches PS-4037, PS-4038 and PS-4039 are closed, the solenoid valve SOV-4016 will open, allowing the flow of propane to the pilot burner, and the ignition rod will ignite the pilot. The pilot lamp will light.
- (3) After the pilot flame proves and valve AOV-4014 is open, the pressure in the line downstream of the fume blower reaches 8-inches H_2O , and the pressure switch PS-4034 closes. If the fume high pressure switch PS-4033 and the high limit burner flame temperature switch TS-4035 are closed (which should normally be the case) the fume blower FA-301 will start and the valve MOV-4015 will open, allowing the flow of

fumes to the main burner. The proper fume pressure will be indicated by the lit FUME PRESSURE lamp. The normal burner temperature will be indicated by the lit TEMP NORMAL lamp. The burner temperature is displayed on the dial of the temperature controller.

The proving of the pilot flame is done by means of the pilot flame rod. Limit switches mounted on valve MOV-4015 transmit signals to the master controller, indicating whether the valve is open or closed.

- (4) Upon ignition of the fumes in the main burner, the dilution air damper which has remained at its low flow position, goes under control of the temperature controller TC-4031 which senses the stack temperature through thermocouple TE-4031. The proving of the flame in the main burner is done by means of the UV detector BE-4030.
- (5) All the above steps should occur within 33 seconds. If all steps take place within that time period, the burner will continue its normal operation. If not, after 48 seconds an override circuit opens MOV-4015 and starts fume blower FA-301 (without ignition) to assure venting of the TSU.

The vapors coming from the TSU may, under certain conditions, contain a high proportion of nitrogen. This will happen if the make up gas to the TSU during the preceding extraction cycle was provided from the standby nitrogen supply. If the proportion of nitrogen in the fumes flowing to the burner exceeds a certain level the flame in the main burner will go out. When this happens the UV detector BE-4030 will activate the audible alarm and light the red BURNER OUT lamp. Simultaneously an alarm signal will be sent to the master controller, indicating that there is no flame in the burner. This signal will require a visual inspection of the unit in order to determine whether the reason for the absence of flame is caused by a malfunction of the system or by a lack of combustible gases in the fumes. To silence the alarm the ALARM SILENCE button has to be depressed.

The indication that the lack of flame in the burner is caused by an absence of combustibles in the fumes will be as follows:

- (1) The PILOT lamp will be on. (The pilot flame, once lighted, will be on as long as the propane supply is normal and the relay ICR is energized). With the PILOT lamp lit, the LIMITS NORMAL lamp has

also to be lit. These two lamps, if lit, indicate that the flow of propane is normal, that the air blower is running, and that the pilot flame is on.

- (2) The FUME PRESSURE lamp will be lit, indicating that there is a flow of fumes to the burner.
- (3) The TEMP NORMAL lamp will be lit, indicating that no overtemperature condition in the stack has taken place.

If it is found that the lack of combustibles is the cause for the "burner out" alarm, no further action is required except the silencing of the audible alarm. If during the same charging cycle the content of combustible gases becomes high enough, the fumes will be ignited by the pilot flame. This will cancel the alarm signal to the master controller, and turn off the red BURNER OUT lamp.

It is, however, necessary to examine the cause for the high content of nitrogen in the TSU vapors. The two major groups of possible causes are the malfunction of the condensate return system and the misadjustment of the pressure regulating valves in the nitrogen supply system. If the "burner out" alarm is caused by a malfunction in the system as indicated by the lamps on the control panels or by some other indication, the cause shall be determined and rectifying actions shall be implemented immediately. If the malfunction is of a nature that requires more than several minutes to rectify, action shall be taken immediately to discharge the heat from the TSU.

A detailed analysis of malfunctions of the UMU and of corresponding troubleshooting actions is given in a separate section of this manual.

When the pressure in the TSU ullage space drops to 8.5-inches H_2O on the pressure transducer PI-4008, the ILS breaks the circuit, de-energizing relay 1CR and closing the solenoid valve SOV-4014. This will cause the valve AOV-4014 to close, and the de-energizing of relay 1CR will end the operation of the thermal oxidizer. The air fan and the fume blower will stop, and the valves SOV-4016 and MOV-4015 will close. As a result the pilot flame and the main flame will be extinguished and all lamps on the thermal oxidizer control panel, with the exception of the POWER lamp, will be off.

Condensate Return

During the TSU extraction mode the temperature of the oil in the TSU will drop, resulting in a decrease of the volume of oil. During those periods and whenever the pressure in the ullage space of the TSU drops, make-up gas has to be added to the TSU from the UMU.

The primary source of the make-up gas is the condensate return circuit, consisting of the ullage pump P-308 and an assortment of valves and controls. The condensate pump from tank TK-302 into the TSU ullage space vaporizes when heated to the operating temperature at the top of the TSU bed, thus increasing the pressure in the ullage space. The condensate return is controlled by the ILS through transducer PI-4008 located at the top of the TSU. When the pressure in the ullage space of the TSU drops to 5.5-inches H_2O , the ILS closes the circuit and energizes the pump contactor. After 30 seconds, if the flow switch TS-4024 has not sent a flow signal to the ILS the pump will shut off and a "no flow" alarm will occur. A disconnect switch built in to the pump circuit has to be in the ON position for the pump to operate.

When the TSU ullage pressure increases to 6.5-inches H_2O , the ILS de-energizes the pump contactor, and the pumping stops. When the pump is off, liquid is prevented from returning to the tank by the check valve UHCK. Isolation of the pump for maintenance is provided by valves UHIS-2 and UHIS-3.

Nitrogen Supply

If the condensate return system cannot supply the required amount of make up gas to the TSU, the pressure in the TSU ullage space will gradually decrease. When the pressure drops below 5-inches H_2O , the nitrogen pressure regulator PCV-4006 will open, and when below 3-inches H_2O , PCV-4007 will open allowing the flow of nitrogen to the TSU through line 2-inches-N-5-BBA (PCV-4006 and PCV-4007 are located off the UMU skid).

Nitrogen is supplied to the UMU from the GN_2 supply tank at a pressure of 125 ± 20 psig. The GN_2 inlet pressure is indicated by gage PI-4003. Nitrogen pressure regulator PCV-4004 provides first stage regulation at 25 ± 5 psig. This pressure is maintained at all times in the line downstream of pressure regulator PCV-4004, and is indicated by gage PI-4005.

Line one-half-inch-N-4-BBD supplies nitrogen to the UMU tank TK-302 when the pressure in the UMU tank drops below 2-inches H_2O . Pressure regulator PCV-4023 which is set at 2-inches H_2O regulates the pressure of the supplied nitrogen which is indicated by gage PI-4017.


Pressure transmitter PTX-4052 transmits the pressure of nitrogen in line 1-inch-N-2-BBA to the master controller. A temperature transmitter TEX-4051 and a flow transmitter are also available to provide information regarding the nitrogen temperature and flow condition.

SETTING OF CONTROL INSTRUMENTATION UMU & TSU

INSTRUMENT	TAG NO.	FUNCTION	SETTING	REMARKS
Pressure Control Valve	PCV-4004	Main nitrogen pressure regulator	25 psig	
Pressure Control Valve	PCV-4023	Nitrogen make-up to UMU Tank Pressure Regulator	2" H ₂ O	
Pressure Control Valve	PCV-4009	First stage propane pressure regulator	6 psig	
Pressure Control Valve	PCV-4012	Second stage propane pressure regulator	4 to 8 oz/sq.in.	Field adjustment required to obtain pilot flame that will prove
Pressure Control Valve	PCV-4006	Primary nitrogen press. regulator	5" H ₂ O	Located off UMU in pipeline to TSU
Pressure Control Valve	PCV-4007	Secondary nitrogen press. regulator	3" H ₂ O	Located off UMU in pipeline to TSU
Pressure switch	PS-4001	Low pressure switch in main nitrogen line	60 psig	
Pressure switch	PS-4033	Fume high pressure switch	32" H ₂ O	
Pressure Switch	PS-4034	Fume low pressure switch	8" H ₂ O	
Pressure switch	PS-4037	Low Combustion air pressure switch	0.2" H ₂ O	
Pressure switch	PS-4038	Low pilot gas pressure switch	1.5 psig	
Pressure switch	PS-4039	High pilot gas pressure switch	10 psig	
Pressure transducer	PI-4008 + ILS	Controls operation of UMU pump P-308	Makes at 5.5" H ₂ O Breaks at 6.5" H ₂ O	This transducer is located at the top of the

INSTRUMENT	TAG NO.	FUNCTION	SETTING	REMARKS
Pressure transducer	PI-4008 + ILS	Controls operation of UMU Burner Assembly	Makes at 10.5" H ₂ O Breaks at 8.5" H ₂ O	
Temperature switch	TS-4035	High limit burner flame temperature switch	1550°F	
Temperature Controller	TC-4031	Burner flame temperature control	1400	
Flame safeguard purge timer	_____	Controls the purge period	30 seconds	
1 Timer/TDR	_____	Allows burner to run before main flame proves	2 minutes	
MOV-4015 override timer 3 TDR	_____	Open MOV-4015 to vent TSU if no flame (plus turn on FA-301)	48 seconds	

UMU VENTING AND FLARING SEQUENCE



APPENDIX B

MISCELLANEOUS

DESIGN DATA

APPENDIX B

MISCELLANEOUS DESIGN DATA

CALORIA PROPERTIES

1. Vapor Pressure: The vapor pressure of both fresh and weathered (1000 hours at 581°F) Caloria HT-43, as recently measured by Exxon, are shown in the attached figure.
2. Normal Boiling Point: Caloria HT-43 is a complex mixture of petroleum hydrocarbons, and as such has no discrete boiling point. Rather, various components fractionate (distill) across the temperature range of 700°F to 1000°F.
3. Density: The density of Caloria HT-43 varies linearly from 7.10 lb/gal at 75°F to 5.48 lb/gal at 575°F.
4. Other Properties: Other properties of Caloria HT-43 are discussed in the attached brochure and OSHA Data Sheets. Note that the vapor pressure shown in the brochure is in error.

SYSTEM FLOWRATES

The maximum Caloria flowrate in the system is 210,000 gallons per hour. The flowrate varies from zero to the maximum in a random manner in response to solar insolation and load transients; an approximate average flowrate is, perhaps, 100,000 gallons per hour.

TANK DATA

1. TSU Tank: The TSU Tank is 60 feet in diameter by 44 feet in height and cost approximately \$1,750,000.
2. Caloria Make-up Tank: The Caloria Make-up Tank is 14 feet in diameter by 10 feet in height and cost approximately \$30,000.

ULLAGE MAINTENANCE UNIT (UMU) DATA

1. UMU Stack Dimensions: The UMU Thermal Oxidizer (burner) stack outlet is 2 feet in diameter and is 23 feet above grade.
2. UMU Stack Gas: The flow rate of the exhaust gas from the UMU Thermal Oxidizer stack is 5770 ACFM of 800°F gas. This is equivalent to a stack exhaust velocity of 30 feet per second.

VAPOR PRESSURE · CALORIA HT-43






PLATE 92 K-E ALBANY 1951 68328
 VAPOR PRESSURE · PSIA
 K-E ALBANY 1951 68328
 TRACING PAPER



Caloria HT 43



Lubetex DG-2C
 ©1977, Exxon Corporation
 Printed in USA 3-1-77
 Supersedes issue of 9-15-76

CALORIA HT 43

CALORIA HT 43 is a heat-transfer fluid that provides excellent performance in a wide variety of applications. CALORIA HT 43 is a petroleum-base heat-transfer fluid formulated from a highly stable paraffinic base stock fortified with a high-temperature oxidation inhibitor.

FLUID TEMPERATURES

In the operation of any heat-transfer system, a wide range of fluid temperatures exists between the hottest and the coolest areas. When fluid temperatures are considered, therefore, it is important to identify them and to recognize their relationship to one another.

Next to the wall of the heating tube or coil is a layer of heat-transfer fluid that is distinct from the main stream (see illustration). Clinging to the surface of the tube, this layer flows more slowly than the main stream. Its slower speed and its proximity to the heat source raise its temperature to a higher level. In fact, this temperature—the maximum film (skin) temperature—may be far above the bulk temperature, the overall fluid temperature of the flowing system. Thus, the film temperature may exceed the maximum operating temperature for which the fluid is recommended. Since fluid life is shortened by overheating, this temperature differential must be taken into consideration.

The differential between maximum film temperature and bulk temperature depends primarily on flow velocity. Flow velocity, in turn, depends on the design of the installation and the flow properties of the fluid. In the evaluation of any heat-transfer fluid, therefore, its heat resistance should be related to the characteristics of the installation in which it is to be used. Unless the fluid is rated on a bulk-temperature basis allowing a reasonable margin for a higher film temperature, and unless the equipment is so designed and operated that this margin is not exceeded, the fluid may be overheated. By the same token, the fluid must have adequate flow properties—not only under normal operating conditions, but during low-temperature start-up, when it is relatively thick and sluggish.

THERMAL STABILITY

One of the most vital properties of a heat-transfer fluid is, of course, its resistance to heat. This includes resistance to oxidation at high temperatures and to thermal cracking, two forms of chemical decomposition to which organic compounds are commonly subject. Thermal cracking is the high-temperature breakdown of the fluid into fractions that are wholly undesirable from a heat-transfer standpoint. Some fractions form heavy, sluggish tars that may eventually break down into coke. The coke may in turn deposit on the heating coils, producing an insulating effect and thus interfering with the circulation required for efficient heat transfer. Other petroleum fractions are high in volatility, increasing the vapor pressure of the fluid and lowering its flash point. Fractions of this type are conducive to fire hazard and evaporation loss.

CALORIA HT 43 heat-transfer fluid is manufactured from petroleum stocks produced by a special refining method. Since thermally unstable components are separated and removed by this treatment, the resulting product has exceptional resistance to thermal decomposition.

OXIDATION STABILITY

Base stocks used in the manufacture of CALORIA HT 43 are selected for good oxidation stability, a characteristic that is further improved by selected refining techniques and the addition of an oxidation inhibitor. With these advantages, CALORIA HT 43 is especially resistant to the formation of oxidation sludges that may otherwise insulate the coil against efficient heat transfer and may also cause obstructions to fluid flow.

LOW VOLATILITY

Another essential high-temperature property is low volatility—low vapor pressure and high flash point. The low vapor pressure of CALORIA HT 43 (Figure 1) helps to eliminate vapor lock in circulating pumps; and reduces the possibility of cavitation, which is destructive to centrifugal pump blades. The low vapor pressure of CALORIA HT 43 throughout the normal operating range also prevents the buildup of excessive

pressure in closed systems. It also minimizes evaporation loss in open systems. In open systems operated at moderately high temperature, some evaporation loss can occur. This will result in a weathering effect which effectively reduces the vapor pressure to a still lower, equilibrium value as illustrated in Figure 1.

The low volatility and high flash point of CALORIA HT 43 are due to its excellent distillation characteristics. (Figure 2). The characteristic high flash point of this heat-transfer fluid permits higher expansion tank temperatures than common with many other fluids.

LOW-TEMPERATURE PERFORMANCE

The effectiveness of a heat-transfer fluid depends upon its low-temperature performance as well as its high-temperature performance. With a typical pour point of -9°C (15°F), CALORIA HT 43 has good pumpability in cold-weather start-ups, thereby diminishing the likelihood of hot spots—dangerously high fluid temperatures at the heater. The oil's low-temperature fluidity is a function of its high viscosity index—typically 115. This exceptionally high value gives CALORIA HT 43 greater resistance to changes in viscosity with varying temperatures, as illustrated in Figure 3.

HEATING EFFICIENCY

CALORIA HT 43 has the ability not only to resist heat, but to transfer it efficiently. Its viscosity characteristics are such that it provides a high rate of circulation under a wide range of operating temperatures. Other properties enable CALORIA HT 43 to transmit full heating loads rapidly. High specific heat gives CALORIA HT 43 the capacity to supply or remove the large amount of heat that efficient operation requires (Figure 4). High thermal conductivity enables it to transfer heat efficiently (Figure 5). These properties contribute not only to fuel economy, but to more even heat distribution and longer equipment life.

COMPATIBILITY

CALORIA HT 43 is compatible with other petroleum heat-transfer fluids and, if necessary, can be added to

them as make-up. This is not recommended, however, for fluids that are in poor condition. The mixing of a new petroleum oil with one that has deteriorated may cause the precipitation of sludges particularly at elevated temperatures—and will accelerate degradation of fresh oil. Adding of other petroleum fluids to CALORIA HT 43 is also feasible, though it can be expected that performance will be modified in proportion of the amount of added material.

THERMAL EXPANSION

All petroleum oils expand upon heating, and it is desirable to be able to predict the volume expansion of the oil to permit proper design of the expansion tank. In Figure 6, the volume of oil at a specific temperature relative to its volume at standard temperature is given. From this figure the increase in volume with an increase in temperature can be estimated.

APPLICATION—OPEN SYSTEM

CALORIA HT 43 gives good performance in open systems—where the fluid is exposed to air—provided the oil does not exceed 316°C (600°F) bulk temperature or 191°C (375°F) at the point of exposure to air.

If the 191°C temperature level will be exceeded, the Exxon representative should be consulted for alternate recommendations. For exposures above 191°C , the heat-transfer fluid should be chosen on the basis of flash point, to provide the lowest viscosity oil with a flash point at least 14°C (25°F) above the exposure temperature to prevent a fire hazard.

It should be recognized that at temperatures appreciably above 66°C (150°F), even the finest petroleum oils are subject to significant oxidation when exposed to air—the higher the temperature, the shorter the service life of the oil.

APPLICATION—CLOSED SYSTEM

CALORIA HT 43 heat-transfer fluid is recommended for service in closed, inert-gas blanketed systems, involving a maximum film temperature at the heater surface of 360°C (680°F). On the basis of a typical

temperature drop of 44°C (80°F) across the fluid film adjacent to the heater surface, this permits a maximum bulk temperature of 316°C (600°F).

general, however, the fluid will burn if subjected to the proper combinations of high temperature, oxygen, and source of ignition.

SAFETY

With its low volatility and high flash point, CALORIA HT 43 offers a reasonable degree of safety. When used as recommended in both open and closed systems that are mechanically sound, the danger of fire or explosion is minimized. Like petroleum products in

CALORIA HT 43 presents no special toxicity hazards and can be handled with the simple precautions ordinarily observed with lubricating oils. "Work Safely—Personal Care" cards suitable for mounting throughout a plant are available from the Exxon representative.

TYPICAL INSPECTIONS

The values shown here are representative of current production. Some are controlled by manufacturing specifications, while others are not. All of them may vary within modest ranges.

Gravity, °API	33.2
Density at 15°C, g(cm) ⁻³	0.8587
Color, ASTM	L1.0
Viscosity, cSt at 40°C	29.6
cSt at 100°C	5.4
SSU at 100°F	153
SSU at 210°F	44.4
Viscosity index	115
Flash point, COC, °C	204
°F	400
Pour point, °C	-9
°F	15
Rotary bomb oxidation life 150°C, minutes	115
Phenol, mass %	0.002
Saturates, mass % (ASTM D 2007)	91.0
Conradson carbon, mass %	0.003
Aniline point, °C	109.8
°F	229.7

Sulphur %
 Ash
 No Heavy metals

10/27/82
 RA
 ND

Tom Lipscomb Exxon, Houston Texas 713-686-5318
 #175/gal

Figure 1
 Vapor Pressure of Caloria HT 43
 (Calculated)




Figure 2
Distillation of Caloria HT 43
(Gas Chromatograph)




Figure 3
Viscosity-Temperature Relationship
of Caloria HT 43




Figure 4
Specific Heat of Caloria HT 43




Figure 5
Thermal Conductivity of Caloria HT 43





Figure 6
Thermal Expansion of Caloria HT 43



SECTION V HEALTH HAZARD DATA

THRESHOLD LIMIT VALUE

5 mg/m³ for oil mist in air. (OSHA Regulation 29 CFR 1910.1000)

EFFECTS OF OVEREXPOSURE

Prolonged or repeated skin contact may cause mild skin irritation.

EMERGENCY AND FIRST AID PROCEDURES

In case of skin contact, wash thoroughly with soap and warm water. If splashed into the eyes, flush with clear water for 15 minutes or until irritation subsides.

SECTION VI REACTIVITY DATA

STABILITY	UNSTABLE		CONDITIONS TO AVOID
	STABLE	X	
<p>INCOMPATIBILITY (Materials to avoid) Strong oxidants like: liquid chlorine, concentrated oxygen, sodium or calcium hypochlorite</p>			
<p>HAZARDOUS DECOMPOSITION PRODUCTS Fumes, smoke, carbon monoxide, and sulfur oxides, in the case of incomplete combustion.</p>			
HAZARDOUS POLYMERIZATION	MAY OCCUR		CONDITIONS TO AVOID
	WILL NOT OCCUR	X	

SECTION VII SPILL OR LEAK PROCEDURES

STEPS TO BE TAKEN IN CASE MATERIAL IS RELEASED OR SPILLED
 Recover free liquid. Add absorbent (sand, earth, sawdust, etc.) to spill area. Keep petroleum products out of sewers and watercourses by diking or impounding. Advise authorities if product has entered or may enter sewers, watercourses or extensive land area.

WASTE DISPOSAL METHOD

Assure conformity with applicable disposal regulations. Dispose of absorbed material at approved waste disposal site or facility.

SECTION VIII SPECIAL PROTECTION INFORMATION

RESPIRATORY PROTECTION (Specify type) Normally not needed. Use supplied-air respiratory protection in confined or enclosed spaces.

VENTILATION	LOCAL EXHAUST Use local exhaust to capture fumes and vapors.	SPECIAL Provide greater than 60 fpm hood face velocity for confined spaces.
	MECHANICAL (General)	OTHER

PROTECTIVE GLOVES Use chemical resistant gloves if needed to avoid prolonged skin contact. **EYE PROTECTION** Use splash goggles or face shield when eye contact may occur.

OTHER PROTECTIVE EQUIPMENT Use chemical resistant apron or other clothing if needed to avoid prolonged skin contact.

SECTION IX SPECIAL PRECAUTIONS

PRECAUTIONS TO BE TAKEN IN HANDLING & STORING

Keep containers closed when not in use. Do not handle or store near heat, sparks, flame or strong oxidants.

OTHER PRECAUTIONS



Avoid breathing oil mist. Remove oil-soaked clothing and launder before re-use. Discard oil-soaked shoes. Wash skin thoroughly with soap and water after handling.

FOR ADDITIONAL INFORMATION ON HEALTH EFFECTS CONTACT:

Director of Industrial Hygiene
 (713) 656-2443

FOR OTHER PRODUCT INFORMATION CONTACT:

Manager, Marketing Technical Services
 (713) 656-4929 134



To ILS
301

16-S-BIKINGHAM DEVICE DESIGNATIONS		REV. 07/15
FACILITIES ENGINEERING		
IOMW SOLAR PILOT PLANT SA311 UMU ELECTRICAL DIAGRAM		
DATE	BY	REV.
1974	J. THOMPSON	1
16A000-909J7-E20		1