

DOE FILE COPY


SAN/0499-48
MDC G8263

DOE/SF/10499-T89
(STMPO-174)

10 MWe Solar Thermal
Central Receiver Pilot Plant

SOLAR FACILITIES DESIGN INTEGRATION


PILOT PLANT AVAILABILITY



May 1980

WORK PERFORMED UNDER CONTRACT
DE-AC03-79SF10499

STEARNS-ROGER ENGINEERING CORP
4500 CHERRY CREEK DRIVE
P.O. BOX 5888
DENVER, CO 80217



U.S. Department of Energy



Solar Energy

SAN/0499-48
MDC G8263

**10 MWe Solar Thermal
Central Receiver Pilot Plant
Solar Facilities Design Integration**

PILOT PLANT AVAILABILITY

May 1980

DISCLAIMER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**MCDONNELL DOUGLAS ASTRONAUTICS COMPANY
5301 BOLSA AVENUE
HUNTINGTON BEACH, CA 92647**

**PREPARED FOR THE
U.S. DEPARTMENT OF ENERGY
SOLAR ENERGY
UNDER CONTRACT DE-AC-03-79SF10499**

TABLE OF CONTENTS

| | | |
|-----------|---|----|
| Section 1 | GENERAL | 1 |
| | 1.1 Introduction | 1 |
| | 1.2 Purpose | 1 |
| | 1.3 Scope | 1 |
| Section 2 | APPLICABLE DOCUMENTS | 2 |
| Section 3 | SYSTEM DEFINITION AND ANALYSIS DATA | 4 |
| | 3.1 System Description | 4 |
| | 3.2 Operating Times | 6 |
| | 3.2.1 Estimated Operating Hours | 6 |
| | 3.2.2 Subsystem Operating Calculations | 6 |
| | 3.3 Ground Rules and Definitions | 8 |
| | 3.3.1 Availability Goal | 8 |
| | 3.3.2 Failure Modes and Effects Analysis (FMEA) | 8 |
| | 3.3.3 Forced and Planned Outages | 9 |
| | 3.3.4 Availability Methodology | 10 |
| Section 4 | AVAILABLE ANALYSIS AND PREDICTIONS | 11 |
| | 4.1 Summary of Results of Analysis | 11 |
| | 4.2 Pilot Plant Availability | 11 |
| | 4.2.1 Collector Subsystem Availability | 14 |
| | 4.2.2 Receiver Subsystem Availability | 14 |
| | 4.2.3 Thermal Storage Subsystem Availability | 14 |
| | 4.2.4 Master Control Subsystem Availability | 14 |
| | 4.2.5 Electrical Power Generation Subsystem Availability | 15 |
| | 4.2.6 Plant Support Subsystem Availability | 15 |
| Section 5 | SUBSYSTEM FIGURES AND AVAILABILITY ANALYSIS TABULATIONS | 16 |

LIST OF FIGURES

| <u>Figure No.</u> | | <u>Page</u> |
|-------------------|--|-------------|
| 3-1 | Central Receiver Baseline Concept | 5 |
| | Solar Flow Diagram 10 MW Pilot Plant | 17 |
| | Receiver Subsystem (RS) OCS P & ID | 18 |
| | Receiver Subsystem (RS) Instrument Air and GN ₂ OCS P & ID's | 19 |
| | Piping and Instrument Diagram Receiver Subsystem (RS) Steam & Feedwater | 20 |
| | Thermal Storage Subsystem (TSS) Instrument Air P & ID | 23 |
| | Ullage Maintenance Unit (UMU) P & ID DAS & OCS | 24 |
| | Thermal Storage Subsystem (TSS) OCS P & ID | 25 |
| | Piping & Instrument Diagram Thermal Storage Subsystem (TSS) Thermal Oil | 26 |
| | Piping & Instrument Diagram Thermal Storage Subsystem (TSS) Steam & Condensate | 27 |
| | Piping & Instrument Diagram Electrical Power Generation Subsystem (EPGS) Steam | 36 |
| | Piping & Instrument Diagram Electric Power Generation Subsystem (EPGS) Condensate & Feed Water | 37 |
| | Piping & Instrument Diagram Plant Support Subsystem (PSS) Water Treatment | 46 |

LIST OF TABLES

| <u>Table No.</u> | | <u>Page</u> |
|------------------|-----------------------------------|-------------|
| 3-1 | Annual Operating Hours | 7 |
| 4-1 | Availability Predictions | 11 |
| 4-2 | Unavailability Predictions | 12 |
| 4-3 | Mean Time Between Failures (MTBF) | 13 |

Section 1

GENERAL

1.1 INTRODUCTION

The System Specification (RADL Item 2-3), PRELIMINARY, dated November 1979 (MDC G8220), herein referred to as the System Specification, specifies the availability goal for the 10 MWe Solar Thermal Central Receiver Pilot Plant, herein referred to as the "pilot plant", and assigns availability goals to the subsystems of the pilot plant. This Pilot Plant Availability report presents the current predictions of the availability of the pilot plant and its subsystems.

1.2 PURPOSE

In addition to presenting the current predictions of availability, this report points out those subsystems and components which are major contributors to pilot plant unavailability so that the responsible design and other engineering disciplines may implement changes to increase equipment availability or reduce the effect of unavailability.

1.3 SCOPE

In determining availability, only functional components of the subsystem that are unavailable to perform their required functions due to component failure (component forced outage) and due to planned maintenance (component planned outage) are taken into account. Support equipment, such as site structures (i.e., receiver tower), facility service equipment (i.e., service trucks and cranes), operations control (i.e., computer software), and passive components (i.e., piping), are assumed to be functional 100% of the time the pilot plant is in operation. Availability analysis of this kind of support equipment is beyond the scope of this report.

The Beam Characterization Subsystem is not included in this availability analysis and the availability of the Collector Subsystem is assumed to be the assigned value (99.9%).

Section 2
APPLICABLE DOCUMENTS

1. MDC G8217, Piping and Instrumentation Diagrams (RADL Item 2-16), September 1979.
2. MDC G8220, System Specification (RADL Item 2-3) PRELIMINARY, November 1979.
3. MDC G8221, Failure Modes and Effects Analysis (RADL Item 2-23), December 1979.
4. EEI Publication No. 77-64, Report on Equipment Availability for the Ten-Year Period, 1967-1976, Prime Movers Committee, Edison Electric Institute.
5. ORNL/ENG/TM-2, Nuclear Reliability Assurance Data Source Guide, Oak Ridge National Laboratory.
6. RADC-TR-75-22, Nonelectric Reliability Notebook, Rome Air Development Center, January 1975.
7. NPRD-1, Nonelectric Parts Reliability Data, Rome Air Development Center, Summer 1978.
8. SP-862-05, Failure Rate Data Handbook, (FARADA), June 1973.
9. MIL-STD-217 C, Reliability Prediction of Electronic Equipment.
10. Drawings and Schematics
 - a. Solar Flow Diagram; S10MW-PP, Rev. 6, Sep. 24, 1979.
 - b. Receiver Subsystem (RS) OCS P&ID; C060479, Rev. B, Sep. 17, 1979.
 - c. Receiver Subsystem (RS) Instrument Air and GN2 OCS P&ID's; C060579, Rev. A, Sep. 17, 1979.
 - d. Thermal Storage Subsystem (TSS) Instrument Air P&ID; C060779, Rev. A, Sep. 17, 1979.
 - e. Ullage Maintenance Unit (UMU) P&ID DAS & OCS; C060879, Rev. A, Sep. 17, 1979.
 - f. Thermal Storage Subsystem (TSS) OCS P&ID; C061179, Rev. B, Sep. 17, 1979.
 - g. P&ID, Electrical Power Generation Subsystem (EPGS) Steam; 40P7005133140, Rev. P3, Oct. 11, 1979.
 - h. P&ID, Electrical Power Generation Subsystem (EPGS) Condensate & Feed Water; 40P7005133141, Rev. P3, Sep. 10, 1979.
 - i. P&ID Thermal Storage Subsystem (TSS) Thermal Oil; 40P7005133142, Rev. P3, Sep. 11, 1979.

- j. P&ID Thermal Storage Subsystem (TSS) Steam & Condesate; 40P7005133143,
Rev. P3, Sep. 7, 1979.
- k. P&ID Receiver Subsystem (RS) Steam & Feedwater; 40P7005133144,
Rev. P3, Sep. 6, 1979.
- l. P&ID Plant Support Subsystem (PSS) Water Treatment; 40P7005133145,
Rev. P3, Sep. 6, 1979.

Section 3
SYSTEM DEFINITION AND ANALYSIS DATA

3.1 SYSTEM DESCRIPTION

The pilot plant is a solar thermal central receiver type. It derives thermal energy directly from incident solar radiation to heat water and converts the water to steam which is used to drive a conventional steam turbine to produce electricity. Part of the thermal energy derived from solar radiation may be stored and used during periods of no sunlight or on cloudy days to produce steam to drive the turbine. The pilot plant has a nominal 10MWe rating. It consists of seven subsystems which perform the following functions:

A. Collector Subsystem - array of sun-tracking mirrors (heliostats) which focus the incoming sun's radiation and reflect it to the tower - mounted receiver panels.

B. Receiver Subsystem - absorbs the redirected solar energy and uses it to convert feedwater into superheated steam.

C. Thermal Storage Subsystem - stores excess thermal energy produced by the Receiver Subsystem for use to produce steam during periods of nonsunshine.

D. Electrical Power Generation Subsystem - receives steam from the Receiver Subsystem and/or Thermal Storage Subsystem and converts its thermal energy into electrical power.

E. Master Control Subsystem - monitors and controls pilot plant operations.

F. Plant Support Equipment - interconnecting piping and wiring and support systems for pilot plant subsystems.

G. Beam Characterization Subsystem - consists of equipment used to calibrate heliostats.

Figure 3-1 schematically depicts the pilot plant. The schematics and drawings of the pilot plant and subsystems used in this analysis are listed in the applicable documents section and are included in this report for reference.




Figure 3-1. Central Receiver Baseline Concept

3.2 OPERATING TIMES

A summary of the operating times for the subsystems of the pilot plant to be used for calculating availability is given in Table 3-1.

3.2.1 Estimated Operating Hours

The "estimated" operating hours shown in Table 3-1 were determined as explained in the sections which follow and represent the number of hours per year that the specific subsystem would be operational if no failures occurred. The "actual" operating hours were determined by assuming a plant availability of 90%, the availability goal in the System Specification. Therefore, the total of forced outages and planned outages of one or more of the subsystems causes the actual operating hours of each subsystem to be 10% less than its estimated operating hours.

3.2.2 Subsystem Operating Calculations

1. Collector Subsystem

Estimated operating hours = total hours per year when the sun is at an angle greater than 10° above the horizon minus a 10% random cloud cover reduction plus a 1 hour per day allowance for heliostat operations before sunrise and after sunset.

$$= 3,366 * 0.9 (365) = 3,695 \text{ hours}$$

2. Receiver Subsystem

Estimated operating hours = gross sunshine hours (includes 10% random cloud cover reduction).

$$= 3,366 * \text{ hours}$$

3. Thermal Storage Subsystem - Charging Loop

Estimated operating hours = gross sunshine hours (includes 10% random cloud cover reduction).

$$= 3,366 * \text{ hours}$$

*From memo A3-202-EP-RGR-337, dated 30 April 1979 from R. W. Hallet, Jr. to Richard N. Schweinberg.

Table 3-1. ANNUAL OPERATING HOURS

| Subsystem | Operating Hours | |
|---|-----------------|--------|
| | Estimated | Actual |
| Collector | 3,695 | 3,326 |
| Receiver | 3,366 | 3,028 |
| Thermal Storage | | |
| Charging | 3,366 | 3,029 |
| Extraction | 1,651 | 1,486 |
| Charging and Extraction | 4,680 | 4,212 |
| Master Control | 8,760 | 7,884 |
| Electrical Power Generation (RS Steam Only) | 3,366 | 3,029 |
| (TSS Steam Only) | 1,651 | 1,486 |
| | 4,680 | 4,212 |
| Plant Support | 8,760 | 7,884 |

4. Thermal Storage Subsystem - Extraction Loop

Estimated operating hours = 4 hours per day of gross sunshine days (includes 10% random cloud cover reduction) + 10% of maximum operating hours of Receiver Subsystem to account for operating periods when the Thermal Storage Subsystem is also delivering steam to the Electrical Power Generation Subsystem during cloudy daytime periods.

$$= 4 \times 365 \times 0.9 + 0.1 \times 3,366$$

$$= 1,651 \text{ hours}$$

5. Thermal Storage Subsystem - Common Equipment

Estimated operating hours = gross sunshine hours (including 10% random cloud cover reduction) + 4 hours per day of gross sunshine days (including 10% random cover reduction).

$$= 3,366 + 4 \times 365 \times 0.9$$

$$= 4,680 \text{ hours}$$

6. Master Control and Plant Support

Estimated operating hours = continuous operation for year.
= 8,760 hours

7. Electrical Power Generation

When receiving steam from Receiver Subsystem only, estimated operating hours are same as for Receiver Subsystem.

= 3,366 hours

When receiving steam from Thermal Storage Subsystem only, estimated operating hours are same as for extraction loop of Thermal Storage Subsystem.

= 1,651 hours

EPGS operating hours for Common Equipment are the same as the Thermal Storage Subsystem while charging and extracting.

= 4,680 hours

3.3 GROUND RULES AND DEFINITIONS

3.3.1 Availability Goal

In accordance with paragraph 3.2.1.3 of the System Specification, the pilot plant shall have an availability goal of 90% over a 1-year period. Availability shall be as defined by the Edison Electric Institute (EEI-77-64) but in the context of a solar facility operation.

Component failures which cause power output reductions of less than 2% do not reduce subsystem or pilot plant availability.

Component failures which cause power output reductions of between 2% and 100% shall reduce subsystem or pilot plant availability in proportion to the reduction in power output.

The System Specification states "no availability penalty shall be assessed if plant operations can be maintained through a change in operating mode." In this analysis only the basic operating mode of the specific subsystem was taken into account. Therefore, availability predictions presented are lower than would be expected if other alternate operating modes were considered.

3.3.2 Failure Modes and Effects Analysis (FMEA)

Component failure modes and their effect on subsystem performance as determined in the FMEA, RADL Item 2-23, December 1979, were used to assess subsystem unavailability due to component failures. FMEA criticality category C failures,

failures that will have little or no effect on plant performance, or failures that will be corrected during nonoperating periods or on a noninterference basis, are assumed to have no effect on availability. Therefore, criticality category C failures are not listed in the availability analysis tabulations, but criticality category A and B failures are included. Category A includes failures that will cause complete plant shutdown and category B includes failures that will cause major reduction in plant efficiency.

Instrumentation failures which do not result in full or partial subsystem shutdown do not render the subsystem unavailable.

No availability penalty is assessed to a subsystem for component failures which do not reduce subsystem performance, i.e., single failures in redundant paths.

3.3.3 Forced and Planned Outages

The time shown in the Component Planned Outage column of the Availability Analysis tabulations is actual lost operating times per year due to planned maintenance. For example, if the subsystem is operational 10 hours each 24 hour day and the actual planned maintenance is performed in 168 hours each 1-1/2 years, the operational hours lost in one year is as follows:

$$\frac{168}{1.5} \times \frac{10}{24} = 47 \text{ hours}$$

The mean time to restore, (MTTR), the subsystem to operation after a component failure is multiplied by failures per year to determine component forced outage time. For two or more of the same component, the figure is further multiplied by the number of similar components to determine the subsystem unavailability. Where the MTTR is less than the daily operational period for the subsystem, it is assumed (worst case) that the entire forced outage occurs during the subsystem operational period. Where the MTTR is more than the daily operational period for the subsystem, the forced outage is adjusted to reflect only actual lost operational hours, (i.e., it is estimated that the MTTR of the Thermal Storage Unit tank is 3 months (2,160 hours), but this results in a forced outage of the Thermal Storage Subsystem of only 1,350 operational hours).

3.3.4 Availability Methodology

Availability is the percent of time a subsystem, or the pilot plant, is capable of performing its specified function or provide its specified output during the subsystem, or pilot plant, annual operating periods. The mathematical expression is as follows:

$$A = \frac{OH - U}{OH} \times 100$$

or

$$= 100 - 100 \sum \left(\frac{nF}{YR} \times MTTR + PO \right)$$

where

A = availability - %

OH = component operational hours per year

U = unavailable time - hours per year

$\frac{F}{YR}$ = number of component failures per year

MTTR = mean time to restore - hours

PO = planned outage time - hours

U = unavailable time - hours

and

$$\frac{F}{YR} = \frac{OH}{MTBF}$$

where

MTBF = mean time between failures - hours/failure

Section 4
 AVAILABILITY ANALYSIS AND PREDICTIONS

4.1 SUMMARY OF ANALYSIS RESULTS

Table 4-1 is a summary of the availability goals and current predictions for the pilot plant and each of its subsystems. The availability analysis tabulations listed the forced and planned outage figures and the unavailability contributed by each component of the subsystems. Table 4-2 is a summation of the results of the availability analysis tabulations. The component mean time between failures (MTBF) used in the Availability Analysis tabulations were derived from the failure rate source publications shown in the Applicable Documents section of this report and are listed in Table 4-3 for reference.

4.2 PILOT PLANT AVAILABILITY

Pilot Plant availability will be 92.05% if planned maintenance on all subsystems is performed during the same shutdown period, and 88.5% if planned maintenance on the subsystems is performed during different shutdown periods. It is probable that neither method of planned maintenance will be used exclusively. Therefore, these figures represent the range into which the actual availability of the pilot plant will fall, the average being approximately 90.28%.

Table 4-1. Availability Predictions

| Pilot Plant/Subsystem | Availability - % | | Notes |
|-----------------------------|------------------|-------------|-------|
| | Goal/Assigned | Predictions | |
| Pilot Plant | 90 | 88.5 | (1) |
| Collector Subsystem | 99.90 | 99.90 | |
| Receiver Subsystem | 98.05 | 97.44 | |
| Thermal Storage Subsystem | 98.10 | 96.23 | |
| Master Control Subsystem | 99.95 | 99.99 | |
| Electrical Power Generation | 95.00 | 96.33 | |
| Plant Support Subsystem | 99.00 | 98.61 | |

(1) If planned outages for all subsystems are concurrent, the pilot plant availability prediction increases from 88.50% to 92.05%.

Table 4-2. Unavailability Predictions

| <u>Subsystem</u> | <u>Outages (Hrs/Yr)</u> <u>Forced</u> | <u>Planned</u> | <u>Operating</u> <u>Hours</u> | <u>Outage Rates (%)</u> <u>Forced</u> | <u>Planned</u> |
|--|--|----------------|----------------------------------|--|----------------|
| Collector | 3.70 | 0 | 3695 | 0.10 | 0 |
| Receiver | 39.54 | 47 | 3366 | 1.17 | 1.39 |
| Thermal Storage | | | | | |
| Charging | 17.55 | 0 | 3366 | 0.52 | 0 |
| Discharge | 7.08 | 0 | 1651 | 0.43 | 0 |
| Common | 85.16 | 47 | 4680 | 1.82 | 1.00 |
| Master Control | 0.79 | 0 | 8760 | 0.01 | 0 |
| Elec. Power Gen. | | | | | |
| Receiver Steam | 63.28 | 104 | 3366 | 1.35 | 2.22** |
| T. S. Steam | 1.57 | 0 | 1651 | 0.10 | 0 * |
| Plant Support | 20.57 | 101 | 8760 | 0.23 | 1.16 |
| TOTALS | | | | 5.73 | 5.77 |
| Pilot Plant Availability = 88.50 → 92.05 | | | | | |

* Figures shown are for Electrical Power Generation Subsystem components which operate when the subsystem receives steam from the receiver subsystem.

** Figures shown are for the additional components that operate when the subsystem receives steam from the Thermal Storage Subsystem.

The Electrical Power Generation Subsystem accounts for 32% of the unavailability of the pilot plant. The next larger contributors are the Thermal Storage Subsystem with 33% of the unavailability and the Receiver Subsystem with 22% of the unavailability. The remaining three subsystems combined contribute only 13% of the unavailability of the pilot plant.

Table 4-3. Mean Time Between Failures (MTBF)

| Component | MTBF (10^3 Hours) |
|-------------------------------------|----------------------|
| Air Cooler | 31 |
| Boiler | 91 |
| Circuit Breaker | 1000 |
| Condenser | 91 |
| Controller | 27.4 |
| Deaerator | 100 |
| Demineralizer | 100 |
| Desuperheater | 31.5 |
| Filter, liquid | 330 |
| Filter, gas | 830 |
| Heaters | 91 |
| Heat Exchanger | 31 |
| Hiway Traffic Director | 10 |
| Manifold | 1000 |
| Orifices | 270 |
| Panel, preheater | 62.5 |
| Pump | 16 |
| Restrictor | 80 |
| Steam Trap | 1000 |
| Superheater | 91 |
| Strainer, Y Type | 250 |
| Strainer, cleanout | 330 |
| Separator, moisture | 250 |
| Tank | 1000 |
| Transmitter, pressure and flow rate | 32.5 |
| Transformer | 500 |
| Turbine-Generator | 5.5 |
| Valves | |
| - Butterfly, check and manual | 250 |
| - Control, regulator, 3 way | 160 |
| - Safety, relief | 100 |

4.2.1 Collector Subsystem Availability

Collector Subsystem availability was taken as the assigned goal of 99.9%, which reflects the results of a previous analysis. Assuming the previously estimated MTBF of 17,000 hours for an entire heliostat and 330 days per year of operating time for the subsystem, 1.2 failures per day can be expected in a collector field of 1,818 heliostats. An outage of up to 36 heliostats, depending on their location and failure mode, will not reduce the pilot plant output more than 2%, and thus will not effect availability. Therefore, 99.9% appears to be a realistic estimate of the availability of the Collector Subsystem.

The Receiver Subsystem availability prediction is 97.44%. The assigned goal is 98.05%. There are several factors that contribute to this value. The largest contributor is the planned outage of 47 hours (1.39%) required for tube cleaning. The largest forced outage item is the failure of the 18 flow rate transmitters with a total outage of 10.044 hours per year. The next time is the 18 moisture separators with a failure rate of 0.030 per year, a MTTR of 9 hours and a component forced outage of 0.27 hours per year for each separator.

4.2.3 Thermal Storage Subsystem Availability

The Thermal Storage Subsystem availability prediction is 96.23%. This is below the assigned goal of 98.10%. Forced outages due to failures of components connected to the Thermal Storage Unit, 3 shutoff valves TFAIS-1, TUFIS and TUFFIS, contribute 40% of the unavailability of the entire subsystem. This is because replacement of any of these valves requires that the Thermal Storage tank be drained. The mean time to restore the subsystem to full operation after one of these valves fails is estimated to be 3 calendar months or 1,350 subsystem operational hours. Design improvements to eliminate the need to drain the Thermal Storage Tank in the event of a shutoff valve failure should be considered.

4.2.4 Master Control Subsystem Availability

The Master Control Subsystem availability prediction is 99.99%. This prediction exceeds the goal of 99.95%.

4.2.5 Electrical Power Generation Subsystem Availability

The Electrical Power Generation Subsystem availability predictions is 96.33%, which value exceeds the goal of 95.0%. Approximately 62% of the unavailability of the subsystem results from planned outage for maintenance of the major components in the subsystem - the turbine generator, condenser, low and high pressure heaters, desuperheaters, and demineralizers. The component planned outage for each of these components is estimated to require 104 subsystem operational hours per year. This subsystem has the largest planned maintenance outage of all of the subsystems.

The second largest contributor to the unavailability of the subsystem is forced outage, 30.64 hours per year, for the turbine generator. This high component outage results because of the high failure rate predicted for the turbine generator, 5,500 hrs MTBF.


4.2.6 Plant Support Subsystem Availability

The Plant Support Subsystem availability prediction is 98.61%, which approximates the goal of 99.0%. The largest contributor to the unavailability of subsystem results from the estimate of 101 subsystem operational hours of outage required for planned maintenance of the cooling water heat exchanger. This accounts for 83% of the unavailability of the subsystem.

Section 5

SUBSYSTEM FIGURES AND AVAILABILITY ANALYSIS TABULATIONS

The figures used for the Availability Analyses as well as the tabulated results of the analyses, are contained in this section.



TEMPORARY (DEPT 585-141 VALVES & CONTROLS)

SOLAR TEN TECHWATT PROJECT OFFICE
 1550 FLAME DRIVE, SUITE 210
 SAN FRANCISCO OPERATIONS OFFICE
 25 MONTE, CALIFORNIA 94721

8000 SOLAR PILOT PLANT - SAGGOTT, CALIFORNIA


| REVISIONS | | | | REFERENCE DRAWINGS | | | | PART EXCISES | | | | N.C. (6-8-79) | | | | SOLAR FACILITIES DESIGN INTEGRATOR | | | |
|-----------|-------------------|---|---------|--------------------|--|--|--|--------------|--|--|--|---------------|--|--|--|------------------------------------|--|--|--|
| A | ISSUED FOR REVIEW | 1 | 1/15/79 | | | | | | | | | | | | | | | | |
| B | ISSUED FOR REVIEW | 2 | 1/15/79 | | | | | | | | | | | | | | | | |
| C | ISSUED FOR REVIEW | 3 | 1/15/79 | | | | | | | | | | | | | | | | |

DATE: 9-17-79

RECEIVER SUBSYSTEM (RS)
 OCS P&ID

C060479

Sheet: B



| TAG NO. | DESCRIPTION |
|-----------------------|--|
| RPWDV-1 THRU RPWDV-3 | PREHEATER PANEL WATER DRAIN VALVE |
| RBWDV-4 THRU RBWDV-6 | BOILER PANEL WATER DRAIN VALVE |
| RPWDV-7 THRU RPWDV-24 | PREHEATER PANEL WATER DRAIN VALVE |
| RPWVY | PREHEATER PANEL WATER VENT VALVE |
| RAWDV | MOISTURE ACCUMULATOR WATER DRAIN VALVE |
| RFSIV | FLASH TANK STEAM INLET VALVE |
| RMSVV-N-2 | DOWNCOMER MANIFOLD STEAM VENT VALVE |
| RPWIV | PREHEATER PANEL FEEDWATER INLET VALVE |

| TAG NO. | DESCRIPTION |
|-------------------------|--|
| RBWTCV-4 THRU RBWTCV-21 | BOILER PANEL WATER TEMPERATURE CONTROL VALVE |
| RFSPCV | FLASH TANK STEAM PRESSURE CONTROL VALVE |
| RWBV | FEEDWATER BYPASS VALVE |
| RDSIV | DOWNCOMER STEAM INLET VALVE |

GENERAL NOTES:
 1. GAGE VALVE (NOT SHOWN) WILL BE INSTALLED. ONE VALVE EACH FOR ALL PRESSURE GAGES.
 2. FOR RS-OCS COMPONENTS INFORMATION REFER TO P&ID NO. C060479.


* TEMPORARY (DEPT 585-141 VALVES & CONTROLS)

DEPARTMENT OF ENERGY SOLAR THERMAL ENERGY PROJECT OFFICE
 SAN FRANCISCO OPERATIONS OFFICE 9550 PLAS 24-14 SUITE 210
 8 MONTE CALPORNIA WY 20
 10 8700 SOLAR PILOT PLANT - DAGUERRE, CALIFORNIA

SOLAR FACILITIES DESIGN INTEGRATOR
 RECEIVER SUBSYSTEM (RS) INSTRUMENT AIR AND GN2 OCS P & ID'S
 DATE: 9-17-79
 NO. C060577

| REVISIONS | EDITS/REVIEWS | PRINT RECORD | DATE | BY | APP'D |
|-----------|---------------|--------------|------|----|-------|
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

9-17-79 2:00 PM JWA TEM 28



- NOTES:
1. ALL EQUIPMENT AND PIPING SHOWN IN PARANTON SHALL BE PROVIDED BY ROCKWELL. FOR DETAILS OF PIPING AND INSTRUMENTATION SEE ROCKWELL P & ID C06678 & C06679.
 2. ALL INSTRUMENTATION BY ROCKWELL.

9-12-79 REVISIONS: ADDED INTERFACE NUMBERS, LINE NUMBERS NA-1, VT-3, NA-1, CO-6, VT-1 & CO-1. CHANGED PREHEATER & BOILER PANEL NUMBERS. ADDED "HOLD".

| NO. | REVISIONS | DATE | BY | CHKD. | APP'D. | REFERENCE DRAWINGS | PRINT RECORD | DESIGN | SCALE | DATE | FOR APPROVAL |
|-----|-----------|------|----|-------|--------|--------------------|--------------|--------|-------|------|--------------|
| 1 | | | | | | | | | | | |
| 2 | | | | | | | | | | | |
| 3 | | | | | | | | | | | |
| 4 | | | | | | | | | | | |
| 5 | | | | | | | | | | | |
| 6 | | | | | | | | | | | |
| 7 | | | | | | | | | | | |
| 8 | | | | | | | | | | | |
| 9 | | | | | | | | | | | |
| 10 | | | | | | | | | | | |
| 11 | | | | | | | | | | | |
| 12 | | | | | | | | | | | |
| 13 | | | | | | | | | | | |
| 14 | | | | | | | | | | | |
| 15 | | | | | | | | | | | |
| 16 | | | | | | | | | | | |
| 17 | | | | | | | | | | | |
| 18 | | | | | | | | | | | |
| 19 | | | | | | | | | | | |

DEPARTMENT OF ENERGY SOLAR TEN MEGAWATT PROJECT OFFICE
 SAN FRANCISCO OPERATIONS OFFICE 3550 FLUOR DRIVE, SUITE 210
 EL MONTE, CALIFORNIA 91731

10 MW SOLAR PILOT PLANT - GACETTI, CALIFORNIA

SOLAR FACILITIES DESIGN INTEGRATOR

TITLE: P&ID (P3-5) RECEIVER SUBSYSTEM (RS) STEAM & FEEDWATER

DATE: 9-6-79

40P7005133144

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

ITEM 5.1 RECEIVER SUBSYSTEM

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Downcomer Input Valve, RDSIV | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | A | 0.162 | |
| Flush-Tank Input Valve, RFSIV | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | A | 0.162 | |
| Receiver Flash Tank, RF | 3,029 | 1,000,000 | 0.003 | 6 | 0.018 | 0 | A | 0.018 | |
| Flash-Tank Relief Valve, RFSRV | 3,029 | 1,000,000 | 0.003 | 9 | 0.027 | 0 | B | 0.027 | |
| Flash-Tank Pressure Control Valve, RFSPCV | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | A | 0.162 | |
| Receiver-Water Bypass Valve, RWBV | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | B | 0.162 | |
| Main Nitrogen Valve, RNMV | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | B | 0.162 | |
| Nitrogen High-Pressure Regulator, RNPR-1 | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | B | 0.162 | |
| Relief Valve, RNRV | 3,029 | 100,000 | 0.030 | 9 | 0.270 | 0 | B | 0.270 | |
| Filter, RNF | 3,029 | 830,000 | 0.004 | 6 | 0.024 | 0 | B | 0.024 | |
| Pressure Regulator, RNPR-2 | 3,029 | 160,000 | 0.019 | 8.5 | 0.162 | 0 | B | 0.162 | |
| Control Valve, RNPV-2 | 3,029 | 160,000 | 0.019 | 9 | 0.171 | 0 | B | 0.171 | |

AVAILABILITY ANALYSIS


PREPARED BY HAROLD BURG

ITEM 5.5 PLANT SUPPORT SUBSYSTEM




DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Cooling-Tower Transformer | 7,884 | 500,000 | 0.016 | 4.0 | 0.064 | 0 | A | 0.064 | |
| Cooling-Tower Transformer Output Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-L Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-A Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-B Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Receiver PPA Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Centers for Power Panels | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.024 | |

| TSS INSTRUMENT AIR OPERATED STOP VALVES | | |
|---|---|----------|
| TAG NO | DESCRIPTION | SKID NO. |
| TMSIV-1 | THERMAL STORAGE HEATER, TH-1 STEAM INLET CONT VALVE | SA 302 |
| TMSIV-2 | THERMAL STORAGE HEATER, TH-2 STEAM INLET CONT VALVE | SA 303 |
| TMSWV-1 | THERMAL STORAGE HEATER, TH-1 BLANKET STEAM CONT VALVE | SA 302 |
| TMSWV-2 | THERMAL STORAGE HEATER, TH-2 BLANKET STEAM CONT VALVE | SA 303 |
| TSVV-1 | STEAM TRAP TT-1 VENT CONTROL VALVE | SA 302 |
| TSVV-2 | STEAM TRAP TT-2 VENT CONTROL VALVE | SA 303 |
| UGVV-1 | THERMAL STORAGE UNIT ULLAGE VENT VALVE | |
| TFBIV-1 | FLASH TANK BLANKET STEAM CONTROL VALVE | SA 301 |
| TRFBV | CHARGING PUMP INTERCONNECT CONTROL VALVE | SA 304 |
| TFEPV | EXTRACTION PUMP INTERCONNECT CONTROL VALVE | SA 309 |
| TFAPV | THERMAL STORAGE AUXILIARY FLUID CONTROL VALVE | SA 309 |
| TFAIV-1 | THERMAL STORAGE AUXILIARY FLUID INLET CONTROL VALVE | SA 307 |
| TFAIV-2 | THERMAL STORAGE AUXILIARY FLUID INLET CONTROL VALVE | SA 308 |
| TSSWV-1 | STEAM GENERATOR BLANKET STEAM CONTROL VALVE | SA 307 |
| TSSWV-2 | STEAM GENERATOR BLANKET STEAM CONTROL VALVE | SA 308 |
| TSSBV-1 | STEAM GENERATOR BLEED CONTROL VALVE | SA 307 |
| TSSBV-2 | STEAM GENERATOR BLEED CONTROL VALVE | SA 308 |
| TUFV | THERMAL STORAGE UNIT, TU FLUID EXTRACTION CONT VALVE | |
| TUFV | THERMAL STORAGE UNIT, TU BYPASS CONTROL VALVE | |
| TUFCV | THERMAL STORAGE UNIT, TU INLET/OUTLET CONTROL VALVE | |
| TBWBV-1 | BOILER WATER BLOWDOWN VALVE | SA 307 |
| TBWBV-2 | BOILER WATER BLOWDOWN VALVE | SA 308 |
| UGVV-2 | ULLAGE STORAGE TANK VENT VALVE | SA 311 |
| UGPCV | ULLAGE GAS PRESSURE CONTROL VALVE | |



| TSS INSTRUMENT AIR OPERATED MODULATING VALVES | | |
|---|---|----------|
| TAG NO | DESCRIPTION | SKID NO. |
| TDSIV | DESUPERHEATER INLET STEAM PRESS CONT VALVE | SA 301 |
| TDWTCV | DESUPERHEATER COOLANT WATER CONTROL VALVE | SA 301 |
| TTWPCV-1 | STEAM TRAP TT-1 WATER PRESSURE CONTROL VALVE | SA 302 |
| TTWPCV-2 | STEAM TRAP TT-2 WATER PRESSURE CONTROL VALVE | SA 303 |
| THFIV-1 | THERMAL STORAGE HEATER TH-1 FLUID CONTROL VALVE | SA 304 |
| THFIV-2 | THERMAL STORAGE HEATER TH-2 FLUID CONTROL VALVE | SA 304 |
| TBFCV-1 | BOILER TB-1 FLUID CONTROL VALVE | SA 307 |
| TBFCV-2 | BOILER TB-2 FLUID CONTROL VALVE | SA 308 |
| TFAPCV | AUXILIARY FLUID FLOW CONTROL VALVE | SA 309 |
| TSFTCV-1 | SUPERHEATER TS-1 STEAM TEMP (FLUID) CONT VALVE | SA 307 |
| TSFTCV-2 | SUPERHEATER TS-2 STEAM TEMP (FLUID) CONT VALVE | SA 308 |
| TPWCV-1 | SUPERHEATER TS-1 WATER CONTROL VALVE | SA 305 |
| TPWCV-2 | SUPERHEATER TS-2 WATER CONTROL VALVE | SA 306 |



GENERAL NOTES:
1. PRESSURE SENSING INSTRUMENTS HAVE LINE ISOLATION VALVES NOT SHOWN.

TEMPORARY (DEPT 585-141 VALVES & CONTROLS)
DEPARTMENT OF ENERGY
SAN FRANCISCO OPERATIONS OFFICE
SOLAR THERMOCHEMICAL PROJECT OFFICE
1550 FLAKE DRIVE, SUITE 200
EMERYVILLE, CALIFORNIA 94608
SOLAR FACILITIES DESIGN INTEGRATOR

| REVISIONS | REFERENCE DRAWINGS | PRINT RECORD |
|------------------------|--------------------|--------------|
| INCORPORATED PROGRAM | | |
| OFFICE REVIEW COMMENTS | | |


SOLAR THERMOCHEMICAL PROJECT OFFICE
1550 FLAKE DRIVE, SUITE 200
EMERYVILLE, CALIFORNIA 94608

SOLAR FACILITIES DESIGN INTEGRATOR

THERMAL STORAGE SUBSYSTEM (TSS)
INSTRUMENT AIR P & ID

DATE: 17 SEPT 79

PROJECT NO: C060779



- NOTES:
1. ALL EQUIPMENT AND PIPING SHOWN IN PARANTON SHALL BE PROVIDED BY ROCKETDYNE. FOR DETAILS OF PIPING AND INSTRUMENTATION, SEE ROCKETDYNE PIPING AND INSTRUMENT DIAGRAM C061178.
 2. ALL INSTRUMENTATION BY ROCKETDYNE.


9-13-79 REVISIONS: ADDED SKID NUMBERS, VT-9, RE-POWERING CROSS-OVER, & MS SPEC. DELETED CO-2 & AS-4. CHANGED VT-3 ROUTING

DEPARTMENT OF ENERGY SOLAR TEN MEGAWATT PROJECT OFFICE
 SAN FRANCISCO OPERATIONS OFFICE 8550 FLAIR DRIVE, SUITE 210
 EL MONTE, CALIFORNIA 91731

10 MW SOLAR PILOT PLANT - DAGGETT, CALIFORNIA

| NO. | REVISIONS | DATE | BY | CHKD | APP'D | REF. DRAWINGS | PRINT RECORD | DESIGN | ISS | 5/14/78 | FOR APPROVAL | SOLAR FACILITIES DESIGN INTEGRATOR |
|-----|-----------|------|----|------|-------|---------------|--------------|--------|-----|---------|--------------|------------------------------------|
| 1 | ISSUED | | | | | | | | | | | |
| 2 | REVISED | | | | | | | | | | | |
| 3 | REVISED | | | | | | | | | | | |
| 4 | REVISED | | | | | | | | | | | |
| 5 | REVISED | | | | | | | | | | | |
| 6 | REVISED | | | | | | | | | | | |
| 7 | REVISED | | | | | | | | | | | |
| 8 | REVISED | | | | | | | | | | | |
| 9 | REVISED | | | | | | | | | | | |
| 10 | REVISED | | | | | | | | | | | |
| 11 | REVISED | | | | | | | | | | | |
| 12 | REVISED | | | | | | | | | | | |
| 13 | REVISED | | | | | | | | | | | |
| 14 | REVISED | | | | | | | | | | | |
| 15 | REVISED | | | | | | | | | | | |
| 16 | REVISED | | | | | | | | | | | |
| 17 | REVISED | | | | | | | | | | | |
| 18 | REVISED | | | | | | | | | | | |
| 19 | REVISED | | | | | | | | | | | |
| 20 | REVISED | | | | | | | | | | | |

| | |
|-------------|--|
| PROJECT NO. | 40P7005133143 |
| TITLE | PIPING & INSTRUMENT DIAGRAM THERMAL STORAGE SUBSYSTEM (TSS) STEAM & CONDENSATE |
| DATE | 9/17/78 |
| SCALE | NONE |
| DRAWING NO. | P & ID (P3-4) |
| PROJECT NO. | 40P7005133143 |



9-14-79 REVISIONS: ADDED SKID NUMBERS; REVISED AREA ZN-G11


NOTES:
 1. ALL EQUIPMENT AND PIPING SHOWN IN PARAGRAPH SHALL BE PROVIDED BY ROCKWELL. FOR DETAILS OF PIPING AND INSTRUMENTATION SEE ROCKWELL PAID COB1179.
 2. ALL INSTRUMENTATION BY ROCKWELL.
HOLD

105 NO. 8F9161

| NO. | REVISIONS | DATE | BY | CHKD. | APP. NO. | REFERENCE DRAWINGS | PRINT RECORD | DESIGN | DATE | NO. | ISS | DATE | FOR APPROVAL | DATE | NO. | ISS | DATE | FOR APPROVAL | DATE | NO. | ISS | DATE | |
|-----|-----------|------|----|-------|----------|--------------------|--------------|--------|------|-----|-----|------|--------------|------|-----|-----|------|--------------|------|-----|-----|------|--|
| 1 | | | | | | | | | | | | | | | | | | | | | | | |

DEPARTMENT OF ENERGY SOLAR ENERGY RESEARCH PROJECT OFFICE
 SAN FRANCISCO OPERATIONS OFFICE 9550 FLORA DRIVE, SUITE 210
 EL MONTE, CALIFORNIA 91731

| | |
|---|-----------------------------|
| 10 MW SOLAR PILOT PLANT - DAGGETT, CALIFORNIA | |
| TITLE | PIPING & INSTRUMENT DIAGRAM |
| THERMAL STORAGE SUBSYSTEM (TSS) | THERMAL OIL |
| DATE | 9/11/79 |
| DRWING NO. | 40P7005133142 |
| SHEET NO. | 1 OF 1 |



AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--------------------------------------|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--------------------------------------|
| Control Valves, TSSWV-1 & -2 | 1,486 | 160,000 | 0.009 | 4.0 | 0.036 | 0 | B | 0.036 | Each Loop Provides 50% of Total Flow |
| Check Valves, TSSWCK-1 & -2 | 1,486 | 250,000 | 0.006 | 3.0 | 0.018 | 0 | B | 0.018 | Each Loop Provides 50% of Total Flow |
| Check Valves, TSSCK-1 & -2 | 1,486 | 250,000 | 0.006 | 4.0 | 0.024 | 0 | B | 0.024 | Each Loop Provides 50% of Total Flow |
| Control Valves, TSSBV-1 & -2 | 1,486 | 160,000 | 0.009 | 4.0 | 0.036 | 0 | B | 0.036 | Each Loop Provides 50% of Total Flow |
| Check Valves, TSSBCK-1 & -2 | 1,486 | 250,000 | 0.006 | 3.0 | 0.018 | 0 | B | 0.018 | Each Loop Provides 50% of Total Flow |
| Shutoff Valves, TSSWIS-1 & -2 | 1,486 | 250,000 | 0.006 | 3.0 | 0.018 | 0 | B | 0.018 | Each Loop Provides 50% of Total Flow |
| Flow Orifices, TBWO-1 & 2 | 1,486 | 80,000 | 0.019 | 4.0 | 0.076 | 0 | B | 0.076 | Each Loop Provides 50% of Total Flow |
| Relief Valves, TSSRV-1 & 2 | 1,486 | 100,000 | 0.015 | 4.0 | 0.060 | 0 | B | 0.060 | Each Loop Provides 50% of Total Flow |
| Flow-Rate Transmitters, TSSFR-1 & -2 | 1,486 | 32,500 | 0.046 | 5.0 | 0.230 | 0 | B | 0.230 | Each Loop Provides 50% of Total Flow |
| Control Valves, TPWCV-1 & -2 | 1,486 | 160,000 | 0.009 | 4.5 | 0.041 | 0 | B | 0.041 | Each Loop Provides 50% of Total Flow |
| Relief Valves, TPFRV-1 & -2 | 1,486 | 100,000 | 0.015 | 4.5 | 0.068 | 0 | B | 0.068 | Each Loop Provides 50% of Total Flow |
| Bypass Valves, TBWBLV-1 & -2 | 1,486 | 160,000 | 0.009 | 4.0 | 0.036 | 0 | B | 0.036 | Each Loop Provides 50% of Total Flow |
| Stop-Check Valves, TPWSK-1 & -2 | 1,486 | 250,000 | 0.006 | 3.0 | 0.018 | 0 | B | 0.018 | Each Loop Provides 50% of Total Flow |
| Flow-Rate Transmitters, TPWFR-1 & -2 | 1,486 | 32,500 | 0.045 | 4.0 | 0.180 | 0 | B | 0.180 | Each Loop Provides 50% of Total Flow |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--------------------------------------|
| Thermal-Storage Boilers, TB-1 & -2 | 1,486 | 91,000 | 0.016 | 82 | 1.312 | 23 | B | 24.312 | Each Loop Provides 50% of Total Flow |
| Thermal-Storage Preheaters, TP-1 & -2 | 1,486 | 91,000 | 0.016 | 82 | 1.312 | 23 | B | 24.312 | Each Loop Provides 50% of Total Flow |
| Shutoff Valves, TPFOV-1 & 2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | Each Loop Provides 50% of Total Flow |
| Flow-Rate Transmitters, TSFFR-1 & -2 | 1,486 | 32,500 | 0.045 | 5.0 | 0.225 | 0 | B | 0.225 | Each Loop Provides 50% of Total Flow |
| Thermal-Storage Superheaters, TS-1 & -2 | 1,486 | 91,000 | 0.016 | 82 | 1.312 | 23 | B | 24.312 | Each Loop Provides 50% of Total Flow |
| Flow-Rate Transmitters, TBFFR-1 & -2 | 1,486 | 32,500 | 0.045 | 6.0 | 0.270 | 0 | B | 0.270 | Each Loop Provides 50% of Total Flow |
| Control Valves, TSFTCV-1 & -2 | 1,486 | 160,000 | 0.009 | 6.5 | 0.059 | 0 | B | 0.059 | Each Loop Provides 50% of Total Flow |
| Check Valves, TSFCK-1 & -2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | Each Loop Provides 50% of Total Flow |
| Shutoff Valves, TSFIS-1 & -2 | 1,486 | 250,000 | 0.006 | 4.0 | 0.024 | 0 | B | 0.024 | Each Loop Provides 50% of Total Flow |
| Control Valves, TBFFCV-1 & -2 | 1,486 | 160,000 | 0.009 | 6.5 | 0.059 | 0 | B | 0.059 | Each Loop Provides 50% of Total Flow |
| Check Valves, TBFCV-1 & -2 | 1,486 | 250,000 | 0.005 | 4.5 | 0.023 | 0 | B | 0.023 | Each Loop Provides 50% of Total Flow |
| Extraction Pumps, TFEP-1 & -2 | 1,486 | 16,000 | 0.093 | 4.5 | 0.419 | 0 | B | 0.419 | Each Loop Provides 50% of Total Flow |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---------------------------------|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--------------------------------------|
| Stop-Check Valves, TFESK-1 & -2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | Each Loop Provides 50% of Total Flow |
| Control Valves, TFEPBV-1 & 2 | 1,486 | 160,000 | 0.009 | 6.0 | 0.054 | 0 | B | 0.054 | Each Loop Provides 50% of Total Flow |
| Shutoff Valves, TFEIS-1 & 2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | Each Loop Provides 50% of Total Flow |
| Y-Type Strainers TFEST-1 & -2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | Each Loop Provides 50% of Total Flow |
| Control Valve, TFAIV-3 | 1,486 | 160,000 | 0.009 | 6.0 | 0.054 | 0 | B | 0.054 | |
| 3-Way Valve, TFAV | 1,486 | 160,000 | 0.009 | 6.0 | 0.054 | 0 | B | 0.054 | |
| Y-Type Strainer TFAST | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | |
| Auxiliary Pump, TFAP | 1,486 | 16,000 | 0.093 | 4.5 | 0.419 | 0 | B | 0.419 | |
| Control Valve, TFAPCV | 1,486 | 160,000 | 0.009 | 6.5 | 0.054 | 0 | B | 0.054 | |
| Flow-Rate Transmitter, TFAFR | 1,486 | 32,500 | 0.046 | 6.0 | 0.275 | 0 | B | 0.275 | |
| Shutoff Valve, TFAIS-2 | 1,486 | 250,000 | 0.006 | 4.5 | 0.027 | 0 | B | 0.027 | |
| Extraction-Loop Controller | 1,486 | 27,400 | 0.054 | 2.0 | 0.108 | 0 | A | 0.108 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Control Valve, TUFBV-1 | 3,029 | 160,000 | 0.019 | 6.0 | 0.114 | 0 | B | 0.114 | |
| Upper and Lower Tank Manifolds | 4,212 | 1,000,000 | 0.004 | 1350.0 | 5.400 | 0 | A | 5.400 | * |
| Seal-Steam Manifold | 4,212 | 1,000,000 | 0.004 | 1350.0 | 5.400 | 0 | B | 5.400 | * |
| Shutoff Valve, TFAIS-1 | 4,212 | 250,000 | 0.017 | 1350.0 | 22.950 | 0 | B | 22.950 | * |
| Shutoff Valve, TUFDV | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.048 | |
| Charging-Loop Controller | 3,029 | 27,400 | 0.111 | 2.0 | 0.222 | 0 | B | 0.222 | |
| Thermal-Storage-Unit Fluid Control Valve, TUFCV | 3,029 | 160,000 | 0.019 | 6.0 | 0.114 | 0 | A | 0.114 | |
| Shutoff Valve, TUFIS | 4,212 | 250,000 | 0.017 | 1350.0 | 22.950 | 0 | A | 22.950 | * |
| Flow-Rate Transmitters, THFFR-1 & -2 | 3,029 | 32,500 | 0.093 | 6.0 | 0.558 | 0 | B | 1.116 | |
| Relief Valves, THFRV-1 & -2 | 3,029 | 100,000 | 0.030 | 4.5 | 0.136 | 0 | B | 0.272 | |
| Shutoff Valves, THFIS-1-1 & -2-1 | 3,029 | 250,000 | 0.012 | 4.5 | 0.540 | 0 | B | 1.080 | |
| Shutoff Valve, TFCIS-3 | 3,029 | 250,000 | 0.012 | 4.5 | 0.540 | 0 | B | 0.540 | |
| Inlet Valves, THFIV-1 & -2 | 3,029 | 160,000 | 0.019 | 6.5 | 0.124 | 0 | B | 0.248 | |

*These components used during charging and extraction operations.

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--------------------------------------|
| Charging-Loop Thermal Transfer Media Pumps TFCP-1 & -2 | 3,029 | 16,000 | 0.189 | 4.5 | 0.851 | 0 | B | 0.851 | Each Loop Provides 50% of Total Flow |
| Stop-Check Valves, TFCCK-1 & -2 | 3,029 | 250,000 | 0.012 | 4.5 | 0.540 | 0 | B | 0.540 | Each Loop Provides 50% of Total Flow |
| Shutoff Valves, TFCIS-1 & 2 | 3,029 | 250,000 | 0.012 | 4.5 | 0.540 | 0 | B | 0.540 | Each Loop Provides 50% of Total Flow |
| Relief Valve, TFSRV | 3,029 | 100,000 | 0.030 | 4.0 | 0.120 | 0 | B | 0.120 | |
| Shutoff Valve, TUFES | 4,212 | 250,000 | 0.012 | 1350.0 | 22.950 | 0 | A | 22.950 | * |
| Output Valve, TUFEV | 4,212 | 160,000 | 0.019 | 6.0 | 0.114 | 0 | A | 0.114 | |
| Flow Orifices, THSO-1 & -2 | 3,029 | 80,000 | 0.038 | 4.0 | 0.152 | 0 | B | 0.304 | |
| Shutoff Valves, TFWIS-1 & -2 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.096 | |
| Thermal-Storage Flash Tank, TF | 3,029 | 1,000,000 | 0.003 | 14.0 | 0.030 | 47 | B | 47.030 | |
| Vent Valves, TTSV-1 & -2 | 3,029 | 160,000 | 0.019 | 4.0 | 0.076 | 0 | B | 0.152 | |
| Flow Orifices, TTSO-1 & -2 | 3,029 | 80,000 | 0.038 | 4.0 | 0.152 | 0 | B | 0.304 | |
| Check Valves, TTWCK-1 & -2 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.096 | |
| Flash-Tank Control Valves, TTWPCV-1 & -2 | 3,029 | 160,000 | 0.019 | 6.0 | 0.114 | 0 | B | 0.114 | Each Loop Provides 50% of Total Flow |
| *This component used during charging and extraction operations. | | | | | | | | | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|---|
| Bypass Valves, THSBLV-1 & -2 | 3,029 | 250,000 | 0.012 | 3.0 | 0.036 | 0 | B | 0.036 | Each Loop Provides 50% of Total Flow |
| Steam Traps, TT-1 & -2 | 3,029 | 1,000,000 | 0.003 | 14.0 | 0.030 | 47 | B | 47.030 | Each Loop Provides 50% of Total Flow |
| Relief Valves, THSRV-1 & -2 | 3,029 | 100,000 | 0.030 | 3.0 | 0.090 | 0 | B | 0.180 | |
| Thermal-Storage Heaters, TH-1-1 & -2 and 2-1 & -2 | 3,029 | 31,000 | 0.098 | 34.2 | 3.35 | 47 | B | 53.700 | Each Loop Provides 50% of Total Energy Requirements |
| Shutoff Valves, THWIS-1 & -2 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.048 | Each Loop Provides 50% of Total Energy Requirements |
| Thermal-Storage-Heater Input Valves, THSIV-1 & -2 | 3,029 | 160,000 | 0.019 | 5.0 | 0.095 | 0 | B | 0.095 | Each Loop Provides 50% of Total Energy Requirements |
| Pressure Regulators, THSWPR-1 & -2 | 3,029 | 160,000 | 0.019 | 4.0 | 0.076 | 0 | B | 0.076 | Each Loop Provides 50% of Total Energy Requirements |
| Pressure Transmitters, TSTWOP-1-1, -2 & -3 and -2-1, -2 & -3 | 3,029 | 32,500 | 0.093 | 2.5 | 0.233 | 0 | B | 0.932 | |
| Thermal-Storage Heater Shutoff Valves, TDSIS-2 & -3 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.048 | Each Loop Provides 50% of Total Energy Requirements |
| Y-Type Strainers, THSST-1 & -2 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.048 | Each Loop Provides 50% of Total Energy Requirements |
| Check Valve, TDWCK | 3,029 | 250,000 | 0.012 | 3.0 | 0.036 | 0 | B | 0.036 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.2 THERMAL STORAGE SUBSYSTEM - EXTRACTION LOOP

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Desuperheater-Team-Input Shutoff Valves, TDSIS-1 | 3,029 | 250,000 | 0.012 | 4.0 | 0.048 | 0 | B | 0.048 | |
| Pressure Transmitter, TDSIP-1, -2 & -3 | 3,029 | 32,500 | 0.093 | 2.5 | 0.233 | 0 | B | 0.699 | |
| Steam-Flow Control Valve, TDSIV | 3,029 | 160,000 | 0.019 | 6.0 | 0.114 | 0 | B | 0.114 | |
| Steam-Flow Input Valve, TDSBV | 3,029 | 250,000 | 0.012 | 3.0 | 0.036 | 0 | B | 0.036 | |
| Flow-Rate Transmitter, TDSFR | 3,029 | 32,500 | 0.099 | 5.0 | 0.466 | 0 | B | 0.466 | |
| Shutoff Flow-Control Valve, TDCDV | 3,029 | 160,000 | 0.019 | 3.0 | 0.057 | 0 | B | 0.057 | |
| Thermal-Storage Unit, TU | 4,212 | 1,000,000 | 0.004 | 1350.0 | 5.400 | 47 | A | 52.40 | * |
| Desuperheater, TD | 3,029 | 31,500 | 0.096 | 14.0 | 0.960 | 47 | B | 47.960 | |
| Desuperheater-Water-Input Shutoff Valve, TDWIS | 3,029 | 250,000 | 0.012 | 3.0 | 0.036 | 0 | B | 0.036 | |
| *This component used during charging and extraction operations. | | | | | | | | | |


AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.3 MASTER CONTROL SUBSYSTEM

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|------------------------|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Hiway Traffic Director | 7,884 | 10,000 | 0.788 | 1 | 0.788 | 0 | B | 0.788 | |



9-14-79 REVISIONS: RE-ROUTED TSS FEEDWATER LINES
 ADDED INTERFERE NUMBERS (41-43) &
 CHEMICAL FEED LINES, *ASTERISK TO VALVES

- NOTES:
1. ALL EQUIPMENT AND PIPING SHOWN IN PHANTOM SHALL BE PROVIDED BY SOUTH-CALIFORNIA Edison; FOR DETAILS OF PIPING AND INSTRUMENTATION SEE THE APPLICABLE S.C.E. PIPING AND INSTRUMENTATION DIAGRAM.
 2. ALL INSTRUMENTATION ON S-R LINES SHALL BE PROVIDED BY S.C.E.
 3. * IN-LINE ITEMS SPECIFIED BY S-R.

DEPARTMENT OF ENERGY SOLAR TEN MEGAWATT PROJECT OFFICE
 SAN FRANCISCO OPERATIONS OFFICE 8950 FLAIR DRIVE, SUITE 210
 CLIMATE, CALIFORNIA 91731
 10 MW SOLAR PILOT PLANT - DAGGERT, CALIFORNIA

| NO. | REV. | DATE | BY | CHKD. | APP'D. | DESCRIPTION |
|-----|------|------|----|-------|--------|-------------|
| | | | | | | |
| | | | | | | |
| | | | | | | |


| NO. | REV. | DATE | BY | CHKD. | APP'D. | DESCRIPTION |
|-----|------|------|----|-------|--------|-------------|
| | | | | | | |
| | | | | | | |
| | | | | | | |

TITLE
 PIPING & INSTRUMENT DIAGRAM
 ELECTRIC POWER GENERATION SUBSYSTEM (EPGS)
 CONDENSATE & FEED WATER

P & ID (P3-2) 40P7005133;41

DATE 9-10-79

1 of 1



- NOTES:
1. ALL EQUIPMENT AND PIPING SHOWN BY CONTAINER SHALL BE PROVIDED BY THE CONTRACTOR. FOR DETAILS OF PIPING AND INSTRUMENTATION, REFER TO THE PIPING AND INSTRUMENTATION SPECIFICATIONS. SHALL BE PROVIDED BY S.C.E. LINES WITHIN EPCS AREA.
 2. * IN-LINE ITEM SPECIFIED BY S-R
 3. * IN-LINE ITEM SPECIFIED BY S-R

9-14-79 REVISIONS: REVISED AUX. STEAM SYS. ADDED MAIN TURBINE STEAM SYSTEM TO VALVES.

DEPARTMENT OF OPERATIONS OFFICE
SOLAR THERMOPILOT PLANT - SAGEHIT, CALIFORNIA

| | |
|-------------|--------------|
| PROJECT NO. | 40P006133140 |
| DATE | MAY 10-11-79 |
| BY | None |
| CHECKED | |
| APPROVED | |
| SCALE | |
| PROJECT | |
| DESIGNER | |
| DRAWN | |
| DATE | |
| BY | |
| CHECKED | |
| APPROVED | |
| SCALE | |
| PROJECT | |

REVISIONS

| NO. | DATE | DESCRIPTION |
|-----|---------|-------------|
| 1 | 5/15/79 | FOR REVIEW |
| 2 | 5/15/79 | FOR REVIEW |
| 3 | 5/15/79 | FOR REVIEW |
| 4 | 5/15/79 | FOR REVIEW |
| 5 | 5/15/79 | FOR REVIEW |
| 6 | 5/15/79 | FOR REVIEW |
| 7 | 5/15/79 | FOR REVIEW |
| 8 | 5/15/79 | FOR REVIEW |
| 9 | 5/15/79 | FOR REVIEW |
| 10 | 5/15/79 | FOR REVIEW |
| 11 | 5/15/79 | FOR REVIEW |
| 12 | 5/15/79 | FOR REVIEW |
| 13 | 5/15/79 | FOR REVIEW |
| 14 | 5/15/79 | FOR REVIEW |
| 15 | 5/15/79 | FOR REVIEW |
| 16 | 5/15/79 | FOR REVIEW |
| 17 | 5/15/79 | FOR REVIEW |
| 18 | 5/15/79 | FOR REVIEW |
| 19 | 5/15/79 | FOR REVIEW |

POINT BEFORE

| NO. | DATE | DESCRIPTION |
|-----|---------|-------------|
| 1 | 5/15/79 | FOR REVIEW |
| 2 | 5/15/79 | FOR REVIEW |
| 3 | 5/15/79 | FOR REVIEW |
| 4 | 5/15/79 | FOR REVIEW |
| 5 | 5/15/79 | FOR REVIEW |
| 6 | 5/15/79 | FOR REVIEW |
| 7 | 5/15/79 | FOR REVIEW |
| 8 | 5/15/79 | FOR REVIEW |
| 9 | 5/15/79 | FOR REVIEW |
| 10 | 5/15/79 | FOR REVIEW |
| 11 | 5/15/79 | FOR REVIEW |
| 12 | 5/15/79 | FOR REVIEW |
| 13 | 5/15/79 | FOR REVIEW |
| 14 | 5/15/79 | FOR REVIEW |
| 15 | 5/15/79 | FOR REVIEW |
| 16 | 5/15/79 | FOR REVIEW |
| 17 | 5/15/79 | FOR REVIEW |
| 18 | 5/15/79 | FOR REVIEW |
| 19 | 5/15/79 | FOR REVIEW |

REFERENCE OPERATIONS

| NO. | DATE | DESCRIPTION |
|-----|---------|-------------|
| 1 | 5/15/79 | FOR REVIEW |
| 2 | 5/15/79 | FOR REVIEW |
| 3 | 5/15/79 | FOR REVIEW |
| 4 | 5/15/79 | FOR REVIEW |
| 5 | 5/15/79 | FOR REVIEW |
| 6 | 5/15/79 | FOR REVIEW |
| 7 | 5/15/79 | FOR REVIEW |
| 8 | 5/15/79 | FOR REVIEW |
| 9 | 5/15/79 | FOR REVIEW |
| 10 | 5/15/79 | FOR REVIEW |
| 11 | 5/15/79 | FOR REVIEW |
| 12 | 5/15/79 | FOR REVIEW |
| 13 | 5/15/79 | FOR REVIEW |
| 14 | 5/15/79 | FOR REVIEW |
| 15 | 5/15/79 | FOR REVIEW |
| 16 | 5/15/79 | FOR REVIEW |
| 17 | 5/15/79 | FOR REVIEW |
| 18 | 5/15/79 | FOR REVIEW |
| 19 | 5/15/79 | FOR REVIEW |

PRINT BEFORE

| NO. | DATE | DESCRIPTION |
|-----|---------|-------------|
| 1 | 5/15/79 | FOR REVIEW |
| 2 | 5/15/79 | FOR REVIEW |
| 3 | 5/15/79 | FOR REVIEW |
| 4 | 5/15/79 | FOR REVIEW |
| 5 | 5/15/79 | FOR REVIEW |
| 6 | 5/15/79 | FOR REVIEW |
| 7 | 5/15/79 | FOR REVIEW |
| 8 | 5/15/79 | FOR REVIEW |
| 9 | 5/15/79 | FOR REVIEW |
| 10 | 5/15/79 | FOR REVIEW |
| 11 | 5/15/79 | FOR REVIEW |
| 12 | 5/15/79 | FOR REVIEW |
| 13 | 5/15/79 | FOR REVIEW |
| 14 | 5/15/79 | FOR REVIEW |
| 15 | 5/15/79 | FOR REVIEW |
| 16 | 5/15/79 | FOR REVIEW |
| 17 | 5/15/79 | FOR REVIEW |
| 18 | 5/15/79 | FOR REVIEW |
| 19 | 5/15/79 | FOR REVIEW |

105 NO. 878158

AVAILABILITY ANALYSIS

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
ITEM - CONDENSATE AND FEEDWATER LOOP

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|-------------------------------|
| Turbine Generator, TG-901 | 4,212 | 5,500 | 0.766 | 40.0 | 30.640 | 104 | TBD | 134.640 | |
| Condenser, E-901 | 4,212 | 91,000 | 0.046 | 10.0 | 0.460 | 104 | | 104.460 | |
| Condenser Vacuum Pump, P-910 | 4,212 | 16,000 | 0.263 | 6.0 | 1.578 | 0 | | 1.578 | |
| Shutoff Valve (Condenser Vacuum) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Shutoff Valves (Condenser Vacuum Pump), 2 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.102 | |
| Control Valve (Condenser Vacuum Pump) | 4,212 | 160,000 | 0.026 | 3.5 | 0.091 | 0 | | 0.091 | |
| Check Valve (Condenser Vacuum Pump) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Vacuum-Breaker Control Valve | 4,212 | 160,000 | 0.026 | 3.5 | 0.091 | 0 | | 0.091 | |
| Shutoff Valves, 4 Each (Condensate Hotwell Pumps) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.272 | |
| Cleanout Strainers, 2 Each | 4,212 | 330,000 | 0.013 | 3.0 | 0.039 | 0 | | 0.039 | Redundant Condensate Paths |
| Condensate Hotwell Pumps, P907, P908 | 4,212 | 16,000 | 0.263 | 10.0 | 2.630 | 0 | | 2.630 | Redundant Condensate Paths |
| Check Valves, 2 Each | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | Redundant Condensate Paths |
| Demineralizers, D 901 and D902 | 4,212 | 100,000 | 0.042 | 10.0 | 0.420 | 52 | | 52.420 | Redundant |
| Shutoff Valves, (Demineralizers) 4 Each | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | TBD | 0.136 | Redundant |

MOBONNELL DOUGLAS

39

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
- CONDENSATE AND FEEDWATER LOOP

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Check Valve | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | TBD | 0.068 | |
| Low-Pressure Heater, E-904 | 4,212 | 91,000 | 0.046 | 10.0 | 0.460 | 104 | | 104.460 | |
| Shutoff Valves, 2 Each (LP Heater) | 4,212 | 250,000 | 0.017 | 6.0 | 0.102 | 0 | | 0.204 | |
| Bypass Valve (LP Heater) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Level Control Valve, (LP Heater) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| Shutoff Valves, 2 Each (LCV LP Heater) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.136 | |
| Drain Valve (Deaerator) | 4,212 | 250,000 | 0.017 | 6.0 | 0.102 | 0 | | 0.102 | |
| Condensate-Level Control Valve (Deaerator) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| Shutoff Valve (Deaerator Condensate) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Deaerator, DA 901 | 4,212 | 100,000 | 0.042 | 10.0 | 0.420 | 52 | | 52.420 | |
| Flow Control Valve (Receiver Feed Pump) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| Restrictor | 4,212 | 80,000 | 0.053 | 4.0 | 0.530 | 0 | | 0.530 | |
| Cleanout Strainer | 4,212 | 330,000 | 0.013 | 3.0 | 0.039 | 0 | | 0.039 | |
| Receiver Feed Pump, P917 | 4,212 | 16,000 | 0.263 | 10.0 | 2.630 | 0 | | 2.630 | |
| Check Valve | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Control Valve | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | TBD | 0.130 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
ITEM - CONDENSATE AND FEEDWATER LOOP

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--------------------------------------|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--------------------------|
| Bypass Valve | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | TBD | 0.068 | |
| High-Pressure Heaters, E902 and E903 | 4,212 | 91,000 | 0.046 | 10.0 | 0.460 | 104 | | 104.920 | |
| Drain Valves, 6 Each (HP Heaters) | 4,212 | 250,000 | 0.017 | 6.0 | 0.102 | 0 | | 0.612 | |
| Bypass Valves, 2 Each (HP Heaters) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.136 | |
| Shutoff Valves, 2 Each (HP Heater) | 4,212 | 250,000 | 0.017 | 6.0 | 0.102 | 0 | | 0.204 | |
| Check Valves, 2 Each | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.136 | |
| Level Control Valve 14 Each | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 1.820 | |
| LCV Bypass Valve 14 Each | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.952 | |
| Shutoff Valves (LCV), 28 Each | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 1.904 | |
| Feedwater Clean-up Control Valve | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| FW Shutoff Valve (Condenser) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| FW Control Valve (Condenser) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| FW Check Valve (Condenser) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Condensate Filters, 2 Each | 4,212 | 330,000 | 0.013 | 4.0 | 0.052 | 0 | | 0.104 | |
| TSS Feed Pumps, P903 and P904 | 1,486 | 16,000 | 0.093 | 10.0 | 0.930 | 0 | TBD | 0.930 | Redundant TSS Feed Paths |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
ITEM - CONDENSATE AND FEEDWATER LOOP

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|--|
| Shutoff Valves, 2 Each (TSS Feed Pumps) | 1,486 | 250,000 | 0.006 | 6.0 | 0.036 | 0 | TBD | 0.036 | Redundant TSS Feed Paths |
| Cleanout Strainers, 2 Each | 1,486 | 330,000 | 0.005 | 3.0 | 0.015 | 0 | | 0.015 | Redundant TSS Feed Paths |
| Check Valves, 2 Each | 1,486 | 250,000 | 0.006 | 4.0 | 0.024 | 0 | | 0.024 | Redundant TSS Feed Paths |
| Control Valves, 2 Each (TSS Feed Pump) | 1,486 | 160,000 | 0.009 | 5.0 | 0.045 | 0 | | 0.045 | Redundant TSS Feed Paths |
| Bypass Valves, 2 Each | 1,486 | 250,000 | 0.006 | 4.0 | 0.024 | 0 | | 0.024 | Redundant TSS Feed Paths |
| Flow Control Valves, 2 Each (FW From TSS Feed Pumps) | 1,486 | 160,000 | 0.009 | 5.0 | 0.045 | 0 | | 0.090 | |
| Restrictors, 2 Each | 1,486 | 80,000 | 0.019 | 4.0 | 0.076 | 0 | | 0.152 | |
| Auxiliary Boiler, B901 | 1,486 | 91,000 | 0.016 | 10.0 | 0.160 | 0 | | 0.160 | |
| Drain Valve (Auxiliary Boiler) | 1,486 | 250,000 | 0.006 | 6.0 | 0.036 | 0 | | 0.036 | |
| Chemical-Feed Shutoff Valves, 3 Each | 4,212 | 250,000 | 0.017 | 6.0 | 0.102 | 0 | | 0.306 | |
| Circulating Water Shutoff Valve | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Surge-Tank Cooling Water Shutoff Valve | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | TBD | 0.051 | |
| Condensate Tank, TK 902, Drain Valve and Shutoff Valve | | | | | | | | | Included in Plant Support Subsystem Analysis |

AVAILABILITY ANALYSIS

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
 ITEM - STEAM LOOP

PREPARED BY HAROLD BURG
 DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Control Valve (Receiver Steam) | 4,212 | 160,000 | 0.026 | 6.0 | 0.156 | 0 | TBD | 0.156 | |
| Control Valves, 2 Each (Turbine/HP Heaters) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.260 | |
| Shutoff Valves, 2 Each (HP Heaters) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.136 | |
| Control Valve (Turbine/Deaerator Steam) | 4,212 | 160,000 | 0.026 | 5.0 | 0.156 | 0 | | 0.156 | |
| Shutoff Valve (Deaerator) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Control Valve (Turbine LP Steam) | 4,212 | 160,000 | 0.026 | 5.0 | 0.130 | 0 | | 0.130 | |
| Shutoff Valve (LP Heater) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Check Valves, 4 Each (Turbine Exhaust Steam) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.272 | |
| Control Valves, 8 Each (Turbine Steam Condensate) | 4,212 | 160,000 | 0.026 | 5.0 | 0.156 | 0 | | 1.248 | |
| Control Valve (Vent Line From Receiver Flash Tank) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| Shutoff Valves, 2 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.102 | |
| Shutoff Valves, 2 Each (LP Heater/Condenser Vent Line) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.102 | |
| Restrictor | 4,212 | 80,000 | 0.053 | 3.0 | 0.159 | 0 | TBD | 0.159 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
ITEM - STEAM LOOP

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|-------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Control Valve (LP Heater) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | TBD | 0.068 | |
| Lo Control Valve, (Main Steam/ Condenser) | 4,212 | 250,000 | 0.017 | 4.0 | 0.068 | 0 | | 0.068 | |
| Control Valves, 3 Each (Vent Lines) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.312 | |
| Shutoff Valves, 6 Each (Vent Control Valves) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.306 | |
| Bypass Valves, 3 Each (Vent Control Valves) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.153 | |
| Check Valves, 4 Each (Deaerator Vent Lines) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.204 | |
| Shutoff Valves, 4 Each (HP Heaters Vent Lines) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.204 | |
| Restrictors, 4 Each (HP Heaters) | 4,212 | 80,000 | 0.053 | 3.0 | 0.159 | 0 | | 0.636 | |
| Check Valve (HP Heater) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Pressure Regulator Valve (Auxiliary Steam) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| Bypass Valve (Aux Steam) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Control Valve (Aux Steam) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| Shutoff Valves, 2 Each (Aux Steam Control Valve) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | TBD | 0.102 | |

MCDONNELL DOUGLAS

44

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

DATE DECEMBER 1979

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
ITEM - STEAM LOOP

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|-------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Check Valves, 2 Each (Aux Steam) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | TBD | 0.102 | |
| Safety Valve (Aux Steam) | 4,212 | 100,000 | 0.042 | 3.0 | 0.126 | 0 | | 0.126 | |
| Shutoff Valve (Turbine Steam Seal Regulator) | 4,412 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Safety Valves, 3 Each (Aux Boiler) | 4,212 | 100,000 | 0.042 | 3.0 | 0.126 | 0 | | 0.378 | |
| Check Valve (Auxiliary Boiler) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Shutoff Valve (Auxiliary Boiler) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Control Valves 2 Each (Auxiliary Steam to HP Heaters) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.208 | |
| Shutoff Valves, 2 Each (Auxiliary Steam to HP Heaters) | 4,212 | 250,000 | 0.017 | 3.0 | 0.054 | 0 | | 0.108 | |
| Pressure Regulator Valve (Auxiliary Steam to Deaerator Bypass) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| Bypass Valve (Auxiliary Steam to Deaerator) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.051 | |
| Control Valve (Auxiliary Steam to Deaerator) | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| Shutoff Valves, 2 Each (Auxiliary Steam Control Valve) | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | TBD | 0.102 | |

AVAILABILITY ANALYSIS


PREPARED BY HAROLD BURG

DATE DECEMBER 1979

5.4 ELECTRICAL POWER GENERATION SUBSYSTEM
- STEAM LOOP

| ITEM | COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|------|---|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| | Control Valve (Nitrogen Line) | 4,212 | 160,000 | 0.026 | 3.0 | 0.078 | 0 | TBD ↓ | 0.078 | |
| | Pressure Regulator Valve (Nitrogen) | 4,212 | 160,000 | 0.026 | 3.0 | 0.078 | 0 | | 0.078 | |
| | Check Valve (Nitrogen) | 4,212 | 250,000 | 0.017 | 2.5 | 0.043 | 0 | | 0.043 | |
| | Check Valve (TSS Steam Gen. Super Heater) | 1,486 | 250,000 | 0.006 | 4.0 | 0.024 | 0 | | 0.024 | |
| | Control Valve (TSS Steam) | 1,486 | 250,000 | 0.006 | 5.0 | 0.030 | 0 | | 0.030 | |
| | Desuperheater, DS 901 and DS 902 | 4,212 | 31,500 | 0.134 | 10.0 | 1.340 | 52 | | 54.680 | |
| | Control Valves, 14 Each | 4,212 | 160,000 | 0.026 | 4.0 | 0.104 | 0 | | 0.104 | |
| | Bypass Valves, 7 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.357 | |
| | Check Valves, 7 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.357 | |
| | Drain Valves, 10 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.510 | |
| | Shutoff Valves, 12 Each | 4,212 | 250,000 | 0.017 | 3.0 | 0.051 | 0 | | 0.612 | |
| | Control Logic | 4,212 | 27,400 | 0.154 | 4.0 | 0.616 | 0 | | 0.616 | |
| | Pressure Safety Valves, 3 Each | 4,212 | 100,000 | 0.042 | 3.0 | 0.126 | 0 | | 0.378 | |

RAW SERVICE WATER PUMPS P3-11, 2N-09



HOLD
TO BE REVISED PER ADDITION OF MOBILE DEMINERALIZER

- NOTES:**
1. PIPING AND EQUIPMENT SHOWN IN THIS AREA IS PROVIDED BY THE WATER TREATMENT EQUIPMENT SUPPLIER. FOR DETAILS OF PIPING AND INSTRUMENTATION SEE THE APPLICABLE WATER TREATING PIPING AND INSTRUMENT DIAGRAM.
 2. ALL PIPING SHOWN IN PHANTOM IS PROVIDED BY MTV.

9-12-79 REVISIONS: IN ADDITION TO "CLOUDS" AREA, ADDED LINE NUMBERS SW-15 & INTERPAGE NUMBER DR-1 WAS DW-8. DELETED (1) ION EXCHANGE SOFTENER.

| | |
|--|--|
| DEPARTMENT OF ENERGY SAN FRANCISCO OPERATIONS OFFICE | SOLAR TEN MEGAWATT PROJECT OFFICE 8550 PLATA DRIVE, SUITE 210 EL MONTE, CALIFORNIA 91731 |
| 10 MW SOLAR PILOT PLANT - DAGGETT, CALIFORNIA | |
| TITLE PIPING & INSTRUMENT DIAGRAM PLANT SUPPORT SUBSYSTEM (PSS) WATER TREATMENT | |
| P&ID (P3-6) | 40P7005133145 |

105 NO. 8F9179

| NO. | REVISIONS | DATE | BY | CHK'D | APP'D | REF. NO. | PREFERENCE DRAWINGS | PRINT RECORD | DATE | 105 | 6/1/78 | FOR APPROVAL | SOLAR FACILITIES DESIGN INTEGRATOR |
|-----|-----------|------|----|-------|-------|----------|---------------------|--------------|------|-----|--------|--------------|------------------------------------|
| | | | | | | | | | | | | | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.5 PLANT SUPPORT SUBSYSTEM

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Raw-Water Storage Tank, TK-701 | 7,884 | 1,000,000 | 0.008 | 5.0 | 0.040 | 0 | B | 0.040 | |
| Demineralized-Water Tank, TK-702 | 7,884 | 1,000,000 | 0.008 | 5.0 | 0.040 | 0 | B | 0.040 | |
| Shutoff Valve (Compressor Output to Air-Tank Input) | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.096 | |
| Service and Instrument Air Receiver, V-701 | 7,884 | 1,000,000 | 0.008 | 8.0 | 0.064 | 0 | A | 0.064 | |
| Relief Valve, 522 | 7,884 | 100,000 | 0.079 | 3.0 | 0.237 | 0 | A | 0.237 | |
| Shutoff Valves, 2 Each (Air Receiver Drain Trap) | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | B | 0.192 | |
| Trap, T-3 | 7,884 | 1,000,000 | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Bypass Valve, (Moisture Drain) | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.096 | |
| Shutoff Valve (Air-Tank Output) | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.096 | |
| Shutoff Valves, 4 Each, (System Prefilters) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | B | 0.320 | |
| Shutoff Valves, 4 Each, (System Refrigerated Air Dryers) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | B | 0.320 | |
| Shutoff Valve, (Plant Subsystems and Instrument Air) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | A | 0.080 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.5 PLANT SUPPORT SUBSYSTEM

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Shutoff Valve, (Instrument Air System) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | A | 0.080 | |
| Shutoff Valves, 4 Each (Instrument Air Hydrant Line) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | A | 0.320 | |
| Butterfly Valve, (Surge Tank Input) | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.096 | |
| Cooling-Water Surge Tank, TK-901 | 7,884 | 1,000,000 | 0.008 | 8.0 | 0.064 | 0 | A | 0.064 | |
| Drain Valve, Cooling Water Surge Tank | 7,884 | 250,000 | 0.032 | 8.0 | 0.256 | 0 | B | 0.256 | |
| Butterfly Valve, (Cooling Water Surge Tank Output) | 7,884 | 250,000 | 0.032 | 8.0 | 0.256 | 0 | A | 0.256 | |
| Pressure Sensor, 313 | 7,884 | 32,500 | 0.243 | 2.5 | 0.608 | 0 | A | 0.608 | |
| Butterfly Valve, (Cooling Water Heat Exchanger Input) | 7,884 | 250,000 | 0.032 | 4.0 | 0.128 | 0 | A | 0.128 | |
| Cooling-Water Heat Exchanger, E-905 | 7,884 | 31,000 | 0.254 | 8.0 | 2.032 | 101 | A | 103.032 | |
| Shutoff Valves, 2 Each (Cooling Water Heat Exchanger Drain/Vent) | 7,884 | 250,000 | 0.032 | 4.0 | 0.128 | 0 | B | 0.256 | |
| Butterfly Valve, (Cooling Water Heat Exchanger Output) | 7,884 | 250,000 | 0.032 | 4.0 | 0.128 | 0 | A | 0.128 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.5 PLANT SUPPORT SUBSYSTEM

DATE DECEMBER 1979

| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTRR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Chemical Feeder, CF-901 | 7,884 | 500,000 | 0.016 | 4.0 | 0.064 | 0 | B | 0.064 | |
| Shutoff Valves, 10 Each (Air Cool Lines) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | A | 0.800 | |
| Air Coolers, 10 Each | 7,884 | 31,000 | 0.254 | 4.5 | 1.143 | 0 | A | 11.430 | |
| Shutoff Valves, 10 Each (Air Cooler Lines) | 7,884 | 250,000 | 0.032 | 2.5 | 0.080 | 0 | A | 0.800 | |
| Auxiliary Transformer (13.8 KV to 4.16 KV) | 7,884 | 500,000 | 0.016 | 8.0 | 0.128 | 0 | A | 0.128 | |
| Solar One Generator Output Circuit Breakers | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 6.0 | 0.048 | 0 | A | 0.048 | |
| Auxiliary Transformer Output Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 6.0 | 0.048 | 0 | A | 0.048 | |
| Station Service Transformer Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Station Service Transformer | 7,884 | 500,000 | 0.016 | 4.0 | 0.064 | 0 | A | 0.064 | |
| Station Service Transformer Output Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Receiver-Feed Pump Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | B | 0.024 | |
| Cooling-Tower Transformer Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |

AVAILABILITY ANALYSIS

PREPARED BY HAROLD BURG

ITEM 5.5 PLANT SUPPORT SUBSYSTEM

DATE DECEMBER 1979


| COMPONENT | OPERATION (HR/YR) | MEAN TIME BETWEEN FAILURE MTBF (HR) | FAILURE/YR | MEAN TIME TO RESTORE MTTR (HR) | COMPONENT FORCED OUTAGE (HR/YR) | COMPONENT PLANNED OUTAGE (HR/YR) | CRITICALITY CATEGORY | SYSTEM UNAVAIL (HR/YR) | COMMENTS |
|--|-------------------|-------------------------------------|------------|--------------------------------|---------------------------------|----------------------------------|----------------------|------------------------|----------|
| Cooling-Tower Transformer | 7,884 | 500,000 | 0.016 | 4.0 | 0.064 | 0 | A | 0.064 | |
| Cooling-Tower Transformer Output Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-L Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-A Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Center-B Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Receiver PPA Input Circuit Breaker | 7,884 | 1,000,000/ 1,000 Cycles | 0.008 | 3.0 | 0.024 | 0 | A | 0.024 | |
| Motor-Control-Centers for Power Panels | 7,884 | 250,000 | 0.032 | 3.0 | 0.096 | 0 | A | 0.024 | |

305 + MPO - 174

5301 Bolsa Avenue, Huntington Beach, CA 92647 (714) 896-3311

A3-202-EP-RGR-496
9 May 1980

Mr. R. N. Schweinberg, Director
Solar Ten Megawatt Project Office
Department of Energy
9550 Flair Drive, Suite 210
El Monte, California 91731



Subject: CONTRACT NO. DE-AC03-79SF10499
SOLAR FACILITIES DESIGN INTEGRATION
SUBMITTAL OF PILOT PLANT AVAILABILITY REPORT

Dear Dick:

This letter transmits copies of the Pilot Plant Availability Report (SAN/0499-48, dated May 1980) prepared as an output from the WBS 2.1.3.1 task of the SFDI Phase I contract effort, but which is not one of the items on the Reports and Deliverables List. The groundrules, definitions, and methodology used for the availability analyses are contained in the document, as well as the assigned goals and availability predictions for the following:

- Pilot Plant
- Collector Subsystem
- Receiver Subsystem
- Thermal Storage Subsystem
- Master Control Subsystem
- Plant Support Subsystem

Please feel free to call Mr. R. G. Riedesel at (714) 896-3357 if you have questions about this report.

Very truly yours,

R. W. Hallet, Jr.
Program Manager
Solar Facilities Design Integration

RGR:bj

Enclosure

- | | |
|---------------------------------------|--------------------------------|
| Cy: R. N. Schweinberg, DOE/STMPO (10) | (w/o enclosure) |
| C. P. Winarski, SCE (3) | J. M. Slaminski, DOE/STMPO |
| W. R. Lang, Stearns-Roger (3) | H. D. Eden, Aerospace/STMPO |
| J. M. Friefeld, Rocketdyne (4) | R. O. Rogers, Aerospace/STMPO |
| L. L. Vant-Hull, EFT (1) | K. L. Adler, ETEC/STMPO |
| P. R. Brown, MMC (3) | R. W. Wiese, ETEC/STMPO |
| | W. C. Morehouse, Sandia/STMPO |
| | D. N. Tanner, Sandia-Livermore |

If you should have any questions or concerns please do not hesitate to contact me by telephone at, (619) 254-2672.

Sincerely,



S.D. Elliott, Jr., Director
DOE Solar One Project Office

SDE/aks
Project File: CCC002.RNO(SDO)

Encl: Nine Document Covers W/forms 70 and RA-426

cc: Roger Gaither, SAN/OPC
W.D. Matheny, DOE/TIC

bcc: Mike Lopez, DOE/SAN (FGS)
Mary Soderstrum, B&McD



DEPARTMENT OF ENERGY
SAN FRANCISCO OPERATIONS OFFICE

CONTRACTOR REQUEST FOR PATENT CLEARANCE
FOR RELEASE OF UNCLASSIFIED DOCUMENT

| |
|--|
| Prime Contract No. DE-AC03-79SF10499 |
| Subcontract No. (N/A) |
| Report No. (STMP0 174) DOE/SF/10499-T89 |
| Date of Report May 1980 |
| Name & Phone No. of DOE Technical Representative S.D. Elliott, Jr. (619) 254-2672 |

TO: Roger S. Gaither, Asst. Chief for Prosecution
Office of Patent Counsel/Livermore Office
P.O. Box 808, L-376
Livermore, California 94550

FROM: McDonnell Douglas Corporation
3855 Lakewood Blvd.
Long Beach, CA 90846

- Document Title: Pilot Plant Availability
- Type of Document: Technical Report, Conference Paper, Journal Article, Abstract or Summary,
 Copy of Oral Presentation, Other (please specify): _____
- In order to meet a publication schedule or submission deadline, patent clearance by _____ (Routine) would be desired.

SENDER IS TO CHECK BOX #4 OR #5 BELOW.

- I have reviewed (or have had reviewed by technically knowledgeable personnel) this document for possible inventive subject matter (Subject Inventions) and that no inventions or discoveries (Subject Inventions) are deemed to be disclosed in this document except as stated below:
 - Attention should be directed to pages _____ of this document.
 - This document describes matter relating to an invention:
 - Contractor Invention Docket No. _____
 - A disclosure of the invention was submitted to DOE on _____ (date)
 - A disclosure of the invention will be submitted shortly _____ (approximate date)
 - A waiver of DOE's patent rights to the contractor:
 has been granted, has been applied for; or will be applied for _____ (date)
- This document is being submitted, but no review has been made of this document for possible inventive subject matter.
Provide copy of clearance to: Solar One Project Office
P.O. Box 366, Daggett, CA 92327

Reviewing/Submitting Official: Name (Print/Type) _____
Title _____
Signature _____ Date _____

TO: INITIATOR OF REQUEST
FROM: ASSISTANT CHIEF FOR PROSECUTION
Office of Patent Counsel/Livermore Office

- No patent objection to above-identified release.
- Please defer release until advised by this office.

Signed _____ Date Mailed _____

U.S. DEPARTMENT OF ENERGY

DOE AND MAJOR CONTRACTOR RECOMMENDATIONS FOR
ANNOUNCEMENT AND DISTRIBUTION OF DOCUMENTS

See Instructions on Reverse Side

| | | |
|--|--------------------------------------|--|
| 1. DOE Report No. (STMPO 174) DOE/SF/10499-T89 | 2. Contract No. DE-AC03-79SF10499 | 3. Subject Category No. UC-62, 62c, 62d |
| 4. Title <u>Pilot Plant Availability</u> | | |
| 5. Type of Document ("x" one) <input checked="" type="checkbox"/> a. Scientific and technical report <input type="checkbox"/> b. Conference paper: Title of conference _____ Date of conference _____ Exact location of conference _____ Sponsoring organization _____ <input type="checkbox"/> c. Other (specify planning, educational, impact, market, social, economic, thesis, translations, journal article manuscript, etc.) _____ | | |
| 6. Copies Transmitted ("x" one or more) <input type="checkbox"/> a. Copies being transmitted for standard distribution by DOE-TIC. <input type="checkbox"/> b. Copies being transmitted for special distribution per attached complete address list. <input checked="" type="checkbox"/> c. Two completely legible, reproducible copies being transmitted to DOE-TIC. (Classified documents, see instructions) <input type="checkbox"/> d. Twenty-seven copies being transmitted to DOE-TIC for TIC processing and NTIS sales. | | |
| 7. Recommended Distribution ("x" one) <input type="checkbox"/> a. Normal handling (after patent clearance): no restraints on distribution except as may be required by the security classification. Make available only <input type="checkbox"/> b. To U.S. Government agencies and their contractors. <input type="checkbox"/> c. within DOE and to DOE contractors. <input type="checkbox"/> d. within DOE. <input type="checkbox"/> e. to those listed in item 13 below. <input checked="" type="checkbox"/> f. Other (Specify) <u>Archive/Issue on request</u> | | |
| 8. Recommended Announcement ("x" one) <input checked="" type="checkbox"/> a. Normal procedure may be followed. <input type="checkbox"/> b. Recommend the following announcement limitations: | | |
| 9. Reason for Restrictions Recommended in 7 or 8 above. <input type="checkbox"/> a. Preliminary information. <input type="checkbox"/> b. Prepared primarily for internal use. <input type="checkbox"/> c. Other (Explain) _____ | | |
| 10. Patent, Copyright and Proprietary Information Does this information product disclose any new equipment, process or material? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify page nos. _____ Has an invention disclosure been submitted to DOE covering any aspect of this information product? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify the DOE (or other) disclosure number and to whom the disclosure was submitted. Are there any patent-related objections to the release of this information product? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, state these objections. Does this information product contain copyrighted material? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify the page number _____ and attach the license or other authority for the government to reproduce. Does this information product contain proprietary information? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify the page numbers _____ ("x" one <input type="checkbox"/> a. DOE patent clearance has been granted by responsible DOE patent group. <input type="checkbox"/> b. Document has been sent to responsible DOE patent group for clearance. | | |
| 11. National Security Information (For classified document only: "x" one) Document <input type="checkbox"/> a. does <input type="checkbox"/> b. does not contain national security information | | |
| 12. Copy Reproduction and Distribution Total number of copies reproduced _____ Number of copies distributed outside originating organization _____ | | |
| 13. Additional Information or Remarks (Continue on separate sheet, if necessary) | | |
| 14. Submitted by (Name and Position) (Please print or type) <u>S.D. Elliott, Jr., Director, DOE Solar One Project Office</u> Organization _____ <u>P.O. Box 366 Daggett, CA. 92327 (619) 254-2672</u> Signature _____ Date _____ | | |



Department of Energy
 San Francisco Operations Office
 1333 Broadway
 Oakland, California 94612

Reply To: DOE Solar One Project Office
 P.O. Box 366
 Daggett, CA 92327

STMPD-174
 1

Mr. Robert L. Gervais
 Solar One Project Office
 McDonnell Douglas Astronautics Corp.
 P.O. Box 366
 Daggett, CA 92327

AUG 13 1984

Subject: Clearance of Control Contract DE-AC03-79SF10499
 Solar One Reports for DOE/TIC Inclusion.

Dear Bob:

Enclosed are copies of covers and title pages of nine reports prepared by McDonnell Douglas Astronautics Corporation for the Solar One Project under the above referenced contract. In preparation for delivery of these documents to DOE/TIC, I have prepared a SAN form 70 "Request for Patent Clearance" and a DOE form RA-426 "Recommendations for Announcement and Distribution of Documents" for each document.

Please have the appropriate MDAC personnel complete and sign these forms. As agreed, SAN form 70 should be forwarded to SAN/OPC by your office with copies of the completed SAN form 70 and the transmittal letter being sent to me. The completed DOE form RA-426 should be sent directly back to me.

The documents covered by this letter are:

| <u>Primary Document No.</u> | <u>Secondary No.</u> | <u>Brief Title</u> |
|-----------------------------|---------------------------------|------------------------------------|
| DOE/SF/10499-T67 | STMPD 133 | Construction Piping and Inst |
| DOE/SF/10499-T68 | STMPD 111 | Initial Project Design Review |
| DOE/SF/10499-T69 | STMPD 112 | Work Plan Revised |
| DOE/SF/10499-T70 | STMPD 114 | Overall Plant Design Description |
| DOE/SF/10499-T72 | STMPD 120 | Management Plan |
| DOE/SF/10499-T74 | STMPD 141 | Fourth Project Design Review |
| DOE/SF/10499-T88 | STMPD 171 | Subsystem Safety Analysis |
| DOE/SF/10499-T89 | STMPD 174 | Pilot Plant Availability |
| DOE/SF/10499-T90 <i>174</i> | STMPD 175 <i>179</i> | Receiver Tower Structural Analysis |

Library Project Instructions

Purpose: Scan abstract to contractor.xls spreadsheet in Excel. Enter new entries, as needed.

How:

1. Open up Excel-contractor.xls spreadsheet from directory D-Library.
2. To scan, have to be in Word.
3. Place abstract page in scanner.
4. File-Acquire text
5. Highlight text area and Perform OCR (button). This automatically spell-checks. If there are obvious spelling errors, correct. Otherwise, ignore. Also, check for special characters. This program doesn't pick up hyphens, degree signs, superscript/subscript, etc. OR Alt-F-Q
PERFORM OCR
6. Once corrections have been made, Edit-Select All
Edit-Copy OR Ctrl-A,
OR Ctrl-C
OR Alt-Tab
Switch back to Excel [BE SURE CURSOR IS IN THE RIGHT CELL (ALWAYS "C") - TO INSERT ABSTRACT]
7. Edit-Paste. OR Ctrl-V
Take out extra spaces at bottom by backspacing.
8. Press Enter, Spacebar, Backspace. This takes you to the next row.

SPECIAL INSTRUCTIONS:

- a. G Field is TRUE if the publication is in the library. If the publication can't be found in the library, make a comment in Notes field (H) "NOT IN LIBRARY"
 - b. H field is for comments, i.e. MULTIPLE COPIES; NOT ON LIST, NOT IN LIBRARY, etc.
 - c. When adding new entries, date field may appear FEB/00. To change it to the correct format, go to Format, Cell, Custom (and change the prompt line to mm/yy. Press Enter. Also left-justify that field, if needed).
9. At lunch break: SAVE OR Ctrl-S (saves into hard drive).
 10. At the end of the day:
 - a. Save Excel spreadsheet (contractor.xls) before copying.
 - b. Close Word and Excel.
 - d. From Windows Explorer - locate D:Library. Copy contractor.xls, and paste on top of the last version of the spreadsheet "Copy (#) of contractor.xls". (More than likely this would be the one that shows for the previous day).



DEPARTMENT OF ENERGY
SAN FRANCISCO OPERATIONS OFFICE

CONTRACTOR REQUEST FOR PATENT CLEARANCE
FOR RELEASE OF UNCLASSIFIED DOCUMENT

| |
|--|
| Prime Contract No. DE-AC03-79SF10499 |
| Subcontract No. (N/A) |
| Report No. (STMP0 174) DOE/SF/10499-T89 |
| Date of Report May 1980 |
| Name & Phone No. of DOE Technical Representative S.D. Elliott, Jr. (619) 254-2672 |

TO: Roger S. Gaither, Asst. Chief for Prosecution
Office of Patent Counsel/Livermore Office
P.O. Box 808, L-376
Livermore, California 94550

FROM: McDonnell Douglas Corporation
3855 Lakewood Blvd.
Long Beach, CA 90846

1. Document Title: Pilot Plant Availability

2. Type of Document: Technical Report, Conference Paper, Journal Article, Abstract or Summary,
 Copy of Oral Presentation, Other (please specify): _____

3. In order to meet a publication schedule or submission deadline, patent clearance by _____ (Routine) would be desired.

SENDER IS TO CHECK BOX #4 OR #5 BELOW.

4. I have reviewed (or have had reviewed by technically knowledgeable personnel) this document for possible inventive subject matter (Subject Inventions) and that no inventions or discoveries (Subject Inventions) are deemed to be disclosed in this document except as stated below:

a. Attention should be directed to pages _____ of this document.

b. This document describes matter relating to an invention:

- i. Contractor Invention Docket No. _____
- ii. A disclosure of the invention was submitted to DOE on _____ (date)
- iii. A disclosure of the invention will be submitted shortly _____ (approximate date)
- iv. A waiver of DOE's patent rights to the contractor:
 has been granted, has been applied for; or will be applied for _____ (date)

5. This document is being submitted, but no review has been made of this document for possible inventive subject matter.
Provide copy of clearance to: Solar One Project Office

6. Remarks: P.O. Box 366, Daggett, CA 92327

Reviewing/Submitting Official: Name (Print/Type) Donald L. Royer
Title Asst. Chief Patent Counsel, MDC (MS 122-23)
Signature *Donald L. Royer* Date 19 Sep 84

TO: INITIATOR OF REQUEST

FROM: ASSISTANT CHIEF FOR PROSECUTION
Office of Patent Counsel/Livermore Office

- No patent objection to above-identified release.
- Please defer release until advised by this office.

DOE Form RA-426
(10/80)

U.S. DEPARTMENT OF ENERGY

OMB NO. 038-R0190

DOE AND MAJOR CONTRACTOR RECOMMENDATIONS FOR
ANNOUNCEMENT AND DISTRIBUTION OF DOCUMENTS

See Instructions on Reverse Side

| | | |
|---|--------------------------------------|--|
| 1. DOE Report No. (STMPO 174) DOE/SF/10499-T89 | 2. Contract No. DE-AC03-79SF10499 | 3. Subject Category No. UC-62, 62c, 62d |
|---|--------------------------------------|--|

4. Title
Pilot Plant Availability

5. Type of Document ("x" one)
 a. Scientific and technical report
 b. Conference paper: Title of conference _____
Date of conference _____

Exact location of conference _____ Sponsoring organization _____
 c. Other (specify planning, educational, impact, market, social, economic, thesis, translations, journal article manuscript, etc.)

6. Copies Transmitted ("x" one or more)
 a. Copies being transmitted for standard distribution by DOE-TIC.
 b. Copies being transmitted for special distribution per attached complete address list.
 c. Two completely legible, reproducible copies being transmitted to DOE-TIC. (Classified documents, see instructions)
 d. Twenty-seven copies being transmitted to DOE-TIC for TIC processing and NTIS sales.

7. Recommended Distribution ("x" one)
 a. Normal handling (after patent clearance): no restraints on distribution except as may be required by the security classification. Make available only
 b. To U.S. Government agencies and their contractors. c. within DOE and to DOE contractors.
 d. within DOE. e. to those listed in item 13 below.
 f. Other (Specify) Archive/Issue on request

8. Recommended Announcement ("x" one)
 a. Normal procedure may be followed. b. Recommend the following announcement limitations:

9. Reason for Restrictions Recommended in 7 or 8 above.
 a. Preliminary information. b. Prepared primarily for internal use. c. Other (Explain)

10. Patent, Copyright and Proprietary Information
Does this information product disclose any new equipment, process or material? No Yes If so, identify page nos. _____
Has an invention disclosure been submitted to DOE covering any aspect of this information product? No Yes
If so, identify the DOE (or other) disclosure number and to whom the disclosure was submitted.
Are there any patent-related objections to the release of this information product? No Yes If so, state these objections.
Does this information product contain copyrighted material? No Yes
If so, identify the page number _____ and attach the license or other authority for the government to reproduce.
Does this information product contain proprietary information? No Yes If so, identify the page numbers
("x" one a. DOE patent clearance has been granted by responsible DOE patent group.
 b. Document has been sent to responsible DOE patent group for clearance.

11. National Security Information (For classified document only; "x" one)
Document a. does b. does not contain national security information

12. Copy Reproduction and Distribution
Total number of copies reproduced _____ Number of copies distributed outside originating organization _____

13. Additional Information or Remarks (Continue on separate sheet, if necessary)

14. Submitted by (Name and Position) (Please print or type)
S.D. Elliott, Jr., Director, DOE Solar One Project Office
Organization

P.O. Box 366 Daggett, CA. 92327 (619) 254-2672
Signature Date