

PROJECT DESCRIPTION OF  
INTERNATIONAL ENERGY AGENCY (IEA)  
SMALL SOLAR POWER SYSTEMS (SSPS)  
CENTRAL RECEIVER SYSTEM (CRS)

BY

W. GRASSE AND M. BECKER

DFVLR, OPERATING AGENT

INTERNATIONAL WORKSHOP  
ON THE DESIGN, CONSTRUCTION AND OPERATION  
OF SOLAR CENTRAL RECEIVER PROJECTS

CLAREMONT, CALIFORNIA

OCTOBER 19-22, 1982.

SSPS/oo3/4000



**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**

PROJECT DESCRIPTION OF  
INTERNATIONAL ENERGY AGENCY (IEA)  
SMALL SOLAR POWER SYSTEMS (SSPS)  
CENTRAL RECEIVER SYSTEM (CRS)

BY

W. GRASSE AND M. BECKER

DFVLR, OPERATING AGENT

INTERNATIONAL WORKSHOP  
ON THE DESIGN, CONSTRUCTION AND OPERATION  
OF SOLAR CENTRAL RECEIVER PROJECTS

CLAREMONT, CALIFORNIA

OCTOBER 19-22, 1982.

SSPS/oo3/4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

CONTENTS

PAGE

1. INTRODUCTION	1
2. DESIGN	6
3. CONSTRUCTION	10
4. CHARACTERISTICS	14
5. PERFORMANCES	25
6. OPERATION AND MAINTENANCE	38
7. SUMMARY	44
8. FUTURE PLANS	45

SSPS/003/4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

1. INTRODUCTION

SSPS / 003 / 4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

1. INTRODUCTION

1.1 PROJECT OBJECTIVES

1.2 INTERNATIONAL PARTICIPATION

1.3 PROJECT ORGANIZATION

1.4 SCHEDULE AND MILESTONES

1.5 SITE CHARACTERISTICS



**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**

DESIGN PHASE  
(STAGE 1)

- o 2 x 500 KW<sub>E</sub> OF DISSIMILAR TECHNOLOGY (CRS/DCS)  
WHENEVER INSOLATION > 700 W/M<sup>2</sup>  
UTILIZING TO MAXIMUM EXTENT  
POSSIBLE OFF-THE-SHELF TECHNOLOGY

CONSTRUCTION PHASE  
(STAGE 2)

- o 2 x 500 KW<sub>E</sub> (CRS/DCS) FOR EQUINOX NOON (920 W/M<sup>2</sup>)
- o TEST + OPERATION FOR MINIMUM OF 2 YEARS WITH REGARD TO
  - VIABILITY OF TECHNOLOGY
  - INDIVIDUAL PLANT BEHAVIOUR
  - COMPARISON DCS/CRS (BREAK-EVEN POINT ?)
  - ECONOMICS OF OPERATIONS
  - ASSESSMENT OF FUTURE POTENTIAL
- o DISTRIBUTION OF DATA + EXPERIENCE TO ALL PARTICIPATING COUNTRIES



1.1 PROJECT OBJECTIVES


IEA - SSPS  
OPERATING AGENT  
DFVLR

<u>PARTICIPATING COUNTRY</u>	<u>CONTRACTING PARTY</u>	<u>ACTING ENTITY</u>	<u>FUNDING ENTITY</u>	<u>SHARE</u>	
				MIO DM	%
AUSTRIA	REPUBLIC OF AUSTRIA	AUSTRIAN SPACE & SOLAR AGENCY	FEDERAL CHANCELLERY	3.1	4
BELGIUM	GOVERNMENT OF BELGIUM	SERVICE DE LA PROGRAMMATION DE LA POLITIQUE SCIENTIFIQUE	MINISTERE DE LA POLITIQUE SCIENTIFIQUE	4.6	5.9
FEDERAL REPUBLIC OF GERMANY	GERMAN AEROSPACE RESEARCH ESTABLISHMENT (DFVLR)	IDEM	FED. MINISTRY OF RESEARCH AND TECHNOLOGY (BMFT)	32.0	40.9
GREECE	MINISTRY OF COORDINATION AND PLANNING	NATIONAL ENERGY COUNCIL	MINISTRY OF COORDINATION AND PLANNING	2.1	2.7
ITALY	CONSIGLIO NAZIONALE DELLE RICERCHE	IDEM	IDEM	1.8	2.3
SPAIN	MINISTRY OF INDUSTRY AND ENERGY	CENTRO DE ESTUDIOS DE LA ENERGIA	MINISTRY OF INDUSTRY AND ENERGY	12.8	16.3
SWEDEN	NATIONAL SWEDISH BOARD FOR ENERGY SOURCE DEVELOPMENT	IDEM	IDEM	2.6	3.3
SWITZERLAND	FEDERAL OFFICE OF ENERGY	FED. INSTITUTE FOR REACTOR RESEARCH	NATIONAL ENERGY RESEARCH FUND (NEFF)	4.1	5.2
UNITED KINGDOM *	DEPARTMENT OF ENERGY	IDEM	IDEM	0.2	0.2
USA *	DEPARTMENT OF ENERGY	SANDIA NAT. LABS.	DOE	15.0	19.2
(PARTICIPATION ONLY IN DESIGN PHASE)				78.3	100.0



## 1.2 INTERNATIONAL PARTICIPATION

**IEA - SSPS**  
OPERATING AGENT  
**DFVLR**



SSPS/003/4000



1.3 PROJECT ORGANIZATION

IEA-SSPS  
OPERATING AGENT  
DFVLR



Phase	1977				1978				1979				1980				1981				1982				1983				1984			
	I	II	III	IV	I	II	III	IV	I	II	III	IV	I	II	III	IV	I	II	III	IV	I	II	III	IV	I	II	III	IV	I	II	III	IV
SSPS-Specifications trade-offs, feasibility considerations	▨																															
Plant (DCS + CRS) final design (Stage 1)					▨																											
Stage 2 preparations									▨																							
Procurement and installation													▨																			
Plant testing, operation and evaluation																					▨				---							
Advanced systems tests									ASR ▨				ASU ▨																			

MILESTONES

- FEB '76 IEA WORKING PARTY
- OCT '77 STAGE 1 IMPLEMENTING AGREEMENT
- MAY '79 STAGE 2 SUPPLEMENT
- JUN '79 SUPPLY CONTRACT AWARDS
- APR '80 START OF ON-SITE CONSTRUCTION
- APR '81 START OF FUNCTIONAL TESTING
- SEP '81 INAUGURATION, PLANT OPTIMIZATION PHASE
- JAN '82 START OF ROUTINE OPERATION
- JUN '82 START OF STAGE 3 DISCUSSIONS
- DEC '83 END OF STAGE 2



LOCATION: SPANISH PLATAFORMA SOLAR WITH 4 PROJECTS, ALMERIA/SOUTHERN SPAIN

- CESA - 1 (1.0 MW<sub>E</sub> CENTRAL RECEIVER SYSTEM)
- SSPS-CRS (0.5 MW<sub>E</sub> CENTRAL RECEIVER SYSTEM)
- SSPS-DCS (0.5 MW<sub>E</sub> DISTRIBUTED COLLECTORS)
- GAST (TECHNOLOGY PROGRAM DIRECTION TOWARDS 20 MWE CENTRAL RECEIVER SYSTEM)

ENVIRONMENT: 3000 HOURS > 300 W/M<sup>2</sup>, AVERAGE TEMPERATURE 17°C, ARID

INFRASTRUCTURE: ROADS, VIGILANCE, WORKSHOPS, OFFICES, CONFERENCE ROOMS, METEO-STATION, VISITORS SERVICES

PARTICIPATION: 9 COUNTRIES, LOCAL UTILITY (SEVILLANA)

TECHNOLOGY: HELIOSTATS FROM USA, GERMANY, SPAIN (1ST AND 2ND GENERATION)  
 PARABOLIC COLLECTORS FROM USA + GERMANY (THICK+THIN GLASS, 1-AXIS, 2-AXES)

HEAT TRANSFER MEDIA: OIL, SODIUM, WATER, AIR

STORAGE MEDIA: OIL, SODIUM, HITEC

PRIME MOVERS: STEAM TURBINES, STEAM MOTOR

TEMPERATURE RANGE: 295°C ... 800°C

COOLING SYSTEMS: WET, DRY



1.5 SITE CHARACTERISTICS

IEA - SSPS  
 OPERATING AGENT  
 DFVLR

1  
5  
1

## 2. DESIGN

SSPS / 003 / 4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

2. DESIGN

2.1 DESIGN CRITERIA

2.2 REQUIREMENTS

2.3 FACILITY SCHEMATIC



GEOGRAPHICAL DATA FOR TABERNAS SITE

LATITUDE	37° 06' N
LONGITUDE	02° 23 W
ALTITUDE	500 M
SUN-SHINE HOURS	2900 TO 3000

DESIGN POINT SPECIFICATION

TIME	EQUINOX 12:00 H
DIRECT RADIATION	920 W/M <sup>2</sup>
NET OUTPUT	500 KW
PARASITE LOAD	100 KW

HELIOSTAT FIELD

TYPE OF FIELD	NORTH
NUMBER OF HELIOSTATS	93
HELIOSTAT REFLECTIVE SURFACE	39.3 M <sup>2</sup>

(US IN-KIND-CONTRIBUTION FROM  
BARSTOW PROCUREMENT)

SSPS/003/4000



2.1 DESIGN CRITERIA (I)

IEA-SSPS  
OPERATING AGENT  
DFVLR

### HEAT TRANSFER CYCLE

MEDIUM	SODIUM
RECEIVER TYPE	CAVITY
CENTER POINT HEIGHT	43.25 M
MAXIMUM TEMPERATURE	530° C
MAXIMUM PRESSURE	8 BAR
HEAT STORAGE	TWO VESSELS OF 70 M <sup>3</sup>

### POWER CONVERSION CYCLE

TYPE	RANKINE
LIVE STEAM	500° C; 100 BAR


### GENERAL

LIFE TIME	10 YEARS
PRICE TYPE -	FIRM FIXED ,
PROVISIONS	12 MONTHS
PERFORMANCE	ELECTRICAL OUTPUT
PENALTY/INCENTIVE	90 % / 100 %




POWER INPUT	2.8 MW TO RECEIVER AT DESIGN CONDITIONS		
ENERGY STORAGE	EQUIVALENT TO ABOUT 1 MW <sub>E</sub> AVAILABLE UP TO 24 H AFTER FULLY CHARGED, TO BE LOADED UNDER FULL, PARTIAL AND ZERO ELECTRICAL OUTPUT		
LAND USE FACTOR	HIGHER THAN 20 %		
COOLING	EVAPORATIVE WATER		
OPERATIONAL MODES	INSOLATION ONLY INSOLATION AND STORAGE STORAGE ONLY		
POWER DELIVERY	UTILITY GRID SUBSTITUTE LOAD		
OPERABILITY	<u>FULL</u>	<u>REDUCED (50 %)</u>	<u>SURVIVAL</u>
INSOLATION	W/M <sup>2</sup>	1100	
WIND	KM/H	13	50
EARTHQUAKE	M/S <sup>2</sup>	0.3	0.3
HAIL SIZE	MM		19
AT SPEED	M/S		20
SAFETY PRECAUTIONS	EMERGENCY POWER DEFOUSSING DEVICES INDEPENDENT SAFETY INSTRUMENTATION ALARM AND PROTECTION SYSTEMS		

SSPS/003/4000



2.2 DESIGN REQUIREMENTS

IEA-SSPS  
OPERATING AGENT  
DFVLR



IEA - SSPS  
OPERATING AGENT  
DFVLR

2.3 FACILITY SCHEMATIC





### 3. CONSTRUCTION

SSPS/003/4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

3. CONSTRUCTION

3.1 PROCUREMENT PRINCIPLES

3.2 INDUSTRIAL PARTICIPATION

3.3 CHECKOUT / ACCEPTANCE

3.4 COSTS



**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**

- o SSPS PROCUREMENT REGULATIONS
- o CONTRIBUTIONS AND PAYMENTS IN DM
- o FIXED SCALE OF CONTRIBUTIONS
- o FIXED SCHEDULE OF CONTRIBUTIONS
- o FIXED PRICE CONTRACTS
  - 60 % OF 70 MDM FIRM FIXED
- o CONTRACTS IN THE NAME OF DFLVR
- o STAGE I COMPETITIVE PROCUREMENT
  - REDUCED COMPETITION IN STAGE II
    - CRS : 3 MAIN CONTRACTORS, DFLVR INTEGRATION
    - DCS : CONSORTIUM OF 3 COMPANIES
- o EXTENSIVE WARRANTY - GUARANTEE PROVISIONS

SSPS / 003 / 4000



### 3.1 PROCUREMENT PRINCIPLES

**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**

<u>COUNTRY</u>		<u>NUMBER OF FIRMS INVOLVED</u>	<u>TOTAL VALUE MIO. DM</u>	<u>REFLOW %</u>
AUSTRIA	(A)	5	1.9	63
BELGIUM	(B)	7	3.0	66
SWITZERLAND	(CH)	4	3.4	85
GERMANY	(D)	14	24.9	79
SPAIN	(E)	16	20.7	165
GREECE	(GR)	2	0.25	12
ITALY	(I)	1	0.6	37
SWEDEN	(S)	1	2.7	108
USA		3	12.8	88
OTHER		4	1.0	--
		57	71.25	



3.2 INDUSTRIAL PARTICIPATION AND REFLOW  
(1979 - 1981)

IEA-SSPS  
OPERATING AGENT  
DFVLR

FUNCTIONAL TESTS	WITHOUT SOLAR ENERGY AT AMBIENT TEMPERATURE AND WITHOUT HEAT TRANSFER MEDIA FOR ALL SUBSYSTEMS FROM HFS TO DAS
FUNCTIONAL TESTS	WITHOUT SOLAR ENERGY AT ELEVATED TEMPERATURES AND WITH HEAT TRANSFER MEDIA FOR SHTS, PCS, AND CES
FUNCTIONAL TESTS	WITH SOLAR ENERGY o INTEGRATIONS HFS/SHTS, SHTS/PCS o COMPONENT TESTS FROM SHTS TO CES
ACCEPTANCE TESTS	PLANT START-UP o CAPABILITY OF HFS/SHTS; SHTS/PCS; STORAGE o START-UPS HFS/SHTS; SHTS/PCS o SHUT-DOWNS HFS/SHTS; SHTS/PCS
ACCEPTANCE TESTS	PLANT EMERGENCY o POWER SUPPLY FAILURE o PUMP FAILURES (SODIUM; FEEDWATER) o STEAM MOTOR FAILURE



PLAN :

MAY 1979	MDM
CENTRAL RECEIVER SYSTEM	33.5
DISTRIBUTED COLLECTOR SYS.	22.5
TEST + OPERATION	6.0 1)
ITET	-
OPERATING AGENT	4.0 1)
GENERAL EXPENDITURE	-
CONTINGENCY	8.5
<b>TOTAL :</b>	<b>74.5 2)</b>

- 1) UNTIL MARCH 1983
- 2) WITHOUT ITALIAN IN-KIND CONTRIBUTIONS

REMARK : - ALL FIGURES NOT SPECIFIED FOR DCS OR CRS ARE FOR TWO PLANTS  
 - ITET = INTERNATIONAL TEST AND EVALUATION TEAM

STATUS :

APRIL 1982	MDM
CENTRAL RECEIVER SYSTEM	36.3 5)
DISTRIBUTED COLLECTOR SYS.	30.2
TEST + OPERATION	10.1 3) 4)
ITET	0.2
OPERATING AGENT	5.9 4)
GENERAL EXPENDITURE	0.5
CONTINGENCY	3.2
<b>TOTAL :</b>	<b>86.4</b>

- 3) INCLUDING CRS/DCS OPERATION OPTIMIZATION (3.4)
- 4) INCLUDING 9 MONTHS EXTENSION TILL END 1983
- 5) BREAKDOWN (APPROXIMATELY ONLY)

HELIOSTAT FIELD	7
SODIUM SYSTEM	
+ ELECTRICAL SYSTEM	
+ CONTROL SYSTEM	23
POWER CONVERSION	3
DATA ACQUISITION SYSTEM	1
BUILDING + INFRASTRUCTURE	
(50 % OF TOTAL)	2.3
	<u>36.3</u>



3.4 FACILITY COSTS

IEA - SSPS  
 OPERATING AGENT  
 DFVLR

#### 4. CHARACTERISTICS

SSPS/003/4000




IEA-SSPS  
OPERATING AGENT  
DFVLR





- o INTERFACES OF IMPORTANCE
  - RADIATION / POWER STATION (HELIOSTATS)
  - HELIOSTAT FIELD / SODIUM CIRCUIT (RECEIVER)
  - SODIUM CIRCUIT / STEAM CIRCUIT (STEAM GENERATOR)
  - POWER STATION / GRID (ALTERNATOR)
  
- o RECEIVER AS SOLAR SPECIFIC INTERFACE
  - TRANSFER OF SOLAR RADIATION INTO THERMAL ENERGY
  - HELIOSTAT FIELD CONCENTRATION PRODUCES DISTRIBUTION OF HEAT FLUX DENSITIES ON ABSORPTION PLANE
  - SPILLAGE PROBLEM ON RECEIVER APERTURE EDGES AS SAFETY CRITERION AND DESIGN PARAMETER
  - ENERGY BALANCE AT RECEIVER
    - ABSORPTION ON TUBES :
    - RADIATION, RERADIATION, REFLECTION,
    - CONDUCTION, CONVECTION
  - REACTIONS OF THERMAL CYCLE ON RADIATION FLUCTUATIONS, CLOUD INTERMISSIONS, STARTS AND SHUT DOWNS




- o HIGH REFLECTIVITY PRE-FOCUSED HELIOSTATS
- o COORDINATION OF TOTAL HELIOSTAT FIELD WITH PURPOSE OF CONCENTRATION
- o DIRECTION TO THERMAL RECEIVER WITH OCTOGONAL APERTURE AREA ON TOP OF TOWER
- o CONTROL ON THREE LEVELS
  - SINGLE HELIOSTAT (HC)
  - HELIOSTAT GROUPS (HFC)
  - TOTAL FIELD (HAC)

TABLE OF MAIN DATA

NUMBER OF HELIOSTATS	93
TOTAL REFLECTIVE AREA	3655 M <sup>2</sup>
APERTURE AREA	9.7 M <sup>2</sup>
AIM POINT IN APERTURE PLANE ABOVE GROUND	43.2 M
POWER INTO CAVITY AT DESIGN CONDITIONS	2840 KW






- Location of Heliostat Field Controllers (4 ea)
- ▲ Location of Sun-Presence Sensors (10 ea)

SSPS/oo3/4000




4.2 HELIOSTAT FIELD  
PLOT PLAN  
(MMC, USA)

IEA-SSPS  
OPERATING AGENT  
DFVLR




SSPS/003/400



4.2 HELIOSTAT FIELD  
INSOLATION, COSINE AND  
CALCULATED POWER FLUX

IEA-SSPS  
OPERATING AGENT  
DFVLR



NOMINAL (DESIGN)  
POWER CONDITIONS [KW]



RECEIVER	
RADIATIVE INPUT	2840
RECEIVER	
THERMAL INPUT	2508
STEAM GENERATOR	
THERMAL INPUT	2203



4.3 SODIUM HEAT TRANSFER CYCLE  
(INTERATOM, GERMANY)

IEA - SSPS  
OPERATING AGENT  
DFVLR

- o CAVITY RECEIVER WITH NORTH ORIENTED OCTOGONAL SHAPED (3.4 M AND 3.5 M MAIN DIMENSION) APERTURE OF 9.7 M<sup>2</sup>
- o CENTER LOCATED 43.25 M ABOVE GROUND
- o ABSORBING SURFACE 17 M<sup>2</sup>  
6 PARALLEL SODIUM CARRYING TUBES DIRECTED IN A SERPENTINE WAY FROM BOTTOM TO TOP WITH 14 TURNS  
PEAK FLUX DENSITY 600 KW/M<sup>2</sup>  
ABSORPTIVITY OF TUBES 0.95  
DESIGN EFFICIENCY 0.883
- o CERAMIC BACK WALL ENABLES SHORT TIME HEAT STORAGE



SSPS / 003 / 4003



4.3 SODIUM HEAT TRANSFER RECEIVER (SÜLZER, SWITZERLAND)

IEA-SSPS OPERATING AGENT DFVLR

DESIGN ITEMS

- o HELICAL TUBE / ONCE TROUGH
- o COILED AROUND CENTRAL DISPLACEMENT TUBE
- o SODIUM FLOW DOWNWARDS BETWEEN SHELL AND DISPLACEMENT AROUND THE HEATING TUBES
- o WATER FLOW UPWARDS
- o TWO RUPTURE DISCS CONNECTED WITH CYCLONE

DATA


HEAT TRANSFER AREA	14.7 M <sup>2</sup>
FEED WATER TEMPERATURE	193 <sup>o</sup> C
OUTLET STEAM TEMPERATURE	500 TO 525 <sup>o</sup> C
OUTLET PRESSURE	105 BAR
STEAM MASS FLOW	0.86 KG/S
SODIUM INLET TEMPERATURE	525 <sup>o</sup> C
SODIUM OUTLET TEMPERATURE	275 <sup>o</sup> C
MAXIMUM SODIUM PRESSURE	8 BAR
SODIUM MASS FLOW	6.9 KG/S

SSPS/003/4000



4.3 SODIUM HEAT TRANSFER  
STEAM GENERATOR  
(SULZER, SWITZERLAND)

IEA-SSPS  
OPERATING AGENT  
DFVLR



NOMINAL (DESIGN)  
POWER CONDITIONS [KW]

STEAM INPUT	2203
GROSS EL. OUTPUT	599
NET EL. OUTPUT	500




4.4 POWER CONVERSION  
 (SPILLING, GERMANY/SWITZERLAND)

IEA - SSPS  
 OPERATING AGENT  
 DFVLR



## Main Functions of CRS Control and Data Acquisition System




HFS	Heliostat Field System	SHTS	Sodium Heat Transfer System
HFC	Heliostat Field Control	PCS	Power Conversion System
HAC	Heliostat Array Control	DAS	Data Acquisition System
HC	Heliostat Control		

SSPS/oo3/4000




### 4.5 CONTROL AND DATA ACQUISITION

**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**



DESIGN CONDITION  
 Day 80 Time: 12:00  
 Insolation 0.92 kW/m<sup>2</sup>  
 Heliostat Field Area 3655 m<sup>2</sup>



4.7 POWER STAIR STEP  
 CALCULATED FOR DESIGN CONDITION

IEA - SSPS  
 OPERATING AGENT  
 DFVLR

5. PERFORMANCES

SSPS / 003 / 4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

5. PERFORMANCE

5.1 METEO DATA

5.2 PLANT OPERATION DATA

5.3 HELIOSTAT FIELD


5.4 SODIUM HEAT TRANSFER

5.5 POWER CONVERSION

5.6 EVENTS AND FAILURES


5.7 MEASUREMENT CAMPAIGN FALL 1982






5.1 METEO DATA  
DIRECT INSOLATION

IEA - SSPS  
OPERATING AGENT  
DFVLR



5.1 METEO DATA  
WIND SPEED AND TEMPERATURE



IEA - SSPS  
OPERATING AGENT  
DFVLR



5.1 METEO DATA  
COMPARISON OF REAL WITH CLEAR SKY  
CALCULATED SUN SHINE HOURS FOR 1982


IEA - SSPS  
OPERATING AGENT  
DFVLR






5.2 PLANT OPERATION DATA  
1982


IEA - SSPS  
OPERATING AGENT  
DFVLR



5.3 HELIOSTAT FIELD  
AVERAGED REFLECTIVITIES IN 1982

IEA - SSPS  
OPERATING AGENT  
DFVLR






SSPS / oo3 / 4000



5.4 SODIUM HEAT TRANSFER TEMPERATURE

IEA-SSPS  
OPERATING AGENT  
DFVLR

$$\eta = \frac{P_{SO}}{P_{MEAS}}$$



SSPS/003/4000



5.4 SODIUM HEAT TRANSFER  
RECEIVER EFFICIENCY

IEA-SSPS  
OPERATING AGENT  
DFVLR

RESULTS OF 1982

JANUARY - MAY	FIRST STAGE STEAM MOTOR REPAIR
JUNE - JULY	FUNCTIONAL TESTS
JULY - AUGUST	TEN-DAY-TEST
SEPTEMBER	OPERATION

TEN-DAY-EXPERIENCE-TEST

- o DEMONSTRATION OF PERFORMANCE  
CAPACITY IN REQUIRED POWER RANGE
- o MAINTENANCE REQUIREMENTS DUE TO  
UNSATISFACTORY RELIABILITY

STEAM ENGINE PERFORMANCE DATA


	<u>AVERAGE LOAD KW</u>	<u>TOTAL ENERGY KWH</u>	<u>GRID TIME H</u>
TO END OF JULY	166	8730	52:34
10-DAY-TEST	259	6855	26:25
POST 10-DAY-TEST	371	7055	19:01
TO SEPT. 27, 1982			
SUM	233	22640	98:00

SSPS/oo3/4000



5.5 POWER CONVERSION  
DATA

**IEA-SSPS**  
OPERATING AGENT  
**DFVLR**




SSPS/oo3/4000



5.5 POWER CONVERSION  
EFFICIENCY

IEA-SSPS  
OPERATING AGENT  
DFVLR

1979	JULY	STAGE 2 CONTRACT
	OCTOBER	CRITICAL DESIGN REVIEW
	DECEMBER	HELIOSTAT PROCUREMENT
1980	APRIL	START OF SITE ACTIVITIES
	DECEMBER	RECEIVER ON TOWER
1981	JANUARY	START OF HELIOSTAT INSTALLATION
	FEBRUARY	FIRST SODIUM FILLING
	APRIL	DAS ACCEPTANCE
	MAY	HFS ACCEPTANCE
		START OF SOLAR TESTS
	JUNE	PROVISIONAL PLANT ACCEPTANCE
	JULY	HFD ACCEPTANCE / FAS OPERATIONAL
		STEAM MOTOR RUN (NO LOAD)
	SEPTEMBER	FIRST POWER TO GRID
		INAUGURATION
	OCTOBER	PLANT OPTIMIZATION
	DECEMBER	PLANT ACCEPTANCE AND
		REPAIR AGREEMENT
1982	JANUARY	ROUTINE OPERATION START AND
		COLD SODIUM TANK GENERAL REPAIR
		FIRST STAGE STEAM MOTOR REPAIR
	MAY	COLD SODIUM TANK OPERATIONAL
	JULY	EC-DECISION TO SUBSTITUTE
		STEAM ENGINE BY TURBINE
	SEPTEMBER	MEASUREMENT CAMPAIGN





1980	SEPTEMBER	FLOODING OF SITE
1981	MARCH	SODIUM FIRE AT TRANSPORT CONTAINER
	APRIL	MIRROR ATTACHMENTS FAILED HELIOSTAT COMMUNICATION PROBLEMS SODIUM PUMP LK02 BLOCKAGE (CONTAMINATION)
	JUNE	SODIUM PUMP LK02 BLOCKAGE
	JULY	SODIUM LEAKAGE AT COLD STORAGE TANK LOWER PART
	AUGUST	CONCENTRATED IMAGE EASTWARD WALK DUE TO POWER FAILURE AND LACK OF RESTAURATION
	SEPTEMBER	SODIUM LEAKAGE AT CAP WELDING OF COLD STORAGE TANK MAN HOLE STEAM ENGINE FIRST STAGE WATER HAMMER
	NOVEMBER	CRANE DAMAGE FROM ONE HELIOSTAT DAS MEMORY ERROR, BLOCKAGE OF SYSTEM
1982	JANUARY	HFS INOPERABLE (HAC)
	APRIL	HFS UNSOLICITED INTERRUPTS HFS DAMAGES (HC, HAC AND HFC/HAC INTERFACE) DUE TO LIGHTNING
	MAY	SODIUM PUMP LK02 OIL LEAK
	JULY	SODIUM PUMP LK02 OIL LEAK
	SEPTEMBER	COLD SODIUM TANK LEAKAGE
	OCTOBER	COLD SODIUM TANK LEAKAGE

SSPS / 003 / 4000



5.6 EVENTS AND FAILURES  
FAILURE LIST

IEA-SSPS  
OPERATING AGENT  
DFVLR

OBJECTIVES

- o CONCENTRATION EFFICIENCY OF HELIOSTAT FIELD
- o CAVITY LOSSES OF RECEIVER
- o POWER STAIR STEP; ENERGY PRODUCTION

GOALS

- o BETTER RECOGNITION OF SOLAR SPECIFIC ELEMENTS
- o INCREASED UNDERSTANDING OF CONTEXTS
- o PROPOSALS FOR IMPROVEMENTS OF PLANT, TECHNIQUES AND PROCEDURES
- o PREPARATION FOR FUTURE DESIGNS


MEASUREMENT TECHNIQUES

GAGES, PYRHELIOMETERS (METEO, SUN SHAPE)  
REFLECTOMETERS  
DUST ANALYSES  
RADIOMETERS / TRAVERSES (VISIBLE; IR)  
CAMERAS FOR REFLECTED LIGHT/TRAVERSES (VISIBLE; IR)  
THERMOCOUPLES (RECEIVER)

OTHER

PLANT POWER STAIR STEP  
(EXPERIMENTALLY AND FOR COMPARISON  
OPTICAL PART ALSO CALCULATED)

SSPS/003/4000



5.7 MEASUREMENT CAMPAIGN  
FALL 1982

IEA-SSPS  
OPERATING AGENT  
DFVLR

6: OPERATION AND MAINTENANCE

SSPS/oo3/4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

6. OPERATION AND  
MAINTENANCE (O + M)

6.1 REQUIREMENTS

6.2 STAFFING

6.3 EXPERIENCES

6.4 COSTS



OPERATION

- o 7 DAYS WITH 2 SHIFT + OVERNIGHT VIGILANCE
- o MAXIMIZATION OF YEARLY ENERGY OUTPUT
- o MINIMIZATION OF PLANT OUTAGES
- o OPTIONALLY GRID CONNECTION AND STAND ALONE OPERATION
- o FLEXIBILITY FOR PARALLEL TESTS AND EXPERIMENTS
- o RECCORDING OF O + M COSTS ON SUBSYSTEM LEVEL

MAINTENANCE

- o ROUTINE / PREVENTIVE MAINTENANCE
- o MAINTENANCE AND REPAIR/MODIFICATION OF MACHINERY AND INSTALLATIONS
- o SUPPLY OF ENERGY, WATER, GASES, ETC.
- o STORE-HOUSE AND SPARE PART SUPPLY
- o COST CONTROL (PERSONNEL AND MATERIALS)
- o SUPPORTING MAINTENANCE CONTRACTS



SHIFT PERSONNEL                      7 DAYS/WEEK  
7:00/15:00; 15:00/23:00; 23:00/7:00

2      SYSTEM ENGINEERS  
4      OPERATION DEPUTIES  
10     OPERATORS  
10    WATCHERS  
26  
13     FOR DCS  
13     FOR CRS


NON SHIFT PERSONNEL                5 DAYS/WEEK  
8:30/17:30

1      PLANT OPERATION MANAGER  
1      ADMINISTRATOR  
1      SECRETARY  
1      TELEPHONIST  
1      MAINTENANCE SUPERVISOR  
8     SPECIALIZED WORKERS  
13     (50 % EACH FOR CRS + DCS)

JOB SHARING WITH CESA-1 PLANT    (5 DAYS/WEEK)

0.5    SAFETY ENGINEER  
0.5    MEDICAL ASSISTANT  
0.5    CHEMIST  
1.5    (50 % EACH FOR CRS + DCS)






			<u>H</u>
1	—	HOURS OF INSOLATION 300 W/M <sup>2</sup>	1605
2	----	HOURS OF ENERGY COLLECTION	543
3	.....	HOURS OF PCS-OPERATION	429
4	-.-.-	HOURS OF ELECTRICITY PRODUCTION	40

GROSS ELECTRIC ENERGY : 11 800 KWH

SSPS/003/4000



6.3 EXPERIENCES  
OPERATION HOURS  
(JAN. TO AUG. 1982)

IEA-SSPS  
OPERATING AGENT  
DFVLR

1982	H O U R S					REASON FOR NON-OPERATION	OUT OF SERVICE (MONTHLY)
	OPER.*	NON-OPER.	TRACK	STAND-BY	STOW		
JANUARY	106	638	0	52	54	1-SHIFT OPERATION (597) HAC-FAILURE (41)	3
FEBRUARY	442	230	0	115	327	HAC-FAILURE (230)	3
MARCH	718	26	0	265	453	HAC-FAILURE (26)	2
APRIL	592	128	19	206	367	HAC-FAILURE (97) MAINTENANCE (31)	11
MAY	503	241	24	161	318	HAC-FAILURE (216) MAINTENANCE (25)	31
JUNE	709	11	197	270	242	MAINTENANCE (11)	3
JULY	731	13	119	246	366	MAINTENANCE (13)	6
AUGUST	736	8	184	121	431	MAINTENANCE (8)	7
TOTAL	4537	1295	543	1436	2558		-
% of 5832 H	(78 %)		(1 %)	(25 %)	(43 %)		* MAX. 24 HOURS PER DAY

- 41 -


	<p>6.3 EXPERIENCES HELIOSTAT FIELD OPERATION HOURS (JAN. TO AUG. 1982)</p>	<p>IEA - SSPS OPERATING AGENT DFVLR</p>
--	--	---



TOTAL MAINTENANCE MANHOURS						
1982	HFS	SHTS	PCS	ES	DAS	TOTAL
JAN	10.75	-	-	0.25	-	11
FEB	63.50	30	-	8	-	101.5
MAR	29	16.5	1	10	-	56.5
APR	43.50	16	173	-	1	233.5
MAY	169	152	-	40	-	361
JUN	79	28	6	2	2	117
JUL	392	345.5	3	0.5	2	743
AUG	211.5	76	19.5	189	-	496
TOTAL	998.25	664.0	202.5	249.75	5	2119.5

MIRROR WASHING MANHOURS							
1982 MONTH	H F S		A C U R E X		M A N		TOTAL
	TIME	MAN-HOUR	TIME	MAN-HOUR	TIME	MAN-HOUR	
JAN	-	-	6.75	13.5	7	14	27.5
FEB	13	26	7	14	4	8	48
MAR	19.75	39.5	-	-	-	-	39.5
APR	4.25	8.5	7	14	10.5	21	43.5
MAY	-	-	8	16	-	-	16
JUN	24.5	49	9	18	10.5	21	88
JUL	13.5	27	9.5	19	17.75	35.5	81.5
AUG	35.5	71	9.5	19	10	20	110
TOTAL	110.5	221	56.75	113.5	59.75	119.5	454

SSPS/003/4000




6.3 EXPERIENCES  
MANHOURS  
(JAN. TO AUG. 1982)

IEA-SSPS  
OPERATING AGENT  
DFVLR

C O N C E P T	C O S T S (DM)
* ADMINISTRATION	9.500
* PERSONNEL	1.007.000
* GENERAL MAINTENANCE	4.500
SPECIAL MAINTENANCE	50.000
* DEVELOPMENT WORKS AND MAINTENANCE OF GENERAL SERVICES	17.200
* ELECTRICITY	82.000
CRS CONSUMABLES	13.500
CRS/HFS SPARES	79.150
CRS/SHTS SPARES	500
CRS/PCS SPARES	—
CRS/ES SPARES	12.000
CRS/DAS SPARES	29.000
CRS DEVELOPMENT WORKS	9.800
	1.314.150

\* TOTAL COSTS FOR SSPS PLANTS  
ONLY 50 % FOR CRS.



7. SUMMARY


SSPS / 003 / 4000



IEA-SSPS  
OPERATING AGENT  
DFVLR

<u>SYSTEM OR COMPONENT</u>	<u>PROBLEM</u>	<u>SOLUTION</u>
HELIOSTAT FIELD	<ul style="list-style-type: none"> <li>- FOCAL LENGTH</li> <li>- MIRROR ATTACHMENT</li> <li>- TRACKING INTERRUPT</li> <li>- DUST, SOIL</li> <li>- COMPUTER MAINTENANCE</li> <li>- EARTHING, LIGHTNING, DAMAGES, OVERVOLTAGES</li> <li>- SOLAR MULTIPLE</li> </ul>	11 16 VARIOUS RIVETING NEW HC WASHING STILL OPEN STILL OPEN MORE HELIOSTATS
RECEIVER	<ul style="list-style-type: none"> <li>- APERTURE FLUX</li> <li>- CONVECTION</li> </ul>	MEASUREMENTS SPEC. ACTIVITIES
SODIUM HEAT TRANSFER	<ul style="list-style-type: none"> <li>- COLD VESSEL LEAKAGE</li> <li>- VALVE LEAKAGE</li> <li>- PUMP</li> <li>- BYPASS FOR COLD VESSEL</li> </ul>	OPEN REPAIR REPAIR AND INCREASED MAINTENANCE OPEN
STEAM GENERATOR	NONE	
POWER CONVERSION	<ul style="list-style-type: none"> <li>- STEAM MOTOR PERFORMANCE</li> <li>- FEED WATER REGENERATION</li> </ul>	REPLACEMENT BY TURBINE SUPPLY FROM DCS
ELECTRICAL SYS. PLANT	<ul style="list-style-type: none"> <li>- GRID OVERVOLTAGES</li> <li>- METEO</li> <li>- DUST</li> </ul>	GRID IMPROVEMENT NONE NONE
OPERATION	<ul style="list-style-type: none"> <li>- START UP AT 300 W/M<sup>2</sup></li> <li>- LACKING ROUTINE EXPERIENCE</li> </ul>	WAIT EXTENSION OF STAGE 2
MAINTENANCE	<ul style="list-style-type: none"> <li>- ONLY ONE SHIFT</li> <li>- LACKING DOCUMENTATION FOR HFS</li> </ul>	OPEN OPEN

SSPS / 003 / 4000



7. SUMMARY  
 PROBLEMS AND SOLUTIONS

IEA-SSPS  
 OPERATING AGENT  
 DFVLR

8. FUTURE PLANS

SSPS / 003 / 4003



IEA-SSPS  
OPERATING AGENT  
DFVLR

- o EXTENSION OF T + 0 PHASE  
(ORIGINALLY 2 YEARS) FOR
  - INCREASE OF OPERATIONAL EXPERIENCE AND DEVELOPMENT AND OPTIMIZATION OF OPERATIONAL STRATEGIES
  - COMPLETION OF DATA EVALUATION
  - EXPLORATION OF OPERATIONAL LIMITS FOR SODIUM AS HEAT TRANSFER MEDIUM
  - IMPROVEMENTS OF HARDWARE  
(STORAGE VESSEL; PRIME MOVER)
  - CONTINUATION OF MEASUREMENT CAMPAIGNS
  
- o ADDITION OF HELIOSTATS FOR BETTER OPERATIONAL FLEXIBILITY  
(SOLAR MULTIPLE FROM 1.1 TO 1.6)
  
- o TESTING OF HIGH FLUX SODIUM RECEIVER
  
- o EXCHANGE OF EXPERIENCE AND DATA IN PARTICULAR WITH RESPECT TO HITEC APPLICATION AT RECEIVER, STORAGE, STEAM GENERATOR

SSPS/003/4000



8. FUTURE PLANS

IEA-SSPS  
OPERATING AGENT  
DFVLR