

**10 MWe Solar Thermal  
Central Receiver Pilot Plant  
Solar Facilities Design Integration**

---

---

**PSS FINAL DESIGN CALCULATIONS  
BOOK 26 OF 26--MDAC GENERAL ANALYSIS AND  
BACKGROUND DATA (RADL ITEM 7-8)**

---

---

September 1980

**DISCLAIMER**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**MCDONNELL DOUGLAS ASTRONAUTICS COMPANY  
5301 BOLSA AVENUE  
HUNTINGTON BEACH, CA 92647**

**PREPARED FOR THE  
U.S. DEPARTMENT OF ENERGY  
SOLAR ENERGY  
UNDER CONTRACT DE-AC-03-79SF10499**

## PREFACE

This document is provided by McDonnell Douglas Astronautics Company (MDAC) in accordance with Department of Energy Contract Number DE-AC03-79SF10499, Reports and Deliverables List (RADL Item 7-8).

The Plant Support Subsystem Final Design Calculations (RADL Item 7-8) are arranged in a twenty-six book volume as shown on the master Table of Contents.

Book 26 of this document is provided as a supplement to the Stearn-Roger calculations. These calculations prepared by MDAC include general design analysis and background data utilized to arrive at the plant design.

Questions concerning this report should be directed to R.J. Perkins at (714) 896-3073.

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM  |   | PAGE                 |
|---|---|----------------------|
| BOOK 1 - SITE DEVELOPMENT AND<br>PRELIMINARY EARTHWORK, CONSTRUCTION<br>PACKAGE 1 |   |                      |
| 1   | Drainage Calculations<br>Culvert Sizing<br>Drainage Structure | 1-4 of 4<br>1 of 1   |
| 2   | Horizontal Layout<br>Curve Data<br>Perimeter Road Stations    | 1 of 2<br>2 of 2     |
| 3   | Quantities<br>Structural Fill<br>Base Course                  | 1 of 4<br>2,3,4 of 4 |
| BOOK 2 - WAREHOUSE, CONSTRUCTION<br>PACKAGE 3                                     |   |                      |
| 1   | Interrupting Rating   | 1,2,3                |
| 2   | Lighting Calculation Sheet                                    | 1 of 1               |
| 3   | Foundation  | 1 thru 8             |
| BOOK 3 - STRUCTURAL STEEL AND<br>BUILDINGS, CONSTRUCTION<br>PACKAGE 5             |   |                      |
| 1   | Raw/Service Water Pump Building<br>Steel                      | RPS-D-1 thru 11      |
| 2   | Secondary Fire Pump Building<br>Steel                         | SPS-D-1 thru 13      |
| 3   | Thermal Storage Control<br>Building Steel                     | TCS-D-1 thru 13      |
| 4   | Thermal Storage Electrical<br>Building Steel                  | TES-D-1 thru 8       |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM |  | PAGE            |
|------|--|-----------------|
| 5    | TSS Pipe Support Structural                    | PR-D-1 thru 117 |
| 6    | TSS Pipe Support Structural<br>Computer Output | PR-C-1 thru 272 |
| 7    | Wind and Pyranometer Towers                    | WPT-D-1 thru 5  |
| 8    | Wind and Pyranometer Towers<br>Reference       | WPT-R-1 thru 11 |

BOOK 4 - RECEIVER TOWER  
STRUCTURAL, CONSTRUCTION  
PACKAGE 5A (RADL ITEM 7-21)

Note: This document includes design calculation for the receiver tower steel (Construction Package 5A) which was previously submitted by MDAC letter A3-228-EP-RJP-46, dated 16 January 1980, and therefore, is not included in this submittal. Please transfer your copy to your RADL ITEM 7-8 file, marking it as BOOK 4 of 25.

BOOK 5 - COLLECTOR FIELD FOUNDATIONS, CONSTRUCTION PACKAGE 5

|   |  |              |
|---|--|--------------|
| 1 | Computer Printout (Heliostat Foundations)    | CO-C-47      |
| 2 | Design Sheets                                |              |
|   | Heliostat                                    | D-1 thru 12  |
|   | Miscellaneous Collector<br>Field Foundations | D-13 thru 18 |



MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM | PAGE   |
|------|--|
| 3    | Reference Sheets   |
|      | Heliostat Loading  |
|      | Test Data From WCC   |
|      | STMPO Design Criteria  |
|      | BCS Camera Criteria  |
|      | Miscellaneous Foundation   |
|      | Input  |
|      | RADL 2-12  |
|      | Anchor Bolt Deflections and  |
|      | Stress   |
|      | R-1  |
|      | R-2 thru R-3   |
|      | R-4 thru R-7   |
|      | R-8 thru R-9   |
|      | R-10 thru R-13   |
|      | R-14 thru R-63   |
|      | R-64 thru R-81   |
| 4    | MDAC Collector Field Design<br>and Plant Power Calculation                                       |
|      | --   |
|      | BOOK 6 - THERMAL STORAGE AND<br>PLANT SUPPORT SUBSYSTEM FOUNDA-<br>TIONS, CONSTRUCTION PACKAGE 7 |
| 1    | Thermal Storage Control Building<br>Foundation   |
|      | TCF-D-1 thru 2   |
| 2    | Thermal Storage Electrical<br>Equipment Building Foundation                                      |
|      | TEF-D-1 thru 2   |
| 3    | Raw/Service Water Pump<br>Building Foundation  |
|      | RPF-D-1 thru 7   |
| 4    | Secondary Fire Pump Building<br>Foundation   |
|      | SPF-D-1 thru 7   |
| 5    | Pipe Trench  |
|      | DT-D-1 thru 11   |
| 6    | Drainage Trench  |
|      | DT-D-1 thru 3  |
| 7    | Thermal Storage Subsystem<br>(TSS) Equipment Foundations   |
|      | TSE-D-1 thru 19  |
| 8    | Thermal Storage Subsystem<br>(TSS) Equipment Foundation<br>Reference                             |
|      | TSE-R-1 thru 3   |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM |   | PAGE            |
|------|---|-----------------|
| 9    | TSS Containment Foundation  | TSC-D-1 thru 2  |
| 10   | TSS Retaining Wall  | TSW-D-1 thru 15 |
| 11   | TSS Sump Structure  | TSS-D-1 thru 10 |
| 12   | TSS Tank Foundation   | TST-D-1 thru 11 |
| 13   | TSS Tank Foundation Reference   | TST-R-1 thru 10 |
| 14   | Blowdown Tank Foundation  | BT-D-1 thru 3   |
| 15   | Blowdown Tank Foundation<br>Reference                                   | BT-R-1          |
| 16   | TSS Pipe Support Foundations  | PRF-D-1 thru 62 |
| 17   | TSS Pipe Support Foundations<br>Computer Output                         | PRFC-1 thru 117 |
|      | <b>BOOK 7 - RECEIVER TOWER FOUNDATION, CONSTRUCTION PACKAGE 7A</b>      |                 |
| 1    | Design Calculations   | RF-D-1 thru 18  |
| 2    | Reference Sheets  |                 |
|      | Trade Study   | RF-R-1 thru 2   |
|      | Drilled Pier Alternate  | RF-R-3 thru 6   |
|      | <b>BOOK 8 - PIPING AND MECHANICAL EQUIPMENT, CONSTRUCTION PACKAGE 9</b> |                 |
| P3-1 | Steam Systems   | --              |
|      | <b>BOOK 9 - PIPING AND MECHANICAL EQUIPMENT CONSTRUCTION PACKAGE 9</b>  |                 |
| P3-2 | Condensate Systems  |                 |
| P3-6 | Water Treatment   |                 |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM      |  | PAGE |
|-----------|--|------|
| P3-8      | Instrument and Service Air   |      |
| P3-9      | Fire Protection  |      |
|           | BOOK 10 - PIPING AND MECHANICAL<br>EQUIPMENT, CONSTRUCTION PACKAGE 9 |      |
| P3-10     | Liquid Waste and Drains  | --   |
| P3-11     | Service Water  | --   |
| P3-13     | Miscellaneous Subsystems   | --   |
| RS & TSS  | Receiver and Thermal Storage<br>Systems                              | --   |
|           | BOOK 11 - PIPING, CONSTRUCTION<br>PACKAGE 9                          |      |
| 1         | General Calculations   | --   |
| 2         | General Seismic Calculations   | --   |
| 3         | Equipment Loads  | --   |
| 4         | Lines AS-10, FW-10 and UG-1<br>Hand Calculations                     | --   |
|           | BOOK 12 - CONDENSATE PIPING,<br>CONSTRUCTION PACKAGE 9               |      |
| Line CO-1 | R.S. Flash Tank Drain (2"-CO-<br>1-FBA)                              | --   |
| Line CO-3 | TSS Heater Drain (4"-CO-3-KBA)                                       | --   |
| Line CO-4 | TSS Heater Drain (4"-CO-4-KBA)                                       | --   |
| Line CO-5 | TSS Flash Tank Drain EPGS<br>(4"-CO-5-BBA)                           | --   |
| Line CO-6 | R.S. Panel Condensate Drain<br>(3" & 1-1/2"-CO-6-BBA)                | --   |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM       |  | PAGE |
|------------|--|------|
| Line CO-15 | TSS Flash Tank Drain to Pump<br>(6"-CO-15-BBA)                                       | --   |
|            | BOOK 13 - RECEIVER FEEDWATER<br>PIPING, CONSTRUCTION<br>PACKAGE 9                    |      |
| Line FW-1  | Receiver Feedwater to Internal<br>Anchor (4"-FW-2-MBA)                               | --   |
| Line FW-2  | Receiver Feedwater to Heater and<br>Interface 2I (4"-FW-2-MBA & 2-1/2"-<br>FW-9-MBA) | --   |
|            | BOOK 14 - MAIN STEAM PIPING,<br>CONSTRUCTION PACKAGE 9                               |      |
| Line MS-1  | Main Steam - Receiver to Internal<br>Anchors (6"-MS-2, 3-QEB)                        | --   |
| Line MS-2  | Main Steam - Internal Anchor to<br>Turbine (6"-MS-2-QEB)                             | --   |
|            | BOOK 15 - MAIN STEAM PIPING,<br>CONSTRUCTION PACKAGE 9                               |      |
| Line MS-3  | Main Steam - Desuperheater Branch<br>(6"-MS-3-QEB)                                   | --   |
| Line MS-4  | Main Steam - Internal Anchor to<br>Condenser (10"-MS-7-FEA)                          | --   |
| Line MS-5  | Main Steam - TSS Exchanger Branch<br>(8"-MS-4-KBA)                                   | --   |
|            | BOOK 16 - STEAM PIPING,<br>CONSTRUCTION PACKAGE 9                                    |      |
| Line ST-5  | Admission Steam (ST-5, 6 & 8-FBA)  | --   |
| Line ST-7  | 2"-ST-7-FBA  | --   |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM       |   | PAGE |
|------------|---|------|
| Line ST-16 | 2"-ST-16-FBA<br><br>BOOK 17 - THERMAL OIL PIPING,<br>CONSTRUCTION PACKAGE 9   | --   |
| Line TO-4  | TSS Oil Charging System Feed<br>(8"-TO-4-BBA)   | --   |
| Line TO-5  | TSS Oil Charging System Feed<br>(8"-TO-5-BBA)   | --   |
| Line TO-12 | TSS Oil - Extraction System Feed<br>(8"-TO-12-BBA)<br><br>BOOK 18 - THERMAL OIL PIPING,<br>CONSTRUCTION PACKAGE 9       | --   |
| Line TO-13 | TSS Oil - Extraction System Feed<br>(8"-TO-13-BBA)  | --   |
| Line TO-22 | TSS Oil Charging System<br>(TO-22, 23 & 24)<br><br>BOOK 19 - THERMAL OIL PIPING,<br>CONSTRUCTION PACKAGE 9              | --   |
| Line TO-10 | TSU Oil Extraction and Charging<br>(TO-3,9,10,11,21-BBA)<br><br>BOOK 20 - THERMAL OIL PIPING,<br>CONSTRUCTION PACKAGE 9 | --   |
| --         | TSU Oil Extraction and Charging<br><br>BOOK 21 - VENT LINE PIPING,<br>CONSTRUCTION PACKAGE 9                            | --   |
| Line VT-1  | Receiver Flash Tank Vent Line<br>(4", 2-1/2", 10"-VT-1, 12,11-KEB,<br>FEA)  | --   |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

| ITEM      |   | PAGE     |
|-----------|---|----------|
| Line VT-4 | TSS Flash Tank Vent<br>(6"-VT-4-FBA)                              | --       |
|           | BOOK 22 - PSS CALORIA MAKEUP<br>TANK, CONSTRUCTION PACKAGE 10     |          |
| 1         | Sizing of Vent  | 1 thru 4 |
| SHT P25-4 | Caloria Makeup Tank Drawing                                       | --       |
|           | BOOK 23 - PSS FIELD ERECTED<br>TANKS, CONSTRUCTION<br>PACKAGE 10A |          |
| SHT P25-1 | Demineralized Water Tank<br>Drawing                               | --       |
| 1         | Mirror Wash Water Tank Sizing                                     | 1 thru 3 |
| 2         | Resizing of Raw Water Storage<br>Tank                             | 1 thru 2 |
| SHT P25-2 | Raw Water Storage Tank Drawing                                    | --       |
| --        | Reference Letters   | --       |
| Figure 1  | Service Water Requirements,<br>Daytime Operations                 | --       |
| Figure 2  | Preliminary Raw/Service Water<br>System                           | --       |
| 3         | Sizing Raw Water Service Tank<br>Pumps and Piping                 | 1 thru 8 |
|           | BOOK 24 - PLANT ELECTRICAL,<br>CONSTRUCTION PACKAGE 11            |          |

MASTER TABLE OF CONTENTS FOR PSS FINAL  
DESIGN CALCULATIONS (RADL ITEM 7-8)

ITEM

PAGE

BOOK 25 - COLLECTOR FIELD  
ELECTRICAL, CONSTRUCTION  
PACKAGE 11A

Note: This document was previously submitted by MDAC Letter A3-228-EP-RJP-262, dated 7 March 1980 and therefore is not included in this submittal. Please transfer your copy to your RADL ITEM 7-8 file, marking it as BOOK 25 of 25.

BOOK-26-MDAC GENERAL ANALYSIS AND  
BACKGROUND DATA

- 1 Plant Process and Preliminary Component Requirements
- 2 Receiver Subsystem Calculations
- 3 Thermal Storage Subsystems Calculations
- 4 Analysis of Plant Cost Reduction Options
- 5 Collector Field Design and Plant Power Calculations
- 6 Miscellaneous Plant Calculations





12/16/79  
1 OF 10

## AUXILIARY STEAM NETWORK SIZING REQUIREMENTS

### OBJECTIVE


DEFINE AUXILIARY STEAM NETWORK PIPING AND CONTROL VALVE REQUIREMENTS. CONSIDERATION SHALL BE GIVEN TO FEEDWATER HEATER BLANKETING, DEAERATOR PEGGING, TURBINE SEALS, AND MISC PIPING/EQUIPMENT HEATING AND CONDITIONING. DEFINE DESUPERHEATER REQUIREMENTS.

### DATA SOURCE :

HEAT AND MASS BALANCE ANALYSIS  
RADL 2-15 DEC 1979

# AUXILIARY STEAM NETWORK

12/16/79  
JER  
2 OF 10



AUXILIARY STEAM SIZING ANALYSIS

I. CROSS TIE TO MAIN STEAM LINE

SUPPLY TO

1. DEAERATOR (PEG TO 20psia)
2. No. 4 HEATER
3. TURBINE SEAL

REFERENCE CASE

RECEIVER STAND ALONE  
RECEIVER STAND ALONE  
GE INPUT  
(MAY NOT PASS THROUGH  
AUX NETWORK)

1. DEAERATOR PEGGING

ADJUST DATA IN RECEIVER STAND ALONE TO ACCEPT  
345 °F, 75psia STEAM <sup>h=1202.6 BTU/LB</sup> (UP FROM 75psia SAT STEAM  
IN RECEIVER STAND ALONE)

FROM RUN → 5334 LB/HR

h<sub>IN</sub> = 1181.9 BTU/LB  
h<sub>OUT</sub> = 196 BTU/LB

$$\dot{m} = \dot{m}_{RUN} \left( \frac{\Delta h_{RUN}}{\Delta h_{ACTUAL}} \right)$$

$$= 5334 \left( \frac{1181.9 - 196}{1202.6 - 196} \right) = \text{[REDACTED]}$$

2. No. 4 HEATER

MAKE SAME ADJUSTMENT AS ABOVE

FROM RUN → 5757 LB/HR

h<sub>IN</sub> = 1181.9 BTU/LB  
h<sub>OUT</sub> = 98.9 BTU/LB

$$\dot{m} = \dot{m}_{RUN} \left( \frac{\Delta h_{RUN}}{\Delta h_{ACTUAL}} \right)$$

$$= 5757 \left( \frac{1181.9 - 98.9}{1202.6 - 98.9} \right) = \text{[REDACTED]}$$


### 3. TURBINE SEALS

- GE CURRENT PLAN IS TO DRAW TURBINE SEAL STEAM FROM THROTTLE STEAM AND ADMISSION STEAM LINES
  - THERE MAY BE SOME INTEREST IN DRAWING STEAM THROUGH AUX NETWORK FOR THE TURBINE
  - LOW TEMP CONDENSER MAY RESULT IN ADDED AUX STEAM CAPABILITY
  - MAY NEED TO PEG DEAERATOR AT  $P > 20 \text{ psia}$
- ALLOCATE AN EXTRA 1300 LB/HR CAPABILITY TO AUX STEAM SYSTEM (PER CONVERSATION WITH PETE DOERSAM)

### TOTAL STEAM DUTY

- DEAERATOR PEGGING = 5224 LB/HR @ 345°F 75psia
- NO. 4 HTR STEAM = 5649 LB/HR @ 345°F 75psia
- TURBINE SEALS + CONTINGENCY = 1300 LB/HR @ 345°F 75psia

TOTAL [REDACTED] - [REDACTED]



1. RATED RECEIVER STEAM, 121 °F (88.9 BTU/LB) SPRAY WATER  
950 °F 1461 BTU/LB

$$\dot{m}_s + \dot{m}_c = \dot{m}_{TOT} = 12173 \text{ LB/HR}$$

$$h_s \dot{m}_s + h_c \dot{m}_c = h_T \dot{m}_T$$

$$h_s \dot{m}_s + h_c (\dot{m}_{TOT} - \dot{m}_s) = h_T \dot{m}_{TOT}$$

$$\dot{m}_s (h_s - h_c) = \dot{m}_{TOT} (h_T - h_c)$$

$$\dot{m}_s = \dot{m}_{TOT} \left( \frac{h_T - h_c}{h_s - h_c} \right) = 12173 \left[ \frac{1202.6 - 88.9}{1461 - 88.9} \right]$$

$$\dot{m}_s = 9880.5 \text{ LB/HR}$$

$$\dot{m}_c = 2292 \text{ LB/HR}$$

2. DERATED RECEIVER STEAM, 121 °F (88.9 BTU/LB) SPRAY WATER  
(650 °F 1243.4 BTU/LB)

$$\dot{m}_s = 12173 \left[ \frac{1202.6 - 88.9}{1243.4 - 88.9} \right]$$

$$\dot{m}_s = 11742.8 \text{ LB/HR}$$

$$\dot{m}_c = 430 \text{ LB/HR}$$

$$\dot{m}_s = 13554 \text{ LB/HR}$$

$$\dot{m}_c = 496 \text{ LB/HR}$$

$$\dot{m}_T = 14050 \text{ LB/HR} \Rightarrow$$

**CORRECTION**

SINCE RECEIVER STAND ALONE AT DERATED STEAM INVOLVES A HIGHER FLOW CAPABILITY (130,000 LB/HR) VS THE 112,625 MAX FOR RATED STEAM, MORE WATER MUST BE HEATED BY THE RATIO OF  $\frac{130,000}{112,625}$  (ESTIMATED)

~~1300 LB/HR TURBINE + CONDENSER~~  
~~6126 LB/HR DEAERATOR~~

## II CROSS TIE TO ADMISSION STEAM LINE

| <u>SUPPLY TO</u>             | <u>REFERENCE CASE</u>                                 |
|------------------------------|---|
| 1. DEAERATOR (PEG TO 20PSIA) | 6-2 <sup>R-1</sup> , OR LOW FLOW MODES 4 <sup>*</sup> |
| 2. No 4 HEATER               | " " "   |
| 3. TURBINE SEAL              | GE INPUT (MAY NOT PASS THROUGH AUX NETWORK)           |

### 1. DEAERATOR PEGGING $p = 20 \text{ psia}$

ADJUST DATA IN MODE 6-2 FOR  $345^\circ\text{F}$ ,  $65 \text{ psia}$  STEAM

$(h = 1204.6 \text{ BTU/LB})$   $h_{out} =$

FROM MODE 6-2

$$\dot{m}_{RUN} = \dot{m}_{TO\ DESUP} + \dot{m}_{COND} = 2530.3 + 140.7 = 2671 \text{ LB/HR}$$

$$h_{RUN} = \frac{\dot{m}_{TO\ DESUP} h_{TO\ DESUP} + \dot{m}_{COND} h_{COND}}{\dot{m}_{RUN}}$$

$$= \frac{(2530.3)(1263.1) + (140.7)(77.1)}{2671} = 1200.6 \text{ BTU/LB}$$

$$\dot{m} = \dot{m}_{RUN} \left( \frac{\Delta h_{RUN}}{\Delta h_{ACTUAL}} \right)$$

$$= 2671 \left( \frac{1200.6 - 196.0}{1204.6 - 196.0} \right) = \text{2660 LB/HR ADJUSTED}$$

### 2. No. 4 HEATER

(NO AUX STEAM DEMAND)

\* LOW MODE 4 OR 7 TURBINE FLOWS NO LONGER SIGNIFICANT IF NOT PEGGING THE DEAERATOR AT  $248^\circ\text{F SAT.}$

### 3. TURBINE SEALS


- GE PLANS TO USE ADMISSION STEAM LINE DIRECTLY BUT MAY UTILIZE AUX TIE IN
- ADD CONTINGENCY FOR COLD CONDENSER, LOWER TURBINE LOAD, AND POSSIBLE NEED TO PEG DEAERATOR AT > 29

CONTINGENCY = 1300 LB/HR

### TOTAL STEAM DUTY

- DEAERATOR 2660 LB/HR @ 345°F 65psia (1204.6 BTU/LB)
- No 4 HTR 0
- TURBINE SEALS + CONTINGENCY 1300 LB/HR @ 345°F 65psia (1204.6 BTU/LB)

TOTAL






$$m_s = m_{TOT} \left[ \frac{h_T - h_c}{h_s - h_c} \right]$$

$$= 3960 \text{ LB/HR} \left[ \frac{1204.6 - 77.1}{1263.1 - 77.1} \right]$$



~~3960 LB/HR~~

~~3960 LB/HR~~

MAX DUTY FROM DERATED RECEIVER  
STEAM  
(RECEIVER STAND ALONE)




14050 LB/HR  
75 PSIA  
345°F  
1202.6 BTU/LB



496 LB/HR  
115 PSIA  
121°F  
88.9 BTU/LB


AUXILIARY STEAM SYSTEM



|             |       |  |  |  |  |
|-------------|-------|--|--|--|--|
| REVISION No |       |  |  |  |  |
| DATE ISSUED | 12/17 |  |  |  |  |



MAX DUTY FROM RATED RECEIVER  
STEAM  
(RECEIVER STAND ALONE)




AUXILIARY STEAM SYSTEM

NORMALLY OPEN  
 NORMALLY CLOSED

|              |       |  |  |  |  |
|--------------|-------|--|--|--|--|
| REVISION No. |       |  |  |  |  |
| DATE ISSUED  | 12/17 |  |  |  |  |

MAX DUTY FROM ADMISSION  
STEAM  
(LOW FLOW MODE 6 OPERATION)



AUXILIARY STEAM SYSTEM

NORMALLY OPEN  
 NORMALLY CLOSED

|              |       |  |  |  |  |
|--------------|-------|--|--|--|--|
| REVISION No. |       |  |  |  |  |
| DATE ISSUED  | 12/17 |  |  |  |  |

12/16/79  
1 OF 4

## CONDENSER DUMP NETWORK

### OBJECTIVE


- DEFINE CONDENSER DUMP NETWORK REQUIREMENTS INCLUDING
  - THE STEAM DUMP DRAG VALVE
  - DESUPERHEATER
  - SPRAY WATER VALVE
  - DUMP LINE SIZE
  - RECEIVER FLASH TANK STEAM VALVE

### DATA SOURCE:


HEAT AND MASS BALANCE ANALYSES  
RADL 2-15 DEC 1979

# CONDENSER DUMP NETWORK

12/16/79  
2 OF 4



• TURBINE TRIP — MAX FLOW RATED RECEIVER STEAM




• THERMAL STORAGE CHARGE TRIP

## MAX FLOW DESIGN CASES

\* ASSUMES 3 1/2" Hg CONDENSER PRESSURE DURING THIS OPERATION

# CONDENSER DUMP NETWORK

12/16/79  
3 OF 4




• MAX DUTY FROM RECEIVER FLASH TANK

11

# CONDENSER DUMP NETWORK

12/16/79

4 OF 4



## MINIMUM CONDENSER DUMP NETWORK DUTY

- THIS SET OF CONDITIONS REPRESENT A TYPICAL "MINIMUM DUTY" SITUATION FOR THE CONDENSER DUMP NETWORK. CARE MUST BE EXERCISED TO ENSURE THAT THE DESUPERHEATER AND CONDENSATE SPRAY WATER CONTROL VALVE HAVE SUFFICIENT TURNDOWN CAPABILITY TO ACCOMODATE THIS TYPICAL "MINIMUM DUTY". NOTE: WITH THE EXCEPTION OF PERIODS WHEN THE PLANT IS IN A TURBINE TRIP, THERMAL STORAGE CHARGE LOOP TRIP, OR RECEIVER STAND ALONE MODE, THE NORMAL DUTY FOR THE CONDENSER DUMP NETWORK WILL BE OVER THE RANGE OF LOW TO MODERATE ( $< \frac{1}{2}$  MAX) FLOW.

THERMAL STORAGE FLASH TANK CIRCUIT

OBJECTIVE :

DEFINE BASIC CONTROL VALVE AND LINE SIZING  
REQUIREMENTS FOR THE FLASH TANK OUTLET  
STEAM AND CONDENSATE CIRCUITS

• CONDENSATE LEVEL CONTROL VALVES

LV-74 B      TO NO 2 HTR

LV-74D-1 }  
LV-74D-2 }      TO CONDENSER

• STEAM PRESSURE CONTROL VALVES

PV-636      FLASH TANK OUTLET


PV-640      TO CONDENSER

DATA SOURCE :

HEAT AND MASS BALANCE ANALYSIS

RADL 2-15      DEC 1979

FIGURE 2  
THERMAL STORAGE FLASH TANK CIRCUIT





THERMAL STORAGE FLASH TANK CIRCUIT

1. CONDENSATE CIRCUIT

| (13I) | OPERATING |      | DESIGN |       |
|-------|-----------|------|--------|-------|
|       | MAX       | MIN  |        |       |
|       | 117500    | 5720 | 117500 | LB/HR |
|       | 135       | 135  | 165    | PSIG  |
|       | 358       | 358  | 360    | °F    |
| (17)  | 117500    | 5720 | 117500 |       |
|       | 150       | 150  | 180    |       |
|       | 358       | 358  | 360    |       |

LV 74B (V-17)

- MAX FLOW = 117500 LB/HR
- MIN FLOW = 5876 LB/HR

SOURCE

MODE 5-1  
MIN WATER FLOW  
DURING CHARGE

LV 74D (V-14)

- MAX FLOW = 117500 LB/HR
- MIN FLOW =

## 2. VAPOR CIRCUIT

(18I) TOTAL (MAX) VAPOR = 7IA + 11I + 14I + 12I

7IA - 6060 LB/HR, 460°F, 150 psia, 1252.9 BTU/LB

11I + 14I - 130,000 LB/HR, 435°F, 1355 psia, 413.3 BTU/LB

12I - 11000 LB/HR, 480°F, 150 psia, 1263.6 BTU/LB

$$\bar{h} = \frac{\dot{m}_1 h_1 + \dot{m}_2 h_2 + \dot{m}_3 h_3}{\dot{m}_1 + \dot{m}_2 + \dot{m}_3}$$

$$= \frac{(6060)(1252.9) + (130000)(413.3) + (11000)(1263.6)}{6060 + 130000 + 11000}$$

$$\bar{h} = 511.5 \text{ BTU/LB}$$



@ 150 psia

$$h_f = 330.5, \quad h_g = 1194.1, \quad h_{fg} = 863.6 \text{ BTU/LB}$$

$$x = .20959$$

$$\dot{m}_{\text{STEAM}} = 30822 \text{ LB/HR}$$

$$\dot{m}_{\text{WATER}} = 116,238 \text{ LB/HR}$$



FROM  
STEAM  
GENERATORS  
400 PSIA  
530°F  
 $h = 1264.6 \text{ BTU/LB}$   
(11,000 LB/HR)  
— 5,500 LB/HR EACH —

12/12/79  
1 OF 9

## RECEIVER FLASH TANK CIRCUIT

### OBJECTIVE :

DEFINE BASIC CONTROL VALVE AND LINE SIZING  
REQUIREMENTS FOR THE FLASH TANK OUTLET  
STEAM AND CONDENSATE CIRCUITS.

- CONDENSATE LEVEL CONTROL VALVES

LV-74 A TO No 2 HTR

LV-74 C TO CONDENSER

- STEAM PRESSURE CONTROL VALVES

PV-2002 FLASH TANK OUTLET

PV-649 TO DEAERATOR

PV-XXX (V-5) TO STEAM DUMP


### DATA SOURCE :

HEAT AND MASS BALANCE ANALYSIS

RADL 2-15 DEC 1979

FIGURE 1

RECEIVER FLASH TANK CIRCUIT



RECEIVER FLASH TANK CIRCUIT

1. CONDENSATE LEG

| (R18) | OPERATING |      | DESIGN | LB/HR |
|-------|-----------|------|--------|-------|
|       | MAX       | MIN  |        |       |
|       | 40,000    | 4000 | 40000  |       |
|       | 485       | 385  | 585    | PSIG  |
|       | 467       | 200? | 486    | OF    |

| (18) |                    |                    |                    |
|------|--------------------|--------------------|--------------------|
|      | 40,000             | 4000               | 40000              |
|      | 485 + gravity head | 385 + gravity head | 585 + gravity head |
|      | 467                | 200                | 486                |

LV 74A (V-16)

- MAX FLOW = 23811 LB/HR
- MIN FLOW = 4000 LB/HR

SOURCE  
REC START #918

MIN FLASH TANK  
FLOW  
~ 6:1 TURN DOWN

LV 74C (V-15)

- MAX FLOW = 40,000 LB/HR
- MIN FLOW = 4000 LB/HR

FLASH TANK LIMIT  
FLASH TANK LIMIT

12/12/79  
4 OF 9

## 2. VAPOR LEG

(RIG)

| OPERATING                      |                | DESIGN  |       |
|--------------------------------|----------------|---|-------|
| MAX                            | MIN            |   |       |
| 40000                          | 4000           | 40000   | LB/HR |
| 470*                           | 365            | 585   | PSIG  |
| (15psi ΔP Across VALVE PV2002) |                |   |       |
| 960                            | 439            | 960   | °F    |
|                                | SAT AT 380psia | (SHORT DURATION LINE OPERATION - DON'T COMPOUND DESIGN CONSERVATISM BY GOING TO 1010°F) |       |

(4)

|                 |     |      |       |
|-----------------|-----|------|-------|
| 6285            | 800 | 6285 | LB/HR |
| 365             | 365 | 585  | PSIG  |
| 660             | 439 | 660  | °F    |
| (TEMP OVERRIDE) |     |      |       |

### PV 649

- MAX FLOW = 6285 LB/HR (REC STARTUP - 40,000 LB/HR STEAM)
- MIN FLOW = 800 LB/HR (DESIRABLE LOWER LIMIT - ARBITRARY)
- TEMP 660°F (CONTROLLED BY TEMP OVERRIDE TO PROTECT DA)


### V-5

- ACCOMMODATE FULL VAPOR LEG FLOW - 40,000 LB/HR
- MIN VALUE 4000 LB/HR (MIN FLASH TANK)

(1) ~~6285 LB/HR + 25% ADDITIONAL FLOW TO AID DEAERATION DURING (REC STARTUP) MODE G OPERATION~~

(2) MEN TO DISPLACE AUX STEAM AS SOON AS POSSIBLE

MAIN STEAM NETWORK



| Circled Label | OPERATING |        | DESIGN |        |
|---------------|-----------|--------|--------|--------|
|               | MAX       | MIN    |        | LB/HR  |
| RI3           | 135141    | 31716  | 135141 | LB/HR  |
|               | 1565      | 1455   | 1775   | PSIG   |
|               | 960       | 960    | 1010   | OF     |
| I             | 112300    | 30000  | 120000 |        |
|               | 1450      | 1450   | 1775   |        |
|               | 950       | 950    | 1010   |        |
| II            | 105,000   | 130000 | 5250   | 130000 |
|               | 1450      | 1450   | 1450   | 1775   |
|               | 950       | 650    | 950    | 1010   |



9/27/79  
6 OF 9


VALVE (V1) SIZING DATA

WORKSHEET  
10-071

| FRANK | m      | P <sub>REF</sub> | T <sub>FT</sub> | h <sub>FT</sub> | V <sub>P<sub>OUT</sub></sub> | P <sub>OUT</sub> | T <sub>SUP</sub> | C <sub>v</sub> | LINE VELO. |
|-------|--------|------------------|-----------------|-----------------|------------------------------|------------------|------------------|----------------|------------|
| 500   | 40,000 | 382              | 467             | 1204            | 1.133<br>410PSIA             | 475              | 0                | 83.5           |            |
|       | 20,000 |                  |                 |                 | 1.191<br>390PSIA             | 398              | ↓                | 31.5           |            |
|       | 4,000  |                  |                 |                 | 1.222<br>380PSIA             | 382              | ↓                | 5.9            |            |
|       | 500    |                  |                 |                 | 1.222<br>380PSIA             | 382              | ↓                | 0.74           |            |
| 500   | 40000  | 382              | 960             | 1496            | 1.909<br>@ 420PSIA           | 488              | 493              | 235            |            |
|       | 20000  |                  |                 |                 | 2.083<br>@ 395               | 411              | ↓                | 45             |            |
|       | 4,000  |                  |                 |                 | 2.166<br>@ 380               | 383              | ↓                | 7.8            |            |
|       | 500    |                  |                 |                 | 2.166<br>@ 380               | 382              | ↓                | 0.99           |            |
| 500   | 40000  | 382              | 750             | 1385            | 1.674<br>410PSIA             | 475              | 283              | 146            |            |
|       | 20000  |                  |                 |                 | 1.763<br>390PSIA             | 406              | ↓                | 39             |            |
|       | 4000   |                  |                 |                 | 1.811<br>380PSIA             | 383              | ↓                | 7.1            |            |
|       | 500    |                  |                 |                 | 1.811<br>380PSIA             | 382              | ↓                | .88            |            |

7 OF 9

### VALVE COEFFICIENT DATA FOR RECEIVER FLASH TANK OUTLET STEAM LINE




PREF  
400 psia  
382 psia  
350 psia  
300 psia  
200 psia  
100 psia

FLASH TANK COND  
P = 500 psia  
T = 750 °F


VALVE COEFFICIENT (CV)

STEAM FLOWRATE  
(10<sup>3</sup> LB/HR)



8 of 9

VALVE COEFFICIENT DATA  
FOR RECEIVER FLASH  
TANK OUTLET STEAM LINE




P REF  
400 psia  
382 psia  
350 psia  
300 psia  
200 psia  
100 psia


FLASH TANK COND.  
P = 500 psia  
T = 467°F (SAT STEAM)

STEAM FLOWRATE  
(10<sup>3</sup> LB/HR)

VALVE COEFFICIENT (CV)



VALVE COEFFICIENT DATA  
FOR RECEIVER FLASH  
TANK OUTLET STEAM LINE




VALVE COEFFICIENT (CV)

FLASH TANK COND.  
P=500 PSIA  
T=960 °F

STEAM FLOWRATE  
(10<sup>3</sup> LB/HR)

PREF  
400 PSIA  
382 PSIA  
350 PSIA  
300 PSIA  
200 PSIA  
100 PSIA



A3-255-EP-RES-641  
July 23, 1979

MEMORANDUM

Subject: CONDENSER DUTY - NORMAL AND CONDENSER DUMP OPERATION

To: J. E. Raetz, A3-228; R. G. Riedesel, A3-202

From: R. E. Snyder, A3-255

Copies to: K. R. Knox, R. J. Perkins, E. J. Riel, E. J. Tomei

The purpose of this memo is to:

- Document the condenser duty during normal operation for the worst case operating modes.
- Present the results of an analysis showing the condenser duty during condenser dumps with the corresponding condenser pressure and temperature with no relief/valve flow for the worst case operating modes.
- Present the resulting receiver relief valve flow required to meet the maximum allowable condenser pressure of 5 in. Hg for the critical modes analyzed.

In general, turbine manufactures prescribe a maximum limit on turbine back-pressure (condenser pressure) of 5 in. Hg. The curve shown in Figure 2 summarizes the effect of condenser heat load on the condenser pressure. As the load increases so does the pressure. Both the maximum and design pressure and heat load are noted on the curve. This analysis uses the 5 in. Hg limitation and when this limit is exceeded any additional flow (or load) is vented overboard through the receiver relief valves. As soon as the back pressure requirements of the actual turbine to be purchased is known any changes will be incorporated in this study.

All data used in this analysis was obtained from the following report titled, 10 MWE Solar Thermal Central Receiver Pilot Plant Solar Facilities Design Integration Heat and Mass Balance Design Data, MDC G7842 dated April 1979. Run numbers referenced in this memo are identified in the above document. Operating modes are identified in Figure 1.

Condenser duty was analysed for worst case normal and condenser dump operation as follows:


- Mode 1 maximum flow case (Run 104-1) as a baseline. (TABLE I). Condenser pressure during normal operation was below design (2.5 in. Hg) and was below the maximum allowable during condenser dump.
- Mode 2 was not presented as condenser duty would be less than Mode 1 for normal operation and the same for condenser dump.



- Mode 3 (Run 304-5) was analysed to ensure that in its worst case limit it approached Mode 1 operation, (TSS flow goes to zero) see Table II.
- Mode 4 (Run 408-6) approaches the condenser design pressure during normal operation and potentially exceeds the maximum allowable pressure by more than 1 in. Hg (6.18 in. Hg), TABLE III. However, the condenser dump pressure control valve limits the condenser pressure to 5 in. Hg so that the upstream pressure will rise opening the receiver relief valves. The relief valve flow will be 23689 #/Hr.
- Mode 5 is not critical and was not included.
- Mode 6 is not critical and was not included.
- Mode 7 (Run 701-7) has the highest condenser duty during normal operation and potentially the highest during condenser dump, TABLE IV 40710.7 LB/HR relief valve flow is required to limit the condenser pressure to 5 in. Hg.

Figure 2 is a plot showing condenser pressure as a function of heat load. The control valve on the condenser will limit operation at or below the maximum condenser pressure line. Figure 3 shows receiver relief valve flow versus condenser load. The worst case condenser duty during a condenser dump is shown for the various modes. The Mode 1 and Mode 3 points are identical because in the worst case Mode 3 degrades to a Mode 1 case as the admission flow approaches zero.

For further information contact the undersigned on Extention 3220.



Ray Snyder

TABLE I

MODE 1 (RUN 104-1)

|  | WEIGHTFLOW (w)<br>LB/HR | ENTHALPY (h)<br>BTU/LB | LOAD (Q)<br>M-BTU/HR | CONDTEMP<br>OF | CONDRESS<br>IN-HG |
|--|-------------------------|------------------------|----------------------|----------------|-------------------|
| <u>NORMAL OPERATION</u>                    |                         |                        |                      |                |                   |
| THROTTLE STEAM                             | 115000                  |                        |                      |                |                   |
| ADMISSION STEAM                            | 0                       |                        |                      |                |                   |
| THERMAL STORAGE CHARGING<br>FLOW           | 0                       |                        |                      |                |                   |
| <u>CONDENSER DUTY</u>                      |                         |                        |                      |                |                   |
| TURBINE                                    | 83950.5                 | 1006.1                 | 78.024               |                |                   |
| No4 FEED HTR DRN                           | 8102.7                  | 86.9                   | .083                 |                |                   |
| LP END PKNGS                               | 650                     | 1444.3                 | .889                 |                |                   |
| FROM RESERVOIR                             | 1179.3                  | 1444.3                 | 1.613                |                |                   |
| TOTAL                                      |                         |                        | 80.609               | 105.1          | 2.251             |
| <u>RECEIVER TRIP</u>                       |                         |                        |                      |                |                   |
| <u>CONDENSER DUTY</u>                      |                         |                        |                      |                |                   |
| CONDENSER DUMP                             | 115000                  | 1465.4                 | 159.7                | 124.9          | 3.938             |
| CONDENSER MAX. ALLOW.<br>RELIEF VALVE FLOW | 0                       |                        |                      |                |                   |

TABLE II

MODE 3 (RUN 304-5)

|                         | WEIGHTFLOW (w)<br>LB/HR | ENTHALPY (h)<br>BTU/LB | LOAD (Q)<br>M-BTU/HR | CONDTEMP<br>OF | CONDPRESS<br>IN-HG |
|-------------------------|-------------------------|------------------------|----------------------|----------------|--------------------|
| <u>NORMAL OPERATION</u> |                         |                        |                      |                |                    |
| THROTTLE STEAM          | 90000                   |                        |                      |                |                    |
| ADMISSION STEAM         | 25000                   |                        |                      |                |                    |
| TS CHARGING FLOW        | 0                       |                        |                      |                |                    |
| <u>CONDENSER DUTY</u>   |                         |                        |                      |                |                    |
| TURBINE                 | 86950.3                 | 998.6                  | 80.136               |                |                    |
| No4 FEEDHTR DRN         | 8599.8                  | 86.9                   | .087                 |                |                    |
| LP END PKNGS            | 650                     | 1434.8                 | .883                 |                |                    |
| FROM RESERVOIR          | 1208.3                  | 1434.8                 | .1641                |                |                    |
| TOTAL                   |                         |                        | 82.747               | 105.6          | 2.286              |
| <u>RECEIVER TRIP</u>    |                         |                        |                      |                |                    |
| <u>CONDENSER DUTY</u>   |                         |                        |                      |                |                    |
| CONDENSER DUMP          | 90000                   | 1465.4                 | 124.983              |                |                    |
| TURBINE                 | 23801                   | 1024.4                 | 22.556               |                |                    |
| No4 FEEDHTR DRN         | 896.7                   | 86.8                   | .009                 |                |                    |
| LP END PKNGS            | 650                     | 1263.2                 | .771                 |                |                    |
| TOTAL                   |                         |                        | 148.319              | 122.0          | 3.643              |
| CONDENSER MAX. ALLOW    |                         |                        | 195.211              | 133.7          | 5                  |
| RELIEF VALVE FLOW       | 0                       |                        |                      |                |                    |



TABLE III

MODE 4 (RUN 408-6)

|                              | WEIGHTFLOW (w)<br>LB/HR | ENTHALPY (h)<br>BTU/LB | COND. LOAD<br>/QCond M-BTU/HR | CONDTEMP<br>OF | COND.PRESS<br>IN-HG |
|------------------------------|-------------------------|------------------------|-------------------------------|----------------|---------------------|
| <u>NORMAL OPERATION</u>      |                         |                        |                               |                |                     |
| THROTTLE STEAM               | 0                       |                        |                               |                |                     |
| ADMISSION STEAM              | 1086.25                 |                        |                               |                |                     |
| TS CHARGING FLOW             | 130000                  |                        |                               |                |                     |
| <u>CONDENSER DUTY</u>        |                         |                        |                               |                |                     |
| TURBINE                      | 70706.4                 | 964.7                  | 62.787                        |                |                     |
| No4 FEEDHTR DRN              | 15892.6                 | 86.9                   | .162                          |                |                     |
| LP END PKNGS                 | 650                     | 1263.2                 | .771                          |                |                     |
| TS CHG DRNS,WATER            | 117513.6                | 330.8                  | 29.86                         |                |                     |
| TOTAL                        |                         |                        | 93.58                         | 108.4          | 2.474               |
| <u>RECEIVER TRIP</u>         |                         |                        |                               |                |                     |
| <u>CONDENSER DUTY</u>        |                         |                        |                               |                |                     |
| CONDENSER DUMP               | 103932                  | 1465.4                 | 144.331                       |                |                     |
| TURBINE                      | 91960.3                 | 966.1                  | 81.793                        |                |                     |
| No4 FEEDHTR DRN              | 9458.9                  | 86.9                   | .096                          |                |                     |
| LP END PKNGS                 | 650                     | 1263.2                 | .771                          |                |                     |
| FROM RESERVOIR               | 941.3                   | 1263.2                 | 1.117                         |                |                     |
| TOTAL (NO RELIEF VALUE FLOW) |                         |                        | 228.108                       | 141.9          | 6.180               |
| CONDENSER MAX ALLOW          |                         |                        | 195.211                       | 133.7          | 5.                  |
| RELIEF VALUE FLOW            | 23689                   |                        | 195.211                       | 133.7          | 5.                  |

TABLE IV

## MODE 7 (RUN 701-7)

|                              | WEIGHTFLOW (w)<br>LB/HR | ENTHALPY<br>BTU/LB | LOAD ( Q )<br>M-BTU/HR | COND TEMP<br>°F | COND PRESS<br>IN-HG |
|------------------------------|-------------------------|--------------------|------------------------|-----------------|---------------------|
| <u>NORMAL OPERATION</u>      |                         |                    |                        |                 |                     |
| THROTTLE STEAM               | 30000                   |                    |                        |                 |                     |
| ADMISSION STEAM              | 85000                   |                    |                        |                 |                     |
| TS CHARGING FLOW             | 130000                  |                    |                        |                 |                     |
| <u>CONDENSER DUTY</u>        |                         |                    |                        |                 |                     |
| TURBINE                      | 75831.1                 | 981.2              | 68.593                 |                 |                     |
| No4 FEED HTR DRN             | 15568.8                 | 86.9               | .158                   |                 |                     |
| LP END PKNGS                 | 650                     | 1425.9             | .877                   |                 |                     |
| FROM RESERVOIR               | 1223.9                  | 1425.9             | 1.651                  |                 |                     |
| TOTAL                        |                         |                    | 96.039                 | 109.0           | 2.519               |
| <u>RECEIVER TRIP</u>         |                         |                    |                        |                 |                     |
| <u>CONDENSER DUTY</u>        |                         |                    |                        |                 |                     |
| CONDENSER DUMP               | 133784.3                | 1465.4             | 185.786                |                 |                     |
| TURBINE                      | 72103                   | 971.1              | 64.489                 |                 |                     |
| No4 FEEDHTR DRN              | 6036.3                  | 86.9               | .062                   |                 |                     |
| LP END PKNGS                 | 650                     | 1263.2             | .771                   |                 |                     |
| FROM RESERVOIR               | 537.6                   | 1263.2             | .638                   |                 |                     |
| TOTAL (NO RELIEF VALVE FLOW) |                         |                    | 251.746                | 147.8           | 7.172               |
| CONDENSER MAX ALLOW          |                         |                    | 195.211                | 133.7           | 5                   |
| RELIEF VALVE FLOW            | 40710.7                 |                    |                        | 133.7           | 5                   |

# STEADY STATE OPERATING MODES











FIGURE 1

37



CONDENSER PUMP  
CONDENSER LOAD LIMITATIONS

DESIGN CONDITIONS  
CONDENSER PRESSURE - 2.5 PSI  
TRAP HEIGHTS - 8 FT

CONDENSER PRESSURE - IN HG  
10  
9  
8  
7  
6  
5  
4  
3  
2  
1

MAXIMUM CONDENSER PRESSURE

DESIGN PRESSURE

DESIGN LOAD

MAXIMUM CONDENSER LOAD

DESIGN CONDENSER LOAD - MILLIONS BTU/HR  
100

100

MEMORANDUM

Subject: CONDENSER DUMP PERFORMANCE, OPERATING, AND SIZING REQUIREMENTS

To: R. G. Riedesel

From: J. E. Raetz

Copies to: C. B. Boehmer, P. I. Kawano, K. R. Knox, R. J. Perkins,  
E. J. Riel, R. E. Snyder

The purpose of this memorandum is to document the preliminary top level operating and sizing requirements for the condenser dump line and to indicate potential impacts on the condenser. These preliminary requirements shall be used as the basis of the preliminary design analysis and may be revised on the basis of results developed during that analysis.

The principal elements of the condenser dump line which are shown in Figure 1 include a turbine bypass line, pressure control valve, and desuperheating equipment as well as the indicated temperature and pressure sensing equipment. The condenser dump line would connect to the main steam line upstream of the turbine line isolation valve to allow for the dumping of either turbine main steam or thermal storage charging steam flows. The control valve reduces the steam pressure to a condition acceptable to the condenser. The desuperheater is required to reduce the steam to a saturated condition which can then be accommodated by the condenser. Condensate supply to the desuperheater is currently being taken from the outlet of the hotwell pump. This design for the condensate circuitry is tentative pending a more detailed analysis of the entire condenser dump line. If it is found that the local steam pressure at the desuperheater exceeds the condensate pressure available at the outlet of the hotwell pump, an additional higher head pump may be added for desuperheater operation or the required condensate may be supplied from the outlet of the receiver feed pump.

Performance and Operating Requirements

The condenser dump line shall be designed to satisfy the following performance and operating requirements:

- 1) Control and ramp the receiver steam back pressure\* from 380 psia to 1465 psia during receiver startup at a total steam flow rate of 30,000 - 60,000 lb/hr. (steam enthalpy range of 1336 - 1461 BTU/LB). - Max duration 20 min, minimum duration 5 min.

\* Measured by the condenser dump line pressure sensor


- 2) Control and ramp the receiver steam back pressure \* downward from 1465 psia to 380 psia during receiver shutdown at a total steam flow rate of 30,000 to 60,000 lb/hr. (steam enthalpy range 1461-1336 BTU/lb) - max duration 20 min, minimum duration 2 min.
- 3) Maintain receiver back pressure \* at 1465 + 200 - 100 psia during a turbine trip at a steam flow rate of 30,000 - 115,000 lb/hr. (nominal steam conditions: 1465 psia, 950°F, 1461 BTU/LB) - max duration 20 min, minimum duration 2 min.
- 4) Maintain receiver back pressure \* at 1465 + 200 - 100 psia during a trip of thermal storage charging equipment for nominal steam conditions of:
  - rated steam  
950°F, 1465 psia, 105,000 - 30,000 lb/hr
  - derated steam  
650°F, 1465 psia, 130,000 - 30,000 lb/hr
  - max duration 20 min, minimum duration 2 min
- 5) Control receiver back pressure \* during stand alone receiver operation with steam conditions of:
  - rated steam TBD\*  
950°F, 1465 psia, 30,000 - ~~115,000~~ lb/hr
  - derated steam TBD\*  
650°F, 1465 psia, 30,000 - ~~130,000~~ lb/hr
  - max duration 8 hr

Estimated Condenser Impacts

The potential impacts of the first four requirements on condenser duty and condenser pressure have been defined on a preliminary basis to assess the effects of the dump line flow on condenser/turbine design and operation. Figure 2 illustrates the maximum duty and pressure anticipated during conditions defined by Requirements 1 and 2 above for steam flow rates of 30,000 and 60,000 lb/hr. The data contained in the figure assumes that the dump line flows are superimposed on the condenser duty experienced during a maximum flow Mode 6 operation -  $83.8 \times 10^6$  BTU/HR - which could be occurring during a receiver startup or shutdown. It is seen that for a 60,000 lb/hr dump flow, a maximum condenser pressure of 4.1 in Hg would exist. The corresponding pressure for a 30,000 lb/hr dump is 3.05 in HG.

Figure 3 illustrates the maximum impact of the trip conditions defined by Requirements 3 and 4 above on the condenser duty and pressure. For these conditions which could be produced during Modes 1, 2, and 5, the condenser pressure would be maintained in the range of 3.5 to 4.0 in Hg. Trip conditions of this type which occurred during Mode 4 or 7 operation could result in excessive condenser pressures under the worst case conditions and should be disallowed in the trip logic network. During Mode 4 operation for example where both the TS charge rate and turbine flow (from admission steam) are at their maximum levels, a total heat rejection duty requirement in excess of  $230 \times 10^6$  BTU/HR could be realized by a trip of the TS charging flow. This would result in a condenser pressure in excess of 6 in Hg and may cause other trip actions to be initiated. As a result, during Mode 4 or Mode 7 operation, the use of the condenser dump line should be limited by limitations on the condenser pressure which will be established by condenser and turbine suppliers.

\* NOT TO BE SIZING DRYER FOR THE HEAT REJECTION SYSTEM



43

FIG 1 DESIGN OF CONDENSER DUMP CIRCUIT



FIG 2 IMPACT OF RECEIVER STARTUP/SHUTDOWN LOAD ON CONDENSER





FIG. 3. IMPACT OF TURBINE OR TS TRIP ON CONDENSER LOAD AND PRESSURE



(3)

A3-228-JER-EP-465  
June 4, 1979

The impact on the condenser of using the condenser dump line for extended stand alone receiver operation (Requirement 5 above) was not estimated because extended periods of operation in that manner would cause an increase in the circulating water return temperature which can significantly influence condenser performance.. The temperature rise and the rate at which it occurs depend on the cooling tower capacity and the total volume of water in the circulating water system.

*J. E. Raetz*

J. E. Raetz

SFDI CONTROL VALVE REQUIREMENTS

12/16/79  
1 OF 53

OBJECTIVE :

DEFINE PRELIMINARY CONTROL DESIGN AND PERFORMANCE REQUIREMENTS FOR LONG LEAD SFDI CONTROL VALVES.

NOTE :

THIS PACKAGE NEGLECTS DETAILS OF INLET AND OUTLET PIPING. PRESSURE LOSSES PENDING DETAILED DESIGN OF THE RESPECTIVE PIPING NETWORKS. WHEN FINAL DESIGN IS COMPLETED, THE PRESSURE VALUES ON THE RESPECTIVE DATA SHEETS MUST BE REVISED.

VALVE REVISION CHECK LIST

| DISCRIPTION  | UPDATED                       |
|--|-------------------------------|
| • V-2 RS FLASH TANK TO DA (STEAM)                  | ✓ <del>PV-649</del> (PV-647B) |
| • V-3 TS FLASH TANK TO DA (STEAM)                  | ✓ <del>PV-636</del> (PV-647A) |
| • V-4 TS FLASH TANK TO COND (STEAM)                | ✓ PV-640                      |
| • V-5 RS FLASH TANK TO COND (STEAM)                | ✓ PV-1000                     |
| • V-8 CONDENSER DUMP (STEAM)                       | ✓ PV-1001                     |
| • V-9 CONDENSATE TO DUMP DESUPHTR (COND)           | ✓ TV-1002                     |
| • V-11 MAIN STEAM TO AUX STEAM (STEAM)             | ✓ PV-1003                     |
| • V-12 ADMISSION STEAM TO AUX STEAM (STEAM)        | ✓ PV-1005                     |
| • V-14 TS FLASH TANK TO COND. (COND)               | ✓ LV-74D                      |
| • V-15 RS FLASH TANK TO COND (COND)                | ✓ LV-74C                      |
| • V-16 RS FLASH TANK TO #2 HTR (COND)              | ✓ LV-74A                      |
| • V-17 TS FLASH TANK TO #2 HTR (COND)              | ✓ LV-74B                      |
| • V-23 CONDENSATE TO AUX STEAM DESUP (COND)        | ✓ TV-1004                     |
| • V-24 AUXILIARY STEAM ISOLATION (STEAM)           | ✓ AOV-1008                    |
| • V-25 AUXILIARY STEAM ISOLATION (STEAM)           | ✓ AOV-1009                    |
| • LV-1 TS BLANKETING STEAM INLET WATER LEVEL VALVE |                               |

DIVISION USAGE  
P PP SHI FI ISP

**Stearns-Roger**  
Engineering Standard

EJ41.4  
Page 2

Albany

**CONTROL VALVE DESIGN SHEET**

PV-647 B

ISSUED  
REVISED

CUSTOMER: \_\_\_\_\_

TAG NO.: PV 649 RS FLASH TANK TO DEAERATOR

PROJECT NO.: \_\_\_\_\_

SERVICE: RS FLASH TANK

PROJECT: \_\_\_\_\_

FLUID: STEAM

REV. NO.  
DATE  
BY

|                |  |  |  |
|----------------|--|--|--|
| 1              |  |  |  |
| 12/15          |  |  |  |
| JER.<br>(MDAC) |  |  |  |

| FLOW            | PSIA              | FLUID CONDITIONS AT VALVE INLET |  | VISC.,<br>c <sub>p</sub> or<br>SSU | VALVE<br>$\Delta P$<br>PSI | SYSTEM<br>FRICTION<br>LOSS<br>PSI | APPROX.<br>DESIRED<br>C <sub>v</sub> |
|-----------------|-------------------|---------------------------------|--|------------------------------------|----------------------------|-----------------------------------|--------------------------------------|
|                 |                   | TEMP.<br>OF                     | DENSITY<br>#/FT <sup>3</sup> OR<br>S.V. (FT <sup>3</sup> /#) |                                    |                            |                                   |                                      |
| MAXIMUM<br>6285 | 380<br>SEE NOTE 1 | 660<br>SEE NOTE 2               | 1.6707   |                                    | SEE NOTE 3                 |                                   |                                      |
| DESIGN<br>6285  | 380<br>SEE NOTE 1 | 585                             | 1.53   |                                    | SEE NOTE 3                 |                                   |                                      |
| MINIMUM<br>800  | 380<br>SEE NOTE 1 | 439                             | 1.2222   |                                    | SEE NOTE 3                 |                                   |                                      |

Max. Design Temp.: 660 (SEE NOTE 2) F, Max. Design Press.: 600 PSIA

Max. Shut-Off Press.: 360 (SEE NOTE 1) PSI  
Valve Service: OPEN/CLOSE

MODULATION

Flashing Expected in Valve? YES  NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear   
Quick Opening

Equal Percentage   
Other: MODIFIED PARABOLIC

Tight Shut-Off Required? YES  NO


Adjustable Leakage: \_\_\_\_\_  
Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.   
Valve Action On Loss of Power air/or sensing fluid: Opens  Closes   
Opens  Closes

Form No. : \_\_\_\_\_ Date: 12/15/79

R-1  
12/14/79  
JER  
4 OF 53



PV 649 NOTES

1. VALVE (Y-5) "To CONDENSER" IS SET TO CONTROL UPSTREAM PRESSURE AT 380 PSIA. IT IS ASSUMED HERE THAT THE SAME PRESSURE WILL EXIST UPSTREAM PV 649.
2. VALVE PV649 SHALL HAVE A STEAM TEMPERATURE OVERRIDE CAPABILITY TO PREVENT FLASH TANK STEAM WITH TEMPERATURES > 660°F FROM ENTERING THE DEAERATOR
3. DOWNSTREAM (DEAERATOR) PRESSURE SHALL BE WITHIN THE RANGE OF 20-50 PSIA.
4. MAX SHUTOFF PRESSURE = 380 PSIA - 20 PSIA = 360 PSIA  
↙ MIN DEAERATOR PRESSURE  
↖ MAX UPSTREAM PRESSURE DURING OPERATION

VALVE PV 649 (PV-647B)

STEAM DUTY

C<sub>v</sub> CHECK

|                  |            |           |
|------------------|------------|-----------|
| m                | 6285 LB/HR | 800 LB/HR |
| P <sub>1</sub>   | 380 PSIA   | 380 PSIA  |
| P <sub>2</sub>   | 50 PSIA    | 50 PSIA   |
| S<br>(DEG SUPHT) | 220 °F     | 220 °F    |
| C <sub>v</sub>   | 10.49      | 1.335     |



Tabbany  
 CONTROL VALVE DESIGN SHEET  
 PY647C ISSUED  
 REVISED


CUSTOMER: \_\_\_\_\_ TAG NO.: PV 636 TS FLASH TANK PRESSURE CONTROL  
 PROJECT NO.: \_\_\_\_\_ SERVICE: TS FLASH TANK  
 PROJECT: \_\_\_\_\_ FLUID: STEAM

|          |                |  |  |
|----------|----------------|--|--|
| REV. NO. | 1              |  |  |
| DATE     | 12/15/79       |  |  |
| BY       | JER.<br>(MDAC) |  |  |

| FLOW (#/HR) GPM, SCFM | FLUID CONDITIONS AT VALVE INLET |          |  | VALVE ΔP PSI | SYSTEM FRICTION LOSS PSI | APPROX. DESIRED C <sub>v</sub> |
|-----------------------|---------------------------------|----------|--|--------------|--------------------------|--------------------------------|
|                       | PRESS. PSIA                     | TEMP. °F | DENSITY #/FT <sup>3</sup> OR S.V. (FT <sup>3</sup> /#) |              |                          |                                |
| MAXIMUM 30822         | 150<br>SEE NOTE 1               | 358      | 3.015  | SEE NOTE 2   |                          |                                |
| DESIGN 12500          | 150<br>SEE NOTE 1               | 358      | 3.015  | SEE NOTE 2   |                          |                                |
| MINIMUM 605           | 150<br>SEE NOTE 1               | 358      | 3.015  | SEE NOTE 2   |                          |                                |

Max. Design Temp.: 535 (NOTE 4) °F, Max. Design Press.: 180 PSIA  
 Max. Shut-Off Press.: 130 (SEE NOTE 3) PSI  
 Valve Service: OPEN/CLOSE  MODULATION   
 Is Flashing Expected in Valve? YES  NO   
 Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_  
 Approx. Valve Body Size: \_\_\_\_\_ INCHES  
 Body Type: \_\_\_\_\_  
 Valve Characteristic: Linear  Equal Percentage   
 Quick Opening  Other: 50:1 TURNDOWN  
 Is Tight Shut-Off Required? YES  NO   
 Allowable Leakage: \_\_\_\_\_  
 Is Handjack or Handwheel Required? YES  NO   
 Special Steam Packing Considerations: \_\_\_\_\_  
 Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
 Valve Action On Loss of Power air/or sensing fluid: Opens  Closes   
 Form No. : \_\_\_\_\_ Date: 12/15/79

R-1  
12/14/79  
JER  
7 OF 53



○ - INTERFACE NUMBER

PV 636 NOTES

1. VALVE PV 636 CONTROLS TS FLASH TANK PRESSURE TO 150 PSIA. THE INLET PRESSURE SPECIFIED FOR THE VALVE (150 PSIA) IGNORES LINE LOSSES BETWEEN THE FLASH TANK AND CONTROL VALVE.
2. VALVE DOWNSTREAM PRESSURE CAN BE ANYWHERE IN THE RANGE OF 20-50 PSIA DEPENDING ON CONDITIONS IN THE DEAERATOR.
3. MAX SHUTOFF PRESSURE = 150 PSIA - 20 PSIA  
← MIN DEAERATOR  
← FLASH TANK PRESSURE
4. A MAXIMUM VALVE TEMPERATURE CONDITION EXISTS WHEN STEAM GENERATOR STARTUP FLOWS ONLY PASS INTO THE THERMAL STORAGE FLASH TANK (SEE INTERFACES 82I+83I=12I) OR WARMUP BLEEDS FROM 7I AND 8I ENTER THE FLASH TANK THROUGH 7IA (ASSUMING BLEED STEAM ORIGINATES FROM TS - 530°F 400 PSIA NOMINAL).

Tabbany

CONTROL VALVE DESIGN SHEET

ISSUED  
 REVISED


CUSTOMER: \_\_\_\_\_ TAG NO.: PV 640 TS FLASH TANK  
PRESSURE CONTROL  
 PROJECT NO.: \_\_\_\_\_ SERVICE: TS FLASH TANK  
 PROJECT: \_\_\_\_\_ FLUID: STEAM

|          |                |  |  |
|----------|----------------|--|--|
| REV. NO. | 1              |  |  |
| DATE     | 12/15/79       |  |  |
| BY       | JER.<br>(MDAC) |  |  |

| FLOW #/RR, GPM, SCFM | FLUID CONDITIONS AT VALVE INLET |          |  |                              | VALVE $\Delta P$ PSI | SYSTEM FRICTION LOSS PSI | APPROX. DESIRED $C_v$ |
|----------------------|---------------------------------|----------|--|------------------------------|----------------------|--------------------------|-----------------------|
|                      | PRESS. PSIA                     | TEMP. OF | DENSITY #/FT <sup>3</sup> OR S.V. (FT <sup>3</sup> /#) | VISC., c <sub>p</sub> or SSU |                      |                          |                       |
| MAXIMUM 30822        | 50<br>SEE NOTE 1                | 320      | 9.038  |                              | SEE NOTE 2           |                          |                       |
| DESIGN 12500         | 50<br>SEE NOTE 1                | 320      | 9.038  |                              | SEE NOTE 2           |                          |                       |
| MINIMUM 605          | 50<br>SEE NOTE 1                | 320      | 9.038  |                              | SEE NOTE 2           |                          |                       |

Max. Design Temp.: 520 (SEE NOTE 3) °F, Max. Design Press.: 70 (SEE NOTE 4) PSIA  
 Max. Shut-Off Press.: 50 PSI  
 Valve Service: OPEN/CLOSE  MODULATION   
 Is Flashing Expected in Valve? YES  NO   
 Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_  
 Approx. Valve Body Size: \_\_\_\_\_ INCHES  
 Body Type: \_\_\_\_\_  
 Valve Characteristic: Linear  Equal Percentage   
 Quick Opening  Other: HIGH TURNDOWN  
 Is Tight Shut-Off Required? YES  NO   
 Allowable Leakage: \_\_\_\_\_  
 Is Handjack or Handwheel Required? YES  NO   
 Special Steam Packing Considerations: \_\_\_\_\_  
 Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
 Valve Action On Loss of Power air/or sensing fluid: Opens  Closes   
 Form No. : \_\_\_\_\_ Date: 12/15/79

R-1  
 12/14/79  
 JER  
 95F53



PV 640 NOTES

1. VALVE PV640 CONTROLS UPSTREAM STEAM PRESSURE TO 50 PSID (MAX DEAERATOR VALUE) OVER ENTIRE FLOW RANGE
2. PRESSURE ON THE DOWNSTREAM SIDE EQUALS CONDENSER PRESSURE + LINE LOSSES. IF A DOWNSTREAM ORIFICE IS USED, A HIGHER VALVE BACK PRESSURE WILL EXIST DURING HIGH FLOW PERIODS.
3. DESIGN TEMP AT INTERFACE 3 AS REDUCED BY THROTTLING PRESSURE TO 70 PSID (ASSUMED DEAERATOR RELIEF VALVE SET POINT).
4. ASSUMED DEAERATOR RELIEF VALVE SET POINT

| DIVISION USAGE |   |    |    |    |
|----------------|---|----|----|----|
| U              | P | PP | SH | IF |
|                |   |    |    |    |
|                |   |    |    |    |
|                |   |    |    |    |

# Stearns-Roger

Engineering Standard

EJ41.4  
Page 2 10 OF 53

Tabbyay  
CONTROL VALVE DESIGN SHEET  
PY-1000  
ISSUED  
REVISED

(V-5) RS FLASH TANK

CUSTOMER: \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
PROJECT: \_\_\_\_\_

TAG NO.: To CONDENSER DUMP  
DESUPERHEATER  
SERVICE: RS FLASH TANK  
FLUID: STEAM

|          |                |  |  |
|----------|----------------|--|--|
| REV. NO. | 1              |  |  |
| DATE     | 12/15/79       |  |  |
| BY       | JER.<br>(MDAC) |  |  |

| FLOW (#/HR, GPM, SCFM) | FLUID CONDITIONS AT VALVE INLET |                   |   |       | VALVE SYSTEM | APPROX. DESIRED |
|------------------------|---------------------------------|-------------------|---|-------|--------------|-----------------|
|                        | PSIA                            | TEMP.             | DENSITY   | VISC. |              |                 |
| MAXIMUM 40000          | 380<br>SEE NOTE 1               | 960<br>SEE NOTE 2 | 1.753<br>#/FT <sup>3</sup> OR S.V. FT <sup>3</sup> /# |       | SEE NOTE 4   |                 |
| DESIGN 40000           | 380<br>SEE NOTE 1               | 585               | 1.53  |       | SEE NOTE 4   |                 |
| MINIMUM 4000           | 380<br>SEE NOTE 1               | 439               | 1.222   |       | SEE NOTE 4   |                 |

Max. Design Temp.: 960 °F, Max. Design Press.: 600 PSIA

Max. Shut-Off Press.: 380 (SEE NOTE 3) PSI

Valve Service: OPEN/CLOSE  MODULATION

Is Flashing Expected in Valve? YES  NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_

approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
Quick Opening  Other: MODIFIED PARABOLIC

Is Tight Shut-Off Required? YES  NO


Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
Valve Action On Loss of Power air/or sensing fluid: Opens  Closes

Form No. : \_\_\_\_\_ Date: 12/15/79



(V-5) NOTES

1. VALVE (V-5) CONTROLS UPSTREAM PRESSURE TO 380PSI<sub>a</sub> OVER ENTIRE FLOW RANGE
2. 960°F IS MAX TEMPERATURE COMING THROUGH INTERFACE RI6
3. MAX SHUTOFF PRESSURE = 380 PSI<sub>a</sub> - ~0 PSI<sub>a</sub> = 380 PSI<sub>a</sub>  
↖ UPSTREAM PRESSURE
↖ CONDENSER PRESSURE -
4. THE MAXIMUM ΔP ACROSS THE VALVE IS AS PRESENTED IN "NOTE 3" ABOVE. THE USE OF A DOWNSTREAM ORIFICE AND/OR A NONZERO VALUE FOR PRESSURE DROP THROUGH THE CONDENSER DUMP DESUPERHEATER WILL RESULT IN A HIGHER BACK PRESSURE (ESPECIALLY AT HIGH FLOW) WHICH WILL RESULT IN A REDUCED VALVE ΔP.

VALVE PV 1000

STEAM DUTY

C<sub>v</sub> CHECK

|           |              |            |
|-----------|--------------|------------|
| $\dot{m}$ | 40,000 LB/HR | 4000 LB/HR |
|-----------|--------------|------------|

|                |          |          |
|----------------|----------|----------|
| P <sub>1</sub> | 380 psia | 380 psia |
|----------------|----------|----------|

|                |                       |                       |
|----------------|-----------------------|-----------------------|
| P <sub>2</sub> | 5 psia (?)<br>(SMALL) | 5 psia (?)<br>(SMALL) |
|----------------|-----------------------|-----------------------|

|                  |        |        |
|------------------|--------|--------|
| S<br>(DEG SUPHT) | 520 °F | 520 °F |
|------------------|--------|--------|

|                |       |      |
|----------------|-------|------|
| C <sub>v</sub> | 78.89 | 7.89 |
|----------------|-------|------|

Tabbany

CONTROL VALVE DESIGN SHEET

ISSUED  
REVISED

CUSTOMER: \_\_\_\_\_

CONDENSER DUMP  
TAG NO.: PRESSURE REDUCING DRAG VALVE

PROJECT NO.: \_\_\_\_\_

SERVICE: CONDENSER DUMP

PROJECT: \_\_\_\_\_

FLUID: STEAM  
PV-1001

REV. NO.

DATE

BY

|                |  |  |  |
|----------------|--|--|--|
| 1              |  |  |  |
| 12/16          |  |  |  |
| JER-<br>(MDAC) |  |  |  |

| FLOW (#/HR) GPM, SCFM     | FLUID CONDITIONS AT VALVE INLET |           |  | VALVE | SYSTEM | APPROX. DESIRED C <sub>v</sub> |
|---------------------------|---------------------------------|-----------|--|-------|--------|--------------------------------|
|                           | PRESS. PSIA                     | TEMP. OF  | DENSITY #/FT <sup>3</sup> OR S.V. (FT <sup>3</sup> /#) |       |        |                                |
| MAXIMUM 112,300 / 130,000 | 1465 / 1465                     | 950 / 650 | .534 / .3578   |       |        | 1365 (NOTE 1)                  |
| DESIGN                    |                                 |           |  |       |        |                                |
| MINIMUM 6500              | 380 / 1465                      | 440 / 950 | 1.222 / .534   |       |        | 380 (NOTE 2)                   |

Max. Design Temp.: 1010 (NOTE 3) °F, Max. Design Press.: 1780 (NOTE 3) PSIA  
 Max. Shut-Off Press.: 1465 (NOTE 4) PSI  
 Valve Service: OPEN/CLOSE  MODULATION

Flashing Expected in Valve? YES  NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_  
 Approx. Valve Body Size: \_\_\_\_\_ INCHES  
 Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
 Quick Opening  Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES  NO  ACTUATION TIMES (FULL STROKE) 0.2 SEC  
 Allowable Leakage: \_\_\_\_\_ NO   
 Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
 Valve Action On Loss of Power air/CF sensing fluid: Opens  Closes

Form No. : \_\_\_\_\_ Date: 59 12/16/79



CONDENSER DUMP PRESSURE REDUCING DRAG VALVE #1 OF 50

## (DESIGN NOTES)

1. VALVE  $\Delta P = 1365$  psi BASED ON 1465 psi<sub>a</sub> UPSTREAM STEAM PRESSURE (PRESSURE CONTROL POINT) - AN ASSUMED 100 psi<sub>a</sub> DOWNSTREAM PRESSURE. THIS VALUE NEGLECTS FLOW LOSSES AS THE STEAM PASSES THROUGH THE DOWNSTREAM DESUPERHEATER.
2. VALVE  $\Delta P = 380$  psi<sub>a</sub> BASED ON 380 psi<sub>a</sub> UPSTREAM PRESSURE - CONDENSER PRESSURE ( $\sim 0$ ).
3. BASED ON "DESIGN" INTERFACE CONDITIONS SPECIFIED AT INTERFACES #1 AND #1I
4. MAX SHUTOFF PRESSURE (1465 psi<sub>a</sub>) BASED ON A TRIP CONDITION WITH THE DOWNSTREAM PRESSURE AT THE CONDENSER PRESSURE. NOTE THAT A HIGHER SHUTOFF PRESSURE SHOULD POTENTIALLY BE CONSIDERED DUE TO "STEAM HAMMER" EFFECTS THAT COULD OCCUR DURING A TRIP CONDITION.

FOR REFERENCE DESIGN INFORMATION SEE CONDENSER DUMP NETWORK DESIGN DATA P. 1-3

1/12/80

LAG TIME FOR CONDENSER DUMP VALVE

150F53

500 FT 6" DOUBLE EXTRA STRONG

FLOW AREA = .1308 FT<sup>2</sup>

} V = 65.4 FT<sup>3</sup>

M = 125.8 LB @ T=0

SAFETY VALVES LIFT AT 1780 PSIA

ASSUME  $\bar{P}_{INITIAL} = 1500$  PSIA 960°F  $v = .520$  FT<sup>3</sup>/LB

ASSUME  $\dot{m}_s = 115000$  LB/HR = 31.94 LB/SEC

| $\Delta T$<br>(sec) | INCREMENTAL<br>ACCUMULATION<br>(LB) | CUMULATIVE<br>ACCUMULATION<br>(LB) | (V)   | PRESSURE AT<br>END OF INTERVAL<br>(PSIA) |
|---------------------|-------------------------------------|------------------------------------|-------|--|
| .1                  | 1.6                                 | 127.4                              | .513  | 1516                                     |
| .2                  | 3.2                                 | 130.6                              | .5007 | 1550                                     |
| .3                  | 3.2                                 | 133.8                              | .4888 | 1585                                     |
| .4                  | 3.2                                 | 136.9                              | .4777 | 1624                                     |
| .5                  | 3.2                                 | 140.2                              | .4664 | 1658                                     |
| .6                  | 3.2                                 | 143.4                              | .4560 | 1692                                     |
| .7                  | 3.2                                 | 146.6                              | .446  | 1725                                     |
| .8                  | 3.2                                 | 149.8                              | .4366 | 1758                                     |



## MEMORANDUM

A3-234-EP-JAG-75  
22 January 1980

To: E. J. Riel

Subject: CONDENSER DUMP VALVE ACTUATION REQUIREMENTS

Copies to: R. M. Berry, R. G. Riedesel, J. E. Raetz, G. C. Coleman,  
M. L. Joy, A. B. Smee, MDAC; R. Bicknell, Stearns-Rogers; File

This memorandum presents the analysis of the Condenser Dump Valve response requirements. The goal is to determine the necessary valve response to prevent steam header pressure from exceeding 1715 psi which is 50 psi below vent valve actuation pressure.

The Receiver Subsystem Digital Simulation was used in this analysis, and was modified to eliminate unnecessary thermodynamics.

#### SUMMARY OF RESULTS

The results of the analysis are summarized as a sensitivity plot of Maximum Steam Header Pressure versus Valve Time Constants (Figure I). The plot shows a vent valve relief limit of 1765 psi with a 50 psi margin as the criteria for valve selection.

Pressure transient histories for a 0.8\* second valve, with both proportional and proportion plus integral controllers are shown in Figure II and III respectively.

Based on the results in Figure I, it can be seen that a "faster" valve will minimize the magnitude of the pressure overshoot. Also, a proportional plus integral controller will provide the desirable characteristic of returning the pressure to the setpoint value.

#### RECOMMENDATIONS

From the sensitivity plot and the pressure transient histories of Figures I through III, it was determined that a 0.8\* second valve with proportional

\* Response time to 90% of valve stroke.

plus integral control will provide acceptable pressure control in the event of a turbine trip.

ANALYSIS AND SUPPORTING DATA

A pictorial description of the system configuration is shown in Figure IV. Flow from 18 boiler panels (WID) enters the steam header and is compared with the downcomer flow (WDD) in a compressibility algorithm which yields specific volume. Pressure in the steam header (P3) is a function of specific volume and enthalpy. Flow in the downcomer is the sum of flow through the Turbine Inlet Valve (WDTV) and flow through the Condenser Dump Valve (WCCDV). Pressure at the condenser dump valve is 87 psi lower than the steam header pressure for approximately rated flow and a 450 ft. Barstow downcomer. For the purpose of this analysis, the turbine inlet valve and the condenser dump valve are considered to be side by side and see the same pressure, PD5.

In the simulation, the turbine inlet valve flow was held constant until 10 seconds and then ramped down to 0.0 lb/sec in 0.1 seconds, simulating a turbine trip. The condenser dump valve actuation was delayed until 0.2 seconds after PD5 reached the setpoint (1565 psi) to simulate worst case digital sampling. A pictorial description of a typical turbine trip scenario is shown in Figure V.

Two condenser dump valve controller configurations were compared. The proportional controller is shown in Figure VI, and the Proportional plus Integral controller is shown in Figure VII. For each controller, four different valves were used with 90% time constants of 0.5, 0.8, 1.0 and 2.0 seconds. Additional runs were made with the proportional plus integral controller and 90% valve time constants of 1.472 and 2.76 seconds. A typical flow history showing the 0.2 second delay is included as Figure VIII.

Additional supporting data in terms of the pressure transient histories for various dump valve actuation times are shown in the attachment.

Please direct any questions or comments to Bob Berry at X3220 or John Gaidelis X3220.

*J. A. Gaidelis*  
J. A. Gaidelis




FIGURE I

MAXIMUM STEAM HEADER PRESSURE (P<sub>3\_max</sub>) VS. VALVE TIME CONSTANT

FIGURE II






FIGURE III





# FIGURE IV

## TEST SYSTEM CONFIGURATION






FIGURE V

TYPICAL TURBINE TRIP SCENARIO

JAG 01/18/80

FIGURE VI  
PROPORTIONAL CONTROLLER WITH 0.8 SECOND - 90% VALVE




FIGURE VII  
PROPORTIONAL + INTEGRAL CONTROLLER WITH 0.8 SECOND - 90% VALVE





FIGURE VIII



ATTACHMENT

SUPPORTING DATA

|          |                  |                      |       |
|----------|------------------|----------------------|-------|
| FIGURE 1 | PRESSURE HISTORY | VALVE ACTUATION TIME | 0.5   |
| FIGURE 2 | PRESSURE HISTORY | VALVE ACTUATION TIME | 1.0   |
| FIGURE 3 | PRESSURE HISTORY | VALVE ACTUATION TIME | 1.472 |
| FIGURE 4 | PRESSURE HISTORY | VALVE ACTUATION TIME | 2.0   |
| FIGURE 5 | PRESSURE HISTORY | VALVE ACTUATION TIME | 2.76  |

FIGURE 1




FIGURE 2




FIGURE 3






FIGURE 4





FIGURE 5



| DIVISION USAGE |   |    |    |     |
|----------------|---|----|----|-----|
| MM             | P | PP | SH | ISP |
|                |   |    |    |     |

**Stearns-Roger**  
Engineering Standard

EJ41.4  
Page 2

Tabbany

CONTROL VALVE DESIGN SHEET

ISSUED  
REVISED

CUSTOMER: \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
PROJECT: \_\_\_\_\_

SPRAY WATER CONTROL  
VALVE FOR CONDENSER  
TAG NO.: DUMP DESUPERHEATER  
SERVICE: CONDENSER DUMP  
FLUID: CONDENSATE  
TV-100Q

REV. NO.

DATE

BY

|                |  |  |  |
|----------------|--|--|--|
| 1              |  |  |  |
| 12/16          |  |  |  |
| JER-<br>(MDAC) |  |  |  |

| FLOW    | FLUID CONDITIONS AT VALVE INLET |                     |      |                     | VALVE           | SYSTEM | APPROX. |
|---------|---------------------------------|---------------------|------|---------------------|-----------------|--------|---------|
|         | FRIC. LOSS                      | DES. C <sub>v</sub> | LOSS | DES. C <sub>v</sub> |                 |        |         |
| MAXIMUM | 26372                           | 140                 | 121  | .01621              | ~20             |        |         |
| DESIGN  | 26372                           | 140                 | 121  | .01621              | ~20             |        |         |
| MINIMUM | 170                             | 140                 | 108  | .01616              | 140<br>(NOTE 1) |        |         |

PSIA      OF      #/FT<sup>3</sup> OR S.V. FT<sup>3</sup>/#      c<sub>p</sub> or SSU      Δ P PSI      PSI

MAXIMUM 26372  
DESIGN 26372  
MINIMUM 170

Max. Design Temp.: 135 (NOTE 2) °F,      Max. Design Press.: 160 (NOTE 3) PSIA

Max. Shut-Off Press.: 140 (NOTE 4) PSI

Valve Service:      OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve?      YES

NO

Pipe Size and Schedule: \_\_\_\_\_,      Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic:      Linear   
   Quick Opening

Equal Percentage   
Other: \_\_\_\_\_

Is Tight Shut-Off Required?      YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required?      YES

NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power:      Locks in Pos.   
Valve Action On Loss of Power air/or sensing fluid

Opens   
Opens

Closes   
Closes

Form No. :

Date: 78 12/16/79

SPRAY WATER CONTROL VALVE FOR CONDENSER DUMP

DESUPERHEATER

(DESIGN NOTES)

1.  $\Delta P = 140 \text{ psi}$  IS BASED ON A  $140 \text{ psi}$  UPSTREAM PRESSURE AND CONDENSER PRESSURE  $\sim 0 \text{ psi}$  ON THE DOWNSTREAM SIDE. THIS IGNORES ANY STEAM PRESSURE DROP THROUGH THE DESUPERHEATER OR CONDENSER INLET MANIFOLD WHICH WOULD BE SMALL AT LOW STEAM FLOW.
2. BASED ON AN ASSUMED 5 IN Hg MAX CONDENSER PRESSURE (135 °F SATURATED WATER)
3. MAX DESIGN PRESSURE BASED ON AN ASSUMED 160  $\text{psi}$  MAX HOTWELL PUMP OUTLET PRESSURE
4. BASED ON 140  $\text{psi}$  UPSTREAM PRESSURE WITH CONDENSER DOWNSTREAM PRESSURE ( $\sim 0 \text{ psi}$ )

Tabbany  
 CONTROL VALVE DESIGN SHEET PV-1003  
 ISSUED  
 REVISED

CUSTOMER: \_\_\_\_\_  
 PROJECT NO.: \_\_\_\_\_  
 PROJECT: \_\_\_\_\_

(V-11) MAIN STEAM  
 TO AUX STEAM -  
 TAG NO.: PRESS REDUCING  
 SERVICE: AUX STEAM  
 FLUID: STEAM

|          |                |  |  |
|----------|----------------|--|--|
| REV. NO. | 1              |  |  |
| DATE     | 12/16          |  |  |
| BY       | JER.<br>(MDAC) |  |  |

| FLOW (#/HR, GPM, SCFM) | FLUID CONDITIONS AT VALVE INLET |           |  | VALVE SYSTEM APPROX. DESIRED C <sub>v</sub> |
|------------------------|---------------------------------|-----------|--|---|
|                        | PRESS. PSIA                     | TEMP. °F  | DENSITY #/FT <sup>3</sup> OR S.V. FT <sup>3</sup> /# |   |
| MAXIMUM 13554 / 9880   | 1465 / 1465                     | 650 / 950 | .3493 / .5339  | 1390  |
| DESIGN SEE NOTE 1      | 1465                            | 950       | .5339  | 1390  |
| MINIMUM SEE NOTE 1     | 1465                            | 950       | .5339  | 1390  |


Max. Design Temp.: 1010 °F, Max. Design Press.: 1780 (SEE NOTE 2) PSIA  
 Max. Shut-Off Press.: 1410 (NOTE 3) PSI  
 Valve Service: OPEN/CLOSE  MODULATION   
 Is Flashing Expected in Valve? YES  NO   
 Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_  
 Approx. Valve Body Size: \_\_\_\_\_ INCHES  
 Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
 Quick Opening  Other: MODIFIED PARABOLIC

Is Tight Shut-Off Required? YES  NO   
 Allowable Leakage: \_\_\_\_\_  
 Is Handjack or Handwheel Required? YES  NO   
 Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
 Valve Action On Loss of Power air/cr sensing fluid: Opens  Closes

AUXILIARY STEAM NETWORK



V-11 NOTES

1. DURING NORMAL PLANT OPERATION (TIMES OTHER THAN RECEIVER STAND ALONE), VALVE (V-11) [AND (V-23)] WILL OPEN ONLY AS REQUIRED TO MAINTAIN 345°F 85psia STEAM CONDITIONS DOWNSTREAM OF THE DESUPERHEATER, THEREFORE, THE MAJORITY OF THE DUTY FOR (V-11) [AND (V-23)] WILL BE AT OR NEAR ZERO FLOW. AN ATTEMPT SHOULD BE MADE TO MAXIMIZE THE TURNDOWN CAPABILITY OF (V-11) [AND THE DESUPERHEATER AND (V-23)] TO ENHANCE CONTROL RANGE CAPABILITY SUBJECT TO COST AND ENGINEERING JUDGEMENT RELATED TO A SINGLE CONTROL VALVE.
2. MAX DESIGN PRESSURE SET BY RECEIVER (SEE INTERFACE CONDITIONS 1 AND R13).
3. MAX SHUTOFF PRESSURE = UPSTREAM OPERATING PRESSURE - MIN AUX NETWORK PRESSURE = 1465 - 55 = 1410 PSI

| DIVISION USAGE |   |    |    |    |     |
|----------------|---|----|----|----|-----|
| MM             | P | PP | SH | FI | ISP |
|                |   |    |    |    |     |

**Stearns-Roger**  
Engineering Standard

EJ41.4 330755  
Page 2

Tabbany

**CONTROL VALVE DESIGN SHEET**

PV 1005

ISSUED  
REVISED

CUSTOMER: \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
PROJECT: \_\_\_\_\_

(V-12) ADMISSION  
STEAM To AUX  
TAG NO.: STEAM  
SERVICE: AUX STEAM  
FLUID: STEAM

REV. NO.  
DATE  
BY

|               |  |  |  |
|---------------|--|--|--|
| 1             |  |  |  |
| 12/16         |  |  |  |
| JER<br>(MDAC) |  |  |  |

| FLOW (#/RR, GPM, SCFM) | FLUID CONDITIONS AT VALVE INLET |          |  |                              | VALVE SYSTEM APPROX. FRICTION LOSS PSI | APPROX. DESIRED C <sub>v</sub> |
|------------------------|---------------------------------|----------|--|------------------------------|--|--------------------------------|
|                        | PRESS. PSIA                     | TEMP. OF | DENSITY #/FT <sup>3</sup> OR S.V. FT <sup>3</sup> /# | VISC., c <sub>p</sub> OR SSU |  |                                |
| MAXIMUM 3765           | 385                             | 525      | 1.39   |                              | 320                                    |                                |
| DESIGN SEE NOTE 1      | 385                             | 525      | 1.39   |                              | 320                                    |                                |
| MINIMUM SEE NOTE 1     | 385                             | 525      | 1.39   |                              | 320                                    |                                |

Max. Design Temp.: 580 (NOTE 2) °F, Max. Design Press.: 465 (NOTE 2) PSIA

Max. Shut-Off Press.: 330 (NOTE 3) PSI

Valve Service: OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve? YES

NO

Pipe Size and Schedule: \_\_\_\_\_

Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear   
Quick Opening

Equal Percentage   
Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES

NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.

Opens   
Opens


Closes   
Closes

Valve Action On Loss of Power air/or sensing fluid

Form No. :

Date: 82 12/16/79

AUXILIARY STEAM NETWORK



(V-12) NOTES

1. DURING MOST PERIODS OF OPERATION, THE AUX STEAM DEMAND WILL BE AT OR NEAR ZERO. THEREFORE, IT IS DESIRABLE TO HAVE (V-12) TURNDOWN BE AS HIGH AS PRACTICAL SUBJECT TO LIMITATIONS OF THE DESUPERHEATER, (V-23), AND THE CAPABILITY OF A SINGLE VALVE.
2. MAX DESIGN TEMP AND PRESSURE CONDITION ESTABLISHED BY THERMAL STORAGE STEAM GENERATOR MAX DESIGN VALUES (SEE INTERFACES 2, 84I, AND 85I)
- 3 MAX SHUTOFF PRESSURE = MAX OPERATING PRESSURE - MIN AUX NETWORK PRESSURE = 385 - 55 PSIA = 330PSI



Tabbany

CONTROL VALVE DESIGN SHEET

ISSUED  
 REVISED

CUSTOMER: \_\_\_\_\_  
 PROJECT NO.: \_\_\_\_\_  
 PROJECT: \_\_\_\_\_

LV 74D TS FLASH  
 TAG NO.: TANK TO CONDENSER  
 SERVICE: TS FLASH TANK  
 FLUID: CONDENSATE

REV. NO.  
 DATE  
 BY

|               |  |  |  |
|---------------|--|--|--|
| 1             |  |  |  |
| 12/15/79      |  |  |  |
| JER<br>(MDAC) |  |  |  |

| FLOW (#/RR, GPM, SCFM)               | FLUID CONDITIONS AT VALVE INLET |          |   | VALVE<br>$\Delta P$<br>PSI | SYSTEM<br>FRICTION<br>LOSS<br>PSI | APPROX.<br>DESIRED<br>C <sub>v</sub> |
|--------------------------------------|---------------------------------|----------|---|----------------------------|-----------------------------------|--------------------------------------|
|                                      | PRESS. PSIA                     | TEMP. OF | DENSITY VISC.,<br>#/FT <sup>3</sup> OR c <sub>p</sub> or<br>S.V. (FT <sup>3</sup> /#) SSU |                            |                                   |                                      |
| MAXIMUM 117,500                      | 165<br>SEE NOTE 1               | 358      | .01809  | SEE<br>NOTE 2              |                                   |                                      |
| DESIGN 117,500                       | 165<br>SEE<br>NOTE 1            | 358      | .01809  | SEE<br>NOTE 2              |                                   |                                      |
| MINIMUM 133<br>(AS LOW AS PRACTICAL) | 165<br>SEE<br>NOTE 1            | 358      | .01809  | SEE<br>NOTE 2              |                                   |                                      |

Max. Design Temp.: 360 °F, Max. Design Press.: 195 (NOTE 3) PSIA

Max. Shut-Off Press.: 165 (NOTE 4) PSI

Valve Service: OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve? YES

NO

Pipe Size and Schedule: \_\_\_\_\_

Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear   
 Quick Opening

Equal Percentage   
 Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES

NO

Special Steam Packing Considerations: \_\_\_\_\_


Valve Action On Loss of Power: Locks in Pos.

Opens   
 Opens

Closes   
 Closes

Form No. :

Date: 12/15/79



### LV 74 D NOTES

1. TS FLASH TANK PRESSURE (150psia) + PUMP HEAD RISE (15psia). THE SPECIFIED VALUE (165psia) NEGLECTS FLOW FRICTIONAL LOSS AND GRAVITY HEAD RISE (IF ANY) BETWEEN THE TS CONDENSATE PUMP AND LV 74 D.
2. PRESSURE DOWNSTREAM OF LV 74 D WILL BE CONDENSER PRESSURE + CONDENSER INLET PRESSURE LINE LOSSES. IF A DOWNSTREAM ORIFICE IS USED, A HIGHER BACK PRESSURE WOULD BE EXPERIENCED, ESPECIALLY DURING HIGH FLOW.
3. MAX DESIGN PRESSURE = MAX DESIGN FLASH TANK PRESSURE + PUMP HEAD RISE =  $150 + 15 = 165$  psia  
(DIFFERENCES IN GRAVITY HEAD ARE IGNORED - IF ANY)
4. MAX SHUTOFF PRESSURE = MAX OPERATING PRESSURE - CONDENSER PRESSURE =  $165$  psia -  $\sim 0 = 165$  psia.

Tabbany

CONTROL VALVE DESIGN SHEET

ISSUED  
 REVISED

CUSTOMER: \_\_\_\_\_  
 PROJECT NO.: \_\_\_\_\_  
 PROJECT: \_\_\_\_\_

LV 74C-RS FLASH  
 TAG NO.: TANK TO CONDENSER  
 SERVICE: RS FLASH TANK  
 FLUID: CONDENSATE

|          |               |  |  |
|----------|---------------|--|--|
| REV. NO. | 1             |  |  |
| DATE     | 12/14         |  |  |
| BY       | JER<br>(MPAC) |  |  |

| FLOW (#/HR, GPM, SCFM) | FLUID CONDITIONS AT VALVE INLET |          |  |                              | VALVE SYSTEM APPROX. FRICTION LOSS PSI | APPROX. DESIRED C <sub>v</sub> |
|------------------------|---------------------------------|----------|--|------------------------------|--|--------------------------------|
|                        | PRESS. PSIA                     | TEMP. OF | DENSITY #/FT <sup>3</sup> OR S.V. (FT <sup>3</sup> /#) | VISC., c <sub>p</sub> OR SSU |  |                                |
| MAXIMUM 40,000         | SEE NOTE 1.                     | 467      | 0.0198   |                              | SEE NOTE 3.                            |                                |
| DESIGN 16189           | SEE NOTE 1.                     | 467      | 0.0198   |                              | SEE NOTE 3.                            |                                |
| MINIMUM 4000           | SEE NOTE 2.                     | 439      | 0.01925  |                              | SEE NOTE 3.                            |                                |

Max. Design Temp.: 486 °F, Max. Design Press.: SEE NOTE 4 PSIA  
 Max. Shut-Off Press.: SEE NOTE 5 PSI  
 Valve Service: OPEN/CLOSE  MODULATION

Is Flashing Expected in Valve? YES  UNLESS DOWNSTREAM ORIFICE IS USED NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_  
 Approx. Valve Body Size: \_\_\_\_\_ INCHES  
 Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
 Quick Opening  Other: MODIFIED PARABOLIC


Is Tight Shut-Off Required? YES  NO

Allowable Leakage: \_\_\_\_\_  
 Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
 Valve Action On Loss of Power air/or sensing fluid: Opens  Closes

R-1  
12/14/79  
JER  
41 OF 53



LV 74C NOTES

1. PRESSURE AT INTERFACE RI8 + (GRAVITY HEAD FROM FLASH TANK) - (FRICTION LOSS) = 500 psia + (H) - (F. LOSS)
2. MIN PRESSURE AT INTERFACE RI8 + (GRAVITY HEAD FROM FLASH TANK) - (FLOW FRICTIONAL LOSS) = 380 psia + (H) - (F. LOSS)
3. VALVE DOWNSTREAM PRESSURE EQUALS CONDENSER INLET MANIFOLD PRESSURE. MAY WANT TO PLACE AN ORIFICE DOWNSTREAM OF VALVE TO MINIMIZE FLASHING.
4. INTERFACE RI8 "DESIGN" PRESSURE + GRAVITY HEAD = 600 psia + (H)
5. MAX SHUTOFF PRESS. = 500 psia + (H) - 2 1/2" Hg  
↖ CONDENSER PRESSURE

| DIVISION USAGE |   |    |    |     |
|----------------|---|----|----|-----|
|                | P | PP | SH | ISP |
|                |   |    |    |     |

**STEARN'S ROGER**  
Engineering Standard

EJ41.4  
Page 2 42 DF 53

Albany

**CONTROL VALVE DESIGN SHEET**

ISSUED  
REVISED

CUSTOMER: \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
PROJECT: \_\_\_\_\_

LV 74 A - RS FLASH  
TANK To No. 2 HTR  
TAG NO.: \_\_\_\_\_  
SERVICE: RS FLASH TANK  
FLUID: CONDENSATE

REV. NO.  
DATE  
BY

|               |  |  |  |
|---------------|--|--|--|
| 1             |  |  |  |
| 12/14         |  |  |  |
| JER<br>(MDAC) |  |  |  |

| FLOW (#/RR, GPM, SCFM) | FLUID CONDITIONS AT VALVE INLET |          |  |                              | VALVE<br>$\Delta P$<br>PSI | SYSTEM<br>FRICTION<br>LOSS<br>PSI | APPROX.<br>DESIRED<br>C <sub>v</sub> |
|------------------------|---------------------------------|----------|--|------------------------------|----------------------------|-----------------------------------|--------------------------------------|
|                        | PRESS. PSIA                     | TEMP. °F | DENSITY #/FT <sup>3</sup> OR S.V. FT <sup>3</sup> /# | VISC., c <sub>p</sub> or SSU |                            |                                   |                                      |
| MAXIMUM 23,811         | SEE NOTE 1. 467                 | 467      | 0.0198   |                              | SEE NOTE 3.                |                                   |                                      |
| DESIGN 23,811          | SEE NOTE 1. 467                 | 467      | 0.0198   |                              | SEE NOTE 3.                |                                   |                                      |
| MINIMUM 4000           | SEE NOTE 2. 439                 | 439      | 0.01925  |                              | SEE NOTE 3.                |                                   |                                      |

Max. Design Temp.: 486 °F, Max. Design Press.: SEE NOTE 4 PSIA

Max. Shut-Off Press.: SEE NOTE 5 PSI

Valve Service: OPEN/CLOSE  MODULATION

Is Flashing Expected in Valve? YES  UNLESS DOWNSTREAM ORIFICE IS USED NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
Quick Opening  Other: MODIFIED PARABOLIC

Is Tight Shut-Off Required? YES  NO


Allowable Leakage: \_\_\_\_\_  
Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
Valve Action On Loss of Power air/or sensing fluid: Opens  Closes

Form No. : \_\_\_\_\_ Date: 12/14/79

R-1  
 12/14/79  
 JER  
 43 SF 53



LV 74A NOTES

1. PRESSURE AT INTERFACE RI 8 + GRAVITY HEAD FROM FLASH TANK - FLOW FRICTIONAL LOSS = 500 psia + (H) - (F. Loss)
2. MIN PRESSURE AT INTERFACE RI 8 + GRAVITY HEAD - FLOW FRICTIONAL LOSS = 380 psia + (H) - (F. Loss)
3. DOWNSTREAM PRESSURE CAN VARY OVER THE RANGE OF 20 - 135 psia DEPENDING ON THE STATUS OF THE PLANT DURING RS FLASH TANK OPERATION
4. INTERFACE RI 8 "DESIGN" PRESSURE + GRAVITY HEAD = 600 psia + (H)
5. MAX SHUTOFF PRESS. = 500 psia + (H) - 20 psia  
 ← LOWEST DOWNSTREAM PRESS.

| DIVISION USAGE |  |  |  |  |
|----------------|--|--|--|--|
|                |  |  |  |  |
|                |  |  |  |  |

**Stearns-Roger**  
Engineering Standard

Tabbany ISSUED  
**CONTROL VALVE DESIGN SHEET** REVISED

CUSTOMER: \_\_\_\_\_ TAG NO.: LV 74B TS FLASH TANK To #2 HTR

PROJECT NO.: \_\_\_\_\_ SERVICE: TS FLASH TANK

PROJECT: \_\_\_\_\_ FLUID: CONDENSATE

|          |            |  |  |
|----------|------------|--|--|
| REV. NO. | 1          |  |  |
| DATE     | 12/15/79   |  |  |
| BY       | JER (MDAC) |  |  |

| FLOW (#/HR.) GPM, SCFM | FLUID CONDITIONS AT VALVE INLET |          |   | VALVE SYSTEM APPROX. DESIRED C <sub>v</sub> |
|------------------------|---------------------------------|----------|---|---|
|                        | PRESS. PSIA                     | TEMP. °F | DENSITY VISC., #/FT <sup>3</sup> OR S.V. FT <sup>3</sup> /# |   |
| MAXIMUM 117,500        | 165<br>SEE NOTE 1               | 358      | .01809  | SEE NOTE 2                                  |
| DESIGN 117,500         | 165<br>SEE NOTE 1               | 358      | .01809  | SEE NOTE 2                                  |
| MINIMUM 5679           | 165<br>SEE NOTE 1               | 358      | .01809  | SEE NOTE 2                                  |

Max. Design Temp.: 360 °F, Max. Design Press.: 195 (NOTE 4) PSIA

Max. Shut-Off Press.: 145 (SEE 3.) PSI

Valve Service: OPEN/CLOSE  MODULATION

Is Flashing Expected in Valve? YES  NO

Pipe Size and Schedule: \_\_\_\_\_, Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear  Equal Percentage   
Quick Opening  Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES  NO

Allowable Leakage: \_\_\_\_\_


Is Handjack or Handwheel Required? YES  NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.  Opens  Closes   
Valve Action On Loss of Power air/or sensing fluid: Opens  Closes

Form No. : \_\_\_\_\_ Date: 12/15/79

R-1  
12/14/79  
JER  
453F53



### LV 74B NOTES

1. TS FLASH TANK PRESSURE (150 psia) + PUMP HEAD RISE (15 psia). THE SPECIFIED VALUE (165 psia) NEGLECTS FLOW FRICTIONAL LOSS AND GRAVITY RISE BETWEEN THE TS CONDENSATE PUMP AND LV 74B.
2. PRESSURE DOWNSTREAM OF LV 74B CAN REACH 135 psia DURING HIGH CONDENSATE FLOW PERIODS (AT 135 psia, A PRESSURE CONTROL OVERRIDE ON LV 74B FORCES THE VALVE CLOSED) DURING LOW FLOW PERIODS, DOWNSTREAM PRESSURE MAY BE AS LOW AS 20 psia (MIN DEAERATOR PRESSURE).
3. MAX SHUTOFF PRESSURE = MAX OPERATING PRESSURE - MIN SHELL PRESSURE (MIN DEAERATOR PRESSURE) = 165 - 20 = 145 psia
4. MAX DESIGN PRESSURE = MAX DESIGN FLASH TANK PRESSURE + PUMP HEAD RISE... = 180 + 15 = 195 psia.  
(DIFFERENCES IN GRAVITY HEAD ARE IGNORED)



DIVISION USAGE

|    |   |    |    |    |     |
|----|---|----|----|----|-----|
| MM | P | PP | SH | FI | ISP |
|    |   |    |    |    |     |

**Stearns-Roger**  
Engineering Standard

EJ41.4  
Page 2

43 OF 5

Albany

CONTROL VALVE DESIGN SHEET

TV-1004

ISSUED  
REVISED

(V-23) DESUPERHEATER  
CONDENSATE CONTROL VALVE

CUSTOMER: \_\_\_\_\_

TAG NO.: \_\_\_\_\_

PROJECT NO.: \_\_\_\_\_

SERVICE: AUX STEAM

PROJECT: \_\_\_\_\_

FLUID: CONDENSATE

REV. NO.

DATE

BY

|       |  |  |  |
|-------|--|--|--|
| 1     |  |  |  |
| 12/16 |  |  |  |
| JER   |  |  |  |

| FLOW (#/HR) GPM, SCFM                 | FLUID CONDITIONS AT VALVE INLET |          |  |                                    | VALVE<br>Δ P<br>PSI | SYSTEM<br>FRICTION<br>LOSS<br>PSI | APPROX.<br>DESIRED<br>C <sub>v</sub> |
|---------------------------------------|---------------------------------|----------|--|------------------------------------|---------------------|-----------------------------------|--------------------------------------|
|                                       | PSIA                            | TEMP. OF | DENSITY<br>#/FT <sup>3</sup> OR<br>S.V. FT <sup>3</sup> /# | VISC.,<br>c <sub>p</sub> OR<br>SSU |                     |                                   |                                      |
| MAXIMUM 2292 (NOTE 1)<br>430 (NOTE 2) | 115 (NOTE 4)                    | 121      | .01621   |                                    | 10<br>(SEE NOTES)   |                                   |                                      |
| DESIGN SEE NOTE 3                     | 115 (NOTE 4)                    | 109      | .01616   |                                    | 10<br>(SEE NOTES)   |                                   |                                      |
| MINIMUM SEE NOTE 3                    | 115 (NOTE 4)                    | 109      | .01616   |                                    | 10<br>(SEE NOTES)   |                                   |                                      |

Max. Design Temp.: 135 (NOTE 6) °F, Max. Design Press.: 160 (SEE NOTE 7) PSIA

Max. Shut-Off Press.: 60 (NOTE 8) PSI

Valve Service: OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve? YES

NO

Pipe Size and Schedule: \_\_\_\_\_

Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear   
Quick Opening

Equal Percentage   
Other: LARGE TURNDOWN

Is Tight Shut-Off Required? YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES

NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.

Opens

Closes

Valve Action On Loss of Power air/cr sensing fluid


Opens

Closes

Form No. :

Date: 12/16/79

AUXILIARY STEAM NETWORK



(V-23) NOTES

1. MAX FLOW DURING RECEIVER STAND ALONE WITH RECEIVER PRODUCING 960°F STEAM.
2. MAX FLOW DURING RECEIVER STAND ALONE WITH RECEIVER PRODUCING 660°F STEAM.
3. SINCE THE AUX STEAM SYSTEM WORKS "ON DEMAND", IT SHALL HAVE A GOOD CONTROL CAPABILITY AT LOW (NEAR ZERO FLOW). THEREFORE, (V-23) SHALL HAVE A HIGH TURNDOWN CAPABILITY SUBJECT TO LIMITS OF TURNDOWN ON (V-11), (V-12), AND THE DESUPERHEATER. A TURNDOWN TO LESS THAN 50 LB/HR IS DESIRABLE.
4. A HIGHER PRESSURE (< 160 psia → ESTIMATED HOTWELL PUMP MAX PRESSURE AT MIN FLOW) MAY EXIST AT SOME PERIODS DURING LOW TOTAL FEEDWATER FLOW.
5. BASED ON 85 psia DOWNSTREAM STEAM PRESSURE, A 20 psia ΔP THROUGH THE DESUPERHEATER AND A 115 psia WATER INLET INTERFACE PRESSURE.
6. BASED ON AN ASSUMED 5 IN Hg MAX CONDENSER PRESSURE (135°F SATURATED WATER)
7. 160 psia ASSUMED MAX HOTWELL PUMP OUTLET PRESSURE
8. MAX SHUTOFF PRESSURE = NOMINAL OPER. PRESS. - MIN AUX NETWORK PRESS. = 115 - 55 = 60 psia (THIS VALUE IS 105 psia IF PUMP PRESS. = 160 psia)

DIVISION USAGE

|    |   |    |      |     |
|----|---|----|------|-----|
| AM | P | PP | SHIF | ISP |
|    |   |    |      |     |

Stearns-Roger

Engineering Standard

EJ41.4

Page 2

48 SF 53

Tahbany

CONTROL VALVE DESIGN SHEET

ISSUED

ADV-1008

REVISED

CUSTOMER: \_\_\_\_\_

TAG NO.: (V-24) ADMISSION  
STEAM TO AUX  
STEAM DESUPERHEATER

PROJECT NO.: \_\_\_\_\_

SERVICE: AUX STEAM

PROJECT: \_\_\_\_\_

FLUID: STEAM

REV. NO.

DATE

BY

|                |  |  |  |
|----------------|--|--|--|
| 1              |  |  |  |
| 1/14/80        |  |  |  |
| JER.<br>(MDAC) |  |  |  |

FLUID CONDITIONS AT VALVE INLET VALVE SYSTEM APPROX.

PRESS. TEMP. DENSITY VISC., FRICTION DESIRED

#/FT<sup>3</sup> OR c<sub>v</sub> or ΔP LOSS C<sub>v</sub>  
PSIA OF S.V. FT<sup>3</sup>/# SSU PSI PSI

| FLOW    | #/RR. GPM. SCFM    | PSIA | OF  | S.V. FT <sup>3</sup> /# | SSU | ΔP PSI    | LOSS PSI | C <sub>v</sub> |
|---------|--------------------|------|-----|-------------------------|-----|-----------|----------|----------------|
| MAXIMUM | 3765               | 72   | 460 | 8.285                   |     | NOTE<br>1 |          |                |
| DESIGN  | 3765               | 72   | 460 | 8.285                   |     | NOTE<br>1 |          |                |
| MINIMUM | 0 (SHUT OFF VALVE) | -    | -   | -                       |     | -         |          |                |

Max. Design Temp.: 860 (NOTE 2) °F, Max. Design Press.: 90 (NOTE 3) PSIA

Max. Shut-Off Press.: 75 PSI

Valve Service: OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve? YES

NO

Pipe Size and Schedule: \_\_\_\_\_

Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear

Equal Percentage

Quick Opening

Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES

NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.

Opens

Closes

Valve Action On Loss of Power air/cr sensing fluid

Opens


Closes

Form No. :

Date: 941/14/80

1/14/80  
JER  
49 SF 53

## AUXILIARY STEAM NETWORK



### V-24 NOTES

- VALVE (V-24) MUST BE SIZED TO ACCOMMODATE MAXIMUM OUTLET CONDITIONS FROM VALVE (V-12)
  - DURING OPERATION OF THE AUX STEAM NETWORK (V-24) AND (V-25) MUST BE INTERLOCKED SO THAT ONLY ONE CAN BE OPEN AT A TIME. WHEN THERMAL STORAGE STEAM GENERATOR(S) ARE OPERATING (AT DESIGN OR BLANKET STEAM PRESSURE), (V-24) IS OPEN. WHEN THE TS STEAM GENERATORS ARE PRODUCING NO STEAM PRESSURE AND BLANKETING OF THE STEAM GENERATORS ARE DESIRED, (V-25) IS OPEN.
1. FULL FLOW VALVE PRESSURE DROP SHOULD BE AS LOW AS PRACTICAL CONSISTENT WITH NORMAL ISOLATION VALVE SELECTION PRACTICES ( $\Delta P \leq \sim 2 \text{ psi}$  ESTIMATED VALUE)
  2.  $860^\circ\text{F}$  BASED ON EXPANDING MAIN STEAM FROM  $1465 \text{ psia}$ ,  $950^\circ\text{F}$  TO  $85 \text{ psia}$  (POSSIBLE CONDITION ON DOWNSTREAM SIDE OF (V-24))
  3. AUX NETWORK SAFETY VALVE SETTING

DIVISION USAGE

MM P PP SHIFLISP

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Stearns-Roger**

Engineering Standard

EJ41.4 50 OF 53

Page 2

AOV 1009

ahbany

CONTROL VALVE DESIGN SHEET

ISSUED

REVISED

CUSTOMER: \_\_\_\_\_

PROJECT NO.: \_\_\_\_\_

PROJECT: \_\_\_\_\_

(V-25) Aux STEAM  
CONNECTION TO  
TAG NO.: BLANKET TS

SERVICE: Aux STEAM

FLUID: STEAM

REV. NO.

DATE

BY

|         |  |  |  |
|---------|--|--|--|
| 1       |  |  |  |
| 1/14/80 |  |  |  |
| JER.    |  |  |  |
| (MDAC)  |  |  |  |

FLUID CONDITIONS AT VALVE INLET

PRESS. TEMP. DENSITY VISC.

PSIA OF #/FT<sup>3</sup> OR c<sub>p</sub> or

S.V. FT<sup>3</sup>/# SSU

VALVE

SYSTEM

APPROX.

FRICTION

DESIRED

LOSS

C<sub>v</sub>

Δ P

PSI

PSI

FLOW (#/HR.) GPM. SCFM

MAXIMUM 400

75

345

5.40

NOTE

1

DESIGN 100

75

345

5.40

NOTE

1

MINIMUM (ISOLATION VALVE)

75

345

5.40

—

Max. Design Temp.: 460 (NOTE 2) °F,

Max. Design Press.: 90 (NOTE 3) PSIA

Max. Shut-Off Press.: 75 PSI

Valve Service: OPEN/CLOSE

MODULATION

Is Flashing Expected in Valve? YES

NO

Pipe Size and Schedule: \_\_\_\_\_

Pipe Material: \_\_\_\_\_

Approx. Valve Body Size: \_\_\_\_\_ INCHES

Body Type: \_\_\_\_\_

Valve Characteristic: Linear

Equal Percentage

Quick Opening

Other: \_\_\_\_\_

Is Tight Shut-Off Required? YES

NO

Allowable Leakage: \_\_\_\_\_

Is Handjack or Handwheel Required? YES

NO

Special Steam Packing Considerations: \_\_\_\_\_

Valve Action On Loss of Power: Locks in Pos.

Opens

Closes

Valve Action On Loss of Power air/or sensing fluid

Opens


Closes

Form No. :

Date: 1/14/80

1/14/80  
JER  
51 OF 53

## AUXILIARY STEAM NETWORK




### V-25 NOTES

- DURING OPERATION OF THE AUX STEAM NETWORK, (V-24) AND (V-25) MUST BE INTERLOCKED SO THAT ONLY ONE CAN BE OPEN AT A TIME. WHEN THERMAL STORAGE STEAM GENERATOR(S) ARE OPERATING (AT DESIGN OR BLANKET STEAM PRESSURE), (V-24) IS OPEN. WHEN THE TS STEAM GENERATORS ARE PRODUCING NO STEAM PRESSURE AND TS BLANKETING IS DESIRED, (V-25) IS OPEN.
- 1. VALVE PRESSURE DROP AT FULL FLOW SHOULD BE AS LOW AS PRACTICAL CONSISTENT WITH NORMAL ISOLATION VALVE SELECTION PRACTICES (ESTIMATED VALUE:  $\Delta P \approx 1 \text{ PSI}$ ).
- 2. NORMAL STEAM TEMPERATURE LEAVING (V-12) WHICH WILL BE PRESENT DOWNSTREAM OF (V-25).
- 3. AUX NETWORK SAFETY VALVE SETTING



# AUXILIARY STEAM CONDENSATE SUPPLY

4/24/80  
JER  
53 OF 53



## NOTES ON VALVE LV-1

1. MAX DESIGN PRESSURE = 615 psia OCCURS WHEN THE TS FEEDWATER PUMP IS RECIRCULATING BACK TO THE DEAERATOR AND THE CHECK VALVE DOWNSTREAM OF LV-1 LEAKS.
2. MAX SHUTOFF PRESSURE OCCURS DURING HIGH DOWNSTREAM PRESSURE / LOW UPSTREAM PRESSURE CONDITION WHEN TS FEED PUMP IS OPERATING AND CHECK VALVE LEAKS.

$$\Delta P = \left( \begin{array}{c} \text{MAX DOWNSTREAM} \\ \text{PRESS} \end{array} \right) - \left( \begin{array}{c} \text{MIN DA} \\ \text{PRESSURE} \end{array} \right) - \left( \begin{array}{c} \text{UPSTREAM GRAVITY} \\ \text{HEAD FROM DA} \end{array} \right)$$

$$\Delta P = 615 \text{ psia} - 20 \text{ psia} - \sim 10 \text{ psia} = 585 \text{ psi}$$

3. PER AGREEMENT WITH SCE (4/24/80), THE ENTIRE LINE CONTAINING THIS VALVE WILL BE 1 IN AND COMPLY WITH SCE PIPE SPEC "R".





6/5/80  
10F15

# CALCULATION OF HEAT FLUX ENVIRONMENT ON HORIZONTAL PLANE ABOVE RECEIVER


## • APPROACH

- 1) DEFINE ZONES OF FIELD AND IMPACT OF EACH ZONE ON RECEIVER FLUX
- 2) BREAKDOWN ZONE COMPONENTS INTO HORIZONTAL AND VERTICAL ELEMENTS
- 3) PROJECT COMPONENTS TO HORIZONTAL PLANE ABOVE THE RECEIVER
- 4) SUPERIMPOSE VERTICAL COMPONENTS THAT STRIKE SAME ZONE ON HORIZONTAL PLANE
- 5) INTEGRATE  $360^\circ$  FIELD OF VIEW THAT IS APPROPRIATE TO THE HORIZONTAL ZONE IN QUESTION

TRANSMITTED TO R 6/6/80


611179  
4 of 15

FIGURE 3.2-2 INCIDENT HEAT FLUX PROFILE ABOVE RECEIVER UNIT



104

3.2.1-3



- DATA BASE EXPRESSED FOR VERTICAL SURFACE
- INTENSITY FROM DIRECTION  $i$   
 $C_i > 1$   
 $\sum C_i = 1$  SUM TO UNITY

• COMPONENT ATTRIBUTABLE TO  $i$  DIRECTION

$$P_{Vi} = C_i P_v$$

• PROJECTION BACK TO  $i$  DIRECTION

$$\bar{P}_{Vi} = \frac{P_{Vi}}{\cos \alpha_i} = \frac{C_i P_v}{\cos \alpha_i}$$

• PROJECTION INTO HORIZONTAL PLANE

$$\hat{P}_{Vi} = \bar{P}_{Vi} \sin \alpha_i = \frac{P_{Vi}}{\cos \alpha_i} \sin \alpha_i = C_i P_v \tan \alpha_i$$

$$\hat{P}_{Vi} = C_i P_v \tan \alpha_i$$

PROGRAM LABEL FUNCTIONS

|       |             |                                   |                         |
|-------|-------------|-----------------------------------|-------------------------|
| LBL A | PARAMETER 1 | $\alpha_1 = 15.8^\circ$<br>STO 01 | $C_1 = 0.154$<br>STO 05 |
| LBL B | PARAMETER 2 | $\alpha_2 = 25.^\circ$<br>STO 02  | $C_2 = 0.287$<br>STO 06 |
| LBL C | PARAMETER 3 | $\alpha_3 = 35^\circ$<br>STO 03   | $C_3 = 0.296$<br>STO 07 |
| LBL D | PARAMETER 4 | $\alpha_4 = 44.3^\circ$<br>STO 04 | $C_4 = 0.262$<br>STO 08 |
| LBL E | ZERO        | COEFFICIENTS                      |                         |

^ PV1 STO 09

^ PV2 STO 10

^ PV3 STO 11

^ PV4 STO 12

PV1 → LBL  
A  
\*  
RCL  
0  
1  
TAN  
\*  
RCL  
0  
5  
=  
STO  
0  
9  
HLT

PV3 → LBL  
C  
\*  
RCL  
0  
3  
TAN  
\*  
RCL  
0  
7  
=  
STO  
1  
1  
HLT

LBL  
A  
RCL  
0  
9  
+  
RCL  
1  
0  
+  
RCL  
1  
1  
+  
RCL  
1  
2  
=  
HLT

PV2 → LBL  
B  
\*  
RCL  
0  
2  
TAN  
\*  
RCL  
0  
6  
=  
STO  
1  
0  
HLT

PV4 → LBL  
D  
\*  
RCL  
0  
4  
TAN  
\*  
RCL  
0  
8  
=  
STO  
1  
2  
HLT

LBL  
E  
0  
STO  
0  
9  
STO  
1  
0  
STO  
1  
1  
STO  
1  
2  
HLT

POWER POINT SUMMARY (HORIZONTAL SURFACE)

|     |       |                   |           |
|-----|-------|-------------------|-----------|
| (a) | 1.42  | KW/m <sup>2</sup> | (-10 FT)  |
| (b) | 5.72  | KW/m <sup>2</sup> | (-1.5 FT) |
| (c) | 12.3  | KW/m <sup>2</sup> | (3.5 FT)  |
| (d) | 20.3  | KW/m <sup>2</sup> | (6.5 FT)  |
| (e) |       |                   |           |
| (f) | 19.08 | KW/m <sup>2</sup> | (11.5 FT) |
| (g) |       |                   |           |
| (h) |       |                   |           |
| (i) | 18.27 | KW/m <sup>2</sup> | (13.5 FT) |
| (j) | 17.86 | KW/m <sup>2</sup> | (14.5 FT) |
| (k) | 17.21 | KW/m <sup>2</sup> | (16.5 FT) |
| (l) | 15.86 | KW/m <sup>2</sup> | (19 FT)   |
| (m) | 13.25 | KW/m <sup>2</sup> | (22 FT)   |
| (n) | 9.13  | KW/m <sup>2</sup> | (26 FT)   |


SOUTH FIELD IMAGE SPILLAGE DATA BASE

|       |             |                                 |                        |
|-------|-------------|---------------------------------|------------------------|
| LBL A | PARAMETER 1 | $\alpha = 28.5^\circ$<br>STO 01 | $C_1 = .318$<br>STO 04 |
| LBL B | PARAMETER 2 | $\alpha = 36.5^\circ$<br>STO 02 | $C_2 = .336$<br>STO 05 |
| LBL C | PARAMETER 3 | $\alpha = 44.5^\circ$<br>STO 03 | $C_3 = .346$<br>STO 06 |

POWER POINT SUMMARY (HORIZONTAL SURFACE)

|     |                        |           |
|-----|------------------------|-----------|
| (O) | 3.04 kW/m <sup>2</sup> | (1.5 FT)  |
| (P) | 7.16 kW/m <sup>2</sup> | (4 FT)    |
| (Q) | 11.7 kW/m <sup>2</sup> | (6 FT)    |
| (R) | 11.4 kW/m <sup>2</sup> | (7 FT)    |
| (S) | 10.9 kW/m <sup>2</sup> | (8 FT)    |
| (T) | 10.8 kW/m <sup>2</sup> | (11.5 FT) |
| (U) | 10.4 kW/m <sup>2</sup> | (14.5 FT) |
| (V) | 10.2 kW/m <sup>2</sup> | (15.5 FT) |
| (W) | 9.7 kW/m <sup>2</sup>  | (17.5 FT) |
| (X) | 8.9 kW/m <sup>2</sup>  | (19 FT)   |
| (Y) | 7.8 kW/m <sup>2</sup>  | (21.5 FT) |
| (Z) | 5.6                    | (26 FT)   |

THREE DIMENSIONAL EFFECT



$$I_{TOT} = \int_0^{2\pi} I(\theta) d\theta$$

$$I(\theta) = I_0 f(\theta)$$

$$f(\theta) = \cos \frac{\theta}{2}$$

HALF CONTRIBUTION

$$I_0 = 7 \text{ kW/m}^2$$

$$I_{TOT} = 2 \int_0^{\pi} I_0 \cos \frac{\theta}{2} d\theta$$

$$= 2 I_0 \int_0^{\pi} \cos \frac{\theta}{2} d\theta$$

$$\frac{\theta}{2} = x \rightarrow \theta = 2x \rightarrow d\theta = 2dx$$


$$= 4 I_0 \int_0^{\pi/2} \cos x dx$$

$$= 4 I_0 \left[ \sin x \right]_0^{\pi/2} = 4 I_0 [1 - 0]$$


$$I_{TOT} = 4 I_0 = 28 \text{ kW/m}^2$$



ANGULAR DISTRIBUTION OF TOP SIDE SPILLAGE (NORTH)



NORTH FIELD INTENSITY VECTORS




KROHLETT & ESSEN CO. MADE IN U.S.A.  
10 X 10 10 TO 1/8" INCH 3 X 10 INCHES

48 1351


12 OF 15

# ANGULAR DISTRIBUTION OF TOP SIDE SPILLAGE (SOUTH)



| INTENSITY VECTOR | ABSOLUTE | RELATIVE |        |
|------------------|----------|----------|--------|
| 44.5             | 800      | 1.00     | (.346) |
| 36.5             | 776      | .97      | (.336) |
| 28.5             | 736      | .92      | (.318) |
|                  |          | 2.89     |        |

## INTENSITY VECTORS




K-E KENNETT & ESSER CO. MADE IN U.S.A. 10 X 10 1/4 INCH 3 X 10 INCHES

40 1351

FLUX ON N-S DOWNWARD FACING SURFACE 6 FT ABOVE RECEIVER

(2-DIMENSIONAL ANALYSIS)






14 OF 15

JER  
6/6/80

K&E  
KENNETH & EGGERS CO.  
10 X 10 TO 1/8" INCH  
W/4" M. P.P.  
3 X 10 INCHES



40 1351

# FLUX ON DOWNWARD FACING SURFACE 6 FEET ABOVE RECEIVER



NOTES :

- 1. CRANE STOWED WITH BOOM POINTING SOUTH AND COUNTER WEIGHT POINTING NORTH



4/14/80  
1 SF 3

Recommended Receiver Flash Tank Design Criteria

- Tank Diameter - 26 In (ID)
  - Max Steam Pressure - 600 psig
  - Max Steam Temperature - 950°F (limited by interlock function)
  - Design Basis - ASME Section Sec VIII Division 1
  - Corrosion Allowance - 0\*
  - Material - Alloy Steel SA-335 P22 (2 1/4 Cr - 1 Mo)
- \* Tank wall thickness shall be minimized subject to the above design criteria to minimize thermal shock operating limitations.

Receiver Flash Tank Design and Operating Constraints

1. During receiver operation (steam flowing to the main steam downcomer) when the flash tank is out of service, the flash tank shall be maintained at a temperature of 465-675°F to permit an instantaneous flow switch over. With the above temperature conditioning constraint, any fluid condition from 300°F feedwater to 950°F steam could be introduced into the flash tank.
2. If bypass orifices are used to thermally condition the flash tank, the orifice isolation valve RFSOV must be configured with a remote actuator which will be closed during receiver startup to prevent the startup nitrogen charge from flowing to the condenser. The valve shall be interlocked to flash tank pressure in a manner in which it is commanded open when PT 2906A or B (select function) signal is greater than 500 psia.
3. If bypass orifices are used, the orifice isolation valve RFSIS must have a remote actuator to prevent GN<sub>2</sub> back flow into the receiver during initial flow circulation through PV-2002 (RWBV).
4. A 400 psig nitrogen line must be routed directly to the flash tank for tank pressurization during initial flow circulation.




14/80  
8 OF 6

# ALLOWABLE INSTANTANEOUS WATER TEMPERATURE - "HOT" TANK

(ASSUMES BOILING HEAT TRANSFER)

DI = 26 IN  
3/4 IN WALL  
2 1/4 CR-1 Mo



119

# ALLOWABLE INSTANTANEOUS STEAM TEMPERATURE - "COLD" TANK

( ASSUMES CONDENSATION HEAT TRANSFER )

$D_I = 26$  IN  
3/4 IN WALL  
2 1/4 CR - 1 Mo


( EXCESSIVE  
THERMAL SHOCK )

( ALLOWABLE  
THERMAL SHOCK )

MAX ALLOWABLE  
TANK TEMP. ( 3/4" WALL )

CONDITIONING-  
LIMIT  
( MIN TEMP. )

120  
MAXIMUM ALLOWABLE STEAM TEMPERATURE - OF



200 250 300 350 400 450 500 550 600  
INITIAL TANK WALL TEMPERATURE - OF

MAXIMUM TANGENTIAL STRESS  
FROM THERMAL SHOCK


$$R_1 = 26 \text{ IN}$$

$$B_1 = 80 = \frac{hR}{K}$$

$$\sigma_T = \frac{\alpha E (T_s - T_w)}{1 - \nu}$$


$$\sigma_T = 0$$

NON-DIMENSIONAL TANGENTIAL STRESS -  $\sigma_T$



WALL THICKNESS - t - IN.

# RECEIVER FLASH TANK TEMPERATURE DECAY (NO ORIFICES)



RECEIVER FLASH TANK TEMPERATURE DECAY (NO ORIFICES)

48 1351 2A

3/1/80  
1 OF 11

## RECEIVER $G_N_2$ PRESSURIZATION AND VENT ANALYSIS

### OBJECTIVE:

- DEFINE THE QUANTITY OF  $G_N_2$  CONTAINED IN THE RECEIVER DURING STARTUP WHEN PRESSURIZATION IS REQUIRED TO PREVENT CAVITATION ACROSS THE CONTROL VALVES PRIOR TO APPLYING HEAT TO THE RECEIVER SURFACE
- CALCULATE FILL TIME ( $G_N_2$  PRESSURIZATION TIME) AS A FUNCTION OF  $G_N_2$  SYSTEM FLOW RATING  
→ ESTABLISH FLOW RATE REQUIREMENT
- ESTIMATE THE RATE AT WHICH THE  $G_N_2$  WILL FLOW FROM THE FLASH TANK TO THE DEAERATOR AND CONDENSER ONCE STEAM PRESSURE BUILDS IN THE FLASH TANK
- DEFINE DEAERATOR VENTING IMPLICATIONS TO PREVENT PLANT TRIP DUE TO A HIGH DEAERATOR PRESSURE.

3/1/80  
2 of 11

CN<sub>2</sub> VOLUME (UNMODIFIED DESIGN)

| LINE DESCRIPTION   | LENGTH    | VOLUME (TOTAL)       |
|--|-----------|----------------------|
| 1. HORIZONTAL MANIFOLD OUTLET SECTION<br>TO MOISTURE SEPARATOR<br>3" Sch 160 | 7' (x18)  | 4.73 FT <sup>3</sup> |
| 2. MOISTURE SEPARATOR (ESTIMATED)<br>6" Sch XXS                              | 1' (x18)  | 2.35 FT <sup>3</sup> |
| 3. MOISTURE SEPARATOR STEAM LINE<br>TO 3 → 1 JUNCTION<br>2" Sch 80           | 24' (x18) | 8.86 FT <sup>3</sup> |
| 4. STEAM LINE 3 → 1 JUNCTION TO<br>MAIN STEAM LINE<br>4" Sch 160             | 4.5' (x6) | 1.74 FT <sup>3</sup> |
| 5. MAIN STEAM LINE<br>6" XXS   | 9' (x1)   | 1.18 FT <sup>3</sup> |
| 6. SAFETY VALVE INLET LINES<br>3" Sch 160 (ESTIMATED)                        | 2' (x2)   | 0.15 FT <sup>3</sup> |

3/1/80  
38F11

GN<sub>2</sub> VOLUME (UNMODIFIED DESIGN)

| LINE DESCRIPTION  | LENGTH   | VOLUME-<br>(TOTAL)         |
|---|--|----------------------------|
| <p>7. STEAM LINE TO FLASH TANK<br/>           4" XXS (ASSUME ALL "HORIZONTAL"<br/>           PIPING SHOWN WITH 30° PROJECTION)<br/>           HORIZONTAL [<math>\div .866</math>]<br/>           VERTICAL</p>             | <p><math>\frac{25}{.866} = 28.86'</math><br/> <math>\frac{29.70'}{58.56'}</math></p> | <p>3.17 FT<sup>3</sup></p> |
| <p>8. MOISTURE SEPARATOR WATER OUTLET<br/>           TO RING MANIFOLD<br/>           1" Sch 80 (DIFFERENT DESIGN<br/>           FROM P+ID)<br/>           HORIZONTAL [<math>\div .866</math>]<br/>           VERTICAL</p> | <p><math>15 / .866 = 17.32'</math><br/> <math>\frac{12'}{29.32' (X18)}</math></p>    | <p>2.63 FT<sup>3</sup></p> |
| <p>9. RING MANIFOLD (CENTERLINE<br/>           DIAMETER = 3.2 FT → EQUIVALENT<br/>           STRAIGHT LENGTH<br/>           3" XXS</p>  | <p>10.05'</p>  | <p>0.29 FT<sup>3</sup></p> |

GN<sub>2</sub> VOLUME (UNMODIFIED DESIGN)

| LINE DESCRIPTION   | LENGTH        | VOLUME                |
|--|---------------|-----------------------|
| 10. WATER LINE FROM RING MANIFOLD<br>TO FLASH TANK                       |               |                       |
| 3" Sch 160   |               |                       |
| HORIZONTAL ( $\div .866$ ) 30 FT   | 34.64'        |                       |
| VERTICAL   | <u>32.50'</u> |                       |
|  | 67.14         | 2.52 FT <sup>3</sup>  |
| 11. RECEIVER FLASH TANK<br>(ESTIMATED MINIMUM ACCEPTABLE<br>VOID VOLUME) |               |                       |
| FILL TO WITHIN 3' OF THE   |               |                       |
| TOP  |               |                       |
| 26" TANK ID  |               | 11.06 FT <sup>3</sup> |
| TOTAL GN <sub>2</sub> VOLUME   |               | 38.68 FT <sup>3</sup> |



3/1/80  
5 OF 11

VOLUME FILL TIME TO 400 PSIG (GN<sub>2</sub>)

$$\text{SCF} = 38.68 \text{ FT}^3 \left( \frac{400}{14.7} \right) = 1052 \text{ SCF}$$

| <u>FILL TIME</u> | <u>GN<sub>2</sub> SYSTEM CAPACITY</u> |
|------------------|---------------------------------------|
| 21.05 min        | 50 SCFM                               |
| 10.52 MIN        | 100 SCFM                              |
| 5.26 MIN         | 200 SCFM                              |
| 3.51 MIN         | 300 SCFM                              |

3/1/80  
6 OF 11

## ESTIMATED DEAERATOR VENT VALVE REQUIREMENTS

$$C_v = \frac{q_m' \sqrt{S_g T_1}}{13.9 P_1}$$

GAS SERVICE  
CHOKED FLOW

$S_g$  = SPEC GRAVITY REL TO AIR = 0.97 For  $GN_2$

$T_1$  = ABSOLUTE TEMP °R

$P_1$  = UPSTREAM (INLET) PRESSURE (PSIA)

$q_m'$  = GAS FLOW (SCFM)

ASSUME  $P_1 = 50 \text{ psia}$


$T_1 = 281 + 460 = 741 \text{ °R}$

$$C_v = q_m' \left( \frac{\sqrt{(-.97)(741)}}{(13.9)(50)} \right) = .03858 q_m'$$

| STEAM LOSS (LB/HR) | $C_v$ | $q_m'$  | ESTIMATED VALVE SIZE | VENT TIME |
|--------------------|-------|---------|----------------------|-----------|
| 175.6 [0.39 gpm]   | 1.93  | 50 SCFM | 3/4"                 | 21.0 MIN  |
| 351 [0.78 gpm]     | 3.86  | 100     | 3/4"                 | 10.52 MIN |
| 702 [1.56 gpm]     | 7.72  | 200     | 3/4"                 | 5.26      |
| 1404 [3.12 gpm]    | 15.43 | 400     | 1 1/2"               | 2.63      |
| 2105 [4.68 gpm]    | 23.14 | 600     | 1 1/2 - 2"           | 1.75      |
| 2808 [6.24 gpm]    | 30.86 | 800     | 2"                   | 1.32      |
| 3510 [7.80 gpm]    | 38.57 | 1000    | 2 - 3"               | 1.05      |

3/1/80  
7 OF 11

# RECEIVER FLASH TANK VENT CONTROL NETWORK



VALVE Cv  
(BASED ON STEAM DUTY)

PV-2906 Cv = 18.5 - 185

PV-649 Cv = 1.33 - 10.49

PV-1000 Cv = 7.89 - 78.89

3/1/80  
8 OF 11

VALVE PY-2906

(ASSUME VALVE WIDE OPEN, CHOKED FLOW)

ASSUME  $P_1 = 500$  PSIA

$T_1 = 467 + 460 = 927$  °R

$S_g = .97$

$$q'_m = \frac{(13.9) P_1 C_v}{\sqrt{S_g T_1}}$$

$$= \frac{(13.9)(500)(185)}{\sqrt{(.97)(927)}}$$

$$= 42877 \text{ SCFM} \quad @ C_v = 185$$

$$= 4287 \text{ SCFM} \quad @ C_v = 18.5$$

VENT RATE  
1.47 SEC

14.7 SEC

ASSUME  $P_2 = 450$  PSIA (NOT CHOKED)

$$q'_m = 16 C_v \sqrt{\frac{\Delta P (P_1 + P_2)}{T_1 S_g}}$$

$$= 16 \sqrt{\frac{500 (950)}{927 (.97)}} C_v = (116.3) C_v$$

$$= 21513 \text{ SCFM} \quad @ C_v = 185$$

$$= 2151 \text{ SCFM} \quad @ C_v = 18.5$$

VENT RATE  
2.93 SEC

29.3 SEC

3/1/80

9 DF 11

VALVE PV-649

(ASSUME VALVE WIDE OPEN AND CHOKED)

ASSUME  $P_1 = 380 \text{ psia}$  $T_1 = 467^\circ\text{F} + 460 = 927^\circ\text{R}$  $P_2 = 50 \text{ psia}$  $S_g = .97$ 

$$\dot{q}_m = \frac{(13.9)(380 \text{ psia})(10.49)}{\sqrt{(.97)(927)}}$$

$$= 1847 \text{ SCFM} \quad @ \quad C_v = 10.49$$

VENT RATE

34.1 Sec

$$= 234 \text{ SCFM} \quad @ \quad C_v = 1.33$$

270 SEC

VALVE PV-1000

(ASSUME  $P_1 = 380 \text{ psia}$  $T_1 = 467 + 460 = 927^\circ\text{R}$  $P_2 = 5 \text{ psia}$  $S_g = .97$ )

$$\dot{q}_m = \frac{(13.9)(380 \text{ psia})(78.89)}{\sqrt{(.97)(927)}}$$

$$= 13896 \text{ SCFM} \quad @ \quad C_v = 78.89$$

VENT RATE

4.5 SEC

$$= 1389 \text{ SCFM} \quad @ \quad C_v = 7.89$$

45 SEC

3/1/80  
10 OF 11

CONDENSER VACUUM SYSTEM CAPABILITY  
(PER BOB WILLIAMSON 1/30/80)

7.5 SCFM @ 1" Hg CONDENSER PRESSURE  
170 SCFM @ 10" Hg TRIP PRESSURE  
(4.91 psia)

$G-N_2$  REMOVAL RATE = 140 MIN @ 7.5 SCFM  
(1" Hg)  
= 6.19 MIN @ 170 SCFM  
(10" Hg)

CONSIDER VENT OPERATION THROUGH RMSVV-1  
(POWER VENT VALVE PV 2902)

$$C_v = 65$$

ASSUME  $P_1 = 500 \text{ psia}$

$$T_1 = 467^\circ\text{F} + 460^\circ\text{R} = 927^\circ\text{R}$$

$$P_2 = \text{ATM}$$

$$S_g = 0.97$$

$$q_m = \frac{(13.9)(500 \text{ psia})(65)}{\sqrt{(0.97)(927)}}$$

|              |            |           |
|--------------|------------|-----------|
|              |            | VENT TIME |
| = 15065 SCFM | @ 500 psia | 4.2 SEC   |

|              |            |         |
|--------------|------------|---------|
| = 12052 SCFM | @ 400 psia | 5.2 SEC |
|--------------|------------|---------|

2/10/80  
1 OF 7

RECEIVER PANEL BY PANEL POWER SUMMARY

(ESTIMATED IMPACT OF REDUCING THE COLLECTOR  
FIELD SIZE)

OBJECTIVE :

ESTIMATE THE IMPACT OF REDUCED COLLECTOR  
FIELD SIZING ON RECEIVER PANEL POWER.

DEVELOP SUFFICIENT DATA TO DEFINE ANTICIPATED  
PANEL GRADIENTS.



RECEIVER PANEL POWER  
COMPARISON TABLE

SUMMER NOON  
(DAY 93)

INCIDENT POWER — MW<sub>e</sub>

| RECEIVER<br>PANEL         | COLLECTOR FIELD<br>DEFINED ON<br>30 JULY 1979<br>(1968 MMC<br>HELIOSTATS)  | COLLECTOR FIELD<br>DEFINED ON<br>18 DEC 1979<br>(1818 MMC<br>HELIOSTATS)   | POTENTIAL (FUTURE)<br>REDUCED POWER<br>COLLECTOR FIELD<br><u>ESTIMATED</u><br><u>VALUES</u>  |
|---------------------------|--|--|--|
|                           | ASSUMPTIONS:<br>$\rho_{HELIO} = .86$<br>$\alpha_{REC} = .93$<br>CONTINGENCY =<br>32 HELIO.<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.8 MW <sub>e</sub> PARASITIC | ASSUMPTIONS:<br>$\rho_{HELIO} = .89$<br>$\alpha_{REC} = .95$<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.7 MW <sub>e</sub> PARASITIC | ASSUMPTIONS:<br>$\rho_{HELIO} = .89$<br>$\alpha_{REC} = .95$<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>NOON)<br>1.7 MW <sub>e</sub> PARASITIC |
| (CLOCKWISE FROM<br>SOUTH) |  |  |  |
| 1                         | .984   | .736   | .707   |
| 2                         | 1.116  | .913   | .876   |
| 3                         | 1.347  | 1.171  | 1.124  |
| 4                         | 1.569  | 1.444  | 1.229  |
| 5                         | 1.788  | 1.689  | 1.438  |
| 6                         | 2.063  | 1.925  | 1.639  |
| 7                         | 2.382  | 2.236  | 1.904  |
| 8                         | 2.686  | 2.589  | 2.204  |
| 9                         | 2.892  | 2.862  | 2.437  |
| 10                        | 2.984  | 3.009  | 2.562  |
| 11                        | 2.957  | 3.040  | 2.588  |
| 12                        | 2.910  | 2.997  | 2.552  |
| 13                        | 2.912  | 2.997  | 2.552  |
| 14                        | 2.960  | 3.040  | 2.588  |
| 15                        | 2.990  | 3.009  | 2.562  |
| 16                        | 2.902  | 2.862  | 2.437  |
| 17                        | 2.696  | 2.589  | 2.204  |
| 18                        | 2.392  | 2.236  | 1.904  |
| 19                        | 2.071  | 1.925  | 1.639  |
| 20                        | 1.792  | 1.689  | 1.438  |
| 21                        | 1.571  | 1.444  | 1.229  |
| 22                        | 1.348  | 1.171  | 1.124  |
| 23                        | 1.116  | .913   | .876   |
| 24                        | .984   | .736   | .707   |
| TOTAL                     | 51.411   | 49.223   | 43.243   |

2/10/80  
3 OF 7

RECEIVER PANEL POWER  
COMPARISON TABLE  
INCIDENT POWER — MW<sub>e</sub>

SUMMER — 10°  
AFTERNOON  
SUN  
(DAY 93 —  
6.28 PM)

| RECEIVER<br>PANEL         | COLLECTOR FIELD<br>DEFINED ON<br>30 JULY 1979<br>(1968 MMC<br>HELIOSTATS)<br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .86<br>α <sub>REC</sub> = .93<br>CONTINGENCY =<br>32 HELIO.<br>(10 MW <sub>e</sub> WINTER<br>3 PM)<br>1.8 MW <sub>e</sub> PARASITIC | COLLECTOR FIELD<br>DEFINED ON<br>18 DEC 1979<br>(1818 MMC<br>HELIOSTATS)<br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.7 MW <sub>e</sub> PARASITIC | POTENTIAL (FUTURE)<br>REDUCED POWER<br>COLLECTOR FIELD<br><u>ESTIMATED</u><br><u>VALUES</u><br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>NOON)<br>1.7 MW <sub>e</sub> PARASITIC |
|---------------------------|---|--|---|
| (CLOCKWISE FROM<br>SOUTH) |   |  |   |
| 1                         | .327  | .247   | .237  |
| 2                         | .363  | .304   | .292  |
| 3                         | .419  | .373   | .358  |
| 4                         | .442  | .418   | .356  |
| 5                         | .433  | .421   | .358  |
| 6                         | .421  | .398   | .339  |
| 7                         | .425  | .398   | .339  |
| 8                         | .460  | .439   | .374  |
| 9                         | .526  | .518   | .441  |
| 10                        | .617  | .633   | .539  |
| 11                        | .706  | .750   | .639  |
| 12                        | .792  | .834   | .710  |
| 13                        | .881  | .914   | .778  |
| 14                        | .993  | 1.022  | .870  |
| 15                        | 1.114   | 1.115  | .949  |
| 16                        | 1.159   | 1.135  | .966  |
| 17                        | 1.093   | 1.034  | .880  |
| 18                        | .952  | .870   | .741  |
| 19                        | .802  | .749   | .638  |
| 20                        | .678  | .664   | .565  |
| 21                        | .578  | .558   | .475  |
| 22                        | .480  | .438   | .420  |
| 23                        | .386  | .328   | .315  |
| 24                        | .333  | .253   | .243  |
| TOTAL                     | 15.381  | 14.814   | 13.014  |

137

RECEIVER PANEL POWER  
COMPARISON TABLE  
INCIDENT POWER — MW<sub>e</sub>

EQUINOX  
NOON  
(DAY 186)

| RECEIVER<br>PANEL         | COLLECTOR FIELD<br>DEFINED ON<br>30 JULY 1979<br>(1968 MMC<br>HELIOSTATS)  | COLLECTOR FIELD<br>DEFINED ON<br>18 DEC 1979<br>(1818 MMC<br>HELIOSTATS)   | POTENTIAL (FUTURE)<br>REDUCED POWER<br>COLLECTOR FIELD<br><u>ESTIMATED</u><br><u>VALUES</u>  |
|---------------------------|--|--|--|
|                           | ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .86<br>α <sub>REC</sub> = .93<br>CONTINGENCY =<br>32 HELIO.<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.8 MW <sub>e</sub> PARASITIC | ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.7 MW <sub>e</sub> PARASITIC | ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>NOON)<br>1.7 MW <sub>e</sub> PARASITIC |
| (CLOCKWISE FROM<br>SOUTH) |  |  |  |
| 1                         | .821   | .621   | .596   |
| 2                         | .943   | .776   | .745   |
| 3                         | 1.162  | 1.015  | .974   |
| 4                         | 1.392  | 1.280  | 1.090  |
| 5                         | 1.640  | 1.541  | 1.312  |
| 6                         | 1.963  | 1.818  | 1.548  |
| 7                         | 2.343  | 2.189  | 1.864  |
| 8                         | 2.712  | 2.608  | 2.220  |
| 9                         | 2.981  | 2.946  | 2.508  |
| 10                        | 3.121  | 3.151  | 2.683  |
| 11                        | 3.127  | 3.221  | 2.742  |
| 12                        | 3.095  | 3.197  | 2.722  |
| 13                        | 3.097  | 3.197  | 2.722  |
| 14                        | 3.131  | 3.221  | 2.742  |
| 15                        | 3.129  | 3.151  | 2.683  |
| 16                        | 2.990  | 2.946  | 2.508  |
| 17                        | 2.723  | 2.608  | 2.220  |
| 18                        | 2.353  | 2.189  | 1.864  |
| 19                        | 1.970  | 1.818  | 1.548  |
| 20                        | 1.644  | 1.541  | 1.312  |
| 21                        | 1.393  | 1.280  | 1.090  |
| 22                        | 1.163  | 1.015  | .974   |
| 23                        | .943   | .778   | .745   |
| 24                        | .821   | .621   | .596   |
| TOTAL                     | 50.657   | 48.728   | 42.809   |

2/10/80  
1.50A7

RECEIVER PANEL POWER  
COMPARISON TABLE  
INCIDENT POWER — MW<sub>e</sub>

EQUINOX — 10°  
AFTERNOON  
SUN  
(DAY 186 —  
5.17 PM)

| RECEIVER PANEL         | COLLECTOR FIELD DEFINED ON 30 JULY 1979 (1968 MMC HELIOSTATS)<br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .86<br>α <sub>REC</sub> = .93<br>CONTINGENCY = 32 HELIO.<br>(10 MW <sub>e</sub> WINTER 2 PM)<br>1.8 MW <sub>e</sub> PARASITIC | COLLECTOR FIELD DEFINED ON 18 DEC 1979 (1818 MMC HELIOSTATS)<br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY = 0<br>(10 MW <sub>e</sub> WINTER 2 PM)<br>1.7 MW <sub>e</sub> PARASITIC | POTENTIAL (FUTURE) REDUCED POWER COLLECTOR FIELD ESTIMATED VALUES<br>ASSUMPTIONS:<br>ρ <sub>HELIO</sub> = .89<br>α <sub>REC</sub> = .95<br>CONTINGENCY = 0<br>(10 MW <sub>e</sub> WINTER NOON)<br>1.7 MW <sub>e</sub> PARASITIC |
|------------------------|---|--|---|
| (CLOCKWISE FROM SOUTH) |   |  |   |
| 1                      | .346  | .267   | .256  |
| 2                      | .338  | .278   | .267  |
| 3                      | .347  | .306   | .294  |
| 4                      | .351  | .329   | .280  |
| 5                      | .368  | .351   | .299  |
| 6                      | .428  | .388   | .330  |
| 7                      | .539  | .482   | .410  |
| 8                      | .694  | .653   | .556  |
| 9                      | .856  | .847   | .721  |
| 10                     | .981  | 1.001  | .852  |
| 11                     | 1.050   | 1.094  | .931  |
| 12                     | 1.120   | 1.181  | 1.005   |
| 13                     | 1.225   | 1.314  | 1.119   |
| 14                     | 1.325   | 1.425  | 1.213   |
| 15                     | 1.350   | 1.422  | 1.211   |
| 16                     | 1.291   | 1.314  | 1.119   |
| 17                     | 1.185   | 1.174  | 1.000   |
| 18                     | 1.042   | 1.032  | .879  |
| 19                     | .889  | .890   | .758  |
| 20                     | .753  | .766   | .652  |
| 21                     | .652  | .646   | .550  |
| 22                     | .559  | .523   | .502  |
| 23                     | .460  | .402   | .386  |
| 24                     | .386  | .306   | .294  |
| TOTAL                  | 18.535  | 18.391   | 16.157  |

RECEIVER PANEL POWER  
COMPARISON TABLE

WINTER NOON  
(DAY 276)

INCIDENT POWER — MW<sub>e</sub>

| RECEIVER PANEL         | COLLECTOR FIELD DEFINED ON 30 JULY 1979 (1968 MMC HELIOSTATS) ASSUMPTIONS: P <sub>HELIO</sub> = .86 α <sub>REC</sub> = .93 CONTINGENCY = 32 HELIO. (10 MW <sub>e</sub> WINTER 2 PM) 1.8 MW <sub>e</sub> PARASITIC | COLLECTOR FIELD DEFINED ON 18 DEC 1979 (1818 MMC HELIOSTATS) ASSUMPTIONS: P <sub>HELIO</sub> = .89 α <sub>REC</sub> = .95 CONTINGENCY = 0 (10 MW <sub>e</sub> WINTER 2 PM) 1.7 MW <sub>e</sub> PARASITIC | POTENTIAL (FUTURE) REDUCED POWER COLLECTOR FIELD ESTIMATED VALUES ASSUMPTIONS: P <sub>HELIO</sub> = .89 α <sub>REC</sub> = .95 CONTINGENCY = 0 (10 MW <sub>e</sub> WINTER NOON) 1.7 MW <sub>e</sub> PARASITIC |
|------------------------|---|--|---|
| (CLOCKWISE FROM SOUTH) |   |  |   |
| 1                      | .651  | .496   | .476  |
| 2                      | .765  | .636   | .610  |
| 3                      | .978  | .856   | .822  |
| 4                      | 1.221   | 1.117  | .951  |
| 5                      | 1.498   | 1.392  | 1.185   |
| 6                      | 1.350   | 1.700  | 1.447   |
| 7                      | 2.262   | 2.099  | 1.787   |
| 8                      | 2.662   | 2.540  | 2.162   |
| 9                      | 2.957   | 2.900  | 2.469   |
| 10                     | 3.118   | 3.120  | 2.656   |
| 11                     | 3.136   | 3.202  | 2.726   |
| 12                     | 3.114   | 3.186  | 2.712   |
| 13                     | 3.115   | 3.186  | 2.712   |
| 14                     | 3.141   | 3.202  | 2.726   |
| 15                     | 3.126   | 3.120  | 2.656   |
| 16                     | 2.967   | 2.900  | 2.469   |
| 17                     | 2.673   | 2.540  | 2.162   |
| 18                     | 2.272   | 2.099  | 1.787   |
| 19                     | 1.857   | 1.700  | 1.447   |
| 20                     | 1.501   | 1.392  | 1.185   |
| 21                     | 1.222   | 1.117  | .951  |
| 22                     | .978  | .856   | .822  |
| 23                     | .765  | .636   | .610  |
| 24                     | .651  | .496   | .476  |
| TOTAL                  | 48.482  | 46.487   | 40.840  |

140

2/10/80  
70A7

RECEIVER PANEL POWER  
COMPARISON TABLE  
INCIDENT POWER — MW<sub>e</sub>

WINTER - 10°  
AFTERNOON  
SUN  
(DAY 276 -  
3.85 PM)

| RECEIVER<br>PANEL<br>(CLOCKWISE FROM<br>SOUTH) | COLLECTOR FIELD<br>DEFINED ON<br>30 JULY 1979<br>(1968 MMC<br>HELIOSTATS)<br>ASSUMPTIONS:<br>$\rho_{HELIO} = .86$<br>$\alpha_{REC} = .93$<br>CONTINGENCY =<br>32 HELIO.<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.8 MW PARASITIC | COLLECTOR FIELD<br>DEFINED ON<br>18 DEC 1979<br>(1818 MMC<br>HELIOSTATS)<br>ASSUMPTIONS:<br>$\rho_{HELIO} = .89$<br>$\alpha_{REC} = .95$<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>2 PM)<br>1.7 MW <sub>e</sub> PARASITIC | POTENTIAL (FUTURE)<br>REDUCED POWER<br>COLLECTOR FIELD<br><u>ESTIMATED</u><br><u>VALUES</u><br>ASSUMPTIONS:<br>$\rho_{HELIO} = .89$<br>$\alpha_{REC} = .95$<br>CONTINGENCY =<br>0<br>(10 MW <sub>e</sub> WINTER<br>NOON)<br>1.7 MW <sub>e</sub> PARASITIC |
|--|--|--|---|
|  | 1  | .274   | .203  |
| 2  | .269   | .218   | .209  |
| 3  | .300   | .258   | .248  |
| 4  | .344   | .312   | .266  |
| 5  | .419   | .386   | .329  |
| 6  | .556   | .513   | .437  |
| 7  | .741   | .704   | .599  |
| 8  | .921   | .879   | .765  |
| 9  | 1.051  | 1.057  | .900  |
| 10   | 1.149  | 1.190  | 1.013   |
| 11   | 1.228  | 1.313  | 1.118   |
| 12   | 1.276  | 1.399  | 1.191   |
| 13   | 1.297  | 1.420  | 1.209   |
| 14   | 1.313  | 1.409  | 1.200   |
| 15   | 1.330  | 1.392  | 1.185   |
| 16   | 1.299  | 1.327  | 1.130   |
| 17   | 1.201  | 1.177  | 1.002   |
| 18   | 1.061  | 1.002  | .853  |
| 19   | .935   | .876   | .746  |
| 20   | .823   | .787   | .670  |
| 21   | .701   | .665   | .566  |
| 22   | .557   | .509   | .489  |
| 23   | .418   | .358   | .344  |
| 24   | .323   | .248   | .238  |
| TOTAL  | 19.784   | 19.621   | 17.238  |

141

RECEIVER TEMPERATURE HISTORY DURING LOSS OF ELECTRICAL POWER.

- THIS PACKAGE DEFINES RECEIVER METAL TEMPERATURE HISTORIES DURING LOSS OF COOLANT AND COLLECTOR FIELD ELECTRICAL POWER.
- THE FOLLOWING PARAMETRIC CASES ARE TREATED

( STANDBY POINT  
2 1/2 REC. DIAMETERS  
FROM REC CENTERLINE )

( STANDBY POINT  
5 1/2 REC. DIA.  
FROM REC.  $\phi$  )

[ POWER SWITCHOVER ] + [ MEM. RELOAD ]  
TIME TIME

[ PWR SWITCHOVER ] + [ MEM. RELOAD ]  
TIME TIME

30 SEC + 135 SEC

30 SEC + 135 SEC

30 + 100

30 + 100

30 + 70

30 + 70

30 + 40

30 + 40

30 + 10

30 + 10


15 + 10

15 + 10

- DEFOCUS STRATEGY :

DEFOCUS ON RING BY RING BASIS STARTING FROM THE OUTSIDE OF THE FIELD

Figure 1 -- Temperature response model



$$C_{panel} \frac{dT_{panel}}{dt} = \dot{q}_{absorbed} + \epsilon_2 \sigma A (T_{Rad}^4 - T_{panel}^4) + \frac{1}{R_{conv}} (T_{amb} - T_{panel})$$

$$\dot{q}_{absorbed} = \epsilon_1 \dot{q}_{incident}$$

$$R_{conv} = 1 / (h A)$$

$$C_{panel} = \text{panel capacitance (197.6 Btu/°F)}$$

$$A = \text{panel area (131.27 ft}^2\text{)}$$

$$\epsilon_1 = \text{emissivity (.93)}$$

$$\epsilon_2 = \text{emissivity (.89)}$$

$$\sigma = \text{Stefan - Boltzmann constant}$$

$$h = \text{heat transfer coefficient (4.6 } \frac{\text{Btu}}{\text{hr-ft}^2\text{-°F}}\text{)}$$

$$T_{amb} = T_{Rad} = 80^\circ\text{F}$$

Note: 45 ft panel assumed with water capacitance neglected.



| LOC | CODE | KEY            | COMMENTS  | LOC | CODE | KEY | COMMENTS    | LOC | CODE                              | KEY | COMMENTS   | LABELS  |
|-----|------|----------------|---|-----|------|-----|-------------|-----|-----------------------------------|-----|------------|---|
| 000 |      |                |   |     |      |     |             |     |                                   |     |            |   |
| 112 |      | LBL            |   |     |      | 2   |             |     |                                   | 8   |            | A   |
|     |      | A              |   |     |      | -   |             |     |                                   | ÷   |            | B   |
|     |      | RCL            |   | 040 |      | RCL |             |     |                                   | RCL |            | C   |
|     |      | 0              |   | 152 |      | 0   |             |     |                                   | 0   |            | D   |
|     |      | 1              |   |     |      | 0   |             | 080 |                                   | 3   |            | E   |
| 005 |      | Y <sup>x</sup> |   |     |      | =   |             | 192 |                                   | =   |            | A'  |
| 117 |      | 4              |   |     |      | *   |             |     |                                   | +   |            | B'  |
|     |      | -              |   |     |      | RCL |             |     |                                   | RCL |            | C'  |
|     |      | (              |   | 045 |      | 0   |             |     |                                   | 0   |            | D'  |
|     |      | RCL            |   | 157 |      | 7   |             |     |                                   | 0   |            | E'  |
|     |      | 0              |   |     |      | *   |             | 085 |                                   | =   |            | REGISTERS   |
| 10  |      | 0              |   |     |      | RCL |             | 197 |                                   | STO |            | 00 TP (°F)  |
| 122 |      | 0              |   |     |      | 1   |             |     |                                   | 0   |            | 01 TRAD (°R)  |
|     |      | +              |   |     |      | 1   |             |     |                                   | 0   |            | 02 TAMB °F  |
|     |      | 4              |   | 050 |      | =   |             |     |                                   | RCL |            | 03 CP   |
|     |      | 6              |   | 162 |      | STO |             | 090 |                                   | 1   |            | 04 α = .95  |
| 015 |      | 0              |   |     |      | 1   | } hA(TA-TP) |     |                                   | 4   |            | 05 E = .89  |
| 127 |      | )              |   |     |      | 3   |             |     |                                   |     | +          |   |
|     |      | Y <sup>x</sup> |   | 055 |      | RCL |             |     |                                   | RCL |            | 07 h = 4.6 BTU/HR-FT <sup>2</sup> -°F                                 |
|     |      | 4              |   | 167 |      | 1   |             | 095 |                                   | 0   |            | 08 ΔT   |
|     |      | =              |   |     |      | 0   |             | 207 |                                   | 8   |            | 09 TP + 460 °F  |
| 020 |      | *              |   |     |      | *   |             |     |                                   | =   |            | 10 q inc  |
| 132 |      | RCL            |   |     |      | RCL |             |     |                                   | STO |            | 11 A = 131.27 FT <sup>2</sup>   |
|     |      | 1              |   | 060 |      | 0   |             |     |                                   | 1   |            | 12 E = σA(T <sub>R</sub> <sup>4</sup> - T <sub>P</sub> <sup>4</sup> ) |
|     |      | 1              |   | 172 |      | 4   |             | 100 |                                   | 4   |            | 13 hA(TAMB - TP)  |
|     |      | *              |   |     |      | =   |             | 212 |                                   | RCL |            | 14 ΣAT  |
| 025 |      | RCL            |   |     |      | +   |             |     |                                   | 0   |            | 15 QREF   |
| 137 |      | 0              |   |     |      | RCL |             |     |                                   | 0   |            | 16  |
|     |      | 6              |   | 065 |      | 1   |             |     |                                   | HLT |            | 17  |
|     |      | *              |   | 177 |      | 2   |             | 105 |                                   | LBL | load new q | 18  |
|     |      | RCL            |   |     |      | +   |             | 217 |                                   | B   |            | 19  |
| 030 |      | 0              |   |     |      | RCL |             |     |                                   | *   |            | FLAGS   |
| 142 |      | 5              |   |     |      | 1   |             |     |                                   | RCL | STO        | 0   |
|     |      | =              |   | 070 |      | 3   |             |     |                                   | 1   | 1          | 1   |
|     |      | STO            | } εσA(T <sub>R</sub> <sup>4</sup> - T <sub>P</sub> <sup>4</sup> ) | 182 |      | =   |             | 110 |                                   | 5   | 0          | 2   |
|     |      | 1              |   |     |      |     | *           |     | 222                               |     | =          | HLT   |
| 035 |      | 2              |   |     |      | RCL |             |     |                                   |     |            | 4   |
| 147 |      | RCL            |   |     |      | 0   |             |     | TEXAS INSTRUMENTS<br>INCORPORATED |     |            |   |
|     |      | 0              |   | 075 |      | 0   |             | 187 |                                   |     |            |   |

$$T_P' - T_P = \frac{\Delta T}{C_P} \left\{ \underbrace{\dot{q}_{\text{ABS}}}_{(\dot{q}_{\text{INC}})(\alpha)} + \epsilon_2 \sigma A (T_{\text{RAD}}^4 - T_P^4) + \frac{1}{R_{\text{CONV}}} (T_{\text{AMB}} - T_P) \right\}$$

## REGISTER

|     |   |    |   |
|-----|---|----|---|
| 00  | $T_P = 1150^\circ\text{F}$                            | 06 | $\sigma = .1715 \times 10^{-8} \text{ BTU/HR-FT}^2\text{-}^\circ\text{R}^4$ |
| 01  | $T_{\text{RAD}} (^\circ\text{R}) = 540^\circ\text{F}$ | 07 | $h = 4.6 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$                         |
| 02  | $T_{\text{AMB}} = 80^\circ\text{F}$                   | 08 | $\Delta T = \frac{10}{3600} = .0027777$                                     |
| 03  | $C_P = 197.6 \text{ BTU/}^\circ\text{F}$              | 09 | $T_P + 460^\circ\text{F}$   |
| 04  | $\alpha = .95$  | 10 | $\dot{q}_{\text{INC}} \quad f_n (T) \quad \text{INPUT}$                     |
| 05  | $\epsilon = .89$                                      | 11 | $A = 131.27 \text{ FT}^2$   |
|     |   | 12 | $\epsilon_2 \sigma A (T_{\text{RAD}}^4 - T_P^4)$                            |
|     |   | 13 | $h A (T_{\text{AMB}} - T_P)$  |
| LBL |   | 14 | $\Sigma \Delta T$   |
|     |   | 15 | $Q_{\text{REF}} = 3.25 \times 3.413 \times 10^6$                            |

30 SEC POWER SWITCHOVER

100 SEC MEMORY RELOAD CASE 2A

WORKSHEET 30 SEC POWER SWITCHOVER

FORM 30-103-1 (REV. 10-87) 135 SEC MEMORY RELOAD CASE 1A

| TIME | TEMP | TIME | TEMP | TIME | TEMP | TIME | TEMP | TIME | TEMP | TIME | TEMP | STANDBY | Q         |
|------|------|------|------|------|------|------|------|------|------|------|------|---------|-----------|
| 165  | 2105 | 280  | 1349 | 130  | 2052 | 280  | 1205 | 130  | 2052 | 280  | 1205 | 2 1/2   | REC. DIA. |
| 170  | 2094 | 300  | 1268 | 135  | 2047 | 300  | 1142 | 135  | 2047 | 300  | 1142 |         |           |
| 175  | 2071 | 320  | 1198 | 140  | 2027 | 320  | 1088 | 140  | 2027 | 320  | 1088 |         |           |
| 180  | 2043 | 340  | 1137 | 145  | 2004 | 340  | 1039 | 145  | 2004 | 340  | 1039 |         |           |
| 185  | 2009 | 360  | 1083 | 150  | 1974 | 360  | 995  | 150  | 1974 | 360  | 995  |         |           |
| 190  | 1973 | 380  | 1034 | 155  | 1940 | 380  | 954  | 155  | 1940 | 380  | 954  |         |           |
| 195  | 1930 | 400  | 990  | 160  | 1900 | 400  | 917  | 160  | 1900 | 400  | 917  |         |           |
| 200  | 1891 |      |      | 165  | 1864 |      |      | 165  | 1864 |      |      |         |           |
| 205  | 1850 |      |      | 170  | 1825 |      |      | 170  | 1825 |      |      |         |           |
| 210  | 1807 |      |      | 175  | 1783 |      |      | 175  | 1783 |      |      |         |           |
| 215  | 1762 |      |      | 180  | 1740 |      |      | 180  | 1740 |      |      |         |           |
| 220  | 1721 |      |      | 200  | 1580 |      |      | 200  | 1580 |      |      |         |           |
| 240  | 1566 |      |      | 220  | 1458 |      |      | 220  | 1458 |      |      |         |           |
| 260  | 1446 |      |      | 240  | 1359 |      |      | 240  | 1359 |      |      |         |           |
|      |      |      |      | 260  | 1276 |      |      | 260  | 1276 |      |      |         |           |

WORKSHEET

FORM 30-103-1 (REV. 10-67)

30 SEC POWER SWITCHOVER

70 SEC MEMORY RELOAD

CASE 3A

30 SEC POWER SWITCHOVER

40 SEC MEMORY RELOAD CASE 4A

6 OF 16

|  | TIME | TEMP   |  | TIME | TEMP |  |  | TIME | TEMP |  | TIME | TEMP | STANDBY @      |
|--|------|--------|--|------|------|--|--|------|------|--|------|------|----------------|
|  | 100  | 1964.5 |  | 280  | 1105 |  |  | 70   | 1814 |  | 280  | 1010 | 2 1/2 REC DIA. |
|  | 105  | 1967   |  | 300  | 1054 |  |  | 75   | 1828 |  | 300  | 968  |                |
|  | 110  | 1955   |  | 320  | 1009 |  |  | 80   | 1827 |  | 320  | 930  |                |
|  | 115  | 1938   |  | 340  | 967  |  |  | 85   | 1820 |  | 340  | 895  |                |
|  | 120  | 1913   |  | 360  | 929  |  |  | 90   | 1804 |  | 360  | 863  |                |
|  | 125  | 1884   |  | 380  | 894  |  |  | 95   | 1783 |  | 380  | 833  |                |
|  | 130  | 1849   |  | 400  | 862  |  |  | 100  | 1755 |  | 400  | 805  |                |
|  | 135  | 1816   |  |      |      |  |  | 105  | 1729 |  |      |      |                |
|  | 140  | 1781   |  |      |      |  |  | 110  | 1700 |  |      |      |                |
|  | 145  | 1742   |  |      |      |  |  | 115  | 1660 |  |      |      |                |
|  | 150  | 1702   |  |      |      |  |  | 120  | 1631 |  |      |      |                |
|  | 160  | 1627   |  |      |      |  |  | 140  | 1497 |  |      |      |                |
|  | 180  | 1494   |  |      |      |  |  | 160  | 1391 |  |      |      |                |
|  | 200  | 1389   |  |      |      |  |  | 180  | 1303 |  |      |      |                |
|  | 220  | 1301   |  |      |      |  |  | 200  | 1228 |  |      |      |                |
|  | 240  | 1227   |  |      |      |  |  | 220  | 1163 |  |      |      |                |
|  | 260  | 1162   |  |      |      |  |  | 240  | 1106 |  |      |      |                |
|  |      |        |  |      |      |  |  | 260  | 1056 |  |      |      |                |

148

WORKSHEET

FORM 30-103-1 (REV. 10-67) 10 SEC MEMORY LOAD

30 SEC POWER SWITCHOVER

CASE 5A

15 SEC POWER SWITCHOVER

10 SEC MEMORY RELOAD

CASE 6A

|  | TIME | TEMP |  | TIME | TEMP |  |  | TIME | TEMP |  | TIME | TEMP | STANDBY   | ⊙    |
|--|------|------|--|------|------|--|--|------|------|--|------|------|-----------|------|
|  | 40   | 1584 |  | 220  | 1037 |  |  | 25   | 1436 |  | 220  | 969  | 2 1/2 REC | DIA. |
|  | 45   | 1612 |  | 240  | 993  |  |  | 30   | 1471 |  | 240  | 931  |           |      |
|  | 50   | 1624 |  | 260  | 953  |  |  | 35   | 1490 |  | 260  | 896  |           |      |
|  | 55   | 1630 |  | 280  | 916  |  |  | 40   | 1502 |  | 280  | 864  |           |      |
|  | 60   | 1626 |  | 300  | 882  |  |  | 45   | 1505 |  | 300  | 834  |           |      |
|  | 65   | 1617 |  | 320  | 851  |  |  | 50   | 1502 |  | 320  | 806  |           |      |
|  | 70   | 1599 |  | 340  | 822  |  |  | 55   | 1490 |  | 340  | 779  |           |      |
|  | 75   | 1582 |  | 360  | 794  |  |  | 60   | 1479 |  | 360  | 755  |           |      |
|  | 80   | 1561 |  | 380  | 768  |  |  | 65   | 1463 |  | 380  | 731  |           |      |
|  | 85   | 1535 |  | 400  | 744  |  |  | 70   | 1441 |  | 400  | 710  |           |      |
|  | 90   | 1506 |  |      |      |  |  | 75   | 1417 |  |      |      |           |      |
|  | 100  | 1452 |  |      |      |  |  | 80   | 1394 |  |      |      |           |      |
|  | 120  | 1354 |  |      |      |  |  | 100  | 1306 |  |      |      |           |      |
|  | 140  | 1272 |  |      |      |  |  | 120  | 1231 |  |      |      |           |      |
|  | 160  | 1202 |  |      |      |  |  | 140  | 1166 |  |      |      |           |      |
|  | 180  | 1140 |  |      |      |  |  | 160  | 1108 |  |      |      |           |      |
|  | 200  | 1086 |  |      |      |  |  | 180  | 1057 |  |      |      |           |      |
|  |      |      |  |      |      |  |  | 200  | 1011 |  |      |      |           |      |


149

7 OF 16

SLEW OFF TIMES

| RING | DISTANCE  | TIME               |                       | @ 13.5°/min HELIOSTAT MOTION (27°/MIN BEAM) |                           |
|------|-----------|--------------------|-----------------------|---|---------------------------|
|      |           | CLEAR<br>(→ 23 FT) | RECEIVED<br>(→ 23 FT) | MOVE 2½ DIAMETERS<br>(→ 57.5 FT)            | MOVE 5½ DIA<br>(126.5 FT) |
| 5    | 1317.5 FT | 2.22 Sec           |                       | 5.56 Sec                                    | 12.22 Sec                 |
|      | 1202.3 FT | 2.43 Sec           |                       | 6.09 Sec                                    | 13.39 Sec                 |
| 4    | 1140.3 FT | 2.57 Sec           |                       | 6.42 Sec                                    | 14.12 Sec                 |
|      | 995.0 FT  | 2.94 Sec           |                       | 7.36 Sec                                    | 16.18 Sec                 |
| 3    | 950.7 FT  | 3.08 Sec           |                       | 7.70 Sec                                    | 16.95 Sec                 |
|      | 770.3 FT  | 3.80 Sec           |                       | 9.50 Sec                                    | 20.90 Sec                 |
| 2    | 734.8 FT  | 3.98 Sec           |                       | 9.96 Sec                                    | 21.91 Sec                 |
|      | 564.3 FT  | 5.19 Sec           |                       | 12.97 Sec                                   | 28.52 Sec                 |
| 1    | 535.2 FT  | 5.47 Sec           |                       | 13.67 Sec                                   | 30.08 Sec                 |
|      | 239.6 FT  | 12.18 Sec          |                       | 30.46 Sec                                   | 67.01 Sec                 |

INCREMENTAL DEFOCUS TO  
2 1/2 RECEIVER DIAMETERS




TIME AFTER MANUAL POWER ACTIVATION  
AND MEMORY RELEASE (SEC)

10 OF 16

K&E KETCHUM & FARRIS CO. MADE IN U.S.A. 10 X 10 1/2 INCH 1 X 10 INCHES

40 135A





PANEL HEATUP

— 30 SEC OVER SWITCHOVER  
— 135 SEC MEMORY RELOAD

CASE

NOF 16

| TIME    | TP                  | TIME | TP   | TIME | TP   | TIME | TP | TIME | TP | STANDBY @      |
|---------|---------------------|------|------|------|------|------|----|------|----|----------------|
| 0       | 1150 <sup>o</sup> F | 170  | 2095 | 270  | 1551 |      |    |      |    | 5 1/2 REC DIAM |
| 10 sec  | 1270                | 175  | 2086 | 280  | 1493 |      |    |      |    |                |
| 20 sec  | 1383                | 180  | 2069 | 290  | 1440 |      |    |      |    |                |
| 30 sec  | 1488                | 185  | 2048 | 300  | 1392 |      |    |      |    |                |
| 40 sec  | 1584                | 190  | 2028 | 310  | 1348 |      |    |      |    |                |
| 50 sec  | 1670                | 195  | 2009 | 320  | 1308 |      |    |      |    |                |
| 60 sec  | 1747                | 200  | 1978 | 330  | 1270 |      |    |      |    |                |
| 70 sec  | 1814                | 205  | 1950 | 340  | 1235 |      |    |      |    |                |
| 80 sec  | 1872                | 210  | 1925 | 350  | 1202 |      |    |      |    |                |
| 90 sec  | 1923                | 215  | 1901 | 360  | 1171 |      |    |      |    |                |
| 100 sec | 1964.5              | 220  | 1866 | 370  | 1142 |      |    |      |    |                |
| 110 sec | 1999                | 225  | 1832 | 380  | 1115 |      |    |      |    |                |
| 120 sec | 2028                | 230  | 1801 | 390  | 1089 |      |    |      |    |                |
| 130 sec | 2052                | 235  | 1772 | 400  | 1065 |      |    |      |    |                |
| 140 sec | 2071                | 240  | 1744 |      |      |      |    |      |    |                |
| 150 sec | 2087                | 245  | 1717 |      |      |      |    |      |    |                |
| 160 sec | 2100                | 250  | 1686 |      |      |      |    |      |    |                |
| 165 sec | 2105                | 255  | 1651 |      |      |      |    |      |    |                |
| START   |                     | 260  | 1616 |      |      |      |    |      |    |                |
| DEFOCUS |                     |      |      |      |      |      |    |      |    |                |

30 SEC POWER SWITCHOVER  
100 SEC MEMORY RELOAD  
CASE 2

30 SEC POWER SWITCHOVER 12 OF 16  
70 SEC MEMORY RELOAD  
CASE 3

STANDBY @

|  | TIME | TP   |  | TIME | TP   |  |  | TIME | TP     |  | TIME | TP   |  | 5 1/2 REC | DIA |
|--|------|------|--|------|------|--|--|------|--------|--|------|------|--|-----------|-----|
|  | 130  | 2052 |  | 250  | 1473 |  |  | 100  | 1964.5 |  | 200  | 1558 |  |           |     |
|  | 135  | 2047 |  | 260  | 1421 |  |  | 105  | 1967.2 |  | 210  | 1499 |  |           |     |
|  | 140  | 2042 |  | 270  | 1375 |  |  | 110  | 1969   |  | 220  | 1445 |  |           |     |
|  | 145  | 2030 |  | 280  | 1332 |  |  | 115  | 1964   |  | 230  | 1397 |  |           |     |
|  | 150  | 2012 |  | 290  | 1293 |  |  | 120  | 1952   |  | 240  | 1353 |  |           |     |
|  | 155  | 1996 |  | 300  | 1256 |  |  | 125  | 1941   |  | 250  | 1312 |  |           |     |
|  | 160  | 1980 |  | 310  | 1222 |  |  | 130  | 1929   |  | 260  | 1274 |  |           |     |
|  | 165  | 1951 |  | 320  | 1190 |  |  | 135  | 1905   |  | 270  | 1238 |  |           |     |
|  | 170  | 1926 |  | 330  | 1160 |  |  | 140  | 1883   |  | 280  | 1205 |  |           |     |
|  | 175  | 1901 |  | 340  | 1132 |  |  | 145  | 1863   |  | 290  | 1174 |  |           |     |
|  | 180  | 1880 |  | 350  | 1105 |  |  | 150  | 1844   |  | 300  | 1145 |  |           |     |
|  | 190  | 1847 |  | 360  | 1079 |  |  | 155  | 1813   |  | 310  | 1117 |  |           |     |
|  | 195  | 1814 |  | 370  | 1055 |  |  | 160  | 1783   |  | 320  | 1092 |  |           |     |
|  | 200  | 1784 |  | 380  | 1033 |  |  | 165  | 1755   |  | 330  | 1067 |  |           |     |
|  | 205  | 1756 |  | 390  | 1011 |  |  | 170  | 1729   |  | 340  | 1043 |  |           |     |
|  | 210  | 1728 |  | 400  | 990  |  |  | 175  | 1705   |  | 350  | 1021 |  |           |     |
|  | 215  | 1697 |  |      |      |  |  | 180  | 1680   |  | 360  | 1000 |  |           |     |
|  | 220  | 1661 |  |      |      |  |  | 185  | 1657   |  | 370  | 980  |  |           |     |
|  | 230  | 1591 |  |      |      |  |  | 190  | 1624   |  | 380  | 960  |  |           |     |
|  | 240  | 1528 |  |      |      |  |  |      |        |  | 390  | 941  |  |           |     |
|  |      |      |  |      |      |  |  |      |        |  | 400  | 923  |  |           |     |

154

STANDBY @

| TIME | TP   | TIME | TP   | TIME | TP   | TIME | TP   | 5 1/2 | REC | DIA |
|------|------|------|------|------|------|------|------|-------|-----|-----|
| 70   | 1814 | 170  | 1517 | 40   | 1584 | 140  | 1450 |       |     |     |
| 75   | 1828 | 180  | 1462 | 45   | 1612 | 160  | 1352 |       |     |     |
| 80   | 1842 | 190  | 1412 | 50   | 1639 | 180  | 1270 |       |     |     |
| 85   | 1846 | 200  | 1366 | 55   | 1656 | 200  | 1200 |       |     |     |
| 90   | 1843 | 210  | 1324 | 60   | 1666 | 220  | 1139 |       |     |     |
| 95   | 1841 | 220  | 1285 | 65   | 1675 | 240  | 1084 |       |     |     |
| 100  | 1837 | 240  | 1213 | 70   | 1682 | 260  | 1036 |       |     |     |
| 105  | 1820 | 260  | 1150 | 75   | 1676 | 280  | 992  |       |     |     |
| 110  | 1804 | 280  | 1095 | 80   | 1669 | 300  | 952  |       |     |     |
| 115  | 1790 | 300  | 1045 | 85   | 1663 | 320  | 915  |       |     |     |
| 120  | 1776 | 320  | 1000 | 90   | 1658 | 340  | 881  |       |     |     |
| 125  | 1750 | 340  | 959  | 95   | 1639 | 360  | 850  |       |     |     |
| 130  | 1724 | 360  | 922  | 100  | 1620 | 380  | 821  |       |     |     |
| 135  | 1700 | 380  | 887  | 105  | 1602 | 400  | 794  |       |     |     |
| 140  | 1678 | 400  | 856  | 110  | 1585 |      |      |       |     |     |
| 145  | 1656 |      |      | 115  | 1569 |      |      |       |     |     |
| 150  | 1635 |      |      | 120  | 1552 |      |      |       |     |     |
| 155  | 1609 |      |      | 125  | 1530 |      |      |       |     |     |
| 160  | 1578 |      |      | 130  | 1504 |      |      |       |     |     |
|      |      |      |      |      |      |      |      |       |     |     |
|      |      |      |      |      |      |      |      |       |     |     |
|      |      |      |      |      |      |      |      |       |     |     |

155

WORKSHEET

15 SEC POWER SWITCHOVER

FORM 30-103-1 (REV. 10-67)

10 SEC MEMORY RELOAD


CASE 6

STANDBY @

|  | TIME | TEMP |  | TIME | TEMP |  |  |  |  |  |  |  |  |  |  |  |  |  | 5 1/2 | REC | DIA |
|--|------|------|--|------|------|--|--|--|--|--|--|--|--|--|--|--|--|--|-------|-----|-----|
|  | 25   | 1436 |  | 130  | 1376 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 30   | 1471 |  | 150  | 1290 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 35   | 1505 |  | 170  | 1218 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 40   | 1529 |  | 190  | 1154 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 45   | 1545 |  | 210  | 1098 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 50   | 1561 |  | 230  | 1048 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 55   | 1574 |  | 250  | 1003 |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 60   | 1574 |  | 270  | 962  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 65   | 1573 |  | 290  | 925  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 70   | 1573 |  | 310  | 890  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 75   | 1572 |  | 330  | 858  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 80   | 1558 |  | 350  | 828  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 85   | 1543 |  | 370  | 800  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 90   | 1529 |  | 390  | 774  |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 95   | 1516 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 100  | 1503 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 105  | 1490 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 110  | 1471 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 115  | 1447 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |
|  | 120  | 1423 |  |      |      |  |  |  |  |  |  |  |  |  |  |  |  |  |       |     |     |

156


RECEIVER PANEL TEMPERATURE DURING LOSS  
OF POWER EMERGENCY DEFOCUS



K&E KENNEL & ESPEL CO. MADE IN U.S.A.  
10 X 10 TO 1 1/2 INCH 3 X 10 INCHES

40 1351

# RECEIVER POWER DECAY



Receiver Drain Calc.

ROM water volume to be drained

• Tube .269 ID  $\rightarrow A = .0003947 \text{ ft}^2$   
 $V = (70 \text{ TUBES})(24 \text{ PANELS})(51 \text{ FT})(.0003947) = 33.815 \text{ FT}^3$

• Manifolds ID=11 in  $A = .6599 \text{ FT}^2$   
 $V = (1.5 \text{ FT LENGTH})(.6599 \text{ FT}^2)(48 \text{ MANIFOLDS}) = 47.517 \text{ FT}^3$

• Vertical pipes (Sch 160)  
 $2\frac{1}{2} \text{ in} \rightarrow A = .02463 \text{ FT}^2$   
 $4 \text{ in} \rightarrow A = .06447 \text{ FT}^2$   
 $(2\frac{1}{2} \text{ pipe})(3 \text{ pipes})(45 \text{ FT})(.02463) = 3.325 \text{ FT}^3$   
 $4 \text{ in pipe: } (45 \text{ FT})(.06447) = 2.901 \text{ FT}^3$

total drain volume 87.558 FT<sup>3</sup>

Assume 220° F water  
 $\rho = 60 \text{ LB/FT}^3$   
 $1 \text{ gal} = 8.02 \text{ lb}$

total water  
 5253 lb  
 655 gal

assume  $\Delta P = 10 \text{ PSI}$  frictional drop in drain line  
 "  $L = 400 \text{ ft}$

$1\frac{1}{2} \text{ " Sch 40} \rightarrow 30 \text{ gal/min drain rate}$   
 $14,436 \text{ lb/hr}$   
 $4.01 \text{ CFM}$  21 min drain rate

$3 \text{ " Sch 40} \rightarrow 175 \text{ gal/min drain rate}$   
 $84,210 \text{ lb/hr}$   
 $159 \text{ 23.39 CFM}$  3.7 minutes drain rate

ASSUME 200 PSIA  $\Delta P$   
L = 400 FT

1 1/2" Sch 40  $\rightarrow$  134 gal/min  
4.88 min drain time  
17.9 CFM

3" Sch 40  $\rightarrow$  781.6 gal/min  
.838 min drain time  
104 CFM

GRAVITY HEAD - 280 ft of 220°F WATER

$$\rho = \frac{1}{.01677} = 60 \frac{\text{lb}}{\text{ft}^3}$$

$$\Delta P = \rho h = \frac{(60 \frac{\text{lb}}{\text{ft}^3})(280 \text{ FT})}{144} = 117 \text{ PSIA}$$

MAX TEMP.



MEMORANDUM

A3-233-EP-RES-1106

11 December 1979

To: J. E. Raetz

Subject: DOWNCOMER START-UP RAMP RATE RECOMMENDATION

From: R. E. Snyder

Copies to: R. G. Riedesel, E. J. Riel, G. C. Coleman, R. J. Perkins

The purpose of this memo is to determine the maximum allowable temperature ramp rate of the downcomer during plant start-up.

Standard practice for a 600 MW plant allows a ramp rate of 15°F/minute. This temperature is measured by a thermocouple welded to the outside of the pipe. The following analysis tracks the outside temperature of the 660 MW main steam line for several start-up weight flows representing different Biot numbers (Bi) in order to bracket the 15°F/minute case. The Biot number measures the influence of the film coefficient to conduction of the heat transfer process. Conduction controls at high numbers and the film coefficient controls at low Biot numbers.

Three equivalent cases were analysed for the downcomer and the results were correlated to the 660 MW steam line case. It was assumed that both the downcomer and the 660 MW steam line operated under the same conditions i.e., initial temperature 200°F (auxiliary steam blanket) and 500 psia steam condensing on the walls (467°F saturation temperature).

As a result of the analysis it is recommended that the start-up weight flow be limited to 11300 #/Hr for start-up, corresponding to a Biot number of 5. This results in a maximum stress of approximately 70% of that (-25061 #/in<sup>2</sup>) developed in the 660 MW steam line (-35381 #/in<sup>2</sup>).

The method used (Reference 1) is summarized as follows:

At T = 0 the steam line is assumed to be at uniform temperature (200°F). When steam is introduced into the pipe it condenses on the wall at saturation temperature which is assumed to be constant during warm up, i.e., the pressure is held constant (500 psia, 467°F). The external pipe surface is assumed to be perfectly insulated and heating of the insulation is disregarded.

The differential equation for heat conduction is of the form  $\frac{dt}{dT} = a \left[ \frac{dt}{dr^2} + \frac{dT}{dr} \right]$  (1)

The initial and boundary conditions are:

$$T(r,0) = T_0 \quad (2)$$

$$dt(r_n, T) = -\frac{x}{\lambda} (T_s - T) \quad (3)$$

$$\frac{dt(r_{ex}, T)}{dr} = 0$$

The general solution in terms of dimensionless quantities and parameters is as follows:

$$\frac{\theta}{\theta_0} = \sum_{m=1}^{\infty} e^{-\mu_n^2 Fo} A_N M_N \quad (4)$$

$$\text{Where } A_N = \frac{\pi Bi x}{\mu_n} \frac{[J_1(\mu_n) + \frac{Bi}{\mu_n} J_0(\mu_n)] J_1(\beta_0 \mu_n)}{[J_0(\mu_n) + \frac{Bi}{\mu_n} J_0(\mu_n)]^2 - [1 + \frac{(Bi)^2}{\mu_n^2}] J_1^2(\beta_0 \mu_n)}$$

$$M_N = J_1(\beta_0 \mu_n) Y_0(\beta_0 \mu_n) - Y_1(\beta_0 \mu_n) J_0(\beta_0 \mu_n)$$

$\mu_n$  = roots of the characteristic equation are obtained from the boundary condition (3)

$$\frac{Y_1(\beta_0 \mu_n)}{J_1(\beta_0 \mu_n)} \frac{[J_1(\mu_n) + \frac{Bi}{\mu_n} J_0(\mu_n)]}{[Y_1(\mu_n) + \frac{Bi}{\mu_n} Y_0(\mu_n)]} = 1 \quad (5)$$

Where  $J_0$  &  $Y_0$  = Bessel functions of the first and second kind of zero order.

$J_1$  &  $Y_1$  = Bessel functions of the first and second kind of the first order.

$$Bi = \text{Biot number} = \frac{hr_{in}}{k}$$

$$\beta = r_{in}$$

$$\beta_0 = r_{ex}/r_{in}$$

$r$  = radius of pipe-ft

$T$  = time from initial shock-sec.

A3-233-EP-RES-1106  
11 December 1979

$k$  = thermal conductivity of steel - BTU/FT HR °F

$h$  = heat transfer coefficient - BTU/FT<sup>2</sup> °F

$$a = \frac{k}{\rho c}$$

$Fo$  = Fourier number =  $aT/r_n^2$

$\rho$  = Density of steel - #/FT<sup>3</sup>

$c$  = Specific heat of steel - BTU/# °F

$T$  = temperature - °F

$$\frac{\theta}{\theta_0} = \frac{T_{\text{steam}} - T_r}{T_{\text{steam}} - T_{r_0}}$$

The downcomer is 6 5/8 in. OD with a .864 in wall. Typical 660 MW power plant main steam line is 26 5/8 in. OD with a 4 3/16 in. wall.

It was assumed that  $\beta_0$  for the downcomer was 1.4 (actual  $\beta_0 = 1.353$ ) this was conservative as the stress rises as  $\beta_0$  increases.

Roots ( $\mu_n$ ) were determined for  $\beta_0 = 1.4$  and  $Bi = 5, 10 \& 20$  for the downcomer, and  $\beta_0 = 1.459$  and  $Bi = 10, 20, 40, 60, \& 80$  for the 600 MW main steam line, Table I.

Equation (4) converges so rapidly that only 3 roots per case were required for high accuracy.

Outside wall temperatures were determined by evaluating equation (4) for each of the above cases for various times from initial shock. The 660 MW main steam line was evaluated from 0 to 1800 sec. (.5 Hrs.) and the downcomer was evaluated from 0 to 120 sec. (2 min.) so that both pipes were evaluated over the same range of Fourier numbers (dimensionless time). Due to the difference in inside radius the equivalent time for the main steam line is 13.9 times that of the downcomer.

The results of this evaluation is shown in Figures 1 & 2.

Figure 3 shows curves of nondimensional stress ( $\sigma_T$ ) versus Fourier number from reference 1 for various combinations of  $Bi$  and  $\beta_0$ .

$$\text{The absolute stress } \sigma_T = \frac{E(T_S - T_0)}{(1 - \nu)} \bar{\sigma}_T$$

Where  $\epsilon$  = Coefficient of expansion - in/u°F

$E$  = Modulus of elasticity - #/in<sup>2</sup>

$\nu$  = Poissons Ratio

The resulting maximum tangential stress is shown in Figures 1 & 2 for the two pipes in question.

For any given pipe configuration the Biot number defines the required heat transfer coefficient (h) to satisfy that condition. Film wise condensation is defined by reference 2.

$$h = 0.65 \frac{(D-F f)^{1/2}}{2D-G} (NPR)^{-1/2} C_P \frac{W}{A}$$

Where:

$$f = \frac{.046}{(W 2r_n)} \cdot 2$$
  
$$\frac{A \mu_g}{}$$

$$h = Bi \frac{K}{r_{in}}$$

Substituting and rearranging

$$W = A \left[ \frac{K}{r_{in}} Bi (NPR)^{1/w} \right] \frac{1}{.9}$$
  
$$\left[ \frac{.065 C_P \left\{ \frac{.046 D-F}{2D-G} \left( \frac{2r_{in}}{\mu} \right) \cdot 2 \right\}^{1/2}}{.9} \right]$$

The weight flow and heat transfer coefficient for each case of interest was computed and tabulated in Table II.

Table III tabulates corresponding equivalent times from beginning of shock for the downcomer compared to 660 MW main steam line times.

The maximum tangential stress, as a function of time for the downcomer was calculated at a Biot number of 5 and its maximum stress is always below that of the 660 MW main steam line calculated at a Biot number of 10. It should be noted that the peak maximum stress for the downcomer is approximately 70% of the 660 MW steam line (corresponding roughly to a temperature ramp of 15°/minute). It should also be noted that the maximum stress in the 660 MW line occurs (Bi = 10) at approximately a Fourier number of .025 corresponding to 102 seconds after the initial shock and reduces to approximately half the maximum value in about 10 minutes. On the other hand the downcomer reaches its maximum stress (Bi = 5) at a Fourier number of approximately .025 corresponding to 7.3 seconds after the initial shock and reduces to one half its maximum value in about 48 seconds. It is also interesting to note that a 15°F/minute ramp rate in the 660 MW pipe is equivalent to a ramp rate of 208°F/minute in the downcomer.

Therefore to be conservative it is recommended that during initial start-up of the 10 MW plant a Biot number of 5 be maintained (essentially reducing the maximum stress to about 70% of that occurring in the 660 MW main steam pipe operating at a Biot number of 10). In addition it is recommended that the ramp rate during start up be limited to 200°F/minute for conservatism. The recommended

Biot number of 5 for the downcomer corresponds to a weight flow of approximately 11300 #/hr of steam.

References = 1 Teploenergetika, 1971 18 (2) 78 - 12  
2 GE Heat Transfer and Fluid Flow Data Book, April 1979

For further information contact the undersigned.

*[Handwritten signature]*  
R. E. Snyder

RES:lp

Attachments as noted

TABLE I  
 ROOTS ( $\mu_m$ ) OF CHARACTERISTIC EQUATION  
 FOR DOWNCOMER & 660 MW STEAM LINE

| DOWNCOMER   | 660 MW MAIN STEAM LINE  |
|---|---|
| $B_0 = 5$<br>$\beta_0 = 1.4$<br>$\mu-1$ : 2.470703125<br>$\mu-2$ : 9.103515625<br>$\mu-3$ : 16.454114375  | $B_0 = 20$<br>$\beta_0 = 1.45890411$<br>$\mu-1$ : 2.990234375<br>$\mu-2$ : 9.671191406<br>$\mu-3$ : 16.23271454 |
| $B_0 = 10$<br>$\beta_0 = 1.4$<br>$\mu-1$ : 2.914453125<br>$\mu-2$ : 9.861933125<br>$\mu-3$ : 17.030959375 | $B_0 = 20$<br>$\beta_0 = 1.45890411$<br>$\mu-1$ : 3.046171875<br>$\mu-2$ : 9.8328125<br>$\mu-3$ : 16.4943125    |
| $B_0 = 20$<br>$\beta_0 = 1.4$<br>$\mu-1$ : 3.135548375<br>$\mu-2$ : 10.5039125<br>$\mu-3$ : 17.791778125  | $B_0 = 30$<br>$\beta_0 = 1.45890411$<br>$\mu-1$ : 3.0751875<br>$\mu-2$ : 9.9178125<br>$\mu-3$ : 16.6209175      |

TABLE I. FLOW & HEAT TRANSFER COEFF. VS BIOT NUMBER (CONT.)

HE-1 OF 2 WHERE: RAD = INSIDE PIPE RADIUS - IN. D-G = DENSITY GAS - #/FT<sup>3</sup>  
 K = THERMAL CONDUCTIVITY - BTU/FT OF MU-G = VISCOSITY GAS -  
 NPR = PRANDL NUMBER W = WEIGHT FLOW STREAM - #/HR  
 Cp = SPECIFIC HEAT VAPOR - BTU/# OF H = HEAT TRANSFER COEFF. - BTU/FT<sup>2</sup> OF  
 D-F = DENSITY FLUID - #/FT<sup>3</sup>

Pr = 20. E<sub>2</sub> = 80.  
 β = 1.4 β<sub>0</sub> = 1.45890411

| W, H, VS BIOT NO. |      | W, H, VS BIOT NO. |      |
|-------------------|------|-------------------|------|
| 2.448             | RAD  | 9.125             | RAD  |
| 25.               | K    | 25.               | K    |
| 20.               | B-I  | 80.               | B-I  |
| 0.84222           | NPR  | 0.84222           | NPR  |
| 0.8516275         | C-P  | 0.8516275         | C-P  |
| 50.6408           | D-F  | 50.6408           | D-F  |
| 1.077324          | D-G  | 1.077324          | D-G  |
| 0.000011515       | MU-G | 0.000011515       | MU-G |
| 52974.1175        | W    | 921384.1479       | W    |
| 3142.374638       | H    | 3372.069311       | H    |

E<sub>1</sub> = 10. β<sub>0</sub> = 1.4 E<sub>2</sub> = 60.  
 β<sub>0</sub> = 1.45890411

| W, H, VS BIOT NO. |      | W, H, VS BIOT NO. |      |
|-------------------|------|-------------------|------|
| 2.448             | RAD  | 9.125             | RAD  |
| 25.               | K    | 25.               | K    |
| 10.               | B-I  | 60.               | B-I  |
| 0.84222           | NPR  | 0.84222           | NPR  |
| 0.8516275         | C-P  | 0.8516275         | C-P  |
| 50.6408           | D-F  | 50.6408           | D-F  |
| 1.077324          | D-G  | 1.077324          | D-G  |
| 0.000011515       | MU-G | 0.000011515       | MU-G |
| 24523.6979        | W    | 669298.6016       | W    |
| 1571.187319       | H    | 2529.051983       | H    |

E<sub>1</sub> = 5. β<sub>0</sub> = 1.4 E<sub>2</sub> = 40.  
 β<sub>0</sub> = 1.45890411

| W, H, VS BIOT NO. |      | W, H, VS BIOT NO. |      |
|-------------------|------|-------------------|------|
| 2.448             | RAD  | 9.125             | RAD  |
| 25.               | K    | 25.               | K    |
| 5.                | B-I  | 40.               | B-I  |
| 0.84222           | NPR  | 0.84222           | NPR  |
| 0.8516275         | C-P  | 0.8516275         | C-P  |
| 50.6408           | D-F  | 50.6408           | D-F  |
| 1.077324          | D-G  | 1.077324          | D-G  |
| 0.000011515       | MU-G | 0.000011515       | MU-G |
| 11352.93587       | W    | 426543.1414       | W    |
| 785.5936597       | H    | 1686.034655       | H    |

WEIGHT FLOW & HEAT TRANSFER COEFF IDENTIFICATION

SHEET 2 OF 2

Bus. 10.  
Bo. 1.45890411

W. H. VS BIOT NO.

|             |      |
|-------------|------|
| 9.125       | RAD  |
| 25.         | K    |
| 10.         | B-I  |
| 0.84222     | NPR  |
| 0.8516275   | C-P  |
| 50.6408     | D-F  |
| 1.077324    | D-G  |
| 0.000011515 | MU-G |
| 91412.88537 | W    |
| 421.5086639 | H    |

Bus. 20.  
Bo. 1.45890411

W. H. VS BIOT NO.

|             |      |
|-------------|------|
| 9.125       | RAD  |
| 25.         | K    |
| 20.         | B-I  |
| 0.84222     | NPR  |
| 0.8516275   | C-P  |
| 50.6408     | D-F  |
| 1.077324    | D-G  |
| 0.000011515 | MU-G |
| 197462.7542 | W    |
| 843.0173278 | H    |



TABLE III (Continued) *F* EQUIVALENT-TIME FACTORS  
FOR *F* NUMBERS, (*F*)

WHERE R-1 = INSIDE RADIUS OF COILS FORMED IN 1-IN  
R-2 = INSIDE RADIUS OF COILS FORMED IN 2-IN  
T-1 = TIME FROM INITIAL TO RE-INITIAL - SEE  
T-2 = EQUIVALENT TIME FROM INITIAL TO RE-INITIAL  
IN SEC.

|             |     |
|-------------|-----|
| .0736794965 | FD  |
| 9.125       | R-1 |
| 300.        | T-1 |
| 2.448       | R-2 |
| 21.59127731 | T-2 |
|             |     |
| 0.147358993 | FD  |
| 9.125       | R-1 |
| 600.        | T-1 |
| 2.448       | R-2 |
| 43.18255463 | T-2 |
|             |     |
| .2210384895 | FD  |
| 9.125       | R-1 |
| 900.        | T-1 |
| 2.448       | R-2 |
| 64.77383194 | T-2 |
|             |     |
| 0.294717986 | FD  |
| 9.125       | R-1 |
| 1200.       | T-1 |
| 2.448       | R-2 |
| 86.36510925 | T-2 |
|             |     |
| .3683974825 | FD  |
| 9.125       | R-1 |
| 1500.       | T-1 |
| 2.448       | R-2 |
| 107.9563866 | T-2 |
|             |     |
| 0.442076979 | FD  |
| 9.125       | R-1 |
| 1800.       | T-1 |
| 2.448       | R-2 |
| 129.5476639 | T-2 |




FIGURE 1 - DOWNHOLE STARTUP STRESS & TEMP VS TIME RECOMMENDED TEMP RATE (200°F/Min)

TEMP HISTORY @ B1.5 WITH VIBES MAX


MAX STRESS

MAX. TANGENTIAL STRESS HISTORY

PIPE WALL STRESS - LB. PER SQ. IN.

OUTSIDE WALL TEMP - °F

FIGURE 2 - STANDARD 660 MW MAIN STEAMLINE START UP STRESS & TEMP VS. TIME



# FIG. 3 NON DIMENSIONAL TANGENTIAL STRESS

Thermal shocks




FIG. 5. Diagram for determination of dimensionless tangential stress due to thermal shock  $\bar{\sigma}_t$ .  
 $a$  - stresses at the external surface of the pipe wall;  $b$  - stresses at the internal surface of the pipe wall. The numbers at each curve give Biot number (first) and the ratio of pipe radii  $\beta_0$  (second).  $Fo$  - dimensionless time from the beginning of the thermal shock, in logarithmic scale.

*R. H. H. 1 OF 74*

A3-228-EP-MLJ-1057  
 [REDACTED]

Mr. R. N. Schweinberg, Director  
 Solar Ten Megawatt Project Office  
 Department of Energy  
 9550 Flair Drive, Suite 210  
 El Monte, California 91731

Subject: Contract No. DE-AC03-79SF10499  
 Solar Facilities Design Integration  
 [REDACTED]

- References:
- (1) MDAC Letter A3-226-EP-MLJ-1027, dated 14 November 1979, R. W. Hallet, to R. N. Schweinberg, "Conference Record Report, Receiver Stress Analysis Meeting, 7 November 1979"
  - (2) Code Case N-47-14, Cases of ASME Boiler and Pressure Vessel Code, Meeting of 5 May 1978, Approved by Council 10 July 1978
  - (3) Ten Megawatt Solar Thermal Central Receiver Pilot Plant, Solar Facilities Design Integration, System Data Book, MDC G8211, initial issue - September 1979

Dear Dick:

In response to Action Item (1), assigned at the subject Receiver Stress Analysis Meeting of 7 November 1979, a copy of the MDAC Downcomer/Valve Stress Analysis Report is being forwarded for review.

It is noted that the report has been updated since the Stress Analysis Meeting to incorporate a conservative but realistic "cloud transient" analysis. As suggested by Mr. A. Ludwig of ETEC, at the meeting, the creep-fatigue analysis procedure was also revised to properly reflect the boiler and pressure vessel code procedure delineated in Reference (2). The conclusions of the analysis presented at the meeting will remain valid when the results of the enclosed, updated, analysis are considered.

In response to Action Item (2) from the meeting, a "Typical-day" Pilot Plant Receiver Steam Downcomer load histogram was constructed based on the best data currently available, and is also enclosed, together with a copy of the Receiver operational sequence extracted from the System Data Book (Reference 3).



A3-228-EP-MLJ-1057  
27 November 1979

Please feel free to contact G. C. Coleman at (714) 896-4097 for any further information.

Very truly yours,

ORIGINAL SIGNED BY

R. W. Hallet, Jr.  
Program Manager  
Solar Facilities Design Integration

MLJ:bj

- Attachments: (1) "Downcomer Pipe and Inlet Valve, 10 MWe Solar Pilot Plant, Structural Analysis," draft MDAC Report, dated 2 October 1979
- (2) Steam Downcomer Load History (Histogram)
- (3) Pilot Plant Receiver Operational Sequence

- Cy: K. L. Adler, ETEC/STMPO
- A. Ludwig, ETEC
- I. Berman, Foster-Wheeler
- A. C. Skinrod, Sandia, Livermore
- J. Jones, Sandia, Livermore

- ic: G. C. Coleman
- M. L. Joy
- J. E. Raetz

| Approval Initials Required |                   |
|----------------------------|-------------------|
| Section                    | DATE              |
| MLJ                        | 11-26 [Signature] |
| GCC                        | 11-27 [Signature] |
| RIO                        | 11-27 [Signature] |
|                            |                   |
|                            |                   |



E. GILLIS

10-2-79

PAGE 1

DOWNCOMER PIPE AND INLET VALVE

10 MW SOLAR POWER PLANT

STRUCTURAL ANALYSIS

TABLE OF CONTENTS

|                         | PAGE |
|-------------------------|------|
| INTRODUCTION            | 1-0  |
| STATIC ANALYSIS         | 1-1  |
| DOWNCOMER PIPE          | 1-1  |
| START-UP LOAD CONDITION | 1-1  |
| CLOUD PASSAGE CONDITION | 1-8  |
| DOWNCOMER INLET VALVE   | 2-1  |
| START-UP LOAD CONDITION | 2-1  |
| CIGEP-FATIGUE ANALYSIS  | 3-1  |
| DOWNCOMER PIPE          | 3-1  |
| DOWNCOMER INLET VALVE   | 4-1  |
| CONCLUSIONS             | 5-1  |
| REFERENCES              | 6-1  |
| APPENDIX A              | A-1  |
| APPENDIX B              | B-1  |



DOWNCOMER PIPE AND INLET VALVE  
10 MW SOLAR POWER PLANT

STRUCTURAL ANALYSIS

INTRODUCTION:

IT IS REQUIRED TO ESTABLISH LOAD CRITERIA (ACCEPTABLE LOAD ENVIRONMENT) WITH RESPECT TO STEAM FLOW RATES, PRESSURES, AND TEMPERATURES FOR ALL TRANSIENT AND OPERATING CONDITIONS WHICH WILL RESULT IN STRUCTURAL ADEQUACY OF THE PROPOSED DOWNCOMER PIPE AND DOWNCOMER INLET VALVE. STATIC AND CREEP-FATIGUE ANALYSES WERE PERFORMED FOR A NUMBER OF DIFFERENT LOAD ENVIRONMENTS FOR CONDITIONS OF STARTUP AND CLOUD TRANSIENTS. THE DESIGN CRITERIA UPON WHICH ALL ANALYSES WERE BASED ARE THOSE GIVEN IN ASME BOILER AND PRESSURE VESSEL CODES, REFERENCES 1, 2, AND 3. THE LOAD ENVIRONMENT WHICH RESULTED IN STRUCTURAL ADEQUACY WITH RESPECT TO BOTH STATIC STRESS AND CREEP-FATIGUE DAMAGE WAS SELECTED AS THE LOAD CRITERIA, AND THE ANALYSES FOR THESE LOAD CRITERIA ARE PRESENTED HERE. A SUMMARY OF THE LOAD CRITERIA AND RESULTING MARGINS OF SAFETY AND CREEP-FATIGUE DAMAGE IS GIVEN IN THE CONCLUSIONS SECTION, PAGE 5-1.



STATIC ANALYSIS

~

DOWNCOMER PIPE

§

INLET VALVE

STATIC ANALYSISDOWNCOMER PIPESTRUCTURE

THE DOWNCOMER PIPE (FIGURE 1) IS 6.625 INCH DIAMETER SCHEDULE 160 (.718 INCH THICK) MADE OF LOW ALLOY STEEL, 2 1/4 CR 1 Mo, ASTM A335, GRADE P-22.




FIGURE 1. DOWNCOMER PIPE

START-UP LOAD CONDITION:

PRESSURE;  $p = 500$  PSIA

TEMPERATURE: THE INITIAL TEMPERATURE AND TEMPERATURE GRADIENT 1 SECOND AFTER START OF STEAM FLOW FOR 40000 LBS/H<sub>2</sub>O IS GIVEN IN FIGURE A-1, APPENDIX A-1.

DOWNCOMER PIPE

MATERIAL PROPERTIES

MATL: A335 : -LOW ALLOY STEEL, GRADE P-22, (2 1/4 CR, 1M.)  
SEAMLESS PIPE FOR HIGH TEMP SERVICE

TABLE I

TENSILE STRENGTH, MODULUS OF ELASTICITY, AND  
COEFFICIENT OF EXPANSION, A335 AT ELEVATED TEMPERATURES

| TEMP<br>DEG F | S <sub>m</sub> #<br>(KSI)<br>(REF PG A-2) | E<br>(LBS/IN <sup>2</sup> X 10 <sup>-6</sup> )<br>(REF PG A-4) | α<br>(IN/IN/°F X 10 <sup>6</sup> )<br>(REF PG A-5) |
|---------------|---|--|--|
| RT            | 15.0 Δ                                    | 29.9   | 6.07   |
| 200°          | 15.0                                      | 29.5   | 6.38   |
| 238 □         | 15.0                                      | 29.31 *  | 6.46 *   |
| 250           | 15.0                                      | —  | —  |
| 300           | 15.0                                      | 29.0   | 6.60   |
| 400           | 15.0                                      | 28.6   | 6.82   |

Δ F<sub>TY</sub> = 30 KSI ; F<sub>TU</sub> = 60 KSI (REF APPENDIX PAGE A-2)

\*  $E = \left[ 29.5 - (29.5 - 29.0) \left( \frac{238 - 200}{300 - 200} \right) \right] \times 10^6 = 29.31 \times 10^6 \text{ LBS/IN}^2$

α =  $\left[ 6.38 + (6.60 - 6.38) \left( \frac{238 - 200}{300 - 200} \right) \right] \times 10^{-6} = 6.46 \times 10^{-6} \text{ IN/IN/°F}$

# S<sub>m</sub> IS THE ALLOWABLE TENSILE STRESS EQUAL TO HALF THE YIELD STRESS, F<sub>TY</sub>.

□ T<sub>AVE</sub> = 238° F (REF PAGE 1-A)

DOWNCOMER P.I.P.E.PRIMARY AND SECONDARY STRESS ANALYSIS (START UP CONDITION)PRIMARY STRESS (FROM PRESSURE)

MAX PRESSURE  $p = 500$  PSI

$R_o = 3.3125$  IN.

$R_i = 2.5945$  IN.

Hoop StressREF APPENDIX PAGE A-6  
FOR REFERENCE SOURCES  
AND DERIVATION OF STRESS  
AT INSIDE AND OUTSIDE OF PIPE

$$\sigma_{1P_i} = p \frac{R_o^2 + R_i^2}{R_o^2 - R_i^2}$$

$$= 500 \frac{(3.3125^2 + 2.5945^2)}{(3.3125^2 - 2.5945^2)} = \underline{2087} \frac{\text{LBS}}{\text{IN}^2}$$

$$\sigma_{oP_o} = 2pR_i^2 / (R_o^2 - R_i^2)$$

$$= 2(500) \frac{(2.5945^2)}{(3.3125^2 - 2.5945^2)} = \underline{1587} \frac{\text{LBS}}{\text{IN}^2}$$

LONGITUDINAL STRESS

$$\sigma_{2P_o} = \sigma_{2P_i} = p / (R_o/R_i - 1)$$

$$= 500 \left[ \left( \frac{3.3125}{2.5945} \right) - 1 \right] = \underline{794} \frac{\text{LBS}}{\text{IN}^2}$$

RADIAL STRESS

$$\sigma_{3P_i} = -p = \underline{-500} \frac{\text{LBS}}{\text{IN}^2}$$

$$\sigma_{3P_o} = \underline{0.0}$$

DOWNCOMER PIPE

E GILLIS  
6-12-79

1-4

SECONDARY STRESS ANALYSIS (START UP COND) (REF APPEND PAGE 1)

SINCE IT WILL BE NECESSARY IN CALCULATING THERMAL STRESS (PAGE 1-5) TO INTEGRATE  $\int T dr$ , THIS INTEGRATION WILL BE MADE USING SIMPSON'S RULE APPLIED TO TABLE II.

TABLE II

TEMPERATURE GRADIENT IN PIPE WALL (REF FIG A-1)

| r, RADIAL DIST FROM INSIDE (IN.) | r, RADIAL (IN.) | T TEMP. °F (REF PAGE) | T x r |
|----------------------------------|-----------------|-----------------------|-------|
| 0.0                              | 2.5945          | 400                   | 1038  |
| .0513                            | 2.6458          | 340                   | 900   |
| .1026                            | 2.6971          | 306                   | 825   |
| .1539                            | 2.7484          | 275                   | 756   |
| .2051                            | 2.7996          | 248                   | 694   |
| .2564                            | 2.8509          | 230                   | 656   |
| .3077                            | 2.9022          | 217                   | 630   |
| .3590                            | 2.9535          | 208                   | 614   |
| .4130                            | 3.0048          | 204                   | 613   |
| .4616                            | 3.0561          | 202                   | 617   |
| .5129                            | 3.1074          | 201                   | 625   |
| .5641                            | 3.1586          | 200.5                 | 633   |
| .6154                            | 3.2099          | 200                   | 641   |
| .6667                            | 3.2612          | 200                   | 652   |
| .7180                            | 3.3125          | 200                   | 662   |

$T_{AVE} = 238^*$

THE VALUES OF T x r IN TABLE II ARE NOW INTEGRATED BY SIMPSON'S RULE

$$\int_{2.5945}^{3.3125} T r dr = \frac{h}{2} (y_1 + 2y_2 + 2y_3 + \dots + 2y_{14} + y_{15})$$

WHERE  $h/2 = .0513/2 = .02565$  IN

$$\int_{2.5945}^{3.3125} T r dr = .02565 (1038 + 17712 + 662) = .02565 (19412) = 497.9$$

°F IN

\*  $T_{AVE} = 238^{\circ}F$  IS DETERMINED BY SIMPSON'S RULE AND USED AS THE TEMPERATURE AT WHICH  $\alpha$  &  $E$  ARE EVALUATED (REF PAGE 1-2).

DOWNCOMER PIPESECONDARY (THERMAL) STRESSES: (START UP CONDITION)

THE FOLLOWING PARAMETERS WILL BE USED IN THE THERMAL STRESSES CALCULATED BELOW:

$$\left. \begin{aligned} T_i &= 400^\circ\text{F} \\ T_o &= 200^\circ\text{F} \\ T_{\text{AVE}} &= 238^\circ\text{F} \end{aligned} \right\} \text{(REF PAGE 1-2)}$$

$$\int_a^b T r dr = \int_{2.5945}^{3.3125} T r dr = 497.9 \text{ (DEGREES F. INCHES}^2\text{)} \text{ (REF PAGE 1-4)}$$

$$\left. \begin{aligned} \alpha &= 6.46 \times 10^{-6} \text{ ((IN/IN)/}^\circ\text{F)} \\ E &= 29.31 \times 10^6 \text{ (LBS/IN}^2\text{)} \\ \mu &= .30 \end{aligned} \right\} @ T = 238^\circ\text{F} \text{ (REF TABLE I, PAGE 1-2)}$$

$$\frac{\alpha E}{1-\mu} = \frac{6.46 \times 29.31}{1-.30} = 270.5 \text{ ((LBS/IN}^2\text{)/}^\circ\text{F)}$$

$$\left. \begin{aligned} a &= 2.5945 \text{ IN (INSIDE RADIUS)} \\ b &= 3.3125 \text{ IN (OUTSIDE RADIUS)} \end{aligned} \right\} \text{(REF FIGURE 1, PAGE 1-1)}$$

$$b^2 - a^2 = 3.3125^2 - 2.5945^2 = 4.2412 \text{ IN}^2$$

THERMAL HOOP STRESSES (REF APPENDIX, PAGE A-10)

$$\sigma_{T_i} = \frac{\alpha E}{1-\mu} \left[ \frac{2}{(b^2 - a^2)} \int_a^b T r dr - T \right] = 270.5 \left[ \frac{2}{4.2412} \times 497.9 - 400 \right] = -44.69 \text{ (KSI)}$$

$$\sigma_{T_o} = \frac{\alpha E}{1-\mu} \left[ \frac{-2}{(b^2 - a^2)} \int_a^b T r dr - T \right] = 270.5 \left[ \frac{-2}{4.2412} \times 497.9 - 200 \right] = 9.41 \text{ (KSI)}$$

LONGITUDINAL THERMAL STRESSES

$$\sigma_{T_i} = \frac{\alpha E}{1-\mu} \left( \frac{2}{b^2 - a^2} \int_a^b T r dr - T \right) = -44.69 \text{ (KSI)} \text{ (SAME AS } \sigma_{T_i} \text{ ABOVE)}$$

$$\sigma_{T_o} = \frac{\alpha E}{1-\mu} \left( \frac{2}{b^2 - a^2} \int_a^b T r dr - T \right) = 9.41 \text{ (KSI)} \text{ (SAME AS } \sigma_{T_o} \text{ ABOVE)}$$

RADIAL STRESS

$$\sigma_{3T_i} = \sigma_{T_o} = \frac{0.0}{\text{(KSI)}} \text{ (BY INSPECTION)}$$

TABLE III

PRIMARY AND SECONDARY STRESSES AND STRESS DIFFERENCES  
( $T_o = 400^\circ F$  ;  $T_i = 200^\circ F$ )  
DOWNCOMER PIPE - STABLE UP CONDITION

| TYPE LOAD   | STRESS TYPE                           | STRESS (KSI) |          |
|---|---------------------------------------|--------------|----------|
|   |                                       | INSIDE       | OUTSIDE  |
| PRESSURE<br>(PRIMARY)<br>(500 PSI)<br>(REF PG 1-3)            | $\sigma_{1p}$                         | 2.09 ✓       | 1.59 ✓   |
|   | $\sigma_{2p}$                         | .79 ✓        | .79 ✓    |
|   | $\sigma_{3p}$                         | -.50 ✓       | 0.0 ✓    |
| THERMAL<br>(SECONDARY)<br>(REF PG 1-5)                        | $\sigma_{1T}$                         | -44.69 ✓     | 9.41 ✓   |
|   | $\sigma_{2T}$                         | -44.69 ✓     | 9.41 ✓   |
|   | $\sigma_{3T}$                         | 0.0 ✓        | 0.0 ✓    |
| PRESSURE<br>(PRIMARY)<br>(500 PSI)                            | $S_{12p} = \sigma_{1p} - \sigma_{2p}$ | 1.30 ✓       | -.80 ✓   |
|   | $S_{23p} = \sigma_{2p} - \sigma_{3p}$ | 1.29 ✓       | .79 ✓    |
|   | $S_{31p} = \sigma_{3p} - \sigma_{1p}$ | -2.59 ✓      | -1.59 ✓  |
| THERMAL<br>(SECONDARY)  | $S_{12T} = \sigma_{1T} - \sigma_{2T}$ | 0.0 ✓        | 0.0 ✓    |
|   | $S_{23T} = \sigma_{2T} - \sigma_{3T}$ | -44.69 ✓     | 9.41 ✓   |
|   | $S_{31T} = \sigma_{3T} - \sigma_{1T}$ | 44.69 ✓      | -9.41 ✓  |
| COMBINED<br>PRESSURE +<br>THERMAL<br>(PRIMARY +<br>SECONDARY) | $S_{12PT} = S_{12p} + S_{12T}$        | 1.30 ✓       | -.80 ✓   |
|   | $S_{23PT} = S_{23p} + S_{23T}$        | -43.40 ✓     | 10.20 ✓  |
|   | $S_{31PT} = S_{31p} + S_{31T}$        | 42.10 ✓      | -11.00 ✓ |



TABLE IV

MARGINS OF SAFETY

FOR

PRIMARY AND PRIMARY PLUS SECONDARY LOADS

DOWN COMER PIPE - START UP CONDITION

| ITEM  | INSIDE         | OUTSIDE        |
|---|----------------|----------------|
| $S_p$ , PRIMARY STRESS INTENSITY* (KSI)<br>(REF TABLE III)  | 2.59           | 1.59           |
| $S_{PT}$ , PRIMARY PLUS SECONDARY STRESS INTENSITY (KSI) (REF TABLE III)  | 43.40          | 11.00          |
| $S_m$ , ALLOWABLE STRESS INTENSITY (KSI)  | 15.0           | 15.0           |
| ALLOWABLE PRIMARY STRESS, $K S_m$ (KSI), WHERE $K=1$ *  | 15.0           | 15.0           |
| ALLOWABLE PRIMARY PLUS SECONDARY STRESS, $K S_m$ (KSI) WHERE $K=3$ *  | 45.0           | 45.0           |
| MARGIN OF SAFETY FOR PRIMARY STRESS<br>$M.S. = \left( \frac{\text{ALLOWABLE}}{\text{MAX STRESS}} \right) - 1$   | 4.79<br>(HIGH) | 8.43<br>(HIGH) |
| MARGIN OF SAFETY FOR SECONDARY STRESS<br>$M.S. = \left( \frac{\text{ALLOWABLE}}{\text{MAX STRESS}} \right) - 1$ | .04            | 3.09           |

← (REF PAGE A-3)

CONCLUSION: PIPE IS ADEQUATE (MINIMUM MS = .04 ABOVE) FOR THE PRIMARY AND PRIMARY PLUS SECONDARY LOADS ON THE DOWNCOMER PIPE FOR THE START UP CONDITION

\* REF APPENDIX PAGE A-7 FOR ALLOWABLE STRESS CRITERIA FOR PRIMARY AND SECONDARY STRESSES, AND PAGE A-8 FOR VALUE OF STRESS INTENSITY K.

= THE STRESS INTENSITY  $S$  IS THE LARGEST ABSOLUTE VALUE OF  $S_{12}$ ,  $S_{23}$  AND  $S_{31}$



DOWNCOMER PIPE

CLOUD PASSAGE CONDITION

GENERAL: THE DOWNCOMER PIPE WAS INITIALLY ANALYZED FOR THE CLOUD PASSAGE CONDITION UNDER THE VERY CONSERVATIVE ASSUMPTION THAT THE STEAM TEMPERATURE CHANGED INSTANTANEOUSLY FROM 960°F TO 660°F RESULTING IN A VERY HIGH TEMPERATURE GRADIENT THROUGH THE PIPE WALL AND STRESSES WHICH, WHEN COMBINED WITH STRESS FROM STEAM PRESSURE, RESULTED IN HIGH CREEP DAMAGE. THIS INITIAL ANALYSIS IS GIVEN FOR REFERENCE IN APPENDIX B.

A REVISED MAXIMUM TEMPERATURE GRADIENT, BASED UPON A REALISTIC STEAM TEMPERATURE CHANGE RATE OF 30°F/MIN, HAS BEEN GENERATED (APPENDIX, FIGURE A-2, PAGE A-11).

THE THERMAL STRESS FROM THIS REVISED THERMAL GRADIENT IS NOW CALCULATED.



E GILLIS

11-20-79

PAGE 1-9

DOWNCOMER PIPE

CLOUD PASSAGE CONDITION

SECONDARY STRESS (FROM TEMPERATURE)

THERMAL HOOP AND LONGITUDINAL STRESS (INSIDE)

$$\sigma_{T_2} = \sigma_{T_1} = \frac{\alpha E}{1-\mu} \left[ \frac{2}{b^2 - a^2} \int_a^b T r dr - T \right] \quad \text{(REF APPENDIX, PAGE A-10)}$$

WHERE  $\int_a^b T r dr$  IS OBTAINED FROM TABLE V FOR THE TEMPERATURE GRADIENT OF FIGURE A-2 APPENDIX PAGE A-11. THE VALUES FROM TABLE V WILL BE SUBSTITUTED INTO SIMPSON'S RULE TO NUMERICALLY INTEGRATE  $\int_a^b T r dr$

TABLE V  
TEMP GRADIENT AND VALUES OF T r r

| r<br>Radius<br>(in) | T<br>TEMP<br>(°F) | T r r<br>(°F in) |
|---------------------|-------------------|------------------|
| 2.5945              | 924.0             | 2397             |
| 2.7740              | 927.0             | 2571             |
| 2.9535              | 928.5             | 2742             |
| 3.1330              | 929.5             | 2912             |
| 3.3125              | 930.0             | 3081             |

13703

DOWNCOMER PIPECLOUD PASSAGE CONDITION (CONT)SECONDARY STRESS (CONT)

$$\int_{r_i}^{r_o} T r dr = \frac{\Delta F}{2} \left[ (T r)_1 + 2(T r)_2 + 2(T r)_3 + 2(T r)_4 + (T r)_5 \right] \quad \left( \begin{array}{l} \text{SIMPSON'S} \\ \text{RULE} \end{array} \right)$$

$$= \frac{.1795}{2} \left[ 2397 + 2 \times 2571 + 2 \times 2742 + 2 \times 2912 + 3081 \right] \quad \left( \begin{array}{l} \text{REF} \\ \text{TABLE V} \end{array} \right)$$

$$= \frac{.1795}{2} \times 21928 = 1968$$

ALSO THE AVERAGE TEMPERATURE (REQUIRED FOR MATERIAL PROPERTIES) FROM TABLE V BY SIMPSON'S RULE IS

$$T_{\text{AVE}} = \int_{r_i}^{r_o} T dr / (r_o - r_i)$$

$$= \frac{\Delta F}{2} \left[ T_1 + 2T_2 + 2T_3 + 2T_4 + T_5 \right] / (r_o - r_i)$$

$$= \frac{.1795}{2} \left[ 924 + 2 \times 927 + 2 \times 928.5 + 2 \times 929.5 + 930 \right] / .718$$

$$= \frac{.1795}{2} \times 7424 / .718 = 928^\circ \text{F}$$

THE VALUES OF E AND  $\alpha$  AT  $T_{\text{AVE}} = 928^\circ \text{F}$  ARE NOW OBTAINED

$$E = \left[ 24.5 - (24.5 - 23.0) \left( \frac{928 - 900}{1000 - 900} \right) \right] \times 10^6 = 24.08 \times 10^6 \quad \left( \begin{array}{l} \text{REF} \\ \text{APPENDIX} \\ \text{PAGE} \\ \text{B-3} \end{array} \right)$$

$$\alpha = \left[ 7.84 + (7.97 - 7.84) \left( \frac{928 - 900}{1000 - 900} \right) \right] \times 10^{-6} = 7.88 \times 10^{-6} \quad \left( \begin{array}{l} \text{REF} \\ \text{APPENDIX} \\ \text{PAGE} \\ \text{B-3} \end{array} \right)$$

$$a = 2.5945 \text{ (IN)}$$

$$b = 3.3125 \text{ (IN)}$$

$$T = 924^\circ \text{F} \quad (\text{TABLE V})$$

DOWNCOMER PIPECLOUD PASSAGE CONDITION (CONT)SECONDARY STRESS (CONT)THERMAL HUMP AND LONGITUDINAL STRESS (INSIDE)

$$\begin{aligned} \sigma_{1T} = \sigma_{2T} &= \frac{7.88 \times 24.08}{1-.3} \left[ \frac{2}{3.3125^2 - 2.5945^2} \times 1968 - 924 \right] \\ &= 271.07 \times 4.03 = \underline{\underline{1093}} \text{ (LBS/IN}^2\text{)} \end{aligned}$$

THERMAL HUMP AND LONGITUDINAL STRESS (OUTSIDE)

$$\sigma_{1T0} = \frac{\alpha E}{1-\mu} \left[ \frac{2}{(b^2 - a^2)} \int_a^b T dr - T \right]$$

WHERE  $T = 930^\circ \text{ F}$  (TABLE V)

$$\begin{aligned} \sigma_{1T0} = \sigma_{2T0} &= \frac{7.88 \times 24.08}{1-.3} \left[ \frac{2}{3.3125^2 - 2.5945^2} \times 1968 - 930 \right] \\ &= 271.07 \times (928.03 - 930) = \underline{\underline{-533}} \text{ (LBS/IN}^2\text{)} \end{aligned}$$

ALLOWABLE STRESS INTENSITIES AT ELEVATED TEMPS.

$$\begin{aligned} \sigma_{924} &= 11.0 + (13.1 - 11.0) \left( \frac{950 - 924}{950 - 900} \right) = 12.09 \text{ (KSI)} \left. \begin{array}{l} \text{INSIDE} \\ \text{APPEN-} \\ \text{DIX B} \end{array} \right\} \text{ REF} \\ \sigma_{930} &= 11.0 + (13.1 - 11.0) \left( \frac{950 - 930}{950 - 900} \right) = 11.84 \text{ (KSI)} \left. \begin{array}{l} \text{OUTSIDE} \\ \text{PAGE} \\ \text{B-2} \end{array} \right\} \end{aligned}$$

DOWN COMER PIPE - CLOUD PASSAGE (CONT)PRIMARY AND SECONDARY STRESS ANALYSISPRIMARY STRESS (FROM PRESSURE)HOOP STRESS - INSIDE SURFACE

$$\sigma_{T_i} = P \frac{(R_o^2 + R_i^2)}{(R_o^2 - R_i^2)} \quad (\text{REF APPENDIX PAGE A-6})$$

$$\begin{aligned} \text{WHERE } P &= 1515 \text{ (PSI)} \\ R_o &= 3.3125 \text{ (IN)} \\ R_i &= 2.5945 \text{ (IN)} \end{aligned}$$

$$\sigma_{T_i} = 1515 \left( \frac{3.3125^2 + 2.5945^2}{3.3125^2 - 2.5945^2} \right) = \underline{\underline{6324.0}} \left( \frac{\text{LBS}}{\text{IN}^2} \right)$$

HOOP STRESS - OUTSIDE SURFACE

$$\begin{aligned} \sigma_{T_o} &= 2 P R_i^2 / (R_o^2 - R_i^2) \\ &= 2 \times 1515 \times 2.5945^2 / (3.3125^2 - 2.5945^2) = \underline{\underline{4809.0}} \left( \frac{\text{LBS}}{\text{IN}^2} \right) \end{aligned}$$

LONGITUDINAL STRESS - INSIDE & OUTSIDE

$$\begin{aligned} \sigma_{L_i} = \sigma_{L_o} &= P / (R_o^2 / R_i^2 - 1) \\ &= 1515 / (3.3125^2 / 2.5945^2 - 1) = \underline{\underline{2406}} \text{ (LBS/IN}^2\text{)} \end{aligned}$$

RADIAL STRESS

$$\begin{aligned} \sigma_{R_i} &= -P = -1515 \text{ (LBS/IN}^2\text{)} \text{ (INSIDE)} \\ \sigma_{R_o} &= 0.0 \text{ (LBS/IN}^2\text{)} \text{ (OUTSIDE)} \end{aligned} \quad \left. \vphantom{\begin{aligned} \sigma_{R_i} \\ \sigma_{R_o} \end{aligned}} \right\} \text{BY INSPECTION}$$

19 OF 74

E GIBBS  
11-20-79

TABLE VI

PRIMARY AND SECONDARY STRESS AND STRESS DIFFERENCE SUMMARY  
DOWNCOMER PIPE - CLOUD PASSAGE

| TYPE LOAD                            | STRESS TYPE                           | STRESS (KSE) |         |
|--------------------------------------|---------------------------------------|--------------|---------|
|                                      |                                       | INSIDE       | OUTSIDE |
| PRESSURE<br>(1515 PSF)               | $\sigma_{1P}$                         | 6.32         | 4.81    |
|                                      | $\sigma_{2P}$                         | 2.41         | 2.41    |
|                                      | $\sigma_{3P}$                         | -1.52        | 0.0     |
| THERMAL                              | $\sigma_{1T}$                         | 1.09         | -0.53   |
|                                      | $\sigma_{2T}$                         | 1.09         | -0.53   |
|                                      | $\sigma_{3T}$                         | 0.0          | 0.0     |
| PRESSURE<br>(1515 PSF)               | $S_{12P} = \sigma_{1P} - \sigma_{2P}$ | 3.91         | 2.40    |
|                                      | $S_{23P} = \sigma_{2P} - \sigma_{3P}$ | 3.93         | 2.41    |
|                                      | $S_{31P} = \sigma_{3P} - \sigma_{1P}$ | -7.84        | -4.81   |
| THERMAL                              | $S_{12T} = \sigma_{1T} - \sigma_{2T}$ | 0.0          | 0.0     |
|                                      | $S_{23T} = \sigma_{2T} - \sigma_{3T}$ | 1.09         | -0.53   |
|                                      | $S_{31T} = \sigma_{3T} - \sigma_{1T}$ | -1.09        | +0.53   |
| COMBINED<br>PRESSURE<br>+<br>THERMAL | $S_{12} = \sigma_{1P} + \sigma_{1T}$  | 3.91         | 2.40    |
|                                      | $S_{23} = \sigma_{2P} + \sigma_{2T}$  | 5.02         | 1.88    |
|                                      | $S_{31} = \sigma_{3P} + \sigma_{3T}$  | -8.93        | -4.28   |



DOWNCOMER PIPE - CLOUD PASSAGE (CONT)

MARGINS OF SAFETY

PRIMARY STRESS CASE

$$MS = S_m / S - 1$$

WHERE  $S_m = 12.09$  KSI (INSIDE) } REF PAGE  
 $= 11.84$  KSI (OUTSIDE) } 1-11

$S = 7.84$  KSI (INSIDE) } REF TABLE VI  
 $= 4.81$  KSI (OUTSIDE) }

INSIDE

$$MS = 12.09 / 7.84 - 1 = \underline{\underline{+1.54}}$$

OUTSIDE

$$MS = 11.84 / 4.81 - 1 = \underline{\underline{+1.46}}$$

COMBINED PRIMARY AND SECONDARY STRESS CASE

$$MS = 3 \times S_m / S - 1$$

WHERE  $S_m = 12.09 \times 3 = 36.27$  KSI (INSIDE)  
 $= 11.84 \times 3 = 35.52$  KSI (OUTSIDE)

AND  $S = 8.93$  KSI (INSIDE)  
 $= 4.28$  KSI (OUTSIDE) (REF TABLE VI)

$$MS = 36.27 / 8.93 - 1 = \underline{\underline{3.06}} \text{ (INSIDE)}$$

$$MS = 35.52 / 4.28 - 1 = \underline{\underline{HIGH}} \text{ (OUTSIDE)}$$



DOWNCOMER INLET VALVE

GENERAL: THE DOWNCOMER INLET VALVE (FIGURE 2) WAS ANALYZED FOR A NUMBER OF TRIVIAL LOAD ENVIRONMENTS USING THE NASTRAN FINITE ELEMENT COMPUTER PROGRAM. ANALYSIS FOR THE CASE WHICH RESULTED IN STRUCTURAL ADEQUACY FOR BOTH STATIC STRESS AND CREEP FATIGUE DAMAGE IS PRESENTED HERE.

START-UP LOAD CONDITION

- STEAM FLOW RATE,  $\dot{W} = 20,000$  LBS/HR
- STEAM PRESSURE,  $P = 500$  PSI
- STEAM TEMPERATURE,  $T = 960^\circ$  F
- INITIAL WALL TEMP,  $T = 280^\circ$  F
- TIME STEP,  $\Delta t = 4.8$  SEC'S

THE TEMPERATURE OF THE CRITICAL ELEMENT (REF FIGURE , ELEMENT NO. 179), AT TIME STEP  $\Delta t = 4.8$  SEC'S, FROM THE NASTRAN ANALYSIS IS

$T = 435^\circ$  F

MATERIAL PROPERTIES: THE MATERIAL PROPERTIES ASSUMED FOR THE VALVE ARE THE SAME AS THOSE USED FOR THE DOWNCOMER PIPE (THAT IS, FOR THE SA335 P22 MATERIAL, REF APPENDIX PAGES A-2, A-3, A-4, & A-5).

PREPARED BY: E. GILLES

PAGE: 2-2

CHECKED BY: \_\_\_\_\_


MODEL: \_\_\_\_\_

DATE: \_\_\_\_\_

REPORT BY: \_\_\_\_\_

TITLE: \_\_\_\_\_

DOWNCOMER INLET VALVE



SCALE = 2/5

FIGURE 2. PROPOSED VALVE



DOWNCOMER INLET VALVE




FIGURE 3. DOWNCOMER VALVE, NASTRAN IDEALIZATION AT CRITICAL SECTION SHOWING CRITICAL ELEMENT LOCATION.

DOWNCOMER INLET VALVE (START UP CONDITION) (CONT)

ANALYSIS: The critical part of the inlet valve (Figure 2) for the startup loads (Page 2-1) is idealized (Figure 3) for the NASTRAN finite element program. The element having the highest stresses is element no 179.

The design criteria used for the analysis are that of reference 2 (ASME B31VC Section III, page 80, subsection NB-3200).

Primary (Pressure) Stresses: The primary (pressure) stresses for the valve, which are very low compared to the thermal stresses, are assumed conservatively to be the same as those obtained for the downcomer pipe for the startup load condition.

|               |   |      |     |                |                                     |
|---------------|---|------|-----|----------------|-------------------------------------|
| $\sigma_{1p}$ | = | .79  | KSI | (Longitudinal) | } REF Page 1-3<br>INTERNAL STRESSES |
| $\sigma_{2p}$ | = | -.50 | KSI | (Radial)       |                                     |
| $\sigma_{3p}$ | = | 2.09 | KSI | (hoop)         |                                     |

Secondary (Thermal) Stresses: The secondary (thermal) stresses are obtained from the NASTRAN finite element program (REF FILE NO S930, USER NO. = M64770)

|               |   |       |     |
|---------------|---|-------|-----|
| $\sigma_{1T}$ | = | -43.8 | KSI |
| $\sigma_{2T}$ | = | 0.0   | KSI |
| $\sigma_{3T}$ | = | -37.8 | KSI |



DOWNCOMER INLET VALVE (START-UP CONDITION) (CONT)

ANALYSIS (CONT)

THE STRESS INTENSITIES  $\hat{S}$  FOR PRIMARY, SECONDARY, AND COMBINED PRIMARY PLUS SECONDARY STRESSES ARE OBTAINED AS FOLLOWS:

PRIMARY STRESS INTENSITIES (KSI)

$$S_{12p} = \sigma_{1p} - \sigma_{2p} = .79 + .50 = 1.29$$

$$S_{23p} = \sigma_{2p} - \sigma_{3p} = -7.50 - 2.09 = -2.59$$

$$S_{31p} = \sigma_{3p} - \sigma_{1p} = -2.09 - .79 = -1.30$$

SECONDARY STRESS INTENSITIES (KSI)

$$S_{12T} = \sigma_{1T} - \sigma_{2T} = -43.8 - 0.0 = -43.8$$

$$S_{23T} = \sigma_{2T} - \sigma_{3T} = 0.0 + 37.8 = 37.8$$

$$S_{31T} = \sigma_{3T} - \sigma_{1T} = -37.8 + 43.8 = 6.0$$

COMBINED PRIMARY PLUS SECONDARY STRESS INTENSITIES

$$S_{12ps} = S_{12p} + S_{12T} = 1.29 - 43.8 = -42.5 \text{ KSI}$$

$$S_{23ps} = S_{23p} + S_{23T} = -2.59 + 37.8 = 35.2 \text{ KSI}$$

$$S_{31ps} = S_{31p} + S_{31T} = -1.30 + 6.0 = 4.7 \text{ KSI}$$

DOWNCOMER INLET VALVE (START-UP CONDITION) (CONT)ANALYSIS (CONT)ALLOWABLE STRESS INTENSITIESPRIMARY ALLOWABLE STRESS

$$S_m = 15.0 \text{ KSI} \quad (\text{REF APPENDIX, PAGES A-12 AND A-3})$$

COMBINED PRIMARY PLUS SECONDARY ALLOWABLE STRESS

$$3 \times S_m = 3 \times 15.0 = 45.0 \text{ KSI} \quad (\text{REF APPENDIX, PAGES A-12, A-13, \& A-3})$$

MARGINS OF SAFETYPRIMARY STRESS CONDITION

$$MS_p = S_m / S - 1$$

WHERE S IS THE LARGEST ABSOLUTE VALUE  
OF  $S_{12}$ ,  $S_{23}$ ,  $S_{31}$ , IS  $S = 2.59 \text{ KSI}$   
(REF PAGE 2-5)

$$MS_p = 15 / 2.59 - 1 = \underline{\underline{4.8}}$$



DOWNCOMER INLET VALVE (START-UP CONDITION) (CONT)

ANALYSIS (CONT)

MARGINS OF SAFETY (CONT)

PRIMARY + SECONDARY STRESS CONDITION

$$MS_{ps} = \frac{3 \times S_m}{S} - 1$$

WHERE  $3 \times S_m = 45.0$  KSI (REF PAGE 2-6)

AND  $S = 42.5$  KSI. (THE LARGEST ABSOLUTE VALUE OF  $S_{12ps}, S_{23ps}, S_{31ps}$ , REF PAGE 2-5)

$$MS_{ps} = \frac{45.0}{42.5} - 1 = \underline{\underline{+ .06}}$$



10 MW SOLAR POWER PLANT E GILMS

9-10-79

PAGE 3-0

CREEP-FATIGUE ANALYSIS

~

DOWNCOMER PIPE

F

INLET VALVE



## CREEP FATIGUE ANALYSIS - DOWNCOMER PIPE

### DESIGN CRITERIA

THE CRITERIA FOR CREEP FATIGUE AND THERMAL RATCHETING FOR THE DOWNCOMER PIPING ARE DEFINED IN THE PROPER STEP BY STEP SEQUENCE AS FOLLOWS:

- "CREEP FATIGUE AND THERMAL RATCHETING CRITERIA AS GUIDELINES FROM ASME B&PV CODE SECTION III AND CODE CASE N-47 (1592)" (REF DEFINITION OF DESIGN CRITERIA, (B) CATEGORY A, STEAM PIPING)

- THE FOLLOWING CRITERIA ARE OBTAINED FROM REF 3, ASME BOILER AND PRESSURE VESSEL CODE CASE N-47-14

#### -3251 GENERAL REQUIREMENTS (REF 3, N-47, PAGE 126)

"THE STRESS AND DEFORMATIONS RESULTING FROM THE SPECIFIED OPERATING CONDITIONS SHALL BE EVALUATED. THIS EVALUATION SHALL INCLUDE THE EFFECT OF RATCHETING, THE INTERACTION OF CREEP AND FATIGUE . . . ."

#### 3252 CRITERIA (REF 3, PAGE 126)

"IT IS THE RESPONSIBILITY OF THE OWNER TO DEFINE THE ACCEPTABILITY CRITERIA TO BE APPLIED AS STRAIN, DEFORMATION AND FATIGUE LIMITS IN THE DESIGN SPECIFICATIONS (NCA-3250). THE ACCEPTABILITY CRITERIA AND MATERIAL PROPERTIES CONTAINED IN APPENDIX T MAY BE USED."



CREEP FATIGUE ANALYSIS - DOWNCOMER PIPE (CONT)

DESIGN CRITERIA (CONT)

THE FOLLOWING CRITERIA ARE OBTAINED FROM APPENDIX T (REF 3)

T-1430 LIMITS USING ELASTIC ANALYSIS  
T-1431 GENERAL REQUIREMENTS } (REF 3, APPENDIX T) PAGE 168

"(a) THE ELASTIC ANALYSIS RULES IN THIS PARAGRAPH MAY BE USED ONLY WHEN THE ELASTIC RATCHETING RULES OF T-1320 HAVE BEEN SATISFIED"

T-1320 SATISFACTION OF STRAIN LIMITS USING ELASTIC ANALYSIS  
T-1321 GENERAL REQUIREMENTS } REF 3, APPENDIX T PAGE 165

"WHEN ELASTIC ANALYSIS ARE USED, THE STRAIN LIMITS OF T-1310 (STRAIN LIMITS FOR INELASTIC ANALYSIS) ARE CONSIDERED TO HAVE BEEN SATISFIED IF THE LIMITS OF ANY ONE OF T-1322, T-1323, OR T-1324 IS SATISFIED"

CREEP-FATIGUE ANALYSIS - DOWN-COMER P.P.E (LOWT)THERMAL RATCHETING ANALYSIS (REF 3, T-1321, PAGE 165)EVALUATION OF PARAMETERS

$$X = (P_L + P_b / K_f) / S_y \quad (\text{REF 3, PAGE 165})$$

WHERE  $P_L = 0.32$  KSI (MAX PRIMARY DIRECT STRESS FROM  $P = 1515$  PSI, REF PAGE 1-12)

$$P_b = 0 \quad (\text{PRIMARY BENDING STRESS})$$

$$S_y = 24.7 - (24.7 - 23.6) \left( \frac{960 - 950}{1000 - 950} \right) = 24.48 \text{ KSI} \quad (\text{REF 3, PG 151})$$

$$X = 0.32 / 24.48 = .26$$

$$Y = (Q_R)_{\text{MAX}} / S_y$$

WHERE  $(Q_R)_{\text{MAX}} = 1.09$  KSI

(MAX RANGE OF SECONDARY STRESS FOR CLOUD PASSAGE, TABLE II PAGE 1-13)

$$\therefore Y = 1.09 / 24.48 = .04$$

IN ORDER FOR THE THERMAL RATCHETING NOT TO BE A FACTOR, TEST NOS 1, 2, OR 3, UNDER T-1322, T-1323, AND T-1324 CAN BE SATISFIED

(REF 3, N-47, PAGE 165)

$$X + Y = .26 + .04 = .30$$

TEST No 2.

$$X + Y = .3 < 1$$

CONCLUSIONS: TEST No 2 IS SATISFIED.

THEREFORE, RATCHETING IS NOT A PROBLEM AND CREEP-FATIGUE FAILURE CAN BE ANALYZED USING ELASTIC ANALYSIS.



DOWNCOMER PIPE

CREEP - FATIGUE ANALYSIS

" WHEN ELASTIC ANALYSIS IS USED TO SATISFY THE REQUIREMENTS OF T-1311, THE FATIGUE AND CREEP - RUPTURE DAMAGE SHALL BE SUMMED LINEARLY AND THE TOTAL CREEP - FATIGUE DAMAGE, D, SHALL NOT EXCEED UNITY."  
(REF 3, N-47, T-1331, PAGE 169)

" .... FOR A DESIGN TO BE ACCEPTABLE, THE CREEP AND FATIGUE DAMAGE SHALL SATISFY THE FOLLOWING RELATION : " (REF 3, N-47, T-1411, PAGE 167)

$$\sum_{j=1}^P \left( \frac{n}{N_d} \right)_j + \sum_{k=1}^Q \left( \frac{T}{T_d} \right)_k \leq D \dots\dots\dots (1)$$

WHERE THE FIRST TERM REPRESENTS THE FATIGUE DAMAGE AND THE SECOND TERM REPRESENTS THE CREEP RUPTURE DAMAGE, AND D ≤ 1

THE FATIGUE DAMAGE TERM IS EVALUATED ON THE NEXT PAGE WHILE FOR THE DOWNCOMER PIPE THERE ARE TWO CONDITIONS CONTRIBUTING TO FATIGUE DAMAGE (IE, P = 2, ABOVE) :

- (1) TRANSIENT CONDITION CONSISTING OF THE DAILY START-UP CASE REPRESENTED BY FIG A-1, APPENDIX, PAGE A-1; n = 365 x 30 = 10950 CYCLES
- (2) TRANSIENT CONDITION CONSISTING OF CLOUD PASSAGE REPRESENTED BY THE CURVE FIGURE A-2, APPENDIX, PAGE A-11. ASSUME CONSERVATIVELY APPROXIMATELY ONE CLOUD PER DAY; n ≈ 10<sup>7</sup> CYCLES.



DOWNCOMER PIPE

FATIGUE DAMAGE

CASE 1 (j=1, CURVE NO. 4, FIGURE A-1, START UP CONDITION)

n = 10950 CYCLES (PREVIOUS PAGE)

N<sub>d</sub> = 100,000 CYCLES { REF TABLE II, PAGE 1-6

FUR S<sub>ALT</sub> =  $\frac{44.7}{2} = 22.35$  KSI AND FIG A-3, PAGE A-14

CASE 2 (j=2, CURVE FIGURE A-2, CLOUD PASSAGE, PAGE A-11)

n = 10000 CYCLES (PREVIOUS PAGE)

N ≈ ∞ CYCLES FOR S<sub>ALT</sub> =  $\frac{1.09}{2} = .55$  (KSI) { REF TABLE VI PAGE 1-16 AND FIG A-3, PG A-14

THE FATIGUE DAMAGE IS

$$\sum_{j=1}^P \left( \frac{n}{N_d} \right)_j = \frac{10950}{100,000} + \frac{10,000}{\infty} = .110 + 0.0 = .110$$

(START-UP)                      (CLOUD PASSAGE)



DOWNCOMER PIPE

CREEP DAMAGE

THE CREEP DAMAGE CONSISTS OF ONE CASE (I.E.  $g=1$ , EQUATION 1, PAGE 3-4) OBTAINED FROM THE HISTOGRAM, FIG 4 (PAGE 3-7). INSPECTION OF FIGURE 4 AND THE STRESS TO RUPTURE CURVES, FIGURE A-4, APPENDIX A-15, SHOWS THAT ONLY THE COMBINED OPERATING AND CLOUD PASSAGE CONDITION, AT TEMPERATURE  $T=960^{\circ}F$ , ARE SIGNIFICANT WITH RESPECT TO CREEP DAMAGE.

COMBINED OPERATING AND CLOUD PASSAGE CONDITION

$T=960^{\circ}F$ ,  $p=1515$  PSI (REF FIGURE 4)

TIME  $\tau = .25 \times 24 \times 365 \times 30 = 6.6 \times 10^9$  HOURS

MAX STRESS INTENSITY

$S = 8.93$  KSI (REF TABLE VI, PAGE I-13)  
CLOUD PASSAGE

$T_d = 3.0 \times 10^5$  HRS (REF FIG A-4, APPENDIX, PAGE A-15)

TOTAL CREEP DAMAGE

$$\sum_{k=1}^1 \left( \frac{\tau}{T_d} \right) = \frac{6.6 \times 10^9}{3 \times 10^5} = .22$$

TOTAL CREEP-FATIGUE DAMAGE

$$\sum_{j=1}^p \left( \frac{n}{N} \right)_j + \sum_{k=1}^q \left( \frac{\tau}{T_d} \right)_k = .11 + .22 = .33 < 1.0$$

(FATIGUE) (CREEP)  
(PAGE 3.5) (ABOVE)

CONCLUSIONS: SINCE THE CREEP-FATIGUE DAMAGE  $D = .33 < 1.0$  (ABOVE), THE DOWNCOMER PIPE HAS SUFFICIENT RESISTANCE TO CREEP-FATIGUE FOR THE 30 YEAR LIFE.

DOWNCOMER PIPE

HISTOGRAM




FIGURE 4. HISTOGRAM OF TEMP VS TIME FOR DOWNCOMER PIPE.



10MW SOLAR POWER PLANT 6 GROUP

VALVE 9-14

FATIGUE DAMAGE - INLET VALVE

START-UP CASE

$n = 10950$  CYCLES (REF BOTTOM OF PAGE 3-4)

$N_1 = 8 \times 10^4$  CYCLES  
FOR  $S_{OUT} = \frac{42.5}{2} = 21.25$  KPS } REF PAGE 2-5  
AND FIGURE A-3, PAGE A-14

THE FATIGUE DAMAGE IS

$$\frac{n}{N_1} = \frac{10950}{80000} = .137$$

TOTAL FATIGUE DAMAGE - INLET VALVE

$$D = \sum_{j=1}^p \left( \frac{n}{N_j} \right)_j = .137 < 1.0$$

CONCLUSION: THE PROPOSED DOWN-COMER INLET VALVE IS ACCEPTABLE WITH RESPECT TO FATIGUE DAMAGE (IE  $D = .137 < 1.0$ , ABOVE).



E Grows

MCDONNELL DOUGLAS CORPORATION

11-21-79

PAGE A-2

INLET VALVE

CREEP DAMAGE

ALTHOUGH THE CLOUD PASSAGE CASE AND THE MAXIMUM 1515 PSI RESTRICTION CASE WERE NOT ANALYZED USING THE NASTRON MODEL, IT WILL BE ASSUMED THAT THE MAXIMUM STRESS INTENSITY FOR THESE CONDITIONS IS THE SAME AS THAT OF THE TOWNCOMBELL PIPE,  $\sigma = 8.93 \text{ KSI}$ , (REF PAGE 2.6). THE TOTAL ACTUAL TIME IS  $t = 6.6 \times 10^4 \text{ HRS}$ , AND THE CREEP DAMAGE IS

$$D = \sum_{K=1}^1 \left( \frac{\sigma}{T_1} \right) = \frac{6.6 \times 10^4}{3 \times 10^5} = \underline{\underline{.22}}$$



E. G. Lewis

11-18-79

PAGE 5-1

CONCLUSIONS:

THE LOAD CRITERIA (ACCEPTABLE LOAD ENVIRONMENT) FOR BOTH THE DOWNCOMER PIPE AND DOWNCOMER INLET VALVE ARE SUMMARIZED IN TABLE VII. CORRESPONDING MARGINS OF SAFETY FOR STATIC LOADS ARE SUMMARIZED IN TABLE VIII. CREEP-FATIGUE DAMAGE AND CORRESPONDING NUMBERS OF PREDICTED LIFE CYCLES ARE SUMMARIZED IN TABLE IX.

INSPECTION OF TABLE VIII AND IX SHOWS STRUCTURAL ADEQUACY OF BOTH THE DOWNCOMER PIPE AND DOWNCOMER VALVE WITH RESPECT TO MAXIMUM STATIC STRESSES (I.E. PRIMARY AND SECONDARY STRESSES) AND CREEP-FATIGUE RESISTANCE FOR THE LOAD CRITERIA GIVEN IN TABLE VII.

THE LOAD CRITERIA FOR THE START-UP CONDITION FOR THE INLET VALVE (M.S. = +.06, TABLE VIII) GOVERN OVER THOSE OF FOR THE DOWNCOMER PIPE (MS = +.04), SINCE THE FORMER CRITERIA ARE CONSIDERABLY LESS SEVERE WITH RESPECT TO STEAM FLOW RATES ( $\dot{W} = 20,000$  LBS/HR VS. 40,000 LBS/HR) AND INITIAL WALL TEMPERATURE ( $T_w = 280^\circ\text{F}$  VS.  $200^\circ\text{F}$ ), (REF TABLE VII).

TABLE VII  
LOAD CRITERIA

DOWNCOMER PIPE AND VALVE - 10 MW SOLAR POWER PLANT

| PART                                   | DOWNCOMER PIPE |               | DOWN-COMER VALVE | PIPE & VALVE |
|--|----------------|---------------|------------------|--------------|
|  | START-UP       | CLOUD PASSING | START UP         | OPERATING    |
| $\dot{W}$ STEAM FLOW RATE (LBS/HR)     | 40000          | DESIGN        | 20000            | DESIGN       |
| $P$ STEAM PRESSURE (PSI)               | 500            | 1515          | 500              | 1515         |
| $T_s$ STEAM TEMP ( $^{\circ}$ F)       | 960            | 960 TO 660    | 960              | 960          |
| $T_w$ INTIAL WALL TEMP ( $^{\circ}$ F) | 200            | 960           | 280              | -            |

TABLE VIII

MAX STRESS AND MARGINS OF SAFETY SUMMARY

DOWNCOMER PIPE AND DOWNCOMER INLET VALVE

| PART   | DOWNCOMER PIPE           |                                   | INLET VALVE                  |
|--|--------------------------|-----------------------------------|------------------------------|
|  | START UP<br>(REF PG 1-7) | CLOUD<br>PASSAGE<br>(REF PG 1-14) | START-UP<br>(PAGES 2-6 & 27) |
| $S_p$ MAXIMUM PRIMARY STRESS INTENSITY (KSI)                   | 2.59                     | 7.84                              | 2.6                          |
| $S$ MAXIMUM PRIMARY PLUS SECONDARY STRESS INTENSITY (KSI)      | 43.4                     | 8.93                              | 42.5                         |
| $S_m$ ALLOWABLE PRIMARY STRESS INTENSITY (KSI)                 | 15.0                     | 12.09                             | 15.0                         |
| $3S_m$ ALLOWABLE PRIMARY PLUS SECONDARY STRESS INTENSITY (KSI) | 45.0                     | 36.27                             | 45.0                         |
| $MS_p = S_m / S_p - 1$   | 4.79                     | .54                               | 4.77                         |
| $MS_{ps} = 3S_m / S - 1$                                       | .04                      | 3.06                              | .06                          |



\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

TABLE IX

CREEP-FATIGUE DAMAGE AND PREDICTED LIFE CYCLES

DOWNCOMER PIPE AND DOWNCOMER INLET VALVE

| PART   | DOWNCOMER PIPE<br>(REF PG3-6) | DOWNCOMER INLET VALVE<br>(REF PG 4-1) |
|--|-------------------------------|---------------------------------------|
| CREEP DAMAGE<br>$D_c = \sum_{k=1}^6 \left( \frac{\sigma}{T_d} \right)_k$ | .22                           | .22                                   |
| FATIGUE DAMAGE<br>$D_f = \sum_{j=1}^p \left( \frac{n}{N_d} \right)_j$    | .11                           | .14                                   |
| TOTAL CREEP-FATIGUE DAMAGE<br>$D = D_c + D_f$                            | .33                           | .36                                   |
| PREDICTED NUMBER OF LIFE CYCLES<br>$N' = 1/D$                            | 3.03                          | 2.78                                  |



E Gillis

PAGE 6-1

REFERENCES

1. ANSI B31.1 POWER PIPING, 1977 EDITION ASME, 345 EAST 47TH ST, NEW YORK, N.Y. 10017.
2. ASME BOILER AND PRESSURE VESSEL CODE, SECTION III, ASME, 345 EAST 47TH ST. NEW YORK, N.Y. 10017.
3. N-97-14, CASES OF ASME BOILER AND PRESSURE VESSEL CODE MEETING OF MAY 5, 1978. APPROVED BY COUNCIL JULY 10, 1978.

APPENDIX A

REFERENCE INFORMATION

TEMPERATURE GRADIENT  
THROUGH PIPE WALL




FIGURE A-1 TEMP GRADIENT - DOWNCOMER PIPE  
START UP CONDITION



Table ACS-1

SECTION VIII — DIVISION 2

(REF 1)

TABLE ACS-1 (CONT'D)  
DESIGN STRESS INTENSITY VALUES,  $S_m$  IN TENSION FOR CARBON AND LOW-ALLOY STEELS,  
IN KIPS/SQ IN.

(Multiply by 1000 to Obtain psi)

| Nominal Composition      | P. No. | Gr. No. | Product Form | Specification Number | Grade   | Notes | Specified Minimum Yield | Specified Minimum Tensile |
|--------------------------|--------|---------|--------------|----------------------|---------|-------|-------------------------|---------------------------|
| Low Alloy Steel (Cont'd) |        |         |              |                      |         |       |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Plate        | SA-387               | 22, CL1 | (7)   | 30.0                    | 60.0                      |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Smls. Tb.    | SA-213               | T22     | ...   |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Smls. Pp.    | SA-335               | P22     | ...   |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | FB Pp.       | SA-369               | FP22    | ...   |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Forg.        | SA-336               | F22a    | ...   |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Cast.        | SA-217               | WC9     | (2)   | 40.0                    | 70.0                      |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Plate        | SA-387               | 22, CL2 | (2)   | 45.0                    | 75.0                      |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Forg.        | SA-336               | F22     | ...   |                         |                           |
| 2 1/4 Cr-1 Mo            | 5      | 1       | Forg.        | SA-182               | F22     | ...   | 40.0                    | 70.0                      |
| 2 1/4 Cr-1 Mo            | 5      | 2       | Cast.        | SA-487               | 8N      | (2)   | 55.0                    | 85.0                      |
| 3 Cr-1 Mo                | 5      | 1       | Smls. Tb.    | SA-199               | T21     | ...   | 25.0                    | 60.0                      |
| 3 Cr-1 Mo                | 5      | 1       | Plate        | SA-387               | 21, CL1 | (7)   | 30.0                    | 60.0                      |
| 3 Cr-1 Mo                | 5      | 1       | Smls. Tb.    | SA-213               | T21     | ...   |                         |                           |
| 3 Cr-1 Mo                | 5      | 1       | Smls. Pp.    | SA-335               | P21     | ...   |                         |                           |
| 3 Cr-1 Mo                | 5      | 1       | Forg.        | SA-336               | F21a    | ...   |                         |                           |
| 3 Cr-1 Mo                | 5      | 1       | FB Pp.       | SA-369               | FP21    | ...   |                         |                           |
| 3 Cr-1 Mo                | 5      | 1       | Forg.        | SA-182               | F21     | ...   | 45.0                    | 75.0                      |
| 3 Cr-1 Mo                | 5      | 1       | Forg.        | SA-336               | F21N    | ...   |                         |                           |
| 3 Cr-1 Mo                | 5      | 1       | Plate        | SA-387               | 21, CL2 | (2)   |                         |                           |
| 5 Cr-1/2 Mo              | 5      | 2       | Smls. Tb.    | SA-199               | T5      | ...   | 25.0                    | 60.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Plate        | SA-387               | 5 CL1   | ...   | 30.0                    | 60.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Smls. Tb.    | SA-213               | T5      | ...   |                         |                           |
| 5 Cr-1/2 Mo              | 5      | 2       | Smls. Pp.    | SA-335               | P5      | ...   |                         |                           |
| 5 Cr-1/2 Mo              | 5      | 2       | Smls. Pp.    | SA-369               | FP5     | ...   |                         |                           |
| 5 Cr-1/2 Mo-Si           | 5      | 2       | Smls. Tb.    | SA-213               | T5b     | ...   |                         |                           |
| 5 Cr-1/2 Mo-Si           | 5      | 2       | Smls. Pp.    | SA-335               | P5b     | ...   |                         |                           |
| 5 Cr-1/2 Mo-Ti           | 5      | 2       | Smls. Tb.    | SA-213               | T5c     | ...   |                         |                           |
| 5 Cr-1/2 Mo-Ti           | 5      | 2       | Smls. Pp.    | SA-335               | P5c     | ...   |                         |                           |
| 5 Cr-1/2 Mo              | 5      | 2       | Forg.        | SA-182               | F5      | ...   |                         |                           |
| 5 Cr-1/2 Mo              | 5      | 2       | Forg.        | SA-336               | F5      | ...   | 36.0                    | 60.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Plate        | SA-387               | 5 CL2   | ...   | 45.0                    | 75.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Forg.        | SA-336               | F5a     | ...   | 50.0                    | 80.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Cast.        | SA-217               | C5      | (2)   | 60.0                    | 90.0                      |
| 5 Cr-1/2 Mo              | 5      | 2       | Forg.        | SA-182               | F5a     | ...   | 65.0                    |                           |
| 7 Cr-1/2 Mo              | 5      | 2       | Smls. Tb.    | SA-199               | T7      | ...   | 25.0                    | 60.0                      |

Maximum Allowable Stress Values In Tension In Thousands of Pounds Per Square Inch  
For Metal Temperature Not Exceeding Deg. F (b) (2)

|                                  | 500  | 600  | 650  | 700  | 750  | 800  | 850  | 900  | 950  | 1000 | 1050 | 1100 | 1150 | 1200 | Specification<br>(a) | Grade |
|----------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|----------------------|-------|
| LOW AND INTERMEDIATE ALLOY STEEL |      |      |      |      |      |      |      |      |      |      |      |      |      |      |                      |       |
| Seamless Pipe and Tubes          |      |      |      |      |      |      |      |      |      |      |      |      |      |      |                      |       |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.7 | 14.0 | 12.5 | 10.0 | 6.2  | 4.2  | 2.7  | 1.7  | 1.2  | A199                 | T3b   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A199                 | T5    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.5 | 11.5 | 9.5  | 7.0  | 5.0  | 3.5  | 2.5  | 1.8  | 1.2  | A199                 | T7    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A199                 | T9    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A199                 | T11   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 7.8  | 5.5  | 4.0  | 2.5  | 1.2  | A199                 | T11   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 14.8 | 14.5 | 13.9 | 13.2 | 12.0 | 9.0  | 7.0  | 5.5  | 4.0  | 2.7  | 1.5  | A199                 | T21   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 7.8  | 5.8  | 4.2  | 3.0  | 1.6  | A199                 | T22   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.7 | 12.5 | 10.0 | 6.2  | ...  | ...  | ...  | A213                 | T2    |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.7 | 12.5 | 10.0 | 6.2  | 4.2  | 2.7  | ...  | ...  | A213                 | T3b   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 6.5  | 4.0  | 3.0  | ...  | ...  | A213                 | T5    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A213                 | T5b   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A213                 | T5c   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.5 | 11.5 | 9.5  | 7.0  | 5.0  | 3.5  | 2.5  | 1.8  | 1.2  | A213                 | T7    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A213                 | T9    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A213                 | T11   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 6.5  | 4.0  | 3.0  | ...  | ...  | A213                 | T12   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.7 | 14.2 | 13.1 | 11.0 | 6.5  | 4.0  | 2.8  | ...  | ...  | A213                 | T21   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 14.8 | 14.5 | 13.9 | 13.2 | 12.0 | 9.0  | 7.0  | 5.5  | 4.0  | ...  | ...  | A213                 | T22   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 7.8  | 5.8  | 4.2  | ...  | ...  | A333                 | 3     |
| 16.2                             | 16.2 | 16.2 | 16.2 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A333                 | 4     |
| 15.0                             | 15.0 | 15.0 | 15.0 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A333                 | 7     |
| 16.2                             | 16.2 | 16.2 | 16.2 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A333                 | 9     |
| 13.7                             | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.4 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A335                 | P1    |
| 13.7                             | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.4 | 13.1 | 12.5 | 10.0 | 6.2  | ...  | ...  | ...  | A335                 | P2    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A335                 | P5    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A335                 | P5b   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A335                 | P5c   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.5 | 11.5 | 9.5  | 7.0  | 5.0  | 3.5  | 2.5  | 1.8  | 1.2  | A335                 | P7    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A335                 | P9    |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A335                 | P11   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 6.5  | 4.0  | 3.0  | ...  | ...  | A335                 | P11   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.7 | 14.2 | 13.1 | 11.0 | 6.5  | 4.0  | 2.8  | ...  | ...  | A335                 | P12   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 14.8 | 14.5 | 13.9 | 13.2 | 12.0 | 9.0  | 7.0  | 5.5  | 4.0  | ...  | ...  | A335                 | P21   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 7.8  | 5.8  | 4.2  | ...  | ...  | A335                 | P22   |
| 13.7                             | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.4 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A369                 | FP1   |
| 13.7                             | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.4 | ...  | ...  | ...  | ...  | ...  | ...  | ...  | A369                 | FP2   |
| 13.7                             | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.7 | 13.4 | 13.1 | 12.5 | 10.0 | 6.2  | ...  | ...  | ...  | A369                 | FP2   |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.7 | 14.0 | 12.5 | 10.0 | 6.2  | 4.2  | 2.7  | ...  | ...  | A369                 | FP3b  |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.0 | 10.3 | 7.6  | 5.6  | 4.1  | 3.0  | 2.0  | 1.3  | A369                 | FP5   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.5 | 11.5 | 9.5  | 7.0  | 5.0  | 3.5  | 2.5  | 1.8  | 1.2  | A369                 | FP7   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A369                 | FP9   |
| 15.0                             | 14.5 | 14.0 | 13.7 | 13.4 | 13.1 | 12.8 | 12.5 | 12.0 | 10.8 | 8.5  | 5.5  | 3.3  | 2.2  | 1.5  | A369                 | FP11  |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 6.5  | 4.0  | 3.0  | ...  | ...  | A369                 | FP11  |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.7 | 14.2 | 13.1 | 11.0 | 6.5  | 4.0  | 2.8  | ...  | ...  | A369                 | FP12  |
| 15.0                             | 15.0 | 15.0 | 15.0 | 14.8 | 14.5 | 13.9 | 13.2 | 12.0 | 9.0  | 7.0  | 5.5  | 4.0  | ...  | ...  | A369                 | FP21  |
| 15.0                             | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 15.0 | 14.4 | 13.1 | 11.0 | 7.8  | 5.8  | 4.2  | ...  | ...  | A369                 | FP22  |

**APPENDIX C**  
**MODULI OF ELASTICITY FOR FERROUS MATERIAL<sup>1</sup>**

Table C-1

| Material   | $E$ = Modulus of Elasticity, psi (Multiply tabulated Values by $10^6$ ) |      |      |                 |      |      |      |      |      |      |      |      |      |      |      |
|--|---|------|------|-----------------|------|------|------|------|------|------|------|------|------|------|------|
|  | Temperature, Deg F  |      |      |                 |      |      |      |      |      |      |      |      |      |      |      |
|  | -325  | -200 | -100 | 70 <sup>a</sup> | 200  | 300  | 400  | 500  | 600  | 700  | 800  | 900  | 1000 | 1100 | 1200 |
| Carbon Steels with Carbon Content<br>0.30% or less         | ...   | ...  | 29.0 | 27.9            | 27.7 | 27.4 | 27.0 | 26.4 | 25.7 | 24.8 | 23.4 | ...  | ...  | ...  | ...  |
| Carbon Steels with Carbon Content<br>Above 0.30%           | ...   | ...  | 30.4 | 29.9            | 29.5 | 29.0 | 28.3 | 27.4 | 26.7 | 25.4 | 23.8 | ...  | ...  | ...  | ...  |
| Carbon-Moly Steels   | ...   | ...  | 30.4 | 29.9            | 29.5 | 29.0 | 28.6 | 28.0 | 27.4 | 26.6 | 25.7 | 24.5 | ...  | ...  | ...  |
| Low Cr-Moly Steels—Through 3 Cr                            | ...   | ...  | 30.4 | 29.9            | 29.5 | 29.0 | 28.6 | 28.0 | 27.4 | 26.6 | 25.7 | 24.5 | 23.0 | 20.4 | 15.6 |
| Intermediate Cr-Moly Steels<br>(5 Cr-9 Cr)                 | ...   | ...  | 28.1 | 27.4            | 27.1 | 26.8 | 26.4 | 26.0 | 25.4 | 24.9 | 24.2 | 23.5 | 22.8 | 21.9 | 20.8 |
| Austenitic Stainless Steels:                               |   |      |      |                 |      |      |      |      |      |      |      |      |      |      |      |
| Type 304—18 Cr-8 Ni  | ...   | ...  | ...  | 28.3            | 27.9 | 27.1 | 26.6 | 26.0 | 25.6 | 24.7 | 24.1 | 23.2 | 22.5 | 21.8 | 21.1 |
| Type 309—23 Cr-12 Ni                                       | ...   | ...  | ...  | 28.1            | ...  | ...  | ...  | ...  | ...  | ...  | 23.1 | ...  | 22.6 | ...  | 21.8 |
| Type 310—25 Cr-20 Ni                                       | ...   | ...  | ...  | 29.0            | 28.2 | 27.5 | 26.8 | 26.2 | 25.5 | 24.9 | 24.2 | 23.6 | 23.0 | 22.4 | 21.8 |
| Type 316—16 Cr-12 Ni-2 Mo                                  | ...   | ...  | ...  | 28.3            | 28.1 | 27.5 | 26.9 | 26.3 | 25.6 | 24.9 | 24.2 | 23.5 | 22.8 | 22.2 | 21.5 |
| Type 321—18 Cr-10 Ni-Ti                                    | ...   | ...  | ...  | 28.9            | 28.0 | 27.3 | 26.5 | 25.8 | 25.3 | 24.5 | 23.8 | 23.2 | 22.5 | 21.9 | 21.2 |
| Type 347—18 Cr-10 Ni-Cb                                    | ...   | ...  | ...  | 28.9            | 28.2 | 27.5 | 26.8 | 26.1 | 25.4 | 24.8 | 24.1 | 23.4 | 22.8 | 22.0 | 21.4 |
| Straight Chromium Stainless Steels<br>(12 Cr, 17Cr, 27 Cr) | ...   | ...  | 29.8 | 29.2            | 28.7 | 28.3 | 27.7 | 27.0 | 26.0 | 24.8 | 23.1 | 21.1 | 18.6 | 15.6 | 12.2 |
| Gray Cast Iron   | ...   | ...  | ...  | 13.4            | 13.2 | 12.9 | 12.6 | 12.2 | 11.7 | 11.0 | 10.2 | ...  | ...  | ...  | ...  |

1. These data are for information and it is not to be implied that materials are suitable for all the temperature ranges shown.  
2. Values shown for austenitic stainless steels in this column are at 75 F.

## APPENDIX B

### THERMAL EXPANSION DATA

Mean Coefficient of Thermal Expansion =  $\frac{A}{10}$  (in./in./F)  
 Linear Thermal Expansion =  $B$  (in./100 ft)

In Going from 70 F to Indicated Temperature

| Material  | Coef-<br>ficient | Temperature Range 70 F to |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |       |
|---|------------------|---------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|   |                  | -325                      | -160  | -60   | 70    | 200   | 300   | 400   | 500   | 600   | 700   | 800   | 900   | 1000  | 1100  | 1200  | 1300  | 1400  |
| Carbon steel; Carbon-moly steel<br>low-chrome steels (through 3 Cr) | A                | 5.00                      | 5.50  | 5.80  | 6.07  | 6.38  | 6.60  | 6.82  | 7.02  | 7.23  | 7.44  | 7.65  | 7.84  | 7.97  | 8.12  | 8.19  | 8.28  | 8.36  |
|   | B                | 2.37                      | 1.45  | 0.84  | 0     | 0.99  | 1.82  | 2.70  | 3.62  | 4.60  | 5.63  | 6.70  | 7.81  | 8.89  | 10.04 | 11.10 | 12.22 | 13.34 |
| Intermediate alloy steels;<br>(5 Cr-Mo through 9 Cr-Mo)             | A                | 4.70                      | 5.20  | 5.45  | 5.73  | 6.04  | 6.19  | 6.34  | 6.50  | 6.66  | 6.80  | 6.96  | 7.10  | 7.22  | 7.32  | 7.41  | 7.49  | 7.55  |
|   | B                | 2.22                      | 1.37  | 0.79  | 0     | 0.94  | 1.71  | 2.50  | 3.35  | 4.24  | 5.14  | 6.10  | 7.07  | 8.06  | 9.05  | 10.00 | 11.06 | 12.05 |
| Austenitic stainless steels   | A                | 8.15                      | 8.60  | 8.90  | 9.11  | 9.34  | 9.47  | 9.59  | 9.70  | 9.82  | 9.92  | 10.05 | 10.16 | 10.29 | 10.39 | 10.48 | 10.54 | 10.60 |
|   | B                | 3.85                      | 2.27  | ...   | 0     | 1.46  | 2.61  | 3.80  | 5.01  | 6.24  | 7.50  | 8.80  | 10.12 | 11.48 | 12.84 | 14.20 | 15.56 | 16.92 |
| Straight chromium stainless steels;<br>(12 Cr, 17 Cr, and 27 Cr)    | A                | 4.30                      | 4.70  | 5.00  | 5.24  | 5.50  | 5.66  | 5.81  | 5.96  | 6.13  | 6.26  | 6.39  | 6.52  | 6.63  | 6.72  | 6.78  | 6.85  | 6.90  |
|   | B                | 2.04                      | 1.24  | 0.72  | 0     | 0.86  | 1.56  | 2.30  | 3.08  | 3.90  | 4.73  | 5.60  | 6.49  | 7.40  | 8.31  | 9.20  | 10.11 | 11.01 |
| 25 Cr - 20 Ni   | A                | 6.35                      | 6.85  | 7.20  | 7.48  | 7.76  | 7.92  | 8.08  | 8.22  | 8.38  | 8.52  | 8.68  | 8.81  | 8.92  | 9.00  | 9.08  | 9.12  | 9.18  |
|   | B                | 3.00                      | 1.81  | 0.98  | 0     | 1.21  | 2.18  | 3.20  | 4.24  | 5.33  | 6.44  | 7.60  | 8.78  | 9.95  | 11.12 | 12.31 | 13.46 | 14.65 |
| Monel<br>(67 Ni - 30 Cu)  | A                | 5.55                      | 6.75  | 7.15  | 7.48  | 7.84  | 8.02  | 8.20  | 8.40  | 8.58  | 8.78  | 8.96  | 9.16  | 9.34  | 9.52  | 9.70  | 9.88  | 10.04 |
|   | B                | 2.62                      | 1.79  | ...   | 0     | 1.22  | 2.21  | 3.25  | 4.33  | 5.46  | 6.64  | 7.85  | 9.12  | 10.42 | 11.77 | 13.15 | 14.58 | 16.02 |
| Monel<br>(66 Ni - 29 Cu-Al)   | A                | 5.35                      | 6.45  | 6.80  | 7.12  | 7.48  | 7.68  | 7.90  | 8.09  | 8.30  | 8.50  | 8.70  | 8.90  | 9.10  | 9.30  | 9.50  | 9.70  | 9.89  |
|   | B                | 2.53                      | 1.70  | 0.98  | 0     | 1.17  | 2.12  | 3.13  | 4.17  | 5.28  | 6.43  | 7.62  | 8.86  | 10.16 | 11.50 | 13.00 | 14.32 | 15.78 |
| Aluminum  | A                | 9.90                      | 10.90 | 11.60 | 12.25 | 12.95 | 13.28 | 13.60 | 13.90 | 14.20 |       |       |       |       |       |       |       |       |
|   | B                | 4.68                      | 2.88  | 1.67  | 0     | 2.00  | 3.66  | 5.39  | 7.17  | 9.03  |       |       |       |       |       |       |       |       |
| Gray cast iron  | A                |                           |       |       |       | 5.75  | 5.93  | 6.10  | 6.28  | 6.47  | 6.65  | 6.83  | 7.00  | 7.19  |       |       |       |       |
|   | B                |                           |       |       | 0     | 0.90  | 1.64  | 2.42  | 3.24  | 4.11  | 5.03  | 5.98  | 6.97  | 8.02  |       |       |       |       |
| Bronze  | A                | 8.40                      | 8.75  | 9.15  | 9.57  | 10.03 | 10.12 | 10.23 | 10.32 | 10.44 | 10.52 | 10.62 | 10.72 | 10.80 | 10.90 | 11.00 |       |       |
|   | B                | 3.98                      | 2.31  | 1.32  | 0     | 1.56  | 2.79  | 4.05  | 5.33  | 6.64  | 7.95  | 9.30  | 10.68 | 12.05 | 13.47 | 14.92 |       |       |
| Brass   | A                | 8.20                      | 8.50  | 8.95  | 9.34  | 9.76  | 10.00 | 10.23 | 10.47 | 10.69 | 10.92 | 11.16 | 11.40 | 11.63 | 11.85 | 12.09 |       |       |
|   | B                | 3.88                      | 2.24  | 1.29  | 0     | 1.52  | 2.76  | 4.05  | 5.40  | 6.80  | 8.26  | 9.78  | 11.35 | 12.98 | 14.65 | 16.39 |       |       |
| Wrought iron  | A                | 5.70                      | 6.30  | 6.65  | 6.97  | 7.32  | 7.48  | 7.61  | 7.73  | 7.88  | 8.01  | 8.13  | 8.29  | 8.39  |       |       |       |       |
|   | B                | 2.70                      | 1.67  | 0.96  | 0     | 1.14  | 2.06  | 3.01  | 3.99  | 5.01  | 6.06  | 7.12  | 8.26  | 9.36  |       |       |       |       |
| Copper-Nickel<br>(70 Cu - 30 Ni)                                    | A                | 6.65                      | 7.40  | 7.80  | 8.16  | 8.54  | 8.71  | 8.90  |       |       |       |       |       |       |       |       |       |       |
|   | B                | 3.15                      | 1.95  | 1.13  | 0     | 1.33  | 2.40  | 3.52  |       |       |       |       |       |       |       |       |       |       |

These data are for information and it is not to be implied that materials are suitable for all the temperature ranges shown.

STRESSES IN PIPE FROM PRESSURE

HOOP (TANGENTIAL)

PRIMARY STRESS ON OUTSIDE FROM PRESSURE

$$\sigma_{r_0} = \frac{P_i r_i^2 + (r_i^2 r_o^2 / P^2) P_i}{r_o^2 - r_i^2} \quad \left( \begin{array}{l} \text{REF ADVANCED MECHANICS OF MATERIALS} \\ \text{SEELY & SMITH, 2ND EDITION, JOHN WILEY & SONS} \\ \text{N.Y., PAGE 299, EQ 346} \end{array} \right)$$

WHERE  $P = r_o$

$$\sigma_{r_0} = \frac{P_i (r_i^2 + r_o^2)}{r_o^2 - r_i^2} = \frac{2 P_i r_i^2}{r_o^2 - r_i^2}$$

HOOP (TANGENTIAL)

PRIMARY STRESS ON INSIDE FROM PRESSURE

$$\sigma_{r_i} = \frac{P (r_i^2 + r_o^2)}{r_o^2 - r_i^2} \quad \left( \begin{array}{l} \text{REF 3, PAGE 300} \\ \text{EQ 352} \end{array} \right)$$

PRIMARY LONGITUDINAL STRESS ON INSIDE AND OUTSIDE FROM PRESSURE

$$\sigma_{l_0} = \sigma_{l_i} = \frac{-P \pi r_i^2}{\pi (r_o^2 - r_i^2)}$$


$$\sigma_{l_0} = \sigma_{l_i} = \frac{-P}{\left( \frac{r_o^2}{r_i^2} - 1 \right)}$$

PRIMARY RADIAL STRESS ON INSIDE & OUTSIDE FROM PRESSURE

$$\left. \begin{array}{l} \sigma_{r_i} = -P \\ \sigma_{r_o} = 0.0 \end{array} \right\} \text{FROM INSPECTION}$$

Fig. 4-130.1

SECTION VIII — DIVISION 2



NOTE 1 — This limitation applies to the range of stress intensity. When the secondary stress is due to a temperature excursion at the point at which the stresses are being analyzed, the value of  $S_m$  shall be taken as the average of the  $S_m$  values tabulated in Part AM for the highest and the lowest temperature of the metal during the transient. When part or all of the secondary stress is due to mechanical load, the value of  $S_m$  shall be taken as the  $S_m$  value for the highest temperature of the metal during the transient.

NOTE 2 — The stresses in Category  $Q$  are those parts of the total stress which are produced by thermal gradients, structural discontinuities, etc., and do not include primary stresses which may also exist at the same point. It should be noted, however, that a detailed stress analysis frequently gives the combination of primary and secondary stresses directly and, when appropriate, this calculated value represents the total of  $P_m$  (or  $P_L$ ) +  $P_b$  +  $Q$  and not  $Q$  alone. Similarly, if the stress in Category  $F$  is produced by a stress concentration, the quantity  $F$  is the additional stress produced by the notch, over and above the nominal stress. For example, if a plate has a nominal stress intensity,  $S$ , and has a notch with a stress concentration factor,  $K$ , then  $P_m = S$ ,  $P_b = 0$ ,  $Q = 0$ ,  $F = P_m (K-1)$  and the peak stress intensity equals  $P_m + P_m (K-1) = KP_m$ .

NOTE 3 —  $S_a$  is obtained from the fatigue curves, Figs. 5-110.1, 5-110.2 and 5-110.3. The allowable stress intensity for the full range of fluctuation is  $2 S_a$ .

NOTE 4 — The symbols  $P_m$ ,  $P_L$ ,  $P_b$ ,  $Q$ , and  $F$  do not represent single quantities, but rather sets of six quantities representing the six stress components  $\sigma_t$ ,  $\sigma_L$ ,  $\sigma_r$ ,  $\tau_{tb}$ ,  $\tau_{lr}$ , and  $\tau_{rt}$ .

NOTE 5 — The  $k$  factors are given in Table AD-150.1.

FIG. 4-130.1 STRESS CATEGORIES AND LIMITS OF STRESS INTENSITY

TABLE AD-150.1  
STRESS INTENSITY *k* FACTORS FOR VARIOUS LOAD COMBINATIONS

| Condition  | Load Combination<br>(See AD-110)   | <i>k</i> Factors  | Calculated Stress<br>Limit Basis  |
|--|--|---|---|
| Design   | A The design pressure, the dead load of the vessel, the contents of the vessel, the imposed load of the mechanical equipment, and external attachment loads        | 1.0   | Based on the corroded thickness at design metal temperature                       |
|  | B Condition A above plus wind load   | 1.2   | Based on the corroded thickness at design metal temperature                       |
|  | C Condition A above plus earthquake load   | 1.2   | Based on the corroded thickness at design metal temperature                       |
| (NOTE: The condition of structural instability or buckling must be considered) |  |   |   |
| Operation  | A The actual operating loading conditions. This is the basis of fatigue life evaluation  | See AD-160 and Appendix 5   | Based on corroded thickness at operating pressure and metal operating temperature |
| Test   | A The required test pressure, the dead load of the vessel, the contents of the vessel, the imposed load of the mechanical equipment, and external attachment loads | 1.25 for hydrostatic test and 1.15 for pneumatic test. See AD-151 for special limits. | Based on actual design values at test temperature                                 |

TABLE AD-155.1  
MINIMUM PERMISSIBLE VESSEL METAL TEMPERATURES FOR FERROUS METALS OTHER THAN AUSTENITIC IN RELATION TO IMPACT TEST TEMPERATURE<sup>1</sup>

| Type of Vessel                | Service Temperature | Pressure Test Temperature | Startup Temperature |
|-------------------------------|---------------------|---------------------------|---------------------|
| Base Vessel                   | As-welded           | 30 F higher               | (Note 2)            |
|                               | PWHT                | Same                      | (Note 2)            |
| Lethal                        | As-welded           | Not permitted             | (Note 2)            |
|                               | PWHT                | (Note 5)                  | (Note 2)            |
| Refrigerated Service (Note 4) | As-welded           | 30 F higher               | (Note 2)            |
|                               | PWHT                | Same                      | (Note 2)            |

NOTES:

- (1) When impact tests are not performed because Fig. AM-218.1 is used, the minimum permissible temperature from Fig. AM-218.1 shall be considered the impact test temperature for applying this table.
- (2) If pressure is applied at a metal temperature below the minimum permissible temperature, it shall not exceed 20% of the required test pressure.
- (3) Only when nozzle welds and other areas of high localized stress are postweld heat treated, except in the case of 9% nickel steel up to and including 2 in. thickness; otherwise, 30 F higher.
- (4) Refrigerated service for purposes of this table is defined as service below 32 F where the temperature is controlled in the process rather than being caused by atmospheric conditions.
- (5) 20 F higher for each additional inch of nominal thickness or fraction thereof for thickness over 1 in. but not to exceed 60 F higher.



10-3-77

PAGE A-9

### THERMAL STRESS EQUATIONS

THE FOLLOWING EQUATIONS FOR THERMAL STRESSES IN A LONG CIRCULAR CYLINDER ARE OBTAINED FROM PAGE 412 OF THEORY OF ELASTICITY BY TIMOSHENKO AND GOODIER.

#### THERMAL STRAINS

$$\epsilon_r - \alpha T = \frac{1}{E} [\sigma_r - \nu (\sigma_\theta + \sigma_z)]$$

$$\epsilon_\theta - \alpha T = \frac{1}{E} [\sigma_\theta - \nu (\sigma_z + \sigma_r)]$$

$$\epsilon_z - \alpha T = \frac{1}{E} [\sigma_z - \nu (\sigma_r + \sigma_\theta)]$$

#### THERMAL STRESSES

$$\sigma_r = \frac{\alpha E}{1-\nu} \frac{1}{r^2} \left( \frac{r^2 - a^2}{b^2 - a^2} \int_a^b T r \, dr - \int_a^r T r \, dr \right) \quad (244)$$

$$\sigma_\theta = \frac{\alpha E}{1-\nu} \frac{1}{r^2} \left( \frac{r^2 + a^2}{b^2 - a^2} \int_a^b T r \, dr + \int_a^r T r \, dr - T r^2 \right) \quad (245)$$

$$\sigma_z = \frac{\alpha E}{1-\nu} \left( \frac{2}{b^2 - a^2} \int_a^b T r \, dr - T \right) \quad (246)$$



THE STRESS EQUATIONS ON THE PREVIOUS PAGE REDUCE TO THE FOLLOWING EQUATIONS FOR THE SPECIAL CASES OF  $r = a$  AND  $r = b$ .

HOOP STRESS (REF EQUATION 245, PAGE A-9)

INSIDE  $r = a$

$$\begin{aligned}\sigma_{T_i} &= \frac{\alpha E}{1-\nu} \frac{1}{a^2} \left[ \left( \frac{a^2 + a^2}{b^2 - a^2} \right) \int_a^b T r dr + \int_a^a T r dr - T a^2 \right] \\ &= \frac{\alpha E}{1-\nu} \frac{1}{a^2} \left[ \left( \frac{2a^2}{b^2 - a^2} \right) \int_a^b T r dr - T a^2 \right] \\ &= \frac{\alpha E}{1-\nu} \left[ \left( \frac{2}{b^2 - a^2} \right) \int_a^b T r dr - T \right]\end{aligned}$$

OUTSIDE:  $r = b$

$$\begin{aligned}\sigma_{T_o} &= \frac{\alpha E}{1-\nu} \frac{1}{b^2} \left[ \left( \frac{b^2 + a^2}{b^2 - a^2} \right) \int_a^b T r dr + \int_a^b T r dr - T b^2 \right] \\ &= \frac{\alpha E}{1-\nu} \frac{1}{b^2} \left[ \left( \frac{b^2 + a^2}{b^2 - a^2} + 1 \right) \int_a^b T r dr - T b^2 \right] \\ &= \frac{\alpha E}{1-\nu} \left[ \left( \frac{2}{b^2 - a^2} \right) \int_a^b T r dr - T \right]\end{aligned}$$

461510

K·E 10 X 10 TO THE CENTIMETER 18 X .75  
KEUFFEL & ESSER CO. MADE IN U.S.A.





FIGURE A-2. MAX TEMP GRADIENT THRU PIPE WALL  
CLOUD PASSAGE



| Stress Category   | Membrane  | Local Membrane   | Bending  | Expansion  | Membrane Plus Bending  | Peak  |
|---|---|--|--|--|--|---|
| Description (for examples see Table NB-3217-2)                              | Average primary stress across solid section. Excludes effects of discontinuities and concentrations. Produced by pressure and mechanical loads. | Average stress across any solid section. Considers effects of discontinuities but not concentrations. Produced by pressure and mechanical loads, including inertia earthquake effects. | Component of primary stress proportional to distance from centroid of solid section. Excludes effects of discontinuities and concentrations. Produced by pressure and mechanical loads, including inertia earthquake effects. (Note 6) | Stresses which result from the constraint of "free end displacement" and the effect of anchor point motions resulting from earthquakes. Considers effects of discontinuities but not local stress concentration. (not applicable to vessels) | Self-equilibrating stress necessary to satisfy continuity of structure. Occurs at structural discontinuities. Can be caused by pressure, mechanical loads, or by differential thermal expansion. Excludes local stress concentrations. | (1) Increment added to primary or secondary stress by a concentration (notch). (2) Certain thermal stresses which may cause fatigue but not distortion. |
| Symbol (Note 4)   | $P_m$   | $P_L$  | $P_b$  | $P_e$  | $Q$  | $F$   |
| Combination of stress components and allowable limits of stress intensities |   |  |  |  |  |   |



Note 1. When the secondary stress is due to a temperature transient at the point at which the stresses are being analyzed or to restraint of free end deflection, the value of  $S_m$  shall be taken as the average of the tabulated  $S_m$  values for the highest and the lowest temperatures of the metal during the transient. When part or all of the secondary stress is due to mechanical load, the value of  $S_m$  shall not exceed the value for the highest temperature of metal during the transient.

Note 2. The stresses in category Q are those parts of the total stress that are produced by thermal gradients, structural discontinuities, etc., and they do not include primary stresses that may also exist at the same point. However, it should be noted that a detailed stress analysis frequently gives the combination of primary and secondary stresses directly and, when appropriate, the calculated value represents the total of  $P_m + P_b + Q$  and not Q alone. Similarly, if the stress in category F is produced by a stress concentration, the quantity F is the additional stress produced by the notch over and above the nominal stress. For example, if a point has a nominal stress intensity,  $P_m$ , and has a notch with a stress concentration factor, K, then  $P_m < S_m$ ,  $P_b = Q = 0$ ,  $F = P_m(K - 1)$ , and the peak stress intensity equals  $P_m + P_m(K - 1) = KP_m$ . However,  $P_L$  is the total membrane stress that results from mechanical loads, including discontinuity effects, rather than a stress increment. Therefore, the  $P_L$  value always includes the  $P_m$  contribution.

Note 3.  $S_a$  is obtained from the fatigue curves, Figs. 1-9.0. The allowable stress intensity for the full range of fluctuations is  $2S_a$ .

Note 4. The symbols  $P_m$ ,  $P_L$ ,  $P_b$ ,  $P_e$ ,  $Q$ , and  $F$  do not represent single quantities but sets of six quantities representing the six stress components  $\sigma_1$ ,  $\sigma_2$ ,  $\sigma_3$ ,  $\tau_{11}$ ,  $\tau_{12}$ , and  $\tau_{21}$ .

Note 5. Special rules for exceeding  $3S_m$  are provided in NB-3228.3.

Note 6. Bending component of primary stress for piping shall be the stress proportional to the distance from centroid of pipe cross-section.

FIG. NB-3222-1  
STRESS CATEGORIES AND LIMITS OF STRESS INTENSITY FOR NORMAL AND UPSET OPERATING CONDITIONS

56 OF 74  
A-13

APPENDIX I STRESS TABLES

FIG. 1-9-1




FIG. 1-9-1 DESIGN FATIGUE CURVES FOR CARBON, LOW ALLOY, AND HIGH TENSILE STEELS  
(For Metal Temperatures Not Exceeding 700 F)

FIG A-3

Table I-14.6D

2% Cr-1 Mo - Expected Minimum Stress-to-Rupture Values, ksi

| Temp., °F | 10 hr | 30 hr | 10 <sup>3</sup> hr | 3 X 10 <sup>3</sup> hr | 10 <sup>4</sup> hr | 3 X 10 <sup>4</sup> hr | 10 <sup>5</sup> hr | 3 X 10 <sup>5</sup> hr | 10 <sup>6</sup> hr | 3 X 10 <sup>6</sup> hr |
|-----------|-------|-------|--------------------|------------------------|--------------------|------------------------|--------------------|------------------------|--------------------|------------------------|
| 700       | 59.0  | 59.0  | 59.0               | 59.0                   | 59.0               | 59.0                   | 59.0               | 59.0                   | 54.0               | 49.0                   |
| 750       | 50.0  | 57.0  | 56.0               | 51.6                   | 53.0               | 51.2                   | 48.0               | 43.3                   | 37.5               | 31.1                   |
| 800       | 56.0  | 55.5  | 51.0               | 48.5                   | 43.0               | 37.5                   | 34.5               | 30.5                   | 27.0               | 24.0                   |
| 850       | 52.0  | 50.5  | 46.0               | 40.5                   | 35.0               | 31.0                   | 27.5               | 24.0                   | 21.0               | 18.5                   |
| 900       | 46.0  | 41.0  | 36.0               | 32.0                   | 28.0               | 25.0                   | 21.6               | 19.0                   | 16.4               | 14.1                   |
| 950       | 40.0  | 35.0  | 30.0               | 26.0                   | 22.2               | 19.5                   | 17.0               | 14.6                   | 12.6               | 11.0                   |
| 1000      | 31.5  | 27.5  | 24.0               | 21.0                   | 17.9               | 15.2                   | 13.1               | 11.0                   | 9.4                | 7.9                    |
| 1050      | 26.0  | 22.5  | 19.0               | 16.5                   | 14.0               | 12.0                   | 10.0               | 8.3                    | 7.0                | 5.8                    |
| 1100      | 21.0  | 18.0  | 15.1               | 13.0                   | 10.8               | 9.1                    | 7.5                | 6.2                    | 5.0                | 4.1                    |
| 1150      | 17.0  | 14.1  | 11.8               | 9.8                    | 8.0                | 6.7                    | 5.4                | 4.4                    | 3.5                | 2.8                    |
| 1200      | 13.5  | 11.1  | 9.2                | 7.6                    | 6.2                | 5.0                    | 4.0                | 3.2                    | 2.5                | 2.0                    |




Fig. I-14.6D. 2% Cr/1 Mo - 100 percent of the minimum stress-to-rupture

FIG A-4

CASES OF ASME BOILER AND PRESSURE VESSEL CODE

CASE (continued)  
N-47  
(1592-10)

58 OF 74  
A-15

155

230

APPENDIX B

DOWNCOMER PIPE ANALYSIS

FOR

CLOUD PASSAGE CONDITION

ASSUMING

STEAM TEMPERATURE CHANGES INSTANTANEOUSLY

(REFERENCE INFORMATION ONLY)



DOWNCOMER PIPE

CLOUD PASSAGE CONDITION

LOADS :

PRESSURE  $P = 1515$  PSIA

TEMPERATURE : THE TEMPERATURE GRADIENT THROUGH THE PIPE WALL IS SHOWN IN FIGURE B1, APPENDIX, PAGE B-8, AND IS SUMMARIZED BELOW IN TABLE B1

TABLE B1

TEMPERATURE GRADIENT IN PIPE WALL  
CLOUD PASSAGE CONDITION

| R<br>(IN) | T<br>(°F) |
|-----------|-----------|
| 2.635     | 914       |
| 2.714     | 925       |
| 2.794     | 934       |
| 2.873     | 942       |
| 2.952     | 947       |
| 3.032     | 951       |
| 3.111     | 954       |
| 3.191     | 955       |
| 3.270     | 956       |

$T_o = 956$

$T_i = 908$

$T_{AVE} = 942^\circ F$

(REF PAGE B-5)



DOWNCOMER PIPE - CLOUD PASSAGE  
(CONT)

MATERIAL PROPERTIES

A 335 FERRITIC ALLOY STEEL (2 1/4 CR - 1 Mo.)  
SEAMLESS PIPE FOR HIGH TEMP SERVICE

TABLE B-II

ALLOWABLE STRESS INTENSITIES - A335 AT ELEVATED TEMPS

| TEMP (DEG F) | S <sub>m</sub> (KSI)                           |
|--------------|--|
| R.T.         | F <sub>T</sub> = 30.0<br>F <sub>w</sub> = 60.0 |
| 900°         | 13.1   |
| 950°         | 11.0   |
| 1000°        | 7.8  |

← (REF APPENDIX, PAGE A-2)

} (REF APPENDIX, PAGE A-3)

STRENGTH AT 956° F (OUTSIDE)

$$\sigma_{956} = 11.0 - (11.0 - 7.8) \left( \frac{956 - 950}{1000 - 950} \right) = \underline{10.62 \text{ KSI}}$$

STRENGTH AT 908° F (INSIDE)

$$\sigma_{908} = 11.0 + (13.1 - 11.0) \left( \frac{950 - 908}{950 - 900} \right) = \underline{12.76 \text{ KSI}}$$

DOWN CUMER PIPE - CLOUD PASSAGE  
(CONT)MATERIAL PROPERTIES (CONT)MODULUS OF ELASTICITY & COEFFICIENT OF EXPANSIONTABLE B-IIIMODULUS OF ELASTICITY AND COEFFICIENT OF EXPANSION OF  
A 335 AT ELEVATED TEMPERATURES

| TEMP<br>DEG F | E<br>(LBS/IN <sup>2</sup> )<br>( $\times 10^{-6}$ ) | $\alpha$<br>(IN/IN/°F)<br>( $\times 10^{-6}$ ) |
|---------------|---|--|
| RT            | 29.9  | 6.07   |
| 900°          | 24.5  | 7.84   |
| 1000°         | 23.0  | 7.97   |

↑ REF  
APPENDIX  
PAGE A-4↑ REF  
APPENDIX  
PAGE A-5MODULUS OF ELASTICITY AT AVERAGE TEMP T = 942° F

$$E = \left[ 24.5 - (24.5 - 23.0) \frac{(942 - 900)}{(1000 - 900)} \right] \times 10^6$$

$$= \frac{23.87 \times 10^6}{\text{LBS/IN}^2}$$

COEFFICIENT OF EXPANSION AT T<sub>avg</sub> = 942° F

$$\alpha = \left[ 7.84 + (7.97 - 7.84) \frac{(942 - 900)}{(1000 - 900)} \right] \times 10^{-6}$$

$$= \frac{7.89 \times 10^{-6}}{\text{IN/IN/°F}}$$

DOWNCOMER PIPE - CLOUD PASSAGE (CONT)SECONDARY STRESS (FROM TEMPERATURE)

THE FOLLOWING PARAMETERS ARE REQUIRED FOR USE  
IN THE THERMAL STRESS CALCULATIONS BELOW:

THE INTEGRAL OF  $\int_a^b T r dr$  (FIGURE B-1, APPENDIX B-8)  
IS OBTAINED (PAGE B-5) USING SIMPSON'S RULE ON DATA FROM  
TABLE B-IV.

TABLE B-IVTEMPERATURE GRADIENT IN PIPE WALL, CLOUD PASSING \*

| r<br>RADIUS<br>(IN) | T*<br>TEMP<br>(°F) | T*r<br>(°F IN) |
|---------------------|--------------------|----------------|
| 2.5945              | 908.0              | 2356           |
| 2.6971              | 923.0              | 2489           |
| 2.7996              | 935.0              | 2612           |
| 2.9022              | 944.0              | 2740           |
| 3.0048              | 950.0              | 2855           |
| 3.1074              | 953.5              | 2963           |
| 3.2099              | 955.5              | 3067           |
| 3.3125              | 956.0              | 3167           |

\* REF FIGURE B-1 APPENDIX PAGE B-8

DOWNCOMER PIPE - CLOUD PASSAGE (CONT)

SECONDARY STRESS (FROM TEMPERATURE) (CONT)

$$\int_{r_i}^{r_o} T r dr = \frac{\Delta r}{2} \left[ (Tr)_1 + 2(Tr)_2 + 2(Tr)_3 + \dots + 2(Tr)_7 + (Tr)_8 \right]$$

(SIMPSON'S RULE)

WHERE  $\frac{\Delta r}{2} = \frac{.1026}{2} = .0513$  (IN)

$r_o = 3.3125$  (IN)

$r_i = 2.5945$  (IN)

REF TABLE B-IV

AND  $(Tr)_1, (Tr)_2$ , ETC. ARE OBTAINED FROM TABLE B-IV.

$$\int_{2.5945}^{3.3125} T r dr = .0513 \left[ 2356 + 2 \times 2489 + 2 \times 2618 + 2 \times 2740 + 2 \times 2855 + 2 \times 2963 + 2 \times 3067 + 3167 \right]$$

$$= .0513 [38987] = 2000.0 \text{ (}^\circ\text{F IN}^2\text{)}$$

AVERAGE TEMP (FOR MAT'L PROPERTIES)

$$T_{AVG} = \frac{\int_{r_i}^{r_o} T dr}{(r_o - r_i)} = \frac{676.4}{.718} = 942 \text{ }^\circ\text{F}$$

DOWNCOMER PIPE - CLOUD PASSAGE (CONT)SECONDARY STRESS (FROM TEMPERATURE) (CONT)THERMAL HOOP STRESS - INSIDE

$$\sigma_{Ti} = \frac{\alpha E}{1-\mu} \left[ \frac{2}{b^2 - a^2} \int_a^b T r dr - T \right]$$

WHERE  $\alpha = 7.89 \times 10^{-6}$  (IN/IN/°F) } (REF PAGE B-3)

$E = 23.87 \times 10^6$  (LBS/IN<sup>2</sup>) }

$b = r_2 = 3.3125$  (IN) } (REF PAGE I-1)

$a = r_1 = 2.5945$  (IN) }

$\int_a^b T r dr = 2000.0$  (°F·IN<sup>2</sup>) (REF PAGE B-5)

$T = 908$  (°F) ;  $\mu = .3$

$$\sigma_{Ti} = \frac{7.89 \times 10^{-6} \times 23.87 \times 10^6}{1-.3} \left[ \frac{2}{3.3125^2 - 2.5945^2} \times 2000.0 - 908 \right]$$

$$= 269.05 [943.12 - 908] = \underline{9450 \text{ (LBS/IN}^2\text{)}}$$

THERMAL HOOP STRESS - OUTSIDE

$$\sigma_{To} = \frac{\alpha E}{1-\mu} \left[ \frac{2}{(b^2 - a^2)} \int_a^b T r dr - T \right]$$

WHERE  $\alpha, E$ , ETC ARE THE SAME AS ABOVE  
EXCEPT FOR  $T$

$T = 956$  (°F)

$$\sigma_{To} = (7.89 \times 10^{-6} \times 23.87 \times 10^6) / (1-.3) \left[ \frac{2}{3.3125^2 - 2.5945^2} \times 2000.0 - 956 \right]$$

$$= 269.05 [943.12 - 956] = \underline{-3464 \text{ (LBS/IN}^2\text{)}}$$



E GILLIS

6-7-79

PAGE B-7

DOWN COMET PIPE - CLOUD PASSAGE (CONT)

SECONDARY STRESS (FROM TEMPERATURE) (CONT)

THERMAL LONGITUDINAL STRESSES - INSIDE & OUTSIDE

INSPECTION OF THE EQUATIONS FOR HOOP STRESS AND LONGITUDINAL STRESS (REF APPENDIX PAGES A-9 AND A-10) SHOWS THAT THE LONGITUDINAL STRESS IS EQUAL TO THE HOOP STRESS ON BOTH THE INNER AND OUTER SURFACES.

$$\sigma_{2Ti} = \sigma_{1Ti} = 9450 \text{ (LBS/IN}^2\text{)}$$

$$\text{AND } \sigma_{2To} = \sigma_{1To} = -3464 \text{ (LBS/IN}^2\text{)}$$

# TEMPERATURE GRADIENT THROUGH PIPE WALL

4 SECOND AFTER  
STEAM TEMPERATURE  
DROPS FROM 960°F TO 660°F

REF. JOB PAGE NO. PIK DATE 6-5-59  
JOB PAGE NO. \_\_\_\_\_ MODEL \_\_\_\_\_ REPORT NO. \_\_\_\_\_





FIGURE B-1 Cloud Passage

NOTES:


1) ASSUMES A COLLECTOR FIELD STAGED CLOUD TAKES 1.5 MIN TO PASS OVER THE FIELD EVERY 5 MINUTES (30% CLOUD COVER, PER OPPO)

2) DURING THE 10% SYSTEM DOWN TIME, THE TEMP AND PRESS WILL BE AMBIENT.

Switch to diverted steam  
Rec shutdown



Purge & fill start  
10 deg sun down  
Condition down cover  
sync & load  
Purge transition  
THAT THE INLET PRESSURE



\* STEAM TEMP AT INLET TO DOWNCOVER STEAM INLET VALVE

TYPICAL DAILY CYCLE



## ASSUMPTIONS FOR PLANT STARTUP

1. Circulating water is available.
2. Cooling tower fan is on (one).
3. Bearing cooling water is available.
4. Air compressors are on (service and instrument).
5. Condensate storage water makeup system is active.
6. #1 train active for seal steam, blanket steam and DA pegging steam (on auxiliary pump).
7. Vacuum is on condenser.
8. Hotwell pump is on-line and recirc to condenser is active.
9. Deaerator pegging steam is (20) psia from TSSG.
10. Deaerator water temperature is (228)°F.
11. Downcomer is "bottled up" and on blanket steam.
12. Receiver has been drained and pressurized with GN<sub>2</sub>.
13. TSCH has been on blanket steam overnight with inlet valve (TDSIV) closed.

---

Drawings used

RS P&ID, C060479, A Change  
TSS P&ID, C061179, A Change  
Solar Flow Diagram, S10MW-PP, R4 Revision

RS FEEDPUMP STARTUP

The RS feedpump is started in a recirculating configuration prior to supplying feedwater to the system.

1. Check valve lineup (visual check)
  - (a) RS feedpump discharge valve closed, and bypass closed.
  - (b) Bearing cooling water valve open.
  - (c) Bearing lube oil available.
  
2. Start pump and ramp speed to minimum flow (TBD #/hr) and verify
  - (a) Recirculate valve open
  - (b) Motor current correct
  - (c) Vibration (TBD)
  - (d) Bearing cooling water ok
  - (e) Bearing lube oil ok

CONDENSATE CLEANUP

Prior to RS startup the condensate water chemistry must be within certain specifications. This is accomplished by circulating the condensate through the demineralizers and increasingly larger loops of the system until the total system contains clean condensate.

1. Line up valves for initial condensate cleanup from the deaerator to the RS feedwater pump through tower riser bypass loop (TRBL) to condenser and back through the condenser hotwell, demineralizers, low pressure heater (#4) to the deaerator.
  - (a) Preheat panel inlet (RWISK) and receiver panel bypass (RWBV) closed
  - (b) Verify (or set) receiver feedwater pump flow at (28800) lb/hr on recirculation
  - (c) Open TRBL valve into condenser
  - (d) Open TRBL valve at bottom of tower riser
  - (e) Open receiver feedwater pump discharge bypass valve to fill and pressurize line. Monitor downstream pressure.

Section No 2.7  
Release Initial  
Release Date 9-14-79  
Page 2.7-4

- (f) Open receiver feedwater pump discharge valve when pressure across valve is (50) psia. Close bypass valve.
- (g) Circulate condensate in this configuration until water chemistry is (10) PPB, etc.
- 2. Line up valves for condensate cleanup through receiver panel bypass loop.
  - (a) Flash tank inlet closed (RFSIV)
  - (b) Receiver accumulator outlet closed (RAWDV)
- 3. Activate Flash Tank drain controllers to maintain a water level which is below the steam outlet to RFSPCV. Flash tank drain to condenser controller - manual closed loop, setpoint = (3) ft. Flash tank drain to #2 heater closed loop - valve closed (0%) controller - manual.
- 4. Activate flash tank pressure controller, RFSPCV (setpoints, manual closed loop). This valve should remain closed until steam is being generated by the receiver.
  - (a) Verify flash tank water level (3) feet (if too high, drain to desired level before activating this controller).
  - (b) Verify flash tank pressure (500) psia.
  - (c) Make pressure setpoint = 500 psia.
- 5. Open RWBV valve to receiver flash tank.
- 6. Ramp TRBL valve into condenser closed.
- 7. Verify flash tank pressure 500 psia and water level (3) feet. and pump flow is (28800) #/hr. (adjust pump speed to maintain the above).
- 8. Close TRBL valve at bottom of tower riser.
- 9. Circulate condensate in this configuration until water chemistry is (10) PPB, etc.

RECEIVER STARTUP

Since it was assumed that the receiver had been drained and pressurized it is necessary to vent the GN<sub>2</sub> out of the receiver panels, as the panels are filled with condensate. After filling the condensate is circulated through the panels until the water chemistry is correct. The receiver

2

Section No 2.7  
Release Initial  
Release Date 9-14-79  
Page 2.7-5

is then started through the RS flash tank. When (100)°F of superheat is available the downcomer is conditioned through the turbine inlet bypass loop. Finally pressure control is handed off to the turbine inlet bypass controller, the RS flash tank is shut down and the receiver brought to the desired pressure and temperature for turbine start and/or TS charging.

1. Shutoff GN<sub>2</sub> supply to receiver (if required)
2. Line up valves for startup  
Downcomer stop valve - closed (RDSIV)  
Flash tank inlet valve - closed (RFSIV)
3. Activate the panel temperature controllers in manual - open loop and set the 18 valve positions to (50)% open. Load the closed loop set points - (585)°F.

Note: It may be necessary to have an intermediate boiler outlet temperature setpoint during initial activation of heliostats to prevent thermal shock of the panels, etc. If this is required the above set point would be (400)°F and changed to (585)°F after step 7 below.

4. Open preheat panel inlet valve (RWISK)
5. Close receiver panel bypass valve (RWBV) to (90)% to start condensate flow slowly up into panels (to prevent thermal shock). Open the two main receiver vent valves (to atmosphere) to vent GN<sub>2</sub> (RPWVV, RMSVV). Close each valve as soon as condensate starts flowing. After both vents are closed open the flash tank inlet valve (RFSIV).
6. Monitor all panel temperature (RBSOT-XX). Compare these temperatures with feedwater inlet temperature (RWIT). When all panel temperatures are within 80% of the feedwater temperature, ramp receiver panel bypass valve (RWBV) closed while monitoring flash tank pressure and panel flow. Adjust the pump speed, if required, to maintain the (28,800) #/hr flow and circulate the condensate in this configuration until the water chemistry is

Section No 2.7  
 Release Initial  
 Release Date 9-14-79  
 Page 2.7-6

(10) PPB, etc. (during this period the flash tank pressure should be below 500 psia and the condensate level at (3) ft).

7. Activate flash tank drain to #2 heater controller - manual - closed loop, set point = (3) feet. (This controller has a 135 psia limit override, i.e. the valve closes when the pressure  $\geq$  135 psia.) Close flash tank drain to condenser and reconfigure this controller to manual - closed loop to operate if the RS flash tank high - high level (TBD ft) transducer is activated.
8. Activate the RS panel temperature controllers in manual - closed loop (set point previously loaded at (585)°F). Verify (TBD) #/hr flow (minimum) through each panel.
9. Activate RS feedwater pump controller to manual closed loop, setpoint = 550 psia. This controller maintains preheat panel inlet pressure (RWIP) at this valve.
10. Activate (TBD) segments of heliostats in incremental steps up to an insolation power level of approximately TBD MW (per CS startup procedure).
11. Monitor receiver temperature rise to 585°F (RMSOT) and:
  - (a) Verify flash tank pressure (RFSOP) control ok at 500 psia and water level (RFWL) (3) feet.
  - (b) Verify all panel temperature are rising (BSOT1-18)
  - (c) Add or subtract, CS segments if required
  - (d) Verify total flow 40000 #/hr
12. Activate receiver accumulator (RA) drain valve (RAWDV) controller in manual - closed loop with level setpoint = (1) foot.
13. Setup turbine inlet bypass line:
  - (a) Close main steam line blanket steam valve (steam from/to blanket - seal steam network).
  - (b) Open turbine inlet bypass valve to (50)% with controller in manual - open loop.
  - (c) Actuate desuperheater temperature controllers - (300)°F setpoint.
  - (d) Verify condenser vacuum (2.5) in Hg.
14. Condition downcomer:
  - (a) Verify stable receiver operation - (RSOT)°F, (RSOP psia

Section No 2.7  
 Release Initial  
 Release Date 9-14-79  
 Page 2.7-7

- (b) Open downcomer valve (RDSIV) (5)% (7) GPM, (F) ft/sec flow velocity
  - (c) Open main steam lines low point drains (if required)
  - (d) Monitor turbine inlet bypass line temperature and pressure
  - (e) Adjust flow using RDSIV such that temperature is rising at (10)°F/min.
15. Switch from flash tank to bypass control:
- (a) Verify stable operation of receiver and bypass line temperature is (585)°F.
  - (b) Activate turbine inlet bypass valve controller - manual - closed loop. Put in setpoint of (20 psia less than pressure at this valve) psia - manual - closed loop.
  - (c) Ramp downcomer stop valve (RDSIV) open.
  - (d) Verify RS flash tank pressure control valve (RFSPCV) closed and flash tank pressure \_ 500 psia (leave this controller active).
  - (e) Close flash tank inlet stop valve (RFSIV)
  - (f) Close main steam line low point drains, (if they were opened by the operator).
  - (g) Reactivate main steam line blanket and seal steam controller (blanket and seal steam should now be supplied from main steam).
  - (h) Monitor flash tank pressure to assure it is \_ 500 psia.

Note: Receiver steam is now available for turbine roll or TS charging.

TURBINE STARTUP

(Receiver Steam)

- 1. Increase pressure/temperature to turbine roll conditions (if other than a cold start)
  - (a) Ramp temperature setpoint to (TBD)°F at (TBD)°F/min (if required 18 setpoints).


9/11/79  
10F14

RECEIVER PANEL POWER GRADIENT ANALYSIS

THIS PACKAGE DEFINES ~~S~~ PANEL GRADIENTS  
CAUSED BY


- 1) NORMAL POWER VARIATIONS EXPERIENCED  
ON SUMMER SOLSTICE, EQUINOX,  
AND WINTER SOLSTICE
  
- 2) CLOUD PASSAGE AS DEFINED BY  
A SERIES OF "SNAP SHOTS" AS  
THE CLOUD PASSES OVER THE  
FIELD

PANEL POWER VARIATION - EQUINOX






# PANEL POWER VARIATION - SUMMER SOLSTICE



# PANEL POWER VARIATION - WINTER SOLSTICE




50F14


# PANEL 13 GRADIENT HISTORY

K&E PHOTO ETCHING CO. WASHINGTON  
10 x 10 TO THE CENTIMETER 18 x 20 CM

40 1213



# INCIDENT PANEL POWER ON PANEL (MW)



DAY 216  
HR 077


PANEL NUMBER




IMPACT OF COLLECTOR FIELD LAYOUT OPTIONS ON NORTH

PANEL GRADIENT

OCT 21  
3:50 PM





PANEL POWER (MW)

254

PANEL NUMBER

8 of 14

REF CASE

Row 30 OUT

-1907-

DELETE 20 MORE OFF ENDS

Row 29 SOME DELETES

TEST CASE 1

-1906-

Row 29 + 30 OUT

COMPLETE OUT THRU 19

CIRCLE 20 NO DELETE

CIRCLES 21 - 28 SAME AS REF CASE

TEST CASE 2

Rows 28, 29, + 30 OUT

COMPLETE CIRCLE 20 + 21 COMPLETE

CIRCLES 22 - 27

6 OFF 27  
4 OFF 26





FIGURE 2

This figure looks at the panel gradients created by 3 alternate collector field designs. The data was developed by the U of H for Oct 21 which is less severe from a gradient standpoint than summer solstice. It shows that the gradients on panels 13 and 14 are essentially identical for the three layouts (identical slopes). The penalties in going with option 1 are

- redo Grading and Concrete construction package
- add ~\$300,000 in extra heliostats
- rework preheat panels because of excessive heat loads.

Penalties in going to option 2 are

- redo Grading and Concrete construction packages
- add ~\$720,000 in extra heliostats
- rework or abandon preheat panels because of excessive heat loads.

INCIDENT POWER — NORTH / SOUTH CLOUD PASSAGE  
(EQUINOX NOON)

| EVENT | 13    | 14    | 15 | 16    | 17    | 18    | 19    | 20    | 21    | 22    | 23 | 24    |
|-------|-------|-------|----|-------|-------|-------|-------|-------|-------|-------|----|-------|
| 1     | 3.08  | 3.11  |    | 2.81  | 2.665 | 2.279 | 1.916 | 1.66  | 1.363 | 1.074 |    | .8701 |
| 3     | 2.59  | 2.665 |    | 2.622 |       | 2.249 |       | 1.66  |       | 1.074 |    | .870  |
| 5     | 1.38  | 1.516 |    | 2.093 |       | 2.107 |       | 1.64  |       | 1.072 |    | .870  |
| 7     | .236  | .354  |    | 1.038 |       | 1.432 |       | 1.508 |       | 1.064 |    | .870  |
| 9     | 0     | 0     |    | .0444 |       | .395  |       | 1.037 |       | .936  |    | .854  |
| 11    | 0     | 0     |    | .0045 |       | ~0    |       | .151  |       | .278  |    | .354  |
| 13    | .087  | .079  |    | .035  |       | 0     |       | 0     |       | 0     |    | 0     |
| 15    | 1.059 | .980  |    | .408  | .1739 | .064  |       | 0     |       | 0     |    | 0     |
| 17    | 2.309 | 2.20  |    | 1.163 |       | .419  |       | .0699 |       | .0048 |    | 0     |
| 19    | 3.054 | 3.042 |    | 2.447 |       | 1.46  |       | .287  |       | .016  |    | 0     |
| 21    | 3.08  | 3.111 |    | 2.791 |       | 2.111 |       | 1.159 |       | .445  |    | .167  |
| 23    | 3.08  | 3.11  |    | 2.81  |       | 2.279 |       | 1.66  |       | 1.074 |    | .870  |

FIGURE 1 OF 2

NORTH TO SOUTH CLOUD PASSAGE

(EQUINOX NOON)

EYE # 1  
(NO CLOUD)


3.0

2.0

1.0


0

INCIDENT POWER (MWt)



PANEL NUMBER

NORTH TO SOUTH CLOUD PASSAGE  
(EQUINOX NOON)  
FIGURE 2 OF 2



3/4/79  
1 OF 1

## RECEIVER SIZE DEFINITION

$$\text{BEST DAY 8 AM} \rightarrow (I)(C_{os})(B+S) = 677.41 = (897.66)(.7605)(.9923)$$

$$\text{PDR WINTER 2 PM} \rightarrow (I)(C_{os})(B+S) = 715.43 = (950)(.8015)(.9396)$$

SINCE BOTH MUST SUPPLY THE SAME POWER,

$$A_1 (677.41) = A_2 (715.43)$$

$$A_1 = \left(\frac{715.43}{677.41}\right) A_2 = 1.056 A_2 \quad \text{GLASS AREA SCALING FACTOR}$$

## PEAK POWER COMPARISON

$$\text{BEST DAY NOON} \quad P_1 = A_1 (989.67)(.8442)(.9974) = 833.31 A_1$$

$$\text{PDR NOON} \quad P_2 = A_2 (950)(.8442)(.9974) = 799.90 A_2$$

$$P_1 = 833.31 A_1$$

$$P_2 = 799.90 A_2$$

$$= (833.31)(1.056) A_2$$

$$P_1 = 879.98 A_2$$

$$P_1 = 879.98 \left(\frac{P_2}{799.90}\right) = 1.100 P_2$$

ASSUME SAME RELATIVE CIRCUMFERENTIAL DISTRIB.

$$L_1 = 1.100 L_2 \quad (\text{RECEIVER LENGTH})$$

(ASSUME ADDITIONAL POWER IS APPLIED AT AVERAGE FLUX LEVEL)

$$\text{SEE PEAK TO AVERAGE CALC} \quad \frac{\text{PEAK}}{\text{AVE}} = 1.27$$

IF  $\Delta P$  IS APPLIED AT PEAK LEVEL (SAME END FALL OFF ASSUMED),  $\Delta L$  CAN BE REDUCED BY FACTOR  $P/A = 1.27$

$$\Delta L = 10\% \left(\frac{1}{1.27}\right) = 7.87\%$$

$$L_1 = 1.08 L_2 \rightarrow L_2 \text{ WAS } 41 \text{ FT (12.5m)} \Rightarrow \boxed{L_1 = 44.3 \text{ FT}} \\ \boxed{45 \text{ FT}}$$



ANALYSIS TS FEEDWATERMCDONNELL DOUGLAS  
CORPORATIONPAGE 1 OF 19PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR I

REPORT NO. \_\_\_\_\_

PACKAGE SUMMARY

THIS PACKAGE DEFINES:

1. MINIMUM FEEDWATER PRESSURE AT THE INLET TO THE TS STEAM GENERATOR SKIDS — 500 PSID
2. MAXIMUM FEEDWATER PRESSURE TO WHICH THE PIPING AND FLOW ELEMENTS MUST BE DESIGNED — 615 PSID
3. ALL FLOW PRESSURE DROPS BETWEEN THE OUTLET OF THE FEED PUMP AND INLET TO THE STEAM GENERATOR SKIDS

ANALYSIS THERMAL STORAGE FEEDWATER



PAGE 2 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR I

REPORT NO. \_\_\_\_\_

I. PURPOSE : DEFINE FEEDWATER CONDITIONS ARRIVING AT THE THERMAL STORAGE STEAM GENERATOR EQUIPMENT

II. ASSUMPTIONS :

(a) TS FEEDWATER PUMP (P-903) SUPPLIED BY SCE.

ESTIMATED PUMP CHARACTERISTICS

| (Q)     | (H)     |                       |
|---------|---------|-----------------------|
| 236 gpm | 1137 FT | (FROM SCE)<br>4/18/80 |
| 0 gpm   | 1375 FT | [SEE FIG 1]           |

(b) DEAERATOR CAN OPERATE ANYWHERE WITHIN THE RANGE OF 20 - 50 PSIA

(c) TS FEEDWATER PIPE ROUTING AS SHOWN ON ANALYSIS ISOMETRIC (P13-5) - 40P3005132011  
NOTE: PORTION INSIDE EPGs NOT FIRM DUE TO INCOMPLETE SCE DESIGN.

III. PUMP OUTPUT PRESSURE

(a) INLET CONDITIONS

|                             |   |  |
|-----------------------------|---|--|
| DEAERATOR PRESS             | 20 psia<br>( $\rho_{H_2O} = 59.4 \frac{lb}{ft^3}$ ) | 50 psia<br>( $\rho = 57.9 \frac{lb}{ft^3}$ ) |
| VERT. COLUMN<br>(30 FT MAX) | 12.4 psia   | 12.06 psia                                   |
| (TOTAL INLET PRESS)         | 32.4 psia   | 62.06 psia                                   |




K.E. KENNEL & ESPER CO. MADE IN U.S.A.  
10 X 10 TO 1 1/2 INCH 1 X 10 INCHES

40 1351

4/21/80  
JER

Fig 1 THERMAL STORAGE FEED PUMP H-Q CURVE \*



QUADRILLE WORK SHEET

ANALYSIS TS FEEDWATER



PAGE 4 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR I

REPORT NO. \_\_\_\_\_

(b) OUTLET CONDITIONS

DEAERATOR PRESSURE 20 psia 50 psia

@ 110,000 LB/HR TOTAL FLOW

HEAD RISE 1155 FT 1130 FT  
(476.6 psia) (454.3 psia)

+ INLET PRESS 32.4 psia 62.06 psia

TOTAL OUTLET 509.0 psia 516.36 psia

@ 0 LB/HR TOTAL FLOW

HEAD RISE 1375 FT 1375 FT  
(567 psia) (552.9 psia)

+ INLET PRESS 32.4 psia 62.06 psia

TOTAL OUTLET 599.4 psia 614.96 psia

@ 80,000 LB/HR TOTAL FLOW

HEAD RISE 1290 FT 1282 FT  
(532.3 psia) (515.5 psia)

+ INLET PRESS 32.4 psia 62.06 psia

TOTAL OUTLET 564.7 psia 577.56 psia

ANALYSIS TS FEEDWATER



PAGE 5 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR ONE

REPORT NO. \_\_\_\_\_

IV. TS FEEDWATER LINE LOSS

CALCULATIONS ACCOMPLISHED IN TWO STEPS:

(i) LOSSES FROM PUMP OUTLET TO PIPING SPLIT POINT (SEE ANALYSIS ISOMETRIC P13-5 ZN E-6, POINT (13))

(ii) LOSSES DOWNSTREAM OF THE SPLIT POINT TO THE STEAM GENERATOR INTERFACE POINTS. (76I + 77I)

PIPING CHARACTERISTICS :

| (PUMP TO SPLIT)               | (SPLIT TO 76I)           | (SPLIT TO 77I)           |
|-------------------------------|--------------------------|--------------------------|
| PIPE : 129.65 FT<br>4" SCH 40 | 85.4 FT<br>2 1/2" SCH 40 | 54.7 FT<br>2 1/2" SCH 40 |
| VALVES : 1                    | 0                        | 0                        |
| RT. ANGLES 11                 | 4                        | 4                        |

CALCULATIONS PUMP TO SPLIT

4" SCH 40 LINE DROP :  
236 gpm (129 FT) → 1.55 psia

REF VOGT F-11 CATALOG TABLE 3B  
PAGE 289

ELBOWS :  
 $\Delta H = K \frac{V^2}{2g}$

ASSUME K = 0.21  
RT ANGLE REFERENCE  
STEARNS ROGER  
STANDARD (LONG SWEEP)

**TABLE 3B**  
**FLOW OF WATER IN SCHEDULE 40 PIPE**  
**PRESSURE DROP PER 100 FT. OF SCHEDULE 40 PIPE AT VARIOUS FLUID VELOCITIES\***

| Gallons per Minute | SIZE PIPE, INCHES |       |     |      |      |      |      |      |      |      |       |      |       |       |      |       |
|--------------------|-------------------|-------|-----|------|------|------|------|------|------|------|-------|------|-------|-------|------|-------|
|                    | 1/4               |       | 3/8 |      | 1/2  |      | 3/4  |      | 1    |      | 1 1/4 |      | 1 1/2 |       | 2    |       |
|                    | V                 | ΔP    | V   | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   | V     | ΔP   | V     | ΔP    | V    | ΔP    |
| 1                  | 3.1               | 6.54  | 1.7 | 1.25 | 1.1  | .39  | —    | —    | —    | —    | —     | —    | —     | —     | —    | —     |
| 2                  | 6.2               | 26.2  | 3.4 | 5.00 | 2.1  | 1.56 | 1.2  | .34  | —    | —    | —     | —    | —     | —     | —    | —     |
| 3                  | 9.3               | 58.9  | 5.0 | 11.3 | 3.2  | 3.52 | 1.8  | .77  | —    | —    | —     | —    | —     | —     | —    | —     |
| 4                  | 12.3              | 104.6 | 6.7 | 20.0 | 4.2  | 6.26 | 2.4  | 1.36 | 1.5  | .39  | —     | —    | —     | —     | —    | —     |
| 5                  | —                 | —     | 8.4 | 31.3 | 5.3  | 9.78 | 3.0  | 2.13 | 1.9  | .61  | 1.1   | .15  | —     | —     | —    | —     |
| 10                 | —                 | —     | —   | —    | 10.6 | 39.1 | 6.0  | 8.52 | 3.7  | 2.44 | 2.2   | .59  | 1.6   | .25   | —    | —     |
| 15                 | —                 | —     | —   | —    | —    | —    | 9.0  | 19.2 | 5.6  | 5.49 | 3.2   | 1.33 | 2.4   | .56   | —    | —     |
| 20                 | —                 | —     | —   | —    | —    | —    | 12.0 | 34.1 | 7.4  | 9.76 | 4.3   | 2.37 | 3.2   | 1.0   | 1.9  | .27   |
| 25                 | —                 | —     | —   | —    | —    | —    | —    | —    | 9.3  | 15.3 | 5.4   | 3.70 | 3.9   | 1.56  | 2.4  | .42   |
| 30                 | —                 | —     | —   | —    | —    | —    | —    | —    | 11.0 | 22.0 | 6.4   | 5.33 | 4.7   | 2.24  | 2.9  | .61   |
| 35                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | 7.5   | 7.25 | 5.5   | 3.05  | 3.4  | .83   |
| 40                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | 8.6   | 9.47 | 6.3   | 3.98  | 3.8  | 1.09  |
| 45                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | 9.7   | 12.0 | 7.1   | 5.04  | 4.3  | 1.37  |
| 50                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | 10.7  | 14.8 | 7.9   | 6.23  | 4.4  | 1.70  |
| 70                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | —     | —    | 11.1  | 12.20 | 6.7  | 3.33  |
| 90                 | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | —     | —    | 14.2  | 20.17 | 8.6  | 5.50  |
| 100                | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | —     | —    | —     | —     | 9.6  | 6.79  |
| 120                | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | —     | —    | —     | —     | 11.5 | 9.78  |
| 140                | —                 | —     | —   | —    | —    | —    | —    | —    | —    | —    | —     | —    | —     | —     | 13.4 | 13.31 |

| Gallons per Minute | SIZE PIPE, INCHES |      |      |      |      |      |      |      |      |      |      |      |      |      |      |      |
|--------------------|-------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
|                    | 2 1/2             |      | 3    |      | 4    |      | 5    |      | 6    |      | 8    |      | 10   |      | 12   |      |
|                    | V                 | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   | V    | ΔP   |
| 15                 | 1.0               | .059 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 20                 | 1.3               | .11  | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 25                 | 1.7               | .17  | 1.1  | .053 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 30                 | 2.0               | .24  | 1.3  | .076 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 35                 | 2.4               | .32  | 1.5  | .10  | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 40                 | 2.7               | .42  | 1.7  | .13  | 1.0  | .033 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 45                 | 3.0               | .53  | 2.0  | .17  | 1.1  | .041 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 50                 | 3.4               | .66  | 2.2  | .21  | 1.3  | .051 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    |
| 70                 | 4.7               | 1.29 | 3.0  | .41  | 1.8  | .100 | 1.1  | .030 | —    | —    | —    | —    | —    | —    | —    | —    |
| 100                | 6.7               | 2.64 | 4.3  | .84  | 2.5  | .204 | 1.6  | .062 | 1.1  | .025 | —    | —    | —    | —    | —    | —    |
| 125                | 8.4               | 4.13 | 5.4  | 1.32 | 3.2  | .319 | 2.0  | .096 | 1.4  | .038 | —    | —    | —    | —    | —    | —    |
| 150                | 10.0              | 5.94 | 6.5  | 1.90 | 3.8  | .46  | 2.4  | .14  | 1.7  | .055 | —    | —    | —    | —    | —    | —    |
| 175                | 11.7              | 8.08 | 7.6  | 2.58 | 4.4  | .62  | 2.8  | .19  | 1.9  | .075 | —    | —    | —    | —    | —    | —    |
| 200                | 13.4              | 10.6 | 8.7  | 3.37 | 5.0  | .82  | 3.2  | .25  | 2.2  | .098 | —    | —    | —    | —    | —    | —    |
| 225                | 15.1              | 13.4 | 9.8  | 4.27 | 5.7  | 1.03 | 3.6  | .31  | 2.5  | .12  | 1.4  | .029 | —    | —    | —    | —    |
| 250                | —                 | —    | 10.9 | 5.27 | 6.3  | 1.28 | 4.0  | .39  | 2.8  | .15  | 1.6  | .036 | —    | —    | —    | —    |
| 275                | —                 | —    | 11.9 | 6.38 | 6.9  | 1.54 | 4.4  | .47  | 3.1  | .19  | 1.8  | .044 | —    | —    | —    | —    |
| 300                | —                 | —    | 13.0 | 7.59 | 7.6  | 1.84 | 4.8  | .56  | 3.3  | .22  | 1.9  | .052 | —    | —    | —    | —    |
| 350                | —                 | —    | —    | —    | 8.8  | 2.50 | 5.6  | .76  | 3.9  | .30  | 2.2  | .071 | —    | —    | —    | —    |
| 400                | —                 | —    | —    | —    | 10.1 | 3.26 | 6.4  | .99  | 4.4  | .39  | 2.6  | .093 | —    | —    | —    | —    |
| 450                | —                 | —    | —    | —    | 11.3 | 4.13 | 7.2  | 1.25 | 5.0  | .50  | 2.9  | .12  | —    | —    | —    | —    |
| 475                | —                 | —    | —    | —    | 12.0 | 4.60 | 7.6  | 1.39 | 5.3  | .56  | 3.0  | .13  | —    | —    | —    | —    |
| 500                | —                 | —    | —    | —    | 12.6 | 5.10 | 8.0  | 1.54 | 5.6  | .62  | 3.2  | .15  | 2.0  | .044 | —    | —    |
| 550                | —                 | —    | —    | —    | 13.9 | 6.17 | 8.8  | 1.87 | 6.1  | .74  | 3.5  | .18  | 2.2  | .053 | —    | —    |
| 600                | —                 | —    | —    | —    | 15.1 | 7.34 | 9.6  | 2.22 | 6.7  | .89  | 3.9  | .21  | 2.4  | .063 | —    | —    |
| 650                | —                 | —    | —    | —    | —    | —    | 10.4 | 2.61 | 7.2  | 1.04 | 4.2  | .25  | 2.6  | .074 | —    | —    |
| 700                | —                 | —    | —    | —    | —    | —    | 11.2 | 3.02 | 7.8  | 1.21 | 4.5  | .29  | 2.9  | .085 | 2.0  | .035 |
| 750                | —                 | —    | —    | —    | —    | —    | 12.0 | 3.47 | 8.3  | 1.38 | 4.8  | .33  | 3.1  | .098 | 2.2  | .041 |
| 800                | —                 | —    | —    | —    | —    | —    | 12.8 | 3.95 | 8.9  | 1.57 | 5.1  | .37  | 3.3  | .11  | 2.3  | .046 |
| 850                | —                 | —    | —    | —    | —    | —    | 13.6 | 4.46 | 9.4  | 1.78 | 5.5  | .42  | 3.5  | .13  | 2.4  | .052 |
| 900                | —                 | —    | —    | —    | —    | —    | 14.4 | 5.00 | 10.0 | 1.99 | 5.8  | .47  | 3.7  | .14  | 2.6  | .059 |
| 950                | —                 | —    | —    | —    | —    | —    | —    | —    | 10.6 | 2.22 | 6.1  | .53  | 3.9  | .16  | 2.7  | .065 |
| 1000               | —                 | —    | —    | —    | —    | —    | —    | —    | 11.1 | 2.46 | 6.4  | .58  | 4.1  | .17  | 2.9  | .072 |
| 1100               | —                 | —    | —    | —    | —    | —    | —    | —    | 12.2 | 2.98 | 7.1  | .71  | 4.5  | .21  | 3.2  | .087 |
| 1200               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | 7.7  | .84  | 4.9  | .25  | 3.4  | .10  |
| 1500               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | 9.6  | 1.31 | 6.1  | .39  | 4.3  | .16  |
| 2000               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | 12.8 | 2.33 | 8.1  | .70  | 5.7  | .29  |
| 2500               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | 16.0 | 3.64 | 10.2 | 1.09 | 7.2  | .45  |
| 3000               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | 12.2 | 1.57 | 8.6  | .65  |
| 3500               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | 14.2 | 2.13 | 10.0 | .89  |
| 4000               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | 11.5 | 1.16 |
| 4500               | —                 | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | —    | 12.9 | 1.46 |

\*Above table for water at 60°F flowing in clean commercial steel or wrought iron pipe. V = Velocity in feet per second. ΔP = Pressure drop in PSI.

To determine the pressure drop for pipe lengths other than 100 feet, multiply the pressure drop from the above table by the following ratio:

$$R = \frac{L}{100}, \text{ where } L \text{ is length of pipe in feet for which the pressure drop is required.}$$

To determine the pressure drop for a pipe other than Schedule 40, multiply the value from the above table by the value for the appropriate pipe size and schedule below.

| Pipe Size, Inches | 1/4  | 3/8  | 1/2  | 3/4  | 1    | 1 1/4 | 1 1/2 | 2    | 2 1/2 | 3    | 4    | 5    | 6    | 8    | 10   | 12 |
|-------------------|------|------|------|------|------|-------|-------|------|-------|------|------|------|------|------|------|----|
| SCHEDULE 80       | 2.55 | 2.15 | 1.92 | 1.69 | 1.58 | 1.47  | 1.42  | 1.38 | 1.36  | 1.33 | 1.29 | 1.27 | 1.29 | 1.26 | 1.26 |    |
| SCHEDULE 160      |      |      | 4.23 | 4.35 | 3.53 | 2.38  | 2.52  | 2.74 | 2.12  | 2.18 | 2.20 | 2.19 | 2.18 | 2.21 | 2.28 |    |
| DOUBLE EXTRA      |      |      | 93.1 | 24.7 | 16.5 | 8.67  | 6.72  | 4.92 | 5.27  | 4.22 | 3.40 | 2.96 | 2.91 | 2.11 |      |    |

QUADRILLE WORK SHEET

ANALYSIS TS FEEDWATER

MCDONNELL DOUGLAS CORPORATION

PAGE 7 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR ONE

REPORT NO. \_\_\_\_\_

$$\Delta H = (11)(0.21) \frac{(5.96 \text{ FT/SEC})^2}{(2)(32.2)}$$

$$\Delta H = 1.28 \text{ FT}$$

$$\Delta P = \underline{0.53 \text{ psia}} \quad \text{ASSUMING } \rho_{H_2O} = 59.4 \text{ LB/FT}^3$$

$$\Delta P \text{ VALVE + SENSOR} = \underline{3 \text{ psia}} \quad (\text{ASSUMED AT FULL FLOW})$$

$$\Delta P_{\text{TOTAL}} (\text{PUMP TO SPLIT}) = 5.1 \text{ psia}$$

@ 110,000 LB/HR

$$\text{@ } 80,000 \text{ LB/HR}$$

$$\Delta P = 5.1 \left( \frac{80,000}{110,000} \right)^2 = 2.7 \text{ psia}$$

ABSOLUTE PRESSURE AT SPLIT

(DEAERATOR PRESSURE)                      (20 psia)                      (50 psia)

PUMP OUTLET  
@ 110,000 LB/HR                      509.0 psia                      516.36 psia

LOSSES TO SPLIT                      5.1 psia                      5.1 psia

SPLIT PRESSURE                      503.9 psia                      511.3 psia

PUMP OUTLET  
@ 80,000 LB/HR                      567.7 psia                      577.56 psia

LOSSES TO SPLIT                      2.7 psia                      2.7 psia

SPLIT PRESSURE                      562.0 psia                      574.9 psia

QUADRILLE WORK SHEET

ANALYSIS TS FEED WATER



PAGE 8 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80

PLANT SOLAR I

REPORT NO. \_\_\_\_\_

(20 psia)                      (50 psia)

AT 0<sup>LB</sup>/HR FLOW, FLOW  
LOSSES = 0 psia

∴ SPLIT PRESS = PUMP OUTLET = 599.4 psia      614.96 psia

VARIATION OF SPLIT POINT PRESSURE WITH FLOW

SEE FIGURE 2

PRESSURE DROP CALC SPLIT POINT TO  
INTERFACES 76 I + 77 I

2 1/2" SCH 40 LINE LOSS :

$$118 \text{ gpm (85.4 FT)} \rightarrow \frac{3.18 \text{ psia}}{T_0 \text{ 76 I}}$$


$$118 \text{ gpm (54.7 FT)} \rightarrow \frac{2.04 \text{ psia}}{T_0 \text{ 77 I}}$$

FROM YOGT F-11 CATALOG  
TABLE 3B P 298

ELBOWS

$$\begin{aligned} \Delta H &= K \frac{V^2}{2g} \\ &= (0.21) (4 \text{ BENDS}) \frac{(7.9 \text{ FT/SEC})^2}{(2) (32.2)} \\ &= 0.81 \text{ FT H}_2\text{O} \end{aligned}$$

FIG 2 THERMAL STORAGE FEEDWATER PRESSURE



QUADRILLE WORK SHEET

ANALYSIS TS FEEDWATER



PAGE 10 OF 19

PREPARED BY JER

MODEL \_\_\_\_\_

DATE 4/21/80 PLANT SOLAR I

REPORT NO. \_\_\_\_\_

$$\Delta P_{ELBOWS} = \underline{0.34 \text{ psia}}$$

$$\begin{aligned} \text{MIN PRESSURE AT 76I} &= 503.9 - 3.18 - 0.34 \\ &= 500.4 \text{ psia} \end{aligned}$$

$$\begin{aligned} \text{MAX PRESSURE AT 76I} &= 614.96 \text{ psia} \\ &\text{(DEAD HEAD CONDITION)} \\ &\text{(@ 50 psia DEAERATOR)} \end{aligned}$$

$$\begin{aligned} \text{MIN PRESS AT 77I} &= 503.9 - 2.04 - 0.34 \\ &= 501.5 \text{ psia} \end{aligned}$$

$$\begin{aligned} \text{MAX PRESSURE AT 77I} &= 614.96 \text{ psia} \\ &\text{(SAME AS FOR 76I)} \end{aligned}$$

$$\begin{aligned} \therefore \text{MINIMUM PRESSURE AT INTERFACE TO} \\ \text{TS STEAM GENERATORS} &= \underline{\underline{500 \text{ psia}}} \end{aligned}$$



8/11/80  
11 OF 19

AUDIT QUESTIONS INVOLVING THE TS FEEDWATER CIRCUI

CALCULATIONS SHOULD BE REVISED TO REFLECT

1. ΔP MOV-1132
2. ΔP RECIRC VALVE
3. ΔP FE 35B
4. ΔP FE 56
5. TEE
6. REDUCER

1. ΔP MOV-1132

- NO ΔP SPECIFIED FOR GATE VALVE IN CP 9
- USE "TYPICAL" GATE VALVE

VALVE: FULL PORT GATE  $K = 0.48$

GATE VALVE (WIDE OPEN)  $K = 0.19$

REF: ESSENTIALS OF ENGINEERING FLUID MECHANICS P 219

$$\Delta H = K \frac{V^2}{2g} = (0.19) \frac{(5.96)^2}{(2)(32.2)}$$

$$\Delta H = 0.105 \text{ FT} \rightarrow \Delta P = 0.043 \text{ PSI} \text{ (MOV-1132)}$$

$$\text{VALVE } 0.26 \text{ FT} \quad \frac{(26)(144)}{144} 594 = 0.107 \text{ PSI} = \Delta P$$

2. ΔP RECIRC VALVE

CONVERSATION WITH CLEM SYOBODA 8/4/80  
TS FEED PUMP RECIRC VALVE

YARWAY — ΔP = 3.6 PSI @ 236 GPM

8/11/80  
12 OF 19

3.  $\Delta P$  FE 35B

2.5" ID ELEMENT


$\Delta P = 2.53 \text{ PSIG @ } 110,000 \text{ LB/HR @ } T = 281^\circ\text{F}$   
485 psig

$\Delta P = 0.65 \text{ PSIG @ } 55,000 \text{ LB/HR}$

FROM REID BERNELL  
8/11/80

4.  $\Delta P$  FE 56  $\rightarrow$  NO LONGER IN THE SYSTEM PER SCE

5.  $\Delta P$  TEE



$$Re = \frac{50.6 Q P}{d \mu}$$

$$= \frac{(50.6)(236 \text{ GPM})(59.4 \text{ LB/HR})}{(4.026)(4 \times 10^{-5})(47900)}$$

$$= 9.19 \times 10^4$$

$$= 91900$$

$$f = 0.021$$

FLOW THROUGH RUN (TO 76I)

$L/D$  EQUIVALENT = 20  
REF: CRANE  
P A-30

$V_2 = \frac{5.96 \text{ FT/SEC}}{2} = 2.48 \text{ FT/SEC}$

$D_2 = 4.026$

$f = 0.023$

$Re \sim 45000$

8/11/80  
13 OF 19

$$\Delta h = K \frac{V^2}{2g}$$

$$= f \frac{L}{D} \frac{V^2}{2g} = (0.023) (20) \left( \frac{2.48^2}{(2)(32.2)} \right)$$

$$\Delta h = 0.044 \text{ FT} \rightarrow \Delta P = 0.018 \text{ PSI}$$

### FLOW THROUGH BRANCH (TO 77I)

$$V_2 = 2.48 \text{ FT/SEC}$$

$$D_2 = 2.469 \text{ IN}$$

$$\frac{L}{D} \text{ EQUIVALENT} = 60$$

$$R_E = \frac{(50.6)(118 \text{ GPM})(59.4 \frac{\text{LB}}{\text{FT}^3})}{(2.469)(4 \times 10^{-5})(47900)}$$

$$R_E = 74972$$


$$f = 0.022$$

$$\Delta h = f \frac{L}{D} \frac{V^2}{2g}$$

$$= 0.022 (60) \left( \frac{2.48^2}{(2)(32.2)} \right)$$

$$= 0.126 \text{ FT} \rightarrow .052 \text{ PSI}$$

### 6 REDUCER



$$\tan \frac{\theta}{2} = \frac{0.75}{4} = 0.188$$

$$\frac{\theta}{2} = 10.6^\circ$$

$$\theta = 21.2^\circ$$

$$\beta = \frac{2.469}{4.026} = .613$$

$$k = 0.5 (1 - \beta^2) \sqrt{\sin(\frac{\theta}{2})}$$

$$= .5 (1 - .613^2) \sqrt{\sin 10.6^\circ} = .134$$

8/1/80  
14 OF 19

$$V_2 = 2.48 \text{ FT/SEC}$$

$$\begin{aligned} \Delta h &= \frac{V^2}{2g} \\ &= .134 \left( \frac{2.48^2}{(2)(32.2)} \right) \\ &= 0.013 \text{ FT} \end{aligned}$$

IV. TS FEEDWATER LINE LOSS

CALCULATIONS ACCOMPLISHED IN TWO STEPS:

(i) LOSSES FROM PUMP OUTLET TO PIPING SPLIT POINT (SEE ANALYSIS ISOMETRIC P13-5 ZN E-6, POINT (13))

(ii) LOSSES DOWNSTREAM OF THE SPLIT POINT TO THE STEAM GENERATOR INTERFACE POINTS. (76 I + 77 I)

## PIPING CHARACTERISTICS:

| (PUMP TO SPLIT)              | (SPLIT TO 76 I)          | (SPLIT TO 77 I)          |
|------------------------------|--------------------------|--------------------------|
| PIPE: 129.65 FT<br>4" SCH 40 | 85.4 FT<br>2 1/2" SCH 40 | 54.7 FT<br>2 1/2" SCH 40 |
| VALVES: 1                    | 0                        | 0                        |
| RT. ANGLES 11                | 4                        | 4                        |

## CALCULATIONS PUMP TO SPLIT

4" SCH 40 LINE DROP:  
236 gpm (129 FT) → 1.55 psia

REF VOGT F-11 CATALOG TABLE 3B  
PAGE 289

ELBOWS:  
$$\Delta H = K \frac{V^2}{2g}$$

ASSUME  $K = 0.21$   
RT ANGLE REFERENC.  
STEARNS ROGER  
STANDARD (LONG SWEE

TS FEEDWATER

16 OF 17

JER

4/21/80

SOLAR ONE

$$\Delta H = (11)(0.21) \frac{(5.96 \text{ FT/SEC})^2}{(2)(32.2)}$$

$$\Delta H = 1.28 \text{ FT}$$

$$\Delta P = 0.53 \text{ PSIA} \quad \text{ASSUMING } \rho_{H_2O} = 59.4 \text{ LB/FT}^3$$

ΔP VALVE + SENSOR = 3.0 PSIA

ΔP PIPE 35 B = 2.5 PSIA

ΔP PIPE 35 B = 2.5 PSIA

ΔP PIPE 35 B = 2.5 PSIA

ΔP VALVE + SENSOR = 3 PSIA (ASSUMED AT FULL FLOW)

|   |
|---|
| $\Delta P_{TOTAL} \text{ (PUMP TO SPLIT)} = 5.1 \text{ PSIA}$ $\text{@ } 110,000 \text{ LB/HR}$ |
|---|

$$\text{@ } 80,000 \text{ LB/HR}$$

$$\Delta P = 5.1 \left( \frac{80,000}{110,000} \right)^2 = 2.7 \text{ PSIA}$$

ABSOLUTE PRESSURE AT SPLIT

|                      |           |           |
|----------------------|-----------|-----------|
| (DEAERATOR PRESSURE) | (20 PSIA) | (50 PSIA) |
|----------------------|-----------|-----------|

|                 |            |             |
|-----------------|------------|-------------|
| PUMP OUTLET     |            |             |
| @ 110,000 LB/HR | 509.0 PSIA | 516.36 PSIA |

|                 |          |          |
|-----------------|----------|----------|
| LOSSES TO SPLIT | 5.1 PSIA | 5.1 PSIA |
|-----------------|----------|----------|

|                |            |            |
|----------------|------------|------------|
| SPLIT PRESSURE | 503.9 PSIA | 511.3 PSIA |
|----------------|------------|------------|

|                |            |             |
|----------------|------------|-------------|
| PUMP OUTLET    |            |             |
| @ 80,000 LB/HR | 564.7 PSIA | 577.56 PSIA |

|                 |          |          |
|-----------------|----------|----------|
| LOSSES TO SPLIT | 2.7 PSIA | 2.7 PSIA |
|-----------------|----------|----------|

|                |            |            |
|----------------|------------|------------|
| SPLIT PRESSURE | 562.0 PSIA | 574.9 PSIA |
|----------------|------------|------------|

TS FEED WATER

DESIGNED BY JER

DATE 4/21/80

PROJECT SOLAR I



PAGE 17 OF 19

NO. 1000

REPORT NO.

(20 psia)

(50 psia)

AT 0 LB/HR FLOW, FLOW  
LOSSES = 0 psia

∴ SPLIT PRESS = PUMP OUTLET = 599.4 psia 614.96 psia

### VARIATION OF SPLIT POINT PRESSURE WITH FLOW:

SEE FIGURE 2

### PRESSURE DROP CALC SPLIT POINT TO INTERFACES 76 I + 77 I

2 1/2" SCH 40 LINE LOSS. REDUCER LOSS  
+ FEE (ROW) 0.02  
118 gpm (85.4 FT) → 3.18 psia } 3.21  
To 76 I

TR. BRANCH 0.05  
118 gpm (54.7 FT) → 2.04 psia } 2.09  
To 77 I } 2.09  
PSI


FROM VOGT F-11 CATALOG  
TABLE 3B P 298

ELBOWS

$$\begin{aligned} \Delta H &= K \frac{V^2}{2g} \\ &= (0.21) (4 \text{ BENDS}) \frac{(7.9 \text{ FT/SEC})^2}{(2) (32.2)} \\ &= 0.81 \text{ FT H}_2\text{O} \end{aligned}$$

4/21/80

FIG 2 THERMAL STORAGE FEEDWATER PRESSURE



18 of 19  
61 40 81



TS FEEDWATER

JER

DATE 4/21/80

POINT SOLAR I



19 OF 19

MODEL

REPORT NO.

$$\Delta P_{\text{ELBOWS}} = \underline{0.34 \text{ psia}}$$

$$\begin{aligned} \text{MIN PRESSURE AT 76I} &= \overset{500.7}{503.9} - \overset{3.21}{3.18} - 0.34 \\ &= \overset{497.1}{500.4} \text{ psia} \end{aligned}$$

$$\begin{aligned} \text{MAX PRESSURE AT 76I} &= 614.96 \text{ psia} \\ &(\text{DEAD HEAD CONDITION}) \\ &(\text{@ 50 psia DEAERATOR}) \end{aligned}$$

$$\begin{aligned} \text{MIN PRESS AT 77I} &= \overset{500.7}{503.9} - \overset{2.09}{2.04} - 0.34 \\ &= \overset{498.3}{501.5} \text{ psia} \end{aligned}$$

$$\begin{aligned} \text{MAX PRESSURE AT 77I} &= 614.96 \text{ psia} \\ &(\text{SAME AS FOR 76I}) \end{aligned}$$

∴ MINIMUM PRESSURE AT INTERFACE TO  
TS STEAM GENERATORS = 500 psia

4/21/80  
10F9

DEFINITION OF REQUIREMENTS FOR  
PCV-3207 (THSWPR-1)  
PCV-3307 (THSWPR-2)

OBJECTIVE :

DEFINE PRESSURE CONTROL VALVE REQUIREMENTS TO MAINTAIN CHARGING HEAT EXCHANGER IN "HOT STANDBY" CONDITION WITHOUT REQUIRING CONTINUOUS OIL CIRCULATION TO PREVENT AN OVER TEMP OF THE OIL. THESE VALVES WORK WHEN ONE OF THE TWO TRAINS (CHARGING LOOPS) IS OPERATING. SINCE DESUPERHEATER OPERATION IS REQUIRED.

THE VALVE MUST BE SIZED TO ACCOMMODATE HEAT LOSS THROUGH INSULATED SURFACES AND STEAM LOSS THROUGH NON CONDENSIBLE GAS BLEED ORIFICES SIMULTANEOUSLY.

4/21/80  
2 OF 9

REQUIREMENTS FOR PCV-3207 (THSWPR-1)  
PCV-3307 (THSWPR-2)

APPROX STEAM CONDITIONS UPSTREAM OF SA-302 + 303  
650°F 1400 psia → h = 1250.6 BTU/LB

EXPAND STEAM SO THAT SUPERHEAT MAX TEMP ≤ 575°F

575°F }  
1250.6 BTU/LB } → 800 psia      T<sub>SAT</sub> = 518°F

REVISE SPEC TO REGULATE TO 800 psia (785 psig)

7/11/80  
3 OF 9

CONDENSER UNIT HEAT LOSS ESTIMATE

CONDENSER DIMENSIONS :

$L = 47.64 \text{ FT}$

$D = 3.24 \text{ FT}$

$r = 19.44 \text{ IN}$

S TOTAL END AREA  
 $\pi R^2 (2) = \pi \left(\frac{19.44}{12}\right)^2 (2) = 16.48 \text{ FT}^2$

INSULATION REQ'T : USE S-R STANDARD DP30.1

24" OD AND LARGER } PP 6 → 4 IN MIN THICKNESS  
 600-699°F

CALCIUM SILICATE WITH ALUMINUM LAGGING

$\frac{1}{k} = .68 \text{ } ^\circ\text{F-HR-FT}^2/\text{BTU}$  SURFACE ASSUMPTION  
 (HIGH WIND) →  $\frac{1}{k} = .17 \text{ } ^\circ\text{F-HR-FT}^2/\text{BTU}$

$k_{\text{INSUL}} = 0.04 \text{ BTU/HR-FT}^2\text{ } ^\circ\text{F/FT}$       JOHNS MANVILLE  
 IND-3211 3-76 p.36

AVERAGE TEMPERATURE IN VESSEL MAINTAINED @ 518°F

(  $T_{\text{SAT @ 800PSIA}} = 518 \text{ } ^\circ\text{F}$   
 $T_{\text{SUPERHEATED}} = 575 \text{ } ^\circ\text{F}$  — EXPANDING FROM 1400PSIA  
 650°F )

$\Delta T = 518 - 55 \text{ } ^\circ\text{F} = 463 \text{ } ^\circ\text{F}$

HEAT LEAK (H-X)

$q = \frac{k 2\pi L \Delta T}{\ln\left(\frac{r_2}{r_1}\right)}$   
 $= \frac{(0.04)(2\pi)(47.64)(463)}{\ln\left(\frac{23.44}{19.44}\right)}$   
 $= 29626 \text{ BTU/HR}$

END LOSS  
 $q = k A \frac{\Delta T}{\Delta x} = (0.04)(16.48) \frac{(463)}{.333}$   
 $= 916 \text{ BTU/HR}$

TOTAL H-X HEAT LEAK  
 30542 BTU/HR

7/11/80  
# OF 9

VENT LOSS

NORMAL OPERATION → VENT 1/2% CONTINUOUS

$$\left. \begin{aligned} \dot{m} &= 65000 \text{ LB/HR} \\ P &= 1400 \text{ PSIA} \\ T &= 650 \text{ }^\circ\text{F} \\ \rho &= 2.86 \text{ LB/FT}^3 \end{aligned} \right\} 1/2\% = 325 \text{ LB/HR}$$

EXPAND TO 800 PSIA ( $h = 1250.6 \text{ BTU/LB}$ ) →  
 $\rho = 1.54 \text{ LB/FT}^3$

$$\dot{m} \sim \sqrt{P \rho}$$

$$\therefore \dot{m}_{@800 \text{ PSIA}} = \dot{m}_{@1400 \text{ PSIA}} \frac{\sqrt{(1.54 \text{ LB/FT}^3)(800 \text{ PSIA})}}{\sqrt{(2.86 \text{ LB/FT}^3)(1400 \text{ PSIA})}}$$

$$= (325 \text{ LB/HR}) (0.5547)$$

$\dot{m}_{@800 \text{ PSIA}} = 180 \text{ LB/HR}$  DUE TO REDUCED UPSTREAM PRESSURE AND DENSITY

ENERGY CONTENT OF BLEED STEAM

$$\left. \begin{aligned} h_{IN} &= 1250.6 \text{ BTU/LB} \\ h_{SAT \text{ LIQ}} &= 509.7 \text{ BTU/LB} \end{aligned} \right\} \Delta h = 740.9 \text{ BTU/LB}$$

$$\dot{m} = \frac{30543}{740.9} = 41.2 \text{ LB/HR}$$

~~$\dot{m}_{TOT} = \dot{m}_{BLEED} + \dot{m}_{VENT}$   
 $= 21.3 \text{ LB/HR}$~~

~~6 IN SUL  
 $\frac{16409}{740.9} = 22 \text{ LB/HR}$   
 $22 + 180 = 202 \text{ LB/HR}$~~

7/11/80

5 OF 9

HEAT LOSS THROUGH PIPES

39 FT 6" PIPE (3 1/2" INSULATION THICKNESS)

120 FT 1" PIPE (2" INSULATION THICKNESS)

$$\dot{q} = \frac{k 2\pi L \Delta T}{\ln\left(\frac{x_2}{x_1}\right)}$$

$$\Delta T = 518 - 95 = 423 \text{ } ^\circ\text{F}$$

(SEE 7/11/80 ①)

6" PIPE

$$\dot{q}_6 = \frac{(0.04)(2)(\pi)(39)(463)}{\ln\left(\frac{6.81}{3.312}\right)}$$

$$= 6296 \text{ BTU/HR}$$

1" PIPE

$$\dot{q}_1 = \frac{(0.04)(2)(\pi)(120)(463)}{\ln\left(\frac{2.658}{.6575}\right)}$$

$$= 9996 \text{ BTU/HR}$$

TOTAL PIPE LOSS = 16292 BTU/HR

ADDITIONAL FLOW INCREMENT

$$\frac{16292 \text{ BTU/HR}}{740.9 \text{ BTU/LB}} = 21.99 \frac{\text{LB}}{\text{HR}}$$

CONVERSATION WITH DON LANDY : (7/11/80)

ORIFICES ARE 0.090" (MIN ACCEPTABLE OPENING)

- LEAKAGE PER CONDENSER\* AT FULL PRESS = 650 LB/HR
- LEAKAGE PER CONDENSER\* AT 800 psia = 360 LB/HR

\* 2 ORIFICES PER CONDENSER

7/11/80  
6 OF 9

SUMMARY FLOW PER CONDENSER TRAIN

- LEAKAGE @ 800 PSIA 360 LB/HR
- HEAT LOSS - CONDENSER 41.2 LB/HR 30542 BTU/HR
- HEAT LOSS - 6" PIPE } 21.99 LB/HR 16292 BTU/HR
- HEAT LOSS - 1" PIPE }

TOTAL 423.2 LB/HR

From Carmen Wnaiski. 7-14-80  
7 OF 9

The Bleeds (non-condensables)  
from charging HX'S should be  
0.10 TO 0.15% w max & use  
a needle valve instead of  
an orifice & put a T/D/S  
to adjust valve.

From John Raetz

W<sub>Heatloss</sub> = 58#/HR

W<sub>~~Leakage~~</sub> = ??  
Bleed

130000 #/hr  
65000  
Revolom 65 to 100  
#/HR

Size THSWPR for 220 #/HR

809.4 gal

Change orifices to Lee valve

Jets. size jets for 35 (x2) #/HR  
50 (x2) #/HR  
90 (x2) #/HR



APPENDIX 3

PRESSURE VESSEL AND TANK SCHEDULE

The following vessels and tanks shall be insulated and jacketed as specified in Construction Package No. 12 and in accordance with the following insulation thicknesses:

| <u>Item</u>                                  | <u>Operating Temperature, F</u> | <u>Minimum Insulation Thickness *</u> | <u>Location Indoors/Outdoors**</u> |
|--|---------------------------------|---------------------------------------|------------------------------------|
| 1) Desuperheater (DS-301)                    | 985°                            | 5"                                    | Outdoors                           |
| 2) TSS Flash Tank (V-304)                    | 650°                            | 4"                                    | Outdoors                           |
| 3) Thermal Storage Condenser (E-302)         | 675°                            | 4"                                    | Outdoors                           |
| 4) Thermal Storage Condenser (E-301)         | 675°                            | 4"                                    | Outdoors                           |
| 5) Thermal Storage Subcooler (E-311)         | 675°                            | 4"                                    | Outdoors                           |
| 6) Thermal Storage Subcooler (E-312)         | 675°                            | 4"                                    | Outdoors                           |
| 7) Thermal Storage Heater Drain Tank (V-305) | 610°                            | 4"                                    | Outdoors                           |
| 8) Thermal Storage Heater Drain Tank (V-306) | 610°                            | 4"                                    | Outdoors                           |

\* Single layer insulation unless otherwise specified.

\*\*Vessels and tanks located outdoors will be heat traced by others.

APPENDIX 3PRESSURE VESSEL AND TANK SCHEDULE (CONTD)

| <u>Item</u>                                     | <u>Operating<br/>Temperature, F</u> | <u>Minimum<br/>Insulation<br/>Thickness *</u> | <u>Location<br/>Indoors/<br/>Outdoors**</u> |
|---|-------------------------------------|---|---|
| 9) Superheater (E-307)                          | 600°                                | 4"  | Outdoors                                    |
| 10) Superheater (E-308)                         | 600°                                | 4"  | Outdoors                                    |
| 11) Boiler (E-305)                              | 600°                                | 4"  | Outdoors                                    |
| 12) Boiler (E-306)                              | 600°                                | 4"  | Outdoors                                    |
| 13) Preheater (E-303)                           | 600°                                | 4"  | Outdoors                                    |
| 14) Preheater (E304)                            | 600°                                | 4"  | Outdoors                                    |
| 15) Thermal Storage<br>Surge Tank (V-309)       | 675°                                | 4"  | Outdoors                                    |
| 16) Thermal Storage<br>Surge Tank (V-310)       | 675°                                | 2"  | Outdoors                                    |
| 17) Thermal Storage<br>Blowdown Tank<br>(V-308) | 225°                                | 2"  | Outdoors                                    |

---

\* Single layer insulation unless otherwise specified.

\*\*Vessels and tanks located outdoors will be heat traced by others.

A3-255-EP-RES-543  
21 June 1979

MEMORANDUM

Subject: TSSG AND TS CHARGING HEATER PERFORMANCE REQUIREMENTS

To: R. G. Riedesel / J. E. Raetz

From: R. E. Snyder, A3-255

Copies to: G. C. Coleman; M. H. Lobell; E. J. Riel

This memorandum documents the results of an analysis of off-design performance of both the Thermal Storage Steam Generator and the T. S. Charging Heater, heat exchanger trains.

The procedure followed in this study is as follows:

- Size the units in both trains to meet the design point requirements.
- Operate at constant maximum steam flow rate for both trains 65,000 #/hr. for the Charging Heater and 55,000 #/hr. for the TSSG.
- Using these units, explore the off-design performance of the TSSG and TS Charging Heater throughout their operating regimes.
- Impose the appropriate system constraints to the results and determine any additional constraints caused by the imposed limits, including constraints on one train caused by the other.
- Present these data in a manner that defines the operating envelope of both trains from which design requirements can be generated.

The above was accomplished and the results are shown in figures 1 through 4; figures 5 and 6 show the design points of the TSSG and TS Charging Heater, respectively.

The system constraints used are:

TSSG

|                         |  |
|-------------------------|--|
| Maximum oil temperature | 590°F  |
| Maximum oil flow        | 110% design flow                                   |
| Steam pressure          | 400 $\begin{matrix} + 20 \\ - 0 \end{matrix}$ psia |
| Steam temperature       | 530 $\begin{matrix} + 20 \\ - 0 \end{matrix}$ °F   |

TS CHARGING HEATER

|                         |   |
|-------------------------|---|
| Maximum oil temperature | 590°F   |
| Maximum oil flow        | 110% design flow                                  |
| Maximum steam pressure  | 1500 psia   |
| Steam temperature       | 650 $\begin{matrix} + 30 \\ - 50 \end{matrix}$ °F |

Imposing the oil flow limit of 110% of design for the TSSG, as shown in figure 1, when coupled with the minimum outlet steam temperature of 530°F and maximum steam pressure of 420 psia, sets the minimum oil inlet temperature of 568°F. In other words, if the steam pressure is controlling at 420 psia, and the pump is operating at maximum flow, a minimum inlet oil temperature of 568°F is required to ensure a 530°F outlet oil temperature.

The maximum oil flow requirement of 110% of design limits the minimum operating steam pressure of the TS Charging Heater train to 1335 psia, as shown in figure 3. The operating envelope shown in figure 4 is bounded by the maximum and minimum steam pressures, outlet oil temperatures and inlet steam temperatures imposed on the TS Charging Heater train.

Note that the minimum oil inlet temperature (out of storage) of 568°F required for the TSSG is imposed on the TS Charging Heater as the minimum oil outlet temperature into storage.

In summary, figures 1 and 2 describe the allowable operating range of the TSSG, and figures 3 and 4 show the same for the TS Charging Heater.

Figures 5 and 6 are schematics showing the design point performance of the TSSG and TS Charging Heater, respectively, and is included for information only.

For further information, contact the undersigned.




R. E. SNYDER

RES:ss  
Attachments: (as noted)



TESTING OFF DESIGN PERFORMANCE

W/SIDE = 55500 TON



INLET OIL TEMPERATURE - °F

OUTLET OIL TEMPERATURE - °F

FIG. 2

NO 1213

TS CHARGIC HEATER OFF DESIGN PERFORMANCE

SYSTEM 65000 THER  
TBL W. 123 OF




FIG 3



REPLI & PAPER CO. NEW YORK  
10 X 10 1/2 IN. CEMENT BLOCK 18 X 25 CM

40 1213

7.5 CHARGING HEATRE OUT DESIRY PERFORMANCE

WATERING STOP THE  
TEMP IN 400°F

TEMPERATURE DURING CHARGE

600 550 500 450

600 550 500 450 400 350 300 250

TEMPERATURE INLET STEAM - 400



TOIL OUT = 425°F

T<sub>WATER IN</sub> = 250°F

NOTE:  
THIS IS 1/2 OF THE  
TOTAL SYSTEM




FIGURE 5 - TSSG DESIGN POINT PERFORMANCE




FIGURE 6 - TS CHARGING HEATER DESIGN POINT PERFORMANCE

## ALTERNATE THERMAL STORAGE DESIGNS

### ASSUMPTIONS

- 28 MWh<sub>e</sub> EQUIVALENT CAPACITY
- SAME AUTOMATIC ADMISSION TURBINE AS USED WITH CALORIA STORAGE → MINOR CHANGE IN CONVERSION EFFICIENCY (ASSUME 13000 BTU/KWH GROSS)
- HITEC STORAGE UTILIZES DUAL MEDIA THERMOCLINE DESIGN
- SODIUM STORAGE USES SEPARATE HOT AND COLD TANKS
- EACH APPROACH USES A LOW AND HIGH TEMP. LOOP
- ASSUME IDENTICAL THERMODYNAMIC DESIGN FOR BOTH ALTERNATE APPROACHES

### SIZING DATA

$$28 \text{ MWh}_e \text{ NET} = 31.2 \text{ MWh}_e \text{ GROSS}$$

(4 HOURS OPERATION @ 0.8 MW<sub>e</sub> PARASITIC LOAD)


$$\begin{aligned} \text{STORAGE ENERGY} &= (31200 \text{ KWH}) (13000 \text{ BTU/KWH}) \\ &= 4.056 \times 10^8 \text{ BTU} \end{aligned}$$

$$\text{TANK \#1} = 6.895 \times 10^7 \text{ BTU}$$


$$\text{TANK \#2} = 3.366 \times 10^8 \text{ BTU}$$

# ESTIMATED THERMODYNAMIC CHARACTERISTICS FOR

## ADVANCED THERMAL STORAGE



# HITEC STORAGE CONCEPT (DUAL MEDIA - HITEC/ROCK - THERMOCLINE)



HITEC/ROCK THERMAL CAPACITANCE =  $34.07 \frac{\text{BTU}}{\text{FT}^3 \cdot ^\circ\text{F}}$

$$\text{TANK \#1 } Vol = \frac{Q}{C(\Delta T)} = \frac{6.895 \times 10^7 \text{ BTU}}{(34.07 \frac{\text{BTU}}{\text{FT}^3 \cdot ^\circ\text{F}})(260^\circ\text{F})} = 7784 \text{ FT}^3$$

|            |           |
|------------|-----------|
| DIMENSIONS | H = 44 FT |
|            | D = 15 FT |

3/14/79  
4 OF 9

JER

HITEC STORAGE CONCEPT

TANK # 2  $V = \frac{3.366 \times 10^8}{(34.07)(590-450)} = 70569 \text{ FT}^3$

|            |           |
|------------|-----------|
| DIMENSIONS | H = 44 FT |
|            | D = 45 FT |

HEAT EXCHANGER ESTIMATED DIMENSIONS (ROM)

| CHARGING EQUIPMENT  | (No UNITS) | (L)   | (D)    |
|---------------------|------------|-------|--------|
| DESUPERHEATER STAGE | 2          | 25 FT | 3.0 FT |
| CONDENSER           | 2          | 32 FT | 3.4 FT |
| SUBCOOLER           | 2          | 25 FT | 2.2 FT |

DISCHARGING EQUIPMENT


|             |   |       |        |
|-------------|---|-------|--------|
| PREHEATER   | 2 | 15 FT | 2.1 FT |
| BOILER      | 2 | 33 FT | 5.2 FT |
| SUPERHEATER | 2 | 24 FT | 2.5 FT |

3/14/79  
5 OF 9

JER

# SODIUM STORAGE CONCEPT

(SEPARATE HOT TANK - COLD TANK EACH LOOP)



## CHARGING SIDE

(2 PARALLEL TRAINS)

## DISCHARGING SIDE

(2 PARALLEL TRAINS)

| SODIUM DATA | $\frac{1}{\rho}$<br>( $m^3/kg$ ) | ( $ft^3/LB$ )          | $\rho$                  | $C_p$<br>( $KJ/kg \cdot ^\circ C$ ) | ( $BTU/LB \cdot ^\circ F$ ) |
|-------------|----------------------------------|------------------------|-------------------------|-------------------------------------|-----------------------------|
| 850°F       | $1.194 \times 10^{-3}$           | $1.915 \times 10^{-2}$ | $52.2 \frac{lb}{ft^3}$  | 1.34                                | .321                        |
| 590°F       | $1.145 \times 10^{-3}$           | $1.837 \times 10^{-2}$ | $54.4 \frac{lb}{ft^3}$  | 1.30                                | .311                        |
| 450°F       | $1.114 \times 10^{-3}$           | $1.787 \times 10^{-2}$ | $55.96 \frac{lb}{ft^3}$ | 1.26                                | .302                        |



Table 3-26. Thermodynamic Properties of Mercury\*

| Temp., K | Pressure, bars† | Specific volume, m <sup>3</sup> /kg |         | Enthalpy, kJ/kg |        | Entropy, kJ/kg · K |        |
|----------|-----------------|-------------------------------------|---------|-----------------|--------|--------------------|--------|
|          |                 | Liquid                              | Vapor   | Liquid          | Vapor  | Liquid             | Vapor  |
| 250      | 2.212 -8        | 7.325 -5                            | 5.56 +6 | 39.81           | 347.49 | 0.3544             | 1.5943 |
| 260      | 6.926 -8        | 7.339 -5                            | 1.80 +6 | 41.22           | 348.53 | 0.3597             | 1.5453 |
| 270      | 1.990 -7        | 7.352 -5                            | 6.37 +5 | 42.63           | 349.57 | 0.3649             | 1.5028 |
| 280      | 4.956 -7        | 7.365 -5                            | 2.44 +5 | 44.03           | 350.60 | 0.3699             | 1.4651 |
| 290      | 1.237 -6        | 7.378 -5                            | 1.00 +5 | 45.43           | 351.64 | 0.3748             | 1.4309 |
| 300      | 2.903 -6        | 7.392 -5                            | 4.38 +4 | 46.83           | 352.67 | 0.3795             | 1.3993 |
| 310      | 6.438 -6        | 7.405 -5                            | 2.03 +4 | 48.22           | 353.71 | 0.3841             | 1.3698 |
| 320      | 1.357 -5        | 7.418 -5                            | 9880    | 49.61           | 354.75 | 0.3885             | 1.3423 |
| 330      | 2.732 -5        | 7.432 -5                            | 5030    | 50.99           | 355.78 | 0.3928             | 1.3165 |
| 340      | 5.516 -5        | 7.445 -5                            | 2679    | 52.38           | 356.82 | 0.3969             | 1.2925 |
| 350      | 1.022 -4        | 7.459 -5                            | 1480    | 53.75           | 357.86 | 0.4009             | 1.2699 |
| 360      | 1.829 -4        | 7.472 -5                            | 847     | 55.13           | 358.89 | 0.4048             | 1.2487 |
| 370      | 3.169 -4        | 7.486 -5                            | 500     | 56.50           | 359.93 | 0.4085             | 1.2287 |
| 380      | 5.334 -4        | 7.499 -5                            | 304     | 57.87           | 360.96 | 0.4122             | 1.2099 |
| 390      | 8.733 -4        | 7.513 -5                            | 185     | 59.24           | 362.00 | 0.4157             | 1.1921 |
| 400      | 1.394 -3        | 7.526 -5                            | 120     | 60.61           | 363.04 | 0.4192             | 1.1754 |
| 450      | 1.053 -2        | 7.595 -5                            | 18.0    | 67.41           | 368.21 | 0.4354             | 1.1037 |
| 500      | 5.261 -2        | 7.664 -5                            | 3.98    | 74.19           | 373.38 | 0.4495             | 1.0479 |
| 550      | 0.1917          | 7.735 -5                            | 1.18    | 80.95           | 378.53 | 0.4624             | 1.0035 |
| 600      | 0.5695          | 7.807 -5                            | 0.432   | 87.72           | 383.64 | 0.4741             | 0.9698 |
| 650      | 1.6836          | 7.881 -5                            | 0.187   | 94.51           | 388.68 | 0.4850             | 0.9376 |
| 700      | 3.1527          | 7.957 -5                            | 0.092   | 101.34          | 392.62 | 0.4949             | 0.9127 |
| 750      | 6.197           | 8.036 -5                            | 0.049   | 108.24          | 398.41 | 0.5046             | 0.8915 |
| 800      | 11.18           | 8.118 -5                            | 0.029   | 115.23          | 403.04 | 0.5136             | 0.8733 |
| 850      | 18.82           | 8.203 -5                            | 0.018   | 122.31          | 407.44 | 0.5221             | 0.8576 |
| 900      | 29.88           | 8.292 -5                            | 0.012   | 129.53          | 411.61 | 0.5302             | 0.8437 |
| 950      | 45.23           | 8.385 -5                            | 0.008   | 136.89          | 415.49 | 0.5381             | 0.8313 |
| 1000     | 65.74           | 8.482 -5                            | 0.006   | 144.42          | 419.08 | 0.5456             | 0.8203 |

\* The notation 5.293 -7; 2.44 +5; etc. signifies  $5.293 \times 10^{-7}$ ;  $2.44 \times 10^5$ ; etc.  
 † To convert to pascals (newtons per square meter) multiply by  $10^5$ .

Table 3-27. Thermodynamic Properties of Sodium\*

| Temp., K | Pressure, bars† | Specific volume, m <sup>3</sup> /kg |          | Enthalpy, kJ/kg |       | Entropy, kJ/kg · K |        |
|----------|-----------------|-------------------------------------|----------|-----------------|-------|--------------------|--------|
|          |                 | Liquid                              | Vapor    | Liquid          | Vapor | Liquid             | Vapor  |
| 380      | 2.631 -10       | 1.081 -3                            | 5.222 +9 | 500             | 5003  | 2.853              | 14.703 |
| 400      | 1.385 -9        | 1.086 -3                            | 1.044 +9 | 527             | 5020  | 2.924              | 14.156 |
| 450      | 4.594 -8        | 1.100 -3                            | 3.537 +7 | 555             | 5062  | 3.084              | 13.010 |
| 500      | 7.523 -7        | 1.114 -3                            | 2.395 +6 | 662             | 5101  | 3.225              | 12.102 |
| 550      | 7.377 -6        | 1.129 -3                            | 2.675 +5 | 728             | 5137  | 3.351              | 11.366 |
| 600      | 4.926 -5        | 1.145 -3                            | 4.359 +4 | 793             | 5168  | 3.464              | 10.756 |
| 650      | 2.448 -4        | 1.160 -3                            | 9452     | 858             | 5196  | 3.567              | 10.242 |
| 700      | 9.649 -4        | 1.177 -3                            | 2566     | 922             | 5220  | 3.662              | 9.803  |
| 750      | 3.160 -3        | 1.194 -3                            | 833.2    | 985             | 5241  | 3.749              | 9.424  |
| 800      | 8.904 -3        | 1.211 -3                            | 312.8    | 1048            | 5260  | 3.831              | 9.095  |
| 850      | 2.217 -2        | 1.229 -3                            | 132.3    | 1111            | 5277  | 3.907              | 8.808  |
| 900      | 4.980 -2        | 1.247 -3                            | 61.78    | 1174            | 5292  | 3.979              | 8.555  |
| 950      | 0.1025          | 1.271 -3                            | 31.36    | 1237            | 5307  | 4.046              | 8.331  |
| 1000     | 0.1963          | 1.286 -3                            | 17.08    | 1299            | 5322  | 4.111              | 8.134  |
| 1100     | 0.6002          | 1.327 -3                            | 6.023    | 1426            | 5352  | 4.231              | 7.801  |
| 1200     | 1.5037          | 1.372 -3                            | 2.572    | 1554            | 5386  | 4.343              | 7.536  |
| 1300     | 3.2454          | 1.419 -3                            | 1.264    | 1685            | 5420  | 4.448              | 7.321  |
| 1400     | 6.2538          | 1.469 -3                            | 0.691    | 1820            | 5453  | 4.548              | 7.142  |
| 1500     | 11.014          | 1.525 -3                            | 0.409    | 1959            | 5481  | 4.644              | 6.991  |
| 1600     | 18.02           | 1.581 -3                            | 0.259    | 2104            | 5504  | 4.737              | 6.862  |
| 1700     | 27.78           | 1.643 -3                            | 0.171    | 2255            | 5524  | 4.828              | 6.751  |
| 1800     | 40.91           | 1.713 -3                            | 0.118    | 2410            | 5540  | 4.916              | 6.654  |
| 1900     | 57.97           | 1.792 -3                            | 8.35 -2  | 2570            | 5552  | 5.000              | 6.570  |
| 2000     | 79.49           | 1.884 -3                            | 6.09 -2  | 2734            | 5558  | 5.083              | 6.495  |
| 2100     | 106.0           | 1.993 -3                            | 4.54 -2  | 2905            | 5558  | 5.164              | 6.427  |
| 2200     | 137.9           | 2.123 -3                            | 3.44 -2  | 3085            | 5550  | 5.244              | 6.365  |
| 2300     | 175.6           | 2.285 -3                            | 2.64 -2  | 3275            | 5531  | 5.325              | 6.306  |
| 2400     | 219.5           | 2.493 -3                            | 2.04 -2  | 3480            | 5497  | 5.407              | 6.248  |
| 2500     | 269.8           | 2.781 -3                            | 1.57 -2  | 3708            | 5441  | 5.495              | 6.188  |
| 2600     | 327.0           | 3.230 -3                            | 1.19 -2  | 3977            | 5342  | 5.594              | 6.119  |
| 2700     | 390.9           | 4.201 -3                            | 8.33 -3  | 4369            | 5122  | 5.733              | 6.012  |
| 2733†    | 413.6           | 5.501 -3                            | 5.50 -3  | 4773            | 4773  |                    |        |

Reproduced and converted from A. Padilla, Argonne National Laboratory Report ANL8095, 1974 and private communication, August 1974.

\* The notation 2.631 -10, 5.222 +9, etc. signifies  $2.631 \times 10^{-10}$ ,  $5.222 \times 10^9$  etc.

† To convert to pascals (newtons per square meter) multiply by  $10^5$ .

‡ Critical temperature.

$$850^{\circ}\text{F} = 454^{\circ}\text{C} = 727^{\circ}\text{K}$$

$$590^{\circ}\text{F} = 310^{\circ}\text{C} = 583^{\circ}\text{K}$$

$$450^{\circ}\text{F} = 232^{\circ}\text{C} = 505^{\circ}\text{K}$$

DATA  
USEFUL

3/14/79  
7 OF 9

JER

REVISED 3/29/79

SODIUM STORAGE CONCEPT

LOOP #1 TOTAL STORAGE CAPACITY

$6.895 \times 10^7$  BTU (FROM HITEC DESIGN)

$$m = \frac{Q}{c_p \Delta T} = \frac{6.895 \times 10^7}{(.321)(260^\circ F)} = 8.261 \times 10^5 \text{ LB}$$

$$V_{OL} @ 850^\circ F = 1.583 \times 10^4 \text{ FT}^3$$

|  |
|--|
| 850° F TANK DIMENSIONS<br>H = 27.2 FT<br>D = 27.2 FT |
|--|

LOOP #2 STORAGE CAPACITY

$3.366 \times 10^8$  BTU (FROM HITEC DESIGN)

$$m = \frac{Q}{c_p \Delta T} = \frac{3.366 \times 10^8}{(.302)(140^\circ F)} = 7.961 \times 10^6 \text{ LB}$$

$$V_{OL} @ 450^\circ F = 1.423 \times 10^5 \text{ FT}^3$$

|  |
|--|
| 450° F TANK DIMENSIONS<br>H = 56.5 FT<br>D = 56.5 FT |
|--|

590° F TANK

$$m = 8.261 \times 10^5 + 7.961 \times 10^6 \text{ LB} = 8.787 \times 10^6 \text{ LB}$$

$$V = 1.615 \times 10^5 \text{ FT}^3$$

|                                      |
|--------------------------------------|
| 590° F TANK DIMENSIONS H = D = 59 FT |
|--------------------------------------|

3/14/79

8 OF 9

JER

## SODIUM STORAGE CONCEPT

### HEAT EXCHANGER ESTIMATED DIMENSIONS (ROM)

(USE SAME QUANTITY AND DIMENSIONAL INFORMATION AS SPECIFIED FOR HITEC EXCHANGERS)

NOTE : IT IS CONCEPTUALLY POSSIBLE TO USE THE SAME HEAT EXCHANGERS FOR BOTH THE HITEC AND SODIUM THERMAL STORAGE APPROACHES. THIS WOULD DEPEND ON MATERIALS, FAB TECHNIQUES, DESIGN CODES, ABILITY TO CARVE UNITS TO PREVENT FLUID CONTAMINATION ETC. THIS WOULD REDUCE THE COST OF IMPLEMENTING THE SECOND ADVANCED DESIGN CONCEPT ONCE THE FIRST CONCEPT HAS BEEN COMPLETELY INVESTIGATED.

HITEC/ROCK + CALORIA/ROCK SYSTEM

ASSUME: HITEC/ROCK TANK HAS 30% THERMAL ENERGY CAPACITY AS CALORIA/ROCK TANK

HITEC/ROCK TANK STORED ENERGY  
 $= (.3) \times (4.056 \times 10^8 \text{ BTU}) = 1.217 \times 10^8 \text{ BTU}$

$\Delta T = 850 - 525 \text{ }^\circ\text{F} = 325 \text{ }^\circ\text{F}$

$\text{VOL} = \frac{Q}{C(\Delta T)} = \frac{1.217 \times 10^8}{(34.07)(325)} = 11000 \text{ FT}^3$

$H = 40 \text{ FT}$

$D = \frac{\sqrt{4(11000)}}{\pi(40)} \approx 19 \text{ FT}$

SODIUM + CALORIA/ROCK SYSTEM

ASSUME: SODIUM TANK(S) HAVE 30% THERMAL ENERGY CAPACITY OF CALORIA/ROCK TANK

SODIUM TANK STORED ENERGY =  $1.217 \times 10^8 \text{ BTU}$

$\Delta T = 325 \text{ }^\circ\text{F}$

$\frac{M}{\text{VOL}} = \frac{Q}{C_p \Delta T} = \frac{1.217 \times 10^8}{(0.315)(325)} = 1.19 \times 10^6 \text{ FT}^3 \text{ LB}$

$\rho = 52.2 \text{ LB/FT}^3$

$\text{VOL} = \frac{1.19 \times 10^6 \text{ LB}}{52.2 \text{ LB/FT}^3} = 22800 \text{ FT}^3$

$H = 44 \text{ FT}$

$D = \frac{\sqrt{4(22800)}}{\pi(44)} = 25.7 \text{ FT EACH (HOT \neq COLD)}$

NOTE: 30% IS CONSERVATIVE - 18% IS PROBABLY BETTER NUMBER.



IMPACT OF REDUCING THE COLLECTOR FIELD SIZE

## OBJECTIVE :

DETERMINE THE IMPACT ON PLANT RATING AND OVERALL ENERGY OUTPUT OF REDUCING THE BASELINE HELIOSTAT FIELD BY INCREMENTS OF 100 HELIOSTATS UP TO A TOTAL REDUCTION OF 500 HELIOSTATS.

DEFINE THE NUMBER OF "BASELINE" MARTIN AND MDAC HELIOSTATS AND THE CORRESPONDING NUMBER OF "LARGE" MARTIN AND MDAC HELIOSTATS REQUIRED FOR THE FOLLOWING SIZING CONDITIONS:

- (i) 10 MWe - FOUR HOURS ON WINTER DAY
- (ii) 10 MWe - NOON ON WINTER DAY
- (iii) 10 MWe - NOON ON SUMMER DAY
- (iv) ~ 8 MWe - WINTER NOON
- (v) ~ 8 MWe - SUMMER NOON

IMPACT OF REVISED SIZING ASSUMPTIONS

| DESIGN POINT                                      | (JULY 30 <sup>TH</sup> DESIGN)<br>WINTER 2 PM           | (REVISED DATA)<br>WINTER 2 PM              |
|---|---|--|
| DESIGN POINT ELECT. POWER (10MW <sub>e</sub> NET) | 11.8 MW <sub>e</sub><br>(1.8 MW <sub>e</sub> PARASITIC) | 11.7 MW <sub>e</sub><br>(1.7 MW PARASITIC) |
| ABSORBED THERMAL POWER                            | 34.4 MW <sub>T</sub>                                    | 34.1 MW <sub>T</sub>                       |
| RECEIVER LOSSES                                   | 4.7 MW <sub>T</sub>                                     | 4.7 MW <sub>T</sub>                        |
| AVE REC ABSORPTANCE                               | (0.93)  | (0.95)                                     |
| REC INCID POWER                                   | 42.04 MW <sub>T</sub>                                   | 40.84 MW <sub>T</sub>                      |
| REC INTERCEPT. FACTOR                             | (0.976)   | (0.976)                                    |
| ATM. ATTENUATION                                  | (0.978)   | (0.978)                                    |
| FIELD COSINE                                      | (0.792)   | (0.792)                                    |
| BLOCK + SHADOWING                                 | (0.898)   | (0.898)                                    |
| AVE HELIO. REFLECT.                               | (0.86)  | (0.89)                                     |
| IDEAL POWER REQUIREMENT                           | 72.0 MW <sub>T</sub>                                    | 67.6 MW                                    |
| DIRECT INSOLATION                                 | 917 W/m <sup>2</sup>                                    | 917 W/m <sup>2</sup>                       |
| REQUIRED GLASS AREA                               | 844,923 FT <sup>2</sup>                                 | 793,212 FT <sup>2</sup>                    |
| NO STMPG HELIOSTATS                               | 1878  | 1762                                       |

REVISED DATA (B+S ADJUST)      BASELINE HELIOSTATS

MARTIN :  $1762 \left( \frac{.898}{.911} \right) \left( \frac{450}{430} \right) = 1818$  HELIOSTATS

MDAC :  $1762 \left( \frac{.898}{.887} \right) \left( \frac{450}{479} \right) = 1676$  HELIOSTATS

BIG MDAC :  $1762 \left( \frac{.898}{.877} \right) \left( \frac{450}{514} \right) = 1580$  HELIOSTATS

IMPACT OF REVISED SIZE... ASSUMPTIONS

10/30/79  
8 OF 15

| (WINTER)<br>TIME | REF INC.<br>PWR MWz | 1818 HELIO   |               | 1718 HELIO   |               | 1618 HELIO   |               | 1518 HELIO   |                     | 1418 HELIO   |                    |
|------------------|---------------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------------|--------------|--------------------|
|                  |                     | INCID<br>MWz | ABSORB<br>MWz | INCID<br>MWz | ABSORB<br>MWz | INCID<br>MWz | ABSORB<br>MWz | INCID<br>MWz | ABSORB<br>MWz       | INCID<br>MWz | ABSORB<br>MWz      |
| Noon             | 48.482              | 46.30        | 39.28         | 43.75        | 36.86         | 41.21        | 34.45         | 38.66        | 32.03<br>(9.24 MWz) | 36.11        | 29.60<br>(8.4 MWz) |
| .64              | 48.016              | 45.85        | 38.86         | 43.33        | 36.46         | 40.81        | 34.07         | 38.29        | 31.67               | 35.76        | 29.27              |
| 1.28             | 46.547              | 44.45        | 37.53         | 42.00        | 35.20         | 39.56        | 32.89         | 37.12        | 30.56               | 34.67        | 28.23              |
| 1.92             | 43.447              | 41.49        | 34.72         | 39.20        | 32.55         | 36.93        | 30.38         | 34.64        | 28.21               | 32.36        | 26.04              |
| 2.00             | 42.765              | 40.84        | 34.10         | 38.59        | 31.96         | 36.35        | 29.83         | 34.10        | 27.70               | 31.85        | 25.56              |
| 2.56             | 37.921              | 36.21        | 29.70         | 34.22        | 27.81         | 32.23        | 25.92         | 30.24        | 24.03               | 28.24        | 22.13              |
| 3.20             | 30.154              | 28.80        | 22.66         | 27.21        | 21.15         | 25.63        | 19.65         | 24.04        | 18.14               | 22.46        | 16.63              |
| 3.85             | 19.765              | 18.88        | 13.23         | 17.84        | 12.24         | 16.80        | 11.26         | 15.76        | 10.27               | 14.72        | 9.28               |
| - .64            | 47.916              | 45.76        | 38.77         | 43.24        | 36.38         | 40.73        | 33.99         | 38.21        | 31.60               | 35.69        | 29.20              |
| - 1.28           | 46.547              | 44.45        | 37.53         | 42.00        | 35.20         | 39.56        | 32.89         | 37.12        | 30.56               | 34.67        | 28.23              |
| - 1.92           | 43.447              | 41.54        | 34.76         | 39.25        | 32.59         | 36.97        | 30.42         | 34.68        | 28.25               | 32.39        | 26.07              |
| - 2.56           | 38.399              | 36.67        | 30.14         | 34.65        | 28.22         | 32.64        | 26.31         | 30.62        | 24.39               | 28.60        | 22.47              |
| - 3.20           | 30.534              | 29.16        | 23.00         | 27.55        | 21.48         | 25.95        | 19.96         | 24.35        | 18.43               | 22.74        | 16.90              |
| - 3.85           | 21.715              | 20.74        | 15.00         | 19.60        | 13.92         | 18.46        | 12.83         | 17.32        | 11.75               | 16.17        | 10.66              |

$P_{ABS} = P_{INC} * .95 - 4.7$

Table 2 continued



10/30/79  
4 of 15


| (WINTER) | 1318 HELIOSTATS |                 |
|----------|-----------------|-----------------|
|          | INCLD<br>MWZ    | ABSCRB<br>MWZ   |
| Noon     | 33.57           | 27.19<br>(7.63) |
| .64      | 33.24           | 26.88           |
| 1.28     | 32.23           | 25.91           |
| 1.92     | 30.08           | 23.88           |
| 2.00     | 29.61           | 23.43           |
| 2.56     | 26.25           | 20.24           |
| 3.20     | 20.88           | 15.13           |
| 3.85     | 13.68           | 8.30            |
| -.64     | 33.17           | 26.82           |
| -1.28    | 32.23           | 25.91           |
| -1.92    | 30.11           | 23.90           |
| -2.56    | 26.59           | 20.56           |
| -3.20    | 21.14           | 15.38           |
| -3.85    | 15.03           | 9.58            |

10/30/79  
5 OF 15

K&E  
KENNETH & ESSER CO. MADE IN U.S.A.  
10 X 10 TO 10 1/2 INCH 1 X 10 INCHES

40 1351

# IMPACT OF REVISED SIZING ASSUMPTIONS (WINTER)



1-30/79  
6 OF 15

IMPACT OF REVISED SIZING ASSUMPTIONS  
(INTEGRATION OF WINTER CURVE)

| TIME INCREMENT | 1818 HELIO  | 1718 HELIO  | 1618 HELIO  | 1518 HELIO  | 1418 HELIO  | 1318 HELIO  |
|----------------|-------------|-------------|-------------|-------------|-------------|-------------|
| .85            | 20.5        | 19.0        | 17.2        | 16.1        | 15.0        | 13.8        |
| (AM)           | 30.5        | 28.2        | 26.0        | 24.5        | 22.7        | 20.7        |
|                | 36.4        | 34.4        | 32.0        | 29.5        | 27.4        | 25.0        |
|                | 39.0        | 36.5        | 34.0        | 31.7        | 29.4        | 27.0        |
|                | 39.0        | 36.4        | 34.0        | 31.8        | 29.5        | 26.8        |
|                | 36.8        | 34.0        | 32.0        | 29.8        | 27.5        | 25.0        |
| (PM)           | 30.0        | 28.0        | 26.0        | 24.3        | 22.5        | 20.3        |
| .85            | <u>19.5</u> | <u>18.0</u> | <u>16.5</u> | <u>16.0</u> | <u>14.7</u> | <u>13.0</u> |
|                | 245.7 MWH   | 229 MWH     | 212.6 MWH   | 198.9 MWH   | 184 MWH     | 168 MWH     |

FROM WILLIAMSON SCALING DATA: (9/22/79)

∫ SUMMER ENERGY = 431.8 MWH

∫ WINTER ENERGY = 248.4 MWH

∫ EQUINOX ENERGY = 372.4 MWH → 86.2% SUMMER

EQUINOX 366.1 MWH 342.8 MWH 320.6 MWH 297.5 MWH 274.8 MWH 260.5 MWH

IMPACT OF REVISED SIZING ASSUMPTIONS

10/30/79  
7 OF 15

| SUMMER<br>TIME | REF INC<br>PWR MWZ | 1818 HELIO   |               | 1718 HELIO   |               | 1618 HELIO   |               | 1518 HELIO   |               |
|----------------|--------------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------|
|                |                    | INCID<br>MWZ | ABSORB<br>MWZ | INCID<br>MWZ | ABSORB<br>MWZ | INCID<br>MWZ | ABSORB<br>MWZ | INCID<br>MWZ | ABSORB<br>MWZ |
| -6.28          | 16.588             | 15.84        | 10.15         | 14.97        | 9.32          | 14.10        | 8.49          | 13.23        | 7.67          |
| -5.23          | 31.482             | 30.06        | 23.66         | 28.41        | 22.09         | 26.76        | 20.52         | 25.10        | 18.95         |
| -4.18          | 41.260             | 39.40        | 32.53         | 37.23        | 30.47         | 35.07        | 28.42         | 32.90        | 26.35         |
| -3.14          | 45.774             | 43.71        | 36.63         | 41.31        | 34.34         | 38.91        | 32.06         | 36.50        | 29.77         |
| -2.09          | 49.858             | 47.61        | 40.33         | 44.99        | 37.84         | 42.38        | 35.36         | 39.76        | 32.86         |
| -1.05          | 51.116             | 48.82        | 41.47         | 46.12        | 38.92         | 43.45        | 36.38         | 40.76        | 33.82         |
| NOON           | 51.411             | 49.10        | 41.74         | 46.39        | 39.17         | 43.70        | 36.61         | 40.99        | 34.04         |
| 1.05           | 50.973             | 48.68        | 41.34         | 45.99        | 38.80         | 43.32        | 36.26         | 40.64        | 33.71         |
| 2.09           | 48.887             | 46.69        | 39.45         | 44.11        | 37.01         | 41.55        | 34.58         | 38.98        | 32.13         |
| 3.14           | 46.399             | 44.31        | 37.19         | 41.87        | 34.88         | 39.44        | 32.57         | 36.99        | 30.25         |
| 4.18           | 41.857             | 39.97        | 33.07         | 37.77        | 30.98         | 35.58        | 28.90         | 33.37        | 26.81         |
| 5.23           | 32.141             | 30.69        | 24.26         | 29.00        | 22.65         | 27.32        | 21.05         | 25.63        | 19.45         |
| 6.28           | 15.381             | 14.69        | 9.05          | 13.88        | 8.29          | 13.07        | 7.52          | 12.26        | 6.75          |


ABS = INC \* .95 - 4.9

10/30/79  
8 OF 15

| SUMMER<br>TIME | 1418 HELIO   |                    | 1318 HELIO   |                    |
|----------------|--------------|--------------------|--------------|--------------------|
|                | INCID<br>MWZ | ABSORB<br>MWZ      | INCID<br>MWZ | ABSORB<br>MWZ      |
| - 6.28         | 12.35        | 6.84               | 11.48        | 6.01               |
| - 5.23         | 23.45        | 17.37              | 21.79        | 15.81              |
| - 4.18         | 30.73        | 24.29              | 28.57        | 22.24              |
| - 3.14         | 34.09        | 27.49              | 31.69        | 25.21              |
| - 2.09         | 37.13        | 30.38              | 34.52        | 27.89              |
| - 1.05         | 38.07        | 31.27              | 35.39        | 28.72              |
| NOON           | 38.29        | 31.47<br>(9.10 MW) | 35.59        | 28.91<br>(8.23 MW) |
| 1.05           | 37.96        | 31.16              | 35.29        | 28.63              |
| 2.09           | 36.41        | 29.69              | 33.85        | 27.25              |
| 3.14           | 34.56        | 27.93              | 32.12        | 25.62              |
| 4.18           | 31.17        | 24.72              | 28.98        | 22.63              |
| 5.23           | 23.94        | 17.84              | 22.25        | 16.24              |
| 6.28           | 11.46        | 5.98               | 10.65        | 5.22               |

10/30/79  
9 OF 15

# IMPACT OF REVISED SIZING ASSUMPTIONS (SUMMER)




# IMPACT OF REVISED SIZING ASSUMPTIONS (INTEGRATION OF SUMMER CURVES)

| TIME INCREMENT | 1818 HELIO                    | 1718 HELIO                    | 1618 HELIO                    | 1518 HELIO                    | 1418 HELIO                    | 1318 HELIO       |
|----------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|-------------------------------|------------------|
| ↑ .28 HR       | 12.5                          | 11.5                          | 10.5                          | 9.5                           | 9.0                           | 8.0              |
|                | 21.0                          | 19.7                          | 18.5                          | 17.0                          | 15.8                          | 14.0             |
|                | 30.2                          | 28.1                          | 26.2                          | 24.2                          | 22.5                          | 20.3             |
|                | 35.5                          | 33.2                          | 31.0                          | 28.8                          | 26.7                          | 24.5             |
| Am             | 39.2                          | 36.8                          | 34.3                          | 32.8                          | 29.5                          | 27.0             |
|                | 41.1                          | 38.8                          | 36.2                          | 33.5                          | 31.2                          | 28.5             |
| ↓              | 41.5                          | 39.0                          | 36.5                          | 34.0                          | 31.5                          | 28.9             |
|                | 41.5                          | 39.0                          | 36.5                          | 33.8                          | 31.3                          | 28.8             |
|                | 40.6                          | 38.2                          | 35.8                          | 33.0                          | 30.5                          | 28.3             |
| PM             | 38.8                          | 36.4                          | 34.0                          | 31.6                          | 29.5                          | 27.1             |
|                | 36.0                          | 33.5                          | 31.5                          | 29.3                          | 27.0                          | 25.0             |
|                | 30.8                          | 28.7                          | 26.8                          | 24.7                          | 22.7                          | 20.7             |
|                | 21.6                          | 19.8                          | 18.5                          | 17.0                          | 15.5                          | 13.8             |
| ↓ .28 HRS      | 11.5                          | 11.0                          | 10.5                          | 9.3                           | 8.5                           | 7.2              |
|                | <u>424.5</u> MWH <sub>c</sub> | <u>397.5</u> MWH <sub>c</sub> | <u>371.7</u> MWH <sub>c</sub> | <u>344.9</u> MWH <sub>c</sub> | <u>318.6</u> MWH <sub>c</sub> | <u>302.1</u> MWH |

322

10/30/79  
11 OF 15

IMPACT OF REVISED SIZING ASSUMPTIONS ON HELIOSTAT REQUIREMENTS AND PLANT RATING



K-E KENTLET & EGGERS CO. MADE IN U.S.A.  
10 X 10 TO 10 1/2 INCH 1 X 10 INCHES

401351



10/30/79


12 OF 15

### SUMMARY OF PLOTTED DATA


| No HELIOSTATS |      |      |      | Hours<br>@ 10MW | SUMMER     | WINTER          |            |
|---------------|------|------|------|-----------------|------------|-----------------|------------|
| MMC           | MDAC | MMC  | MDAC |                 | MAX<br>PWR | Hours<br>@ 10MW | MAX<br>PWR |
| 1818          | 1676 | 1762 | 1580 | 7.8             |            | 4               |            |
| 1718          | 1584 | 1666 | 1494 | 6.6             |            | 3               |            |
| 1618          | 1492 | 1568 | 1406 | 5.0             |            | 0.8             |            |
| 1518          | 1400 | 1472 | 1320 | 0               | 10         |                 | 9.29       |
| 1418          | 1308 | 1374 | 1232 |                 | 9.1        |                 | 8.46       |
| 1318          | 1216 | 1278 | 1146 |                 | 8.23       |                 | 7.63       |

| HR    | MW <sub>out</sub> |       |
|-------|-------------------|-------|
| 9895  | 12.52             | 1.0   |
| 9969  | 11.18             | 1.007 |
| 10068 | 9.87              | 1.017 |
| 10839 | 6.31              | 1.095 |
| 14111 | 2.69              | 1.426 |

DEGRADED TURBINE PERFORMANCE



IMPACT OF HELIOSTAT REDUCTION ON DAILY  
THERMAL ENERGY COLLECTION



|            |      |      |      |      |      |                                  |
|------------|------|------|------|------|------|----------------------------------|
| "LARGE"    | 1146 | 1232 | 1320 | 1406 | 1492 | 1580 (MDAC-514 FT <sup>2</sup> ) |
| HELIOSTATS | 1278 | 1374 | 1472 | 1568 | 1666 | 1762 (MMC-450 FT <sup>2</sup> )  |
| BASELINE   | 1319 | 1418 | 1518 | 1618 | 1718 | 1818 (MMC-430 FT <sup>2</sup> )  |
| HELIOSTATS | 1216 | 1308 | 1400 | 1492 | 1584 | 1676 (MDAC-479 FT <sup>2</sup> ) |

K&E KROFFET & FESSER CO. 400 N. 2ND ST. DENVER, CO. 80202

40 1351

# IMPACT ON MDAC "LARGE" HELIOSTATS (514 FT<sup>2</sup> REFLECTIVE SURFACE)

## No. HELIOSTATS

## ASSUMPTIONS

1720

- 4 HOUR @ 10 MW (WINTER 2PM DESIGN PT)
- $\alpha = .93$  (REC ABSORP)
- $\rho = .86$  (HELIO REFLECT)
- 1.8 MWe PARASITIC POWER
- 32 HELIOSTAT CONTINGENCY

1580

- 4 HOURS @ 10 MWe (WINTER 2PM DESIGN POINT)
- $\alpha = .95$  (REC ABSORP)
- $\rho = .89$  (HELIO REFLECT)
- 1.7 MWe PARASITIC POWER
- NO HELIOSTAT CONTINGENCY


1388

- 10 MWe AT WINTER NOON
- $\alpha = .95$  (REC ABSORP)
- $\rho = .89$  (HELIO REFLECT)
- 1.7 MWe PARASITIC POWER
- NO HELIOSTAT CONTINGENCY

1514


- 10 MWe AT WINTER NOON
- $\alpha = .93$  (REC ABSORP)
- $\rho = .86$  (HELIO REFLECT)
- 1.8 MWe PARASITIC
- 32 HELIOSTAT CONTINGENCY

| No. of<br>MARTIN<br>HELIOSTATS | IDEAL<br>POWER<br>GENERATED | FIXED<br>FIELD<br>LOSSES | TOTAL<br>ABSORBED<br>POWER | FRED<br>WINTER<br>LOSSES<br>(approx) | NET<br>ABSORBED<br>POWER | OPERATING<br>TIME<br>10 MWE |
|--------------------------------|-----------------------------|--------------------------|----------------------------|--------------------------------------|--------------------------|-----------------------------|
| 1956                           | 71,552 MW <sub>T</sub>      | -54.64%                  | 39.1 MW <sub>T</sub>       | 4.7 MW <sub>T</sub>                  | 34.4 MW <sub>T</sub>     | 4 Hr                        |
| 1856                           | 67,894 "                    |                          | 37.1 "                     | 4.7 "                                | 32.4 "                   | 3 Hr                        |
| 1756                           | 64,244 "                    |                          | 35.1 "                     | 4.7 "                                | 30.4 "                   | 1 Hr                        |
| 1656                           | 60,588 "                    |                          | 33.1 "                     | 4.7 "                                | 28.4 "                   | NO WAY                      |



OPERATING TIMES  
WINTER DAY

# OPERATING TIMES BEST SUMMER DAY



| NO. OF<br>MARTIN<br>HELIOSTATS | NET<br>ABSORBED<br>POWER | OPERATING<br>TIME<br>10MWE |
|--------------------------------|--------------------------|----------------------------|
| 1956                           | 33.8 MWt                 | 7.8 Hr                     |
| 1856                           | ~ 31.8                   | 6.8 Hr                     |
| 1756                           | ~ 29.8                   | 5.5 Hr                     |
| 1656                           | ~ 27.8                   | 4.0 Hr                     |

ESTIMATED IMPACT OF CHANGES IN COSINE AND  
BLOCKING / SHADOWING FOR 1656 HELIOSTAT

CASE

| <u>WINTER</u><br><u>NOON DATA</u> | ( COMPLETE )<br>FIELD | ( APPROX VALUE )<br>FOR 1656 HELIO |
|-----------------------------------|-----------------------|------------------------------------|
| INTERCEPTION                      | -9746                 | .980                               |
| B + S                             | .935                  | .938                               |

IMPACT OF REDUCED HELIOSTAT QUANTITY (WINTER) 6/11/79  
10F7

| TIME   | REF INCLD Pur | Pwr For 1956 HELIO (INC) | 1956 HELIO (ABS) | Pwr For 1856 HELIO (INC) | (ABS) |
|--------|---------------|--------------------------|------------------|--------------------------|-------|
| Noon   | 48.482        | 47.66                    | 39.62            | 45.22                    | 37.36 |
| .64    | 48.016        | 47.20                    | 39.20            | 44.78                    | 36.95 |
| 1.28   | 46.547        | 45.76                    | 37.85            | 43.42                    | 35.68 |
| 1.92   | 43.447        | 42.71                    | 35.02            | 40.53                    | 32.99 |
| 2.00   | 42.765        | 42.04                    | <u>34.4</u>      | 39.89                    | 32.40 |
| 2.56   | 37.921        | 37.28                    | 29.97            | 35.37                    | 28.20 |
| 3.20   | 30.154        | 29.64                    | 22.87            | 28.12                    | 21.46 |
| 3.85   | 19.765        | 19.43                    | 13.37            | 18.44                    | 12.45 |
| - .64  | 47.916        | 47.10                    | 39.11            | 44.69                    | 36.86 |
| - 1.28 | 46.547        | 45.76                    | 37.85            | 43.42                    | 35.68 |
| - 1.92 | 43.447        | 42.76                    | 35.06            | 40.57                    | 33.03 |
| - 2.56 | 38.399        | 37.75                    | 30.41            | 35.82                    | 28.61 |
| - 3.20 | 30.534        | 30.02                    | 23.22            | 28.49                    | 21.79 |
| - 3.85 | 21.715        | 21.35                    | 15.15            | 20.26                    | 14.14 |



6/11/79  
2 OF 7

| <u>TIME</u> | (WINTER)                    |           | PWR FOR 1656 HELIO<br>(INC) | 1656 HELIO<br>(ABSORB) |
|-------------|-----------------------------|-----------|-----------------------------|------------------------|
|             | PWR FOR 1756 HELIO<br>(INC) | (ABSORB.) |                             |                        |
| Noon        | 42.79                       | 35.09     | 40.35                       | 32.82 (1.46 MWc NET)   |
| .64         | 42.37                       | 34.71     | 39.96                       | 32.46                  |
| 1.28        | 41.08                       | 33.51     | 38.74                       | 31.33                  |
| 1.92        | 38.34                       | 30.96     | 36.16                       | 28.93                  |
| 2.00        | 37.74                       | 30.40     | 35.59                       | 28.40                  |
| 2.56        | 33.47                       | 26.43     | 31.56                       | 24.65                  |
| 3.20        | 26.61                       | 20.05     | 25.09                       | 18.64                  |
| 3.85        | 17.44                       | 11.52     | 16.45                       | 10.60                  |
| -.64        | 42.28                       | 34.62     | 39.87                       | 32.38                  |
| -1.28       | 41.08                       | 33.51     | 38.74                       | 31.33                  |
| -1.92       | 38.39                       | 31.00     | 36.20                       | 28.97                  |
| -2.56       | 33.89                       | 26.82     | 31.96                       | 25.02                  |
| -3.20       | 26.95                       | 20.36     | 25.42                       | 18.94                  |
| -3.85       | 19.17                       | 13.12     | 18.08                       | 12.11                  |

332

9/11/79  
 Continuation  
 of 6/11/79  
 3 OF 7

(WINTER)

| TIME   | P <sub>wr</sub> For 1556 HELIO (ABSORB) | P <sub>wr</sub> For 1456 HELIO (ABSORB) |
|--------|---|---|
| Noon   | 37.91                                   | 35.48                                   |
| .64    | 37.55                                   | 35.13                                   |
| 1.28   | 36.40                                   | 34.06                                   |
| 1.92   | 33.98                                   | 31.79                                   |
| 2.00   | 33.44                                   | 31.29                                   |
| 2.56   | 29.66                                   | 27.75                                   |
| 3.20   | 23.57                                   | 22.06                                   |
| 3.85   | 15.46                                   | 14.46                                   |
| - .64  | 37.47                                   | 35.06                                   |
| - 1.28 | 36.40                                   | 34.06                                   |
| - 1.92 | 34.01                                   | 31.83                                   |
| - 2.56 | 30.03                                   | 28.10                                   |
| - 3.20 | 23.88                                   | 22.34                                   |
| - 3.85 | 16.98                                   | 15.89                                   |

28.29 (7.900046407)

30.56  
 (8.68 P.W.C.)

# APPROXIMATE IMPACT OF REDUCTION IN HELIOSTATS (WINTER PERFORMANCE)

ABSORBED  
POWER  
(MW)

50  
40  
30  
20  
10

NOON

8

9

10

11

12

1

2

3

4

(AM)

(PM)

(118 MW GROSS)  
1958 }  
1856 } MARTIN  
1756 } HELIOSTATS  
1656 }

NOTE: RESULTS IGNORE  
CHANGES IN FIELD  
COSINE AND BLOCKING/  
SHADOWING LOSSES




# IMPACT OF HELIOSTAT AREA ON BLOCKING AND SHADOWING

(ANALYSIS OF "LARGE" MDAC AND MMC HELIOSTATS)

BLOCKING AND SHADOWING @ WINTER 2 PM

| AREA                | B+S  |
|---------------------|------|
| 430 FT <sup>2</sup> | .911 |
| 450 FT <sup>2</sup> | .898 |
| 479 FT <sup>2</sup> | .887 |
| 514 FT <sup>2</sup> | (?)  |




7 of 7  
9/12/79

IMPACT OF HELIOSTAT REDUCTION ON PLANT RATING

REV  
10/20/79

(APPROXIMATE RESULT)

HOURS OF OPERATION  $P \geq 10 \text{ MWe NET}$



\* MMC - 450 FT<sup>2</sup>  
\* MDAC - 514 FT<sup>2</sup>

"LARGE" HELIOSTAT QUANTITIES

|         |      |      |      |      |      |      |
|---------|------|------|------|------|------|------|
| (MMC)*  | 1424 | 1522 | 1618 | 1714 | 1812 | 1910 |
| (MDAC)* | 1284 | 1370 | 1458 | 1544 | 1634 | 1720 |

|                     |                      |        |        |        |        |               |
|---------------------|----------------------|--------|--------|--------|--------|---------------|
| BASELINE HELIOSTATS | 1468                 | 1568   | 1668   | 1768   | 1868   | 1968 (MMC)    |
|                     | (1360)               | (1452) | (1544) | (1636) | (1730) | (1822) (MDAC) |
|                     | NUMBER OF HELIOSTATS |        |        |        |        |               |

K&E KENNEL & ESSER CO. MADE IN U.S.A.  
10 X 10 TO 18 INCH 3 X 10 INCHES

40 1351



4/1/80  
1 OF 4

COLLECTOR FIELD AREA

OBJECTIVE :

DEFINE

- (i) ACTUAL FIELD AREA OCCUPIED BY HELICSTATS
- (ii) TOTAL AREA OF THE FOUR FIELD QUADRANTS  
(BETWEEN THE ROADS)
- (iii) TOTAL AREA OF ROADS AND CORE AREA  
COMBINED



TOP QUADRANT (RIGHT SIDE)

4/1/80  
2 OF 4

INSIDE PERIMETER ROAD  
(INCLUDING 1/2 OF SPOKE ROADS  
AND 1/4 CENTRAL CORE)

AREA OCCUPIED BY  
HELIOSTATS (INCLUDING  
PART OF SPOKE ROADS)

28  
28  
27.8  
27.7  
27.6  
27.4  
27.2  
26.9  
26.6  
26.3  
25.9  
25.4  
25.0  
24.4  
23.8  
23.2  
22.4  
21.5  
21.0  
19.9  
18.8  
17.7  
16.4  
15.0  
13.2  
4.0 (12 \* 1/3)  
591.1

27  
27  
26.5  
26.5  
26.3  
26.2  
26.0  
25.7  
25.5  
25.1  
24.7  
24.3  
23.6  
23.1  
22.5  
21.8  
21.1  
20.2  
19.5  
18.5  
15.5  
14.2  
10.0  
(-8)  
512.8

$$(50 \times 50)(591.1) = 1.4778 \times 10^6 \text{ FT}^2$$

$$(50 \times 50)(512.8) = 1.282 \times 10^6 \text{ FT}^2$$

$$\frac{A_{\text{CORE}}}{4} = \frac{\pi D^2}{16} = \frac{\pi (219)^2}{16} = 9417 \text{ FT}^2$$

$$\frac{A_{\text{CORE}}}{4} = 9417 \text{ FT}^2$$

NORTH ROAD

NORTH ROAD

$$23.5 \times 50 \times 9 = 10620 \text{ FT}^2$$

$$23.0 \times 50 \times 9 = 10350 \text{ FT}^2$$

EAST ROAD

EAST ROAD

$$20.8 \times 50 \times 9 = 9360 \text{ FT}^2$$

$$16.5 \times 50 \times 9 = 7425 \text{ FT}^2$$

$$A_{\text{QUAD}} = 1.448 \times 10^6 \text{ FT}^2$$

(INSIDE ROADS)

$$A_{\text{QUAD}} = 1.2548 \times 10^6 \text{ FT}^2$$

HELIOSTAT AREA

BOTTOM QUADRANT (RIGHT SIDE)

INSIDE PERIMETER ROAD  
(INCLUDING 1/2 OF SPOKE ROADS  
AND 1/4 CENTRAL CORE)

- 15
- 15
- 14.9
- 14.8
- 14.7
- 14.5
- 14.3
- 14.0
- 13.7
- 13.4
- 13.2
- 12.6
- 12.2
- 11.6
- 11.2
- 10.5
- 9.9
- 9.2
- 8.4
- 7.5
- 6.5
- 5.4
- 4.0
- 2.6
- .5 (1x.5)

269.6

$(50 \times 50)(269.6) = 6.74 \times 10^5 \text{ FT}^2$

AREA CORE /4 = 9417 FT<sup>2</sup>

SOUTH ROAD

$(10.5)(50)(25) = 13125 \text{ FT}^2$

EAST ROAD

$20.8 \times 50 \times 9 = 9360 \text{ FT}^2$

A QUAD (INSIDE ROADS) =  $6.421 \times 10^5 \text{ FT}^2$

AREA OCCUPIED BY  
HELIOSTATS (INCLUDING PARTS OF  
SPOKE ROADS)

- 11.5
- 11.7
- 11.6
- 11.2
- 11.6
- 12.0
- 12.0
- 11.5
- 11.8
- 12.0
- 11.8
- 12.0
- 11.2
- 11.0
- 10.2
- 8.5
- 6.0
- 5.5
- 4.0

197.1

$(50 \times 50)(197.1) = 4.9275 \times 10^5 \text{ FT}^2$

AREA CORE /4 = 9417 FT<sup>2</sup>

SOUTH ROAD

$(7.2)(50)(25) = 9000 \text{ FT}^2$

EAST ROAD

$15.5 \times 50 \times 9 = 6975 \text{ FT}^2$

A QUAD (HELIOSTAT AREA) =  $4.674 \times 10^5 \text{ FT}^2$

4/1/80  
4 DF 4

AREA HELIOSTATS

$$\begin{aligned}\Sigma 4 \text{ QUADRANTS} &= 2(4.674 \times 10^5 \text{ FT}^2) + 2(1.2548 \times 10^6 \text{ FT}^2) \\ 3.4444 \times 10^6 \text{ FT}^2 &= 79.07 \text{ ACRES}\end{aligned}$$

AREA QUADRANTS

$$\begin{aligned}\Sigma 4 \text{ QUADRANTS} &= 2(6.421 \times 10^5) + 2(1.448 \times 10^6 \text{ FT}^2) \\ &= 4.1802 \times 10^6 = 95.96 \text{ ACRES}\end{aligned}$$

CORE AREA

$$4(9417) = 37668 \text{ FT}^2$$

EAST + WEST ROAD

$$(20.8)(50)(18)(2) = 37440 \text{ FT}^2$$

NORTH ROAD

$$(23.5)(50)(18) = 21150 \text{ FT}^2$$

SOUTH ROAD

$$(10.5)(50)(50) = 26250 \text{ FT}^2$$

---

$$122508 \text{ FT}^2 = 2.81 \text{ ACRES}$$

1/18/80  
1 OF 14

## TIME FOR HELIOSTAT WIRE WALK

### OBJECTIVE :


CALCULATE THE TYPICAL TIME REQUIRED TO EXECUTE A WIRE WALK FOR A CLOSE IN HELIOSTAT THAT HAS A LONG ANGULAR TRAVEL. CARRYOUT THE CALCULATIONS FOR TWO REPRESENTATIVE WIRES:

(i) BOTTOM OF WIRE ABOVE EAST ROAD  
( 634 FT EAST + 80 FT UP )

(ii) BOTTOM OF WIRE NORTH OF EAST ROAD  
( 634 FT EAST, 192 FT NORTH, + 80 FT UP )

### NOTES :

- TEST HELIOSTAT IS No. 0119
- THIS ANALYSIS IGNORES ANY POTENTIAL SINGULARITY OR DRIVE SYSTEM TRAVEL LIMITS



$$\bar{M} = \text{MIRROR} = X_M, Y_M, Z_M$$

LOCATION OF CENTER OF REFLECTOR RELATIVE TO 0, 0, 0 REFERENCE

$$\bar{S} = \text{SUN LOCATION} = X_S, Y_S, Z_S$$

LOCATION OF SUN RELATIVE TO 0, 0, 0 REFERENCE

$$\bar{AP} = \text{AIM POINT FOR WIRE WALK} = X_{AP}, Y_{AP}, Z_{AP}$$

$$\bar{V}_{M-S} = (X_S - X_M)\bar{i} + (Y_S - Y_M)\bar{j} + (Z_S - Z_M)\bar{k}$$

MIRROR TO SUN

$$\bar{V}_{M-AP} = (X_{AP} - X_M)\bar{i} + (Y_{AP} - Y_M)\bar{j} + (Z_{AP} - Z_M)\bar{k}$$

MIRROR TO AIM POINT

IN GENERAL  $\bar{V} = a\bar{i} + b\bar{j} + c\bar{k}$   
 $r = (a^2 + b^2 + c^2)^{1/2}$

BISECTOR OF ANGLES  $\bar{V}_1$  AND  $\bar{V}_2$

$$\bar{V}_{\text{BISECTOR}} = r \left( \frac{\bar{V}_1}{r_1} \pm \frac{\bar{V}_2}{r_2} \right) \quad r = 1$$

$$\bar{V}_{\text{BISECTOR}} = \left[ \underbrace{\frac{a_1\bar{i} + b_1\bar{j} + c_1\bar{k}}{(a_1^2 + b_1^2 + c_1^2)^{1/2}}}_{D_1} + \underbrace{\frac{a_2\bar{i} + b_2\bar{j} + c_2\bar{k}}{(a_2^2 + b_2^2 + c_2^2)^{1/2}}}_{D_2} \right]$$

$$\bar{V}_{\text{BISECTOR}} = \frac{D_2 a_1 \bar{i} + D_2 b_1 \bar{j} + D_2 c_1 \bar{k}}{D_1 D_2} + \frac{D_1 a_2 \bar{i} + D_1 b_2 \bar{j} + D_1 c_2 \bar{k}}{D_1 D_2}$$

$$\bar{V}_{\text{BISECTOR}} = \frac{D_2 a_1 + D_1 a_2}{D_1 D_2} \bar{i} + \frac{D_2 b_1 + D_1 b_2}{D_1 D_2} \bar{j} + \frac{D_2 c_1 + D_1 c_2}{D_1 D_2} \bar{k}$$

WHERE

$$a_1 = x_s - x_m$$

$$a_2 = x_{AP} - x_m$$

$$b_1 = y_s - y_m$$

$$b_2 = y_{AP} - y_m$$

$$c_1 = z_s - z_m$$

$$c_2 = z_{AP} - z_m$$

$$D_1 = (a_1^2 + b_1^2 + c_1^2)^{1/2}$$

$$D_2 = (a_2^2 + b_2^2 + c_2^2)^{1/2}$$

(STORAGE LOCATION ASSIGNMENTS)

STO 00 - XAP

06 - Xs

12 - a<sub>2</sub>

01 - YAP

07 - Ys

13 - b<sub>2</sub>

02 - ZAP

08 - Zs

14 - C<sub>2</sub>

03 - X<sub>M</sub>

09 - a<sub>1</sub>

15 - D<sub>1</sub>

04 - Y<sub>M</sub>

10 - b<sub>1</sub>

16 - D<sub>2</sub>

05 - Z<sub>M</sub>

11 - C<sub>1</sub>

17 -  $\frac{D_2 a_1 + D_1 a_2}{D_1 D_2}$

$\bar{i}$  COEFFIC.

18 -  $\frac{D_2 b_1 + D_1 b_2}{D_1 D_2}$

$\bar{j}$  COEFFIC.

19 -  $\frac{D_2 c_1 + D_1 c_2}{D_1 D_2}$

$\bar{k}$  COEFFIC.

1/18/80  
4 of 14

PROGRAM: HELIOSTAT ANGLE 1 of 2

LBL  
A  
RCL }  
0 }  $x_s$   
6 }  
-  
RCL }  
0 }  $x_m$   
3 }  
=  
STO }  
0 }  $a_1$   
9 }  
RCL }  
0 }  $y_s$   
7 }  
-  
RCL }  
0 }  $y_m$   
4 }  
=  
STO }  
1 }  $b_1$   
0 }  
RCL }  
0 }  $z_s$   
8 }  
-

RCL }  
0 }  $z_m$   
5 }  
=  
STO }  
1 }  $c_1$   
1 }  
RCL }  
0 }  $x_{AP}$   
0 }  
-  
RCL }  
0 }  $x_m$   
3 }  
=  
STO }  
1 }  $a_2$   
2 }  
RCL }  
0 }  $y_{AP}$   
1 }  
-  
RCL }  
0 }  $y_m$   
4 }  
=  
STO }  
1 }  $b_2$   
3 }  
346

RCL }  
0 }  $z_{AP}$   
2 }  
-  
RCL }  
0 }  $z_m$   
5 }  
=  
STO }  
1 }  $E_2$   
4 }  
RCL  
0  
9  
 $x^2$   
+  
RCL  
1  
0  
 $x^2$   
+  
RCL  
1  
1  
 $x^2$   
=  
 $\sqrt{x}$   
STO }

1 }  $D_1$   
5 }  
RCL  
1  
2  
 $x^2$   
+  
RCL  
1  
3  
 $x^2$   
+  
RCL  
1  
4  
 $x^2$   
=  
 $\sqrt{x}$   
STO }  
1 }  $D_2$   
6 }  
(  
RCL }  
1 }  $D_2$   
6 }  
\*  
RCL }  
0 }  $a_1$   
9 }

PROGRAM: HELIOSTAT ANGLE 2 of 2

```

+
RCL }
1  } D1
5  }

```

```

*
RCL }
1  } a2
2  }
)
÷
(

```

```

RCL }
1  } D1
5  }

```

```

*
RCL }
1  } D2
6  }
)
=

```

```

STO }
1  }  $\frac{D_2 a_1 + D_1 a_2}{D_1 D_2}$ 
7  }
(

```

```

RCL }
1  } D2
6  }

```

```

*
RCL }
1  } b1
0  }

```

```

+
RCL }
1  } D1
5  }

```

```

*
RCL }
1  } b2
3  }
)
÷
(

```

```

RCL }
1  } D1
5  }

```

```

*
RCL }
1  } D2
6  }
)
=

```

```

STO }
1  }  $\frac{D_2 b_1 + D_1 b_2}{D_1 D_2}$ 
8  }

```

```

(
RCL }
1  } D2
6  }

```

```

*
RCL }
1  } c1
1  }

```

```

+
RCL }
1  } D1
5  }

```

```

*
RCL }
1  } c2
4  }
)
÷
(

```

```

RCL }
1  } D1
5  }

```

```

*
RCL }
1  } D2
6  }
)
=

```

```

STO }
1  }
9  }
HLT

```

$$\frac{D_2 c_1 + D_1 c_2}{D_1 D_2}$$



| LOC | CODE | KEY | COMMENTS | LOC | CODE | KEY            | COMMENTS | LOC | CODE | KEY            | COMMENTS | LABELS                                 |
|-----|------|-----|----------|-----|------|----------------|----------|-----|------|----------------|----------|--|
| 000 | 112  | LBL |          |     |      | -              |          |     |      | X <sup>2</sup> |          | A HELIO<br>ANGLE                       |
|     |      | A   |          |     |      | RCL            |          |     |      | +              |          | B                                      |
|     |      | RCL |          | 040 | 152  | 0              |          |     |      | RCL            |          | C                                      |
|     |      | 0   |          |     |      | 3              |          |     |      | 1              |          | D                                      |
|     |      | 6   |          |     |      | =              |          | 080 | 192  | 1              |          | E                                      |
| 005 | 117  | -   |          |     |      | STO            |          |     |      | X <sup>2</sup> |          | A                                      |
|     |      | RCL |          |     |      | 1              |          |     |      | =              |          | B                                      |
|     |      | 0   |          | 045 | 157  | 2              |          |     |      | √X             |          | C                                      |
|     |      | 3   |          |     |      | RCL            |          |     |      | STO            |          | D                                      |
|     |      | =   |          |     |      | 0              |          | 085 | 197  | 1              |          | E                                      |
| 010 | 122  | STO |          |     |      | 1              |          |     |      | 5              |          | REGISTERS                              |
|     |      | 0   |          |     |      | -              |          |     |      | RCL            |          | 00 - XAP                               |
|     |      | 9   |          | 050 | 162  | RCL            |          |     |      | 1              |          | 01 YAP                                 |
|     |      | RCL |          |     |      | 0              |          |     |      | 2              |          | 02 ZAP                                 |
|     |      | 0   |          |     |      | 4              |          | 090 | 202  | X <sup>2</sup> |          | 03 XM                                  |
| 015 | 127  | 7   |          |     |      | =              |          |     |      | +              |          | 04 YM                                  |
|     |      | -   |          |     |      | STO            |          |     |      | RCL            |          | 05 ZM                                  |
|     |      | RCL |          | 055 | 167  | 1              |          |     |      | 1              |          | 06 Xs                                  |
|     |      | 0   |          |     |      | 3              |          |     |      | 3              |          | 07 Ys                                  |
|     |      | 4   |          |     |      | RCL            |          | 095 | 207  | X <sup>2</sup> |          | 08 Zs                                  |
| 020 | 132  | =   |          |     |      | 0              |          |     |      | +              |          | 09 z <sub>1</sub>                      |
|     |      | STO |          |     |      | 2              |          |     |      | RCL            |          | 10 b <sub>1</sub>                      |
|     |      | 1   |          | 060 | 172  | -              |          |     |      | 1              |          | 11 c <sub>1</sub>                      |
|     |      | 0   |          |     |      | RCL            |          |     |      | 4              |          | 12 z <sub>2</sub>                      |
|     |      | RCL |          |     |      | 0              |          | 100 | 212  | X <sup>2</sup> |          | 13 b <sub>2</sub>                      |
| 025 | 137  | 0   |          |     |      | 5              |          |     |      | =              |          | 14 c <sub>2</sub>                      |
|     |      | 8   |          |     |      | =              |          |     |      | √X             |          | 15 D <sub>1</sub>                      |
|     |      | -   |          | 065 | 177  | STO            |          |     |      | STO            |          | 16 D <sub>2</sub>                      |
|     |      | RCL |          |     |      | 1              |          |     |      | 1              |          | 17 $\frac{D_2 a_1 + D_1 a_2}{D_1 D_2}$ |
|     |      | 0   |          |     |      | 4              |          | 105 | 217  | 6              |          | 18 $\frac{D_2 b_1 + D_1 b_2}{D_1 D_2}$ |
| 030 | 142  | 5   |          |     |      | RCL            |          |     |      | 1              |          | 19 $\frac{D_2 c_1 + D_1 c_2}{D_1 D_2}$ |
|     |      | =   |          |     |      | 0              |          |     |      | RCL            |          | FLAGS                                  |
|     |      | STO |          | 070 | 182  | 9              |          |     |      | 1              |          | 0                                      |
|     |      | 1   |          |     |      | X <sup>2</sup> |          |     |      | 6              |          | 1                                      |
|     |      | 1   |          |     |      | +              |          | 110 | 222  | *              |          | 2                                      |
| 035 | 147  | RCL |          |     |      | RCL            |          |     |      | RCL            |          | 3                                      |
|     |      | 0   |          |     |      | 1              |          |     |      |                |          | 4                                      |
|     |      | 0   |          | 075 | 187  | 0              |          |     |      |                |          |  |

TEXAS INSTRUMENTS  
INCORPORATED


| LOC | CODE | KEY | COMMENTS | LOC | CODE | KEY | COMMENTS | LOC                               | CODE | KEY            | COMMENTS                         | LABELS    |
|-----|------|-----|----------|-----|------|-----|----------|-----------------------------------|------|----------------|----------------------------------|-----------|
| 112 |      | 0   |          |     |      | RCL |          |                                   |      | 1              |                                  | A         |
|     |      | 9   |          |     |      | 1   |          |                                   |      | 5              |                                  | B         |
|     |      | +   |          | 040 | 152  | 3   |          |                                   |      | *              |                                  | C         |
|     |      | RCL |          |     |      | )   |          |                                   |      | RCL            |                                  | D         |
|     |      | 1   |          |     |      | ÷   |          | 080                               | 192  | 1              |                                  | E         |
| 005 | 117  | 5   |          |     |      | (   |          |                                   |      | 6              |                                  | A'        |
|     |      | *   |          |     |      | RCL |          |                                   |      | )              |                                  | B'        |
|     |      | RCL |          | 045 | 157  | 1   |          |                                   |      | =              |                                  | C'        |
|     |      | 1   |          |     |      | 5   |          |                                   |      | STO            |                                  | D'        |
|     |      | 3   |          |     |      | *   |          | 085                               | 197  | 1              |                                  | E'        |
| 010 | 122  | )   |          |     |      | RCL |          |                                   |      | 9              |                                  | REGISTERS |
|     |      | ÷   |          |     |      | 1   |          |                                   |      | HLT            | NOT UNET VECTOR                  | 00        |
|     |      | (   |          | 050 | 162  | 6   |          |                                   |      | LBL            | ADD LRLB TO FIND                 | 01        |
|     |      | RCL |          |     |      | )   |          |                                   |      | B              | UNET FACTOR (1/x)                | 02        |
|     |      | 1   |          |     |      | =   |          | 090                               | 202  | RCL            | AND STO 00                       | 03        |
| 015 | 127  | 5   |          |     |      | STO |          |                                   |      | 1              | NOTE THIS WIPES OUT OLD 00 VALUE | 04        |
|     |      | *   |          |     |      | 1   |          |                                   |      | 7              |                                  | 05        |
|     |      | RCL |          | 055 | 167  | 8   |          |                                   |      | x <sup>2</sup> |                                  | 06        |
|     |      | 1   |          |     |      | (   |          |                                   |      | +              |                                  | 07        |
|     |      | 6   |          |     |      | RCL |          | 095                               | 207  | RCL            |                                  | 08        |
| 020 | 132  | )   |          |     |      | 1   |          |                                   |      | 1              |                                  | 09        |
|     |      | =   |          |     |      | 6   |          |                                   |      | 8              |                                  | 10        |
|     |      | STO |          | 060 | 172  | *   |          |                                   |      | x <sup>2</sup> |                                  | 11        |
|     |      | 1   |          |     |      | RCL |          |                                   |      | +              |                                  | 12        |
|     |      | 7   |          |     |      | 1   |          | 100                               | 212  | RCL            |                                  | 13        |
| 025 | 137  | (   |          |     |      | 1   |          |                                   |      | 1              |                                  | 14        |
|     |      | RCL |          |     |      | +   |          |                                   |      | 9              |                                  | 15        |
|     |      | 1   |          | 065 | 177  | RCL |          |                                   |      | x <sup>2</sup> |                                  | 16        |
|     |      | 6   |          |     |      | 1   |          |                                   |      | =              |                                  | 17        |
|     |      | *   |          |     |      | 5   |          | 105                               | 217  | √x             |                                  | 18        |
| 030 | 142  | RCL |          |     |      | *   |          |                                   |      | 1/x            |                                  | 19        |
|     |      | 1   |          |     |      | RCL |          |                                   |      | STO            |                                  | FLAGS     |
|     |      | 0   |          | 070 | 182  | 1   |          |                                   |      | 0              |                                  | 0         |
|     |      | +   |          |     |      | 4   |          |                                   |      | 0              |                                  | 1         |
|     |      | RCL |          |     |      | )   |          | 110                               | 222  | HLT            |                                  | 2         |
| 147 |      | 1   |          |     |      | ÷   |          |                                   |      |                |                                  | 3         |
|     |      | 5   |          |     |      | (   |          |                                   |      |                |                                  | 4         |
|     |      | *   |          | 075 | 187  | RCL |          | TEXAS INSTRUMENTS<br>INCORPORATED |      |                |                                  |           |

MORNING SUN

(SUMMER 10° ELEV

$Z = 111.69^\circ$      $\mathcal{Q} = 10^\circ$

$\frac{90.00}{21.69}^\circ$  NORTH OF EAST



$|\bar{Q}| = 1$

$|\bar{Q}|_{proj} = 1 (\cos 10^\circ) = .9848$

$X_{proj} = .9848 (\sin 21.69^\circ) = -.3696$

$Y_{proj} = .9848 (\cos 21.69^\circ) = .9292$

$Z_{proj} = 1 (\sin 10^\circ) = .1736$

INCREMENTAL TIME CALCULATIONS

AZIMUTH INCREMENT :  $\theta_1 = \tan^{-1} \left| \frac{Y_1}{X_1} \right|$

$\theta_2 = \tan^{-1} \left| \frac{Y_2}{X_2} \right|$

$\Delta \theta_{BEAM} = \theta_2 - \theta_1$

$\Delta \theta_{HELIO} = \frac{\Delta \theta_{BEAM}}{2}$

TIME =  $\frac{\Delta \theta_{HELIO}}{\text{DRIVE RATE HELIO AZIMUTH}}$

ELEV. INCREMENT

$\phi_1 = \tan^{-1} \frac{Z_1}{\sqrt{X_1^2 + Y_1^2}}$

$\phi_2 = \tan^{-1} \frac{Z_2}{\sqrt{X_2^2 + Y_2^2}}$

$\Delta \phi_{BEAM} = \phi_2 - \phi_1$

$\Delta \phi_{HELIO} = \frac{\Delta \phi_{BEAM}}{2}$

TIME =  $\frac{\Delta \phi_{HELIO}}{\text{ELEV DRIVE RATE}}$

|                     |                                  |                    |    |
|---------------------|----------------------------------|--------------------|----|
| TIME INCREMENT      | PROGRAM                          | PROGRAM            | -1 |
| $X_{i+1} - 00$      | $Y_{i+1} - 01$                   | $Z_{i+1} - 02$     |    |
| $X_i - 03$          | $Y_i - 04$                       | $Z_i - 05$         |    |
| $\Theta_{i+1} - 06$ | $\Theta_i - 07$                  | $\Phi_{i+1} - 08$  |    |
| $\Phi_i - 09$       | DRIVE<br>$AZ^{\wedge} RATE - 10$ | EL DRIVE RATE - 11 |    |

|                      |                  |                |                    |
|----------------------|------------------|----------------|--------------------|
| LBL                  | ÷                | ÷              | 0                  |
| A                    | RCL              | 2              | 1                  |
| RCL                  | 0                | ÷              | X <sup>2</sup>     |
| 0                    | 3                | RCL            | )                  |
| 1                    | =                | 1              | √X                 |
| ÷                    | X <sup>2</sup>   | 0              | =                  |
| RCL                  | √X               | =              | INV                |
| 0                    | INV              | HLT AZ         | TAN                |
| 2                    | TAN              | TIME           | STO } $\Phi_{i+1}$ |
| =                    | STO } $\Theta_i$ | INCRE.         | 0                  |
| X <sup>2</sup>       | 0                | RCL            | 8                  |
| √X                   | 7                | 0              | RCL                |
| INV                  | -                | 2              | 0                  |
| TAN                  | RCL              | ÷              | 5                  |
| STO } $\Theta_{i+1}$ | 0                | (              | ÷                  |
| 0                    | 6                | RCL            | (                  |
| 6                    | =                | 0              | RCL                |
| RCL                  | X <sup>2</sup>   | 0              | 0                  |
| 0                    | √X               | X <sup>2</sup> | 3                  |
| 4                    | HLT AQ           | +              | X <sup>2</sup>     |
|                      | BEAM             | RCL            | +                  |

TIME INCREMENT - 2

|                |                        |     |
|----------------|------------------------|-----|
| RCL            |                        | LBL |
| 0              |                        | B   |
| 4              |                        | RCL |
| X <sup>2</sup> |                        | 0   |
| )              |                        | 0   |
| √X             |                        | STO |
| =              |                        | 0   |
| INV            |                        | 3   |
| TAN            |                        | RCL |
| STO            | } $\phi_i$             | 0   |
| 0              |                        | 1   |
| 9              |                        | STO |
| -              |                        | 0   |
| RCL            |                        | 4   |
| 0              |                        | RCL |
| 8              |                        | 0   |
| =              |                        | 2   |
| X <sup>2</sup> |                        | STO |
| √X             |                        | 0   |
| HLT            | $\Delta\phi$<br>BEAM   | 5   |
| ÷              |                        | HLT |
| 2              |                        |     |
| ÷              |                        |     |
| RCL            |                        |     |
| 1              |                        |     |
| 1              |                        |     |
| =              |                        |     |
| HLT            | ELEV<br>TIME<br>INCREM |     |

| LOC        | CODE | KEY        | COMMENTS   | LOC | CODE | KEY        | COMMENTS     | LOC        | CODE | KEY        | COMMENTS       | LABELS                        |
|------------|------|------------|------------|-----|------|------------|--------------|------------|------|------------|----------------|-------------------------------|
| 000        |      | LBL        |            |     |      | $\sqrt{x}$ |              |            |      | 0          |                | A START                       |
|            |      | A          |            |     |      | HLT        | AG BEAM      |            |      | 3          |                | B SHIFT 2+1<br>→ 2 STORE PAGE |
|            |      | RCL        | 040<br>152 |     |      | $\div$     |              |            |      | $x^2$      |                | C                             |
|            |      | 0          |            |     |      | 2          |              |            |      | +          |                | D                             |
|            |      | 1          |            |     |      | $\div$     |              | 080<br>192 |      | RCL        |                | E                             |
| 005<br>117 |      | $\div$     |            |     |      | RCL        |              |            |      | 0          |                | A'                            |
|            |      | RCL        |            |     |      | 1          |              |            |      | 4          |                | B'                            |
|            |      | 0          | 045<br>157 |     |      | 0          |              |            |      | $x^2$      |                | C'                            |
|            |      | 0          |            |     |      | =          |              |            |      | )          |                | D'                            |
|            |      | =          |            |     |      | HLT        | AZ TIME INCR | 085<br>197 |      | $\sqrt{x}$ |                | E'                            |
| 010<br>122 |      | $x^2$      |            |     |      | RCL        |              |            |      | =          |                | REGISTERS                     |
|            |      | $\sqrt{x}$ |            |     |      | 0          |              |            |      | INV        |                | 00 $x_{i+1}$                  |
|            |      | INV        | 050<br>162 |     |      | 2          |              |            |      | TAN        |                | 01 $y_{i+1}$                  |
|            |      | TAN        |            |     |      | $\div$     |              |            |      | STO        |                | 02 $z_{i+1}$                  |
|            |      | STO        |            |     |      | (          |              | 090<br>202 |      | 0          |                | 03 $x_i$                      |
| 015<br>127 |      | 0          |            |     |      | RCL        |              |            |      | 9          |                | 04 $y_i$                      |
|            |      | 6          |            |     |      | 0          |              |            |      | -          |                | 05 $z_i$                      |
|            |      | RCL        | 055<br>167 |     |      | 0          |              |            |      | RCL        |                | 06 $\theta_{i+1}$             |
|            |      | 0          |            |     |      | $x^2$      |              |            |      | 0          |                | 07 $\theta_i$                 |
|            |      | 4          |            |     |      | +          |              | 095<br>207 |      | 8          |                | 08 $\phi_{i+1}$               |
| 020<br>132 |      | $\div$     |            |     |      | RCL        |              |            |      | =          |                | 09 $\phi_i$                   |
|            |      | RCL        |            |     |      | 0          |              |            |      | $x^2$      |                | 10 AZ DRIVE RATE %            |
|            |      | 0          | 060<br>172 |     |      | 1          |              |            |      | $\sqrt{x}$ |                | 11 ELEV DRIVE RATE            |
|            |      | 3          |            |     |      | $x^2$      |              |            |      | HLT        | AG BEAM        | 12                            |
|            |      | =          |            |     |      | )          |              | 100<br>212 |      | $\div$     |                | 13                            |
| 025<br>137 |      | $x^2$      |            |     |      | $\sqrt{x}$ |              |            |      | 2          |                | 14                            |
|            |      | $\sqrt{x}$ |            |     |      | =          |              |            |      | $\div$     |                | 15                            |
|            |      | INV        | 065<br>177 |     |      | INV        |              |            |      | RCL        |                | 16                            |
|            |      | TAN        |            |     |      | TAN        |              |            |      | 1          |                | 17                            |
|            |      | STO        |            |     |      | STO        |              | 105<br>217 |      | 1          |                | 18                            |
| 030<br>142 |      | 0          |            |     |      | 0          |              |            |      | =          |                | 19                            |
|            |      | 7          |            |     |      | 8          |              |            |      | HLT        | ELEV TIME INCR | FLAGS                         |
|            |      | -          | 070<br>182 |     |      | RCL        |              |            |      | LBL        |                | 0                             |
|            |      | RCL        |            |     |      | 0          |              |            |      | B          |                | 1                             |
|            |      | 0          |            |     |      | 5          |              | 110<br>222 |      | RCL        |                | 2                             |
| 035<br>147 |      | 6          |            |     |      | $\div$     |              |            |      | 0          |                | 3                             |
|            |      | =          |            |     |      | (          |              |            |      |            |                | 4                             |
|            |      | $x^2$      | 075<br>187 |     |      | RCL        |              |            |      |            |                |                               |

TEXAS INSTRUMENTS  
 INCORPORATED

# SR-52 Coding Form



TITLE HELIOSTAT TIME INCREMENT PAGE 2 OF 2  
PROGRAMMER \_\_\_\_\_ DATE 1/19/80

| LOC | CODE | KEY | COMMENTS | LOC | CODE | KEY | COMMENTS | LOC | CODE | KEY | COMMENTS | LABELS    |
|-----|------|-----|----------|-----|------|-----|----------|-----|------|-----|----------|-----------|
| 000 |      | 0   |          |     |      |     |          |     |      |     |          | A         |
|     |      | STO |          |     |      |     |          |     |      |     |          | B         |
|     |      | 0   |          | 040 |      |     |          |     |      |     |          | C         |
|     |      | 3   |          | 152 |      |     |          |     |      |     |          | D         |
|     |      | RCL |          |     |      |     |          | 080 |      |     |          | E         |
| 005 |      | 0   |          |     |      |     |          | 192 |      |     |          | A'        |
| 117 |      | 1   |          |     |      |     |          |     |      |     |          | B'        |
|     |      | STO |          | 045 |      |     |          |     |      |     |          | C'        |
|     |      | 0   |          | 157 |      |     |          |     |      |     |          | D'        |
|     |      | 4   |          |     |      |     |          | 085 |      |     |          | E'        |
| 010 |      | RCL |          |     |      |     |          | 197 |      |     |          | REGISTERS |
| 122 |      | 0   |          |     |      |     |          |     |      |     |          | 00        |
|     |      | 2   |          | 050 |      |     |          |     |      |     |          | 01        |
|     |      | STO |          | 162 |      |     |          |     |      |     |          | 02        |
|     |      | 0   |          |     |      |     |          | 090 |      |     |          | 03        |
| 015 |      | 5   |          |     |      |     |          | 202 |      |     |          | 04        |
| 127 |      | HLT |          |     |      |     |          |     |      |     |          | 05        |
|     |      |     |          | 055 |      |     |          |     |      |     |          | 06        |
|     |      |     |          | 167 |      |     |          |     |      |     |          | 07        |
|     |      |     |          |     |      |     |          | 095 |      |     |          | 08        |
| 020 |      |     |          |     |      |     |          | 207 |      |     |          | 09        |
| 132 |      |     |          |     |      |     |          |     |      |     |          | 10        |
|     |      |     |          | 060 |      |     |          |     |      |     |          | 11        |
|     |      |     |          | 172 |      |     |          |     |      |     |          | 12        |
|     |      |     |          |     |      |     |          | 100 |      |     |          | 13        |
| 025 |      |     |          |     |      |     |          | 212 |      |     |          | 14        |
| 137 |      |     |          |     |      |     |          |     |      |     |          | 15        |
|     |      |     |          | 065 |      |     |          |     |      |     |          | 16        |
|     |      |     |          | 177 |      |     |          |     |      |     |          | 17        |
|     |      |     |          |     |      |     |          | 105 |      |     |          | 18        |
| 030 |      |     |          |     |      |     |          | 217 |      |     |          | 19        |
| 142 |      |     |          |     |      |     |          |     |      |     |          | FLAGS     |
|     |      |     |          | 070 |      |     |          |     |      |     |          | 0         |
|     |      |     |          | 182 |      |     |          |     |      |     |          | 1         |
|     |      |     |          |     |      |     |          | 110 |      |     |          | 2         |
| 035 |      |     |          |     |      |     |          | 222 |      |     |          | 3         |
| 147 |      |     |          |     |      |     |          |     |      |     |          | 4         |
|     |      |     |          | 075 |      |     |          |     |      |     |          |           |
|     |      |     |          | 187 |      |     |          |     |      |     |          |           |

TEXAS INSTRUMENTS  
INCORPORATED







1/17/80  
1 OF 2

TIME REQUIRED TO MOVE IMAGES BETWEEN  
STANDBY AND TRACK

OBJECTIVE : DEFINE THE TIME REQUIRED TO MOVE  
IMAGES FROM STANDBY TO RECEIVER TRACK  
IF STANDBY IS DEFINED AS


(i)  $2\frac{1}{2}$  RECEIVER DIAMETERS FROM THE  
RECEIVER CENTERLINE

(ii)  $5\frac{1}{2}$  RECEIVER DIAMETERS FROM THE  
RECEIVER CENTERLINE

(iii) 1 RECEIVER DIAMETER FROM THE  
RECEIVER CENTERLINE

FOR "NEAR IN" AND "FAR OUT" HELIOSTATS ON THE  
NORTH SIDE OF THE FIELD

1/17/80



HORIZONTAL TRAVEL DISTANCE

1. STANDBY TO REC. CENTERLINE  $D = 57.5 \text{ FT}$
  2. POINT OF FIRST INTERACTION TO RECEIVER CENTERLINE  $D = 23 \text{ FT}$
  3. 5 DIAMETERS + TO REC CENTERLINE  $D = 126.5 \text{ FT}$
- FOR CLOSE HELIOSTAT (GROUND RANGE = 239 FT)

TRAVEL ANGLE FOR 1. =  $13.5^\circ$

$\Rightarrow \text{Time} = 31 \text{ SEC @ } 13^\circ/\text{min}$   
 (TIME FOR 3. =  $\frac{126.5}{57} \times 31 = 68.8 \text{ SEC}$ ) HELIOSTAT MOTION  
 ANGLE  $29.97^\circ$  TRAVEL-BEAM (\* 2 - BEAM MOTION)

TRAVEL ANGLE FOR 2. =  $5.5^\circ$

$\Rightarrow \text{TIME} = 12.7 \text{ SEC @ } 13^\circ/\text{min}$   
 (\* 2 - BEAM MOTION)

- FOR DISTANT HELIOSTAT (GROUND RANGE = 1317 FT)

TRAVEL ANGLE FOR 1. =  $2.5^\circ$

$\Rightarrow \text{TIME} = 5.7 \text{ SEC @ } 13^\circ/\text{min}$   
 (\* 2 - BEAM MOTION)

TRAVEL ANGLE FOR 2. =  $1.0^\circ$

$\Rightarrow \text{TIME} = 2.3 \text{ SEC @ } 13^\circ/\text{min}$   
 (\* 2 - BEAM MOTION)

(TIME FOR 3. =  $\frac{126.5}{57} \times 5.7 = 12.65$ )  
 BEAM TRAVEL ANGLE

2 OF 2

Collector Interface WorkshopAction Item No 1

MDAC will document the historical changes in assumptions which resulted in the need for increasing the number of heliostats from the PDR quantity to the current quantity.

Answer:

Table 1 contains a tabular summary of the power requirements and receiver/collector field performance factors which have been developed during previous and current design analyses to reflect changes in the design point (winter 2PM vs summer 8AM), insolation, and parasitic power requirements. The data contained in the table starts with the design point and the electrical power requirement. The appropriate performance factors are listed and applied to the electrical power requirement to determine the "ideal power requirement" which is the amount of incoming sun light which would strike the heliostats assuming all heliostats are oriented normal to the sun. Table 1 then defines the total number of (STMPO) heliostats required to satisfy the "ideal power requirement" at the specified insolation levels.

Data contained in Table 2 shows the conversion in required number of heliostats when the STMPO heliostat is replaced with Martin or MDAC heliostat. In either case, the conversion is made by modifying the "equivalent STMPO heliostat" quantity by the appropriate blocking and shadowing factor and the area of the particular heliostat of interest. An "outage factor" of 32 is then added to the calculated heliostat quantity to determine the required "total heliostat" quantity.

TABLE 1

Historical Evolution of Pilot Plant Heliostat Quantity Requirements

|   | PDR<br>(Oct, 1977)      | Initial Project<br>Review (May 2, 1979) | Scaled Analysis<br>(May 18, 1979) | Preliminary (1)<br>Design Review<br>(July 30, 1979) |
|---|-------------------------|---|-----------------------------------|---|
| Design Point                                  | Winter 2PM              | Summer 8AM                              | Winter 2PM                        | Winter 2PM  |
| Design Point Electrical<br>Power (10 MWe Net) | 11.2 MWe                | 11.6 MWe                                | 11.8 MWe                          | 11.8 MWe  |
| Absorbed Thermal Power                        | 32.6 MWt                | 33.8 MWt                                | 34.4 MWt                          | 34.4 MWt  |
| Receiver Thermal Losses                       | 4.2 MWt                 | 4.8 MWt                                 | 4.7 MWt                           | 4.7 MWt   |
| Average Receiver<br>Absorptance               | (0.95)                  | (0.93)                                  | (0.93)                            | (0.93)  |
| Receiver Incident Power                       | 38.7 MWt                | 41.5 MWt                                | 42.04 MWt                         | 42.04 MWt   |
| Receiver Interception<br>Factor               | (.977)                  | (.976)                                  | (.976)                            | (.976)  |
| Atmospheric Attenuation<br>Factor             | (.98)                   | (.978)                                  | (.978)                            | (.978)  |
| Sensor Post Blocking and<br>Shadowing Factor  | (.98)                   | -                                       | -                                 | -   |
| Field Cosine                                  | (.801)                  | (.749)                                  | (.794)                            | (.792)  |
| Blocking and Shadowing                        | (.952)                  | (.958) <sup>(2)</sup>                   | (.902) <sup>(2)</sup>             | (.898) <sup>(2)</sup>                               |
| Average Heliostat Re-<br>flectivity           | (.88)                   | (.86)                                   | (.86)                             | (.86)   |
| Ideal Power Requirement                       | 61.4 MWt <sup>(3)</sup> | 70.9 MWt <sup>(3)</sup>                 | 71.5 MWt <sup>(3)</sup>           | 72.0 MWt <sup>(3)</sup>                             |

(1) Based on individual heliostat analysis

TABLE 1

Historical Evolution of Pilot Plant Heliostat Quantity Requirements (Continued)

|                           | PDR<br>(Oct, 1977)               | Initial Project<br>Review (May 2, 1979) | Scaled Analysis<br>(May 18, 1979) | Preliminary (1)<br>Design Review<br>(July 30, 1979) |
|---------------------------|----------------------------------|---|-----------------------------------|---|
| Assumed Direct Insolation | 950 <sup>W</sup> /m <sup>2</sup> | 898 <sup>W</sup> /m <sup>2</sup>        | 917 <sup>W</sup> /m <sup>2</sup>  | 917 <sup>W</sup> /m <sup>2</sup>                    |
| Required Glass Area       | 695,400 ft <sup>2</sup>          | 850,137 ft <sup>2</sup>                 | 839,700 ft <sup>2</sup>           | 845,100 ft <sup>2</sup>                             |
| Heliostat Reflector Area  | 408 ft <sup>2</sup>              | 450 ft <sup>2</sup> (2)                 | 450 ft <sup>2</sup> (2)           | 450 ft <sup>2</sup> (2)                             |
| Equivalent Heliostats     | 1703                             | 1890 <sup>(2)</sup>                     | 1866 <sup>(2)</sup>               | 1878 <sup>(2)</sup>                                 |
| Contingency Heliostats    | 57 <sup>(4)</sup>                | 32                                      | 32                                | 32  |
| Total Heliostats          | 1760                             | 1922 <sup>(2)</sup>                     | 1898 <sup>(2)</sup>               | 1910 <sup>(2)</sup>                                 |

(2) STMPO - defined 450 ft<sup>2</sup> heliostat

(3) Rounded off values

(4) Includes non ideal effects not contained in the sizing calculations

TABLE 2

Conversion from STMPO to Martin and MDAC Helio-stat Quantities

|  | Initial Project<br>Review<br>(May 2, 1979) | Scaled Analysis<br>(May 18, 1979) | Preliminary<br>Design Review<br>(July 30, 1979) |
|--|--|-----------------------------------|---|
| Equivalent STMPO Helio-stats                     | 1890 (1922-32)                             | 1866 (1898-32)                    | 1878 (1910-32)                                  |
| <u>Martin Helio-stats</u> (430 ft <sup>2</sup> ) |  |                                   |   |
| Blocking and Shadowing Factor                    | .972                                       | .915                              | .911  |
| Equivalent Martin Helio-stats                    | 1950                                       | 1924                              | 1936  |
| Outage Factor                                    | 32   | 32                                | 32  |
| Total Helio-stats                                | 1982                                       | 1956                              | 1968  |
| <u>MDAC Helio-stats</u> (479 ft <sup>2</sup> )   |  |                                   |   |
| Blocking and Shadowing Factor                    | .945                                       | .889                              | .887  |
| Equivalent MDAC Helio-stats                      | 1800                                       | 1778                              | 1790  |
| Outage Factor                                    | 32   | 32                                | 32  |
| Total Helio-stats                                | 1832                                       | 1810                              | 1822  |

DEFINITION OF FIELD PERFORMANCE FOR FIELD  
SIZED FOR WINTER 2 PM  
(WINTER LOSS MODEL)

| (PERFORMANCE)                            | PARASITIC POWER<br>1.6 MW <sub>e</sub>              | PARASITIC POWER<br>1.8 MW <sub>e</sub>            |
|--|---|---|
| GROSS ELECT                              | 11.6 MW <sub>e</sub>                                | 11.8 MW <sub>e</sub>                              |
| ABSORBED POWER (NET)                     | 33.8 MW <sub>e</sub>                                | 34.4 MW <sub>e</sub>                              |
| WINTER LOSSES                            | 4.7 MW <sub>e</sub>                                 | 4.7 MW <sub>e</sub>                               |
| TOT. ABSORBED PWR.                       | 38.5 MW <sub>e</sub>                                | 39.1 MW <sub>e</sub>                              |
| REC. ABSORPTION (0.93)                   | 41.4 MW <sub>e</sub>                                | 42.04 MW <sub>e</sub>                             |
| (INTERCEPT FACT)* (0.954)<br>(ATM ATTEN) |   |   |
| COSINE (0.794)                           |   |   |
| BLOCK AND SHADOW (0.902)                 |   |   |
| REFLECT (0.86)                           |   |   |
| IDEAL POWER                              | 70.454 MW <sub>e</sub>                              | 71.552 MW <sub>e</sub>                            |
| INSOLATION 917 W/m <sup>2</sup>          |   |   |
| GLASS AREA                               | 76,831 m <sup>2</sup><br>(826,701 ft <sup>2</sup> ) | 78028 m <sup>2</sup><br>(839600 ft <sup>2</sup> ) |
| No STMPO                                 | 1838 + 32 = 1870                                    | 1866 + 32 = 1898                                  |
| No MDAC                                  | 1752 + 32 1784                                      | 1778 + 32 1810                                    |
| No MARTIN                                | <sup>363</sup> 894 + 32 1926                        | 1924 + 32 1956                                    |



5/18/79

(2)

POWER PRODUCTION DURING BEST DAY  
(BEST DAY THERMAL LOSSES)

1.6 MW PARASITICS CF =  $(\frac{76851}{78780})$

1.8 MW PARASITICS CF =  $(\frac{78028}{78980})$

| TIME  | PINC [UH] MW <sub>T</sub> | (PINC)*(CF) MW <sub>T</sub> | PABS [(PINC)(CF)(.93) - 4.9] |
|-------|---------------------------|-----------------------------|------------------------------|
| -6.28 | 16.588                    | 16.137                      | 10.107                       |
| -5.23 | 31.482                    | 30.625                      | 23.581                       |
| -4.18 | 41.260                    | 40.137                      | 32.427                       |
| -3.14 | 45.774                    | 44.528                      | 36.511                       |
| -2.09 | 49.858                    | 48.501                      | 40.206                       |
| -1.05 | 51.116                    | 49.725                      | 41.344                       |
| Noon  | 51.411                    | 50.012                      | 41.611                       |
| 1.05  | 50.973                    | 49.586                      | 41.215                       |
| 2.09  | 48.887                    | 47.557                      | 39.328                       |
| 3.14  | 46.399                    | 45.137                      | 37.077                       |
| 4.18  | 41.857                    | 40.718                      | 32.967                       |
| 5.23  | 32.141                    | 31.266                      | 24.177                       |
| 6.28  | 15.381                    | 14.962                      | 9.015                        |

| (PINC*CF) MW <sub>T</sub> | PABS [(PINC)(CF)(.93) - 4.9] |
|---------------------------|------------------------------|
| 16.388                    | 10.34                        |
| 31.103                    | 24.02                        |
| 40.763                    | 33.01                        |
| 45.222                    | 37.16                        |
| 49.257                    | 40.91                        |
| 50.500                    | 42.06                        |
| 50.791                    | 42.34                        |
| 50.358                    | 41.93                        |
| 48.247                    | 40.02                        |
| 45.840                    | 37.73                        |
| 41.352                    | 33.56                        |
| 31.753                    | 24.63                        |
| 15.196                    | 9.23                         |


KEITHLEY ENGINEERING CO. 1010 15th ST. N.W. WASHINGTON, D.C. 20005

40 1351

5/20/79

# BEST DAY PERFORMANCE FOR FIELD SIZED FOR WINTER 2 PM

JER



5/20/79  
4 OF 7

STORAGE SIZING ( WINTER 2PM FIELD - SIZED FOR  
1.6 MWe PLANT PARASITIC )

(10° SUN)

(15° SUN )

12.2 x .3

18.1 x .5

23.7 x .5

28.5 x .5

31.8 x .5

34.2 x .5

36.4 x .5

38.2 x .5

39.7 x .5

40.7 x .5

41.2 x .5

41.5 x .5

41.6 x .5

41.5 x .5

41.2 x .5

40.8 x .5

40.2 x .5

39.3 x .5

38.2 x .5

37.0 x .5

35.1 x .5

32.5 x .5

29.0 x .5

24.2 x .5

18.0 x .5

11.6 x .3

423.44 MWH

PWR TO TURB  
(7.8HR) (33.8MW) = 263.64 MWH

PWR TO STOR = 159.8 MWH

18.5 x .4

18.6 x .4

413.09 MWH

PWR TO TURB  
(7.8HR) (33.2 MW) = 262.56 MWH

PWR TO STOR = 149.45 MWH

5/20/79  
5 OF 7

STORAGE SIZING (WINTER 2PM FIELD - SIZED FOR  
1.8 MWR PLANT PARASITICS)

(10° SUN)

12.5 x .3  
18.4 x .5  
24.1 x .5  
28.7 x .5  
32.2 x .5  
34.9 x .5  
37.0 x .5  
38.9 x .5  
40.4 x .5  
41.4 x .5  
41.9 x .5  
42.2 x .5  
42.4 x .5  
42.3 x .5  
42.0 x .5  
41.5 x .5  
40.8 x .5  
40.0 x .5  
39.0 x .5  
37.5 x .5  
36.2 x .5  
38.0 x .5  
29.2 x .5  
24.7 x .5  
18.4 x .5  
12.0 x .3

---

433.40 MWH±

PWR TO TURB =  
(7.8 HR) (34.4 MW) = 268.32 MWH±

PWR TO STOR = 165.08 MWH±

(15° SUN)

19.1 x .4

19.0 x .4

---

422.89 MWH±

PWR TO TURB =  
(7.8 HR) (34.4 MW) = 268.32 MWH±


PWR TO STOR = 154.57 MWH±

K&E KROFFET & FROEH CO. WASHINGTON, D.C.

40 1351

5/20/79  
JER

BEST DAY PERFORMANCE FOR FIELD SIZED FOR WINTER 2 PM



5.20/79  
7 OF 7

STORAGE SIZING SUMMARY  
(BEST DAY CAPACITY FOR FIELD SIZED FOR WINTER 2PM)

|   | 1.6 MWe PLANT PARASITICS |                        | 1.8 MWe PLANT PARASITICS |                        |
|---|--------------------------|------------------------|--------------------------|------------------------|
|   | (10° SUN ELEV)           | (15° SUN ELEV)         | (10° SUN ELEV)           | (15° SUN ELEV)         |
| ENER. AVAILABLE FOR STOR.   | 159.8 MWh <sub>e</sub>   | 149.5 MWh <sub>e</sub> | 165.1 MWh <sub>e</sub>   | 154.6 MWh <sub>e</sub> |
| ENERGY FOR<br>• CONDITIONING<br>• HEAT LOSS<br>• ROLL AND LOAD TURB | 11.8 MWh <sub>e</sub>    | 11.8 MWh <sub>e</sub>  | 11.8 MWh <sub>e</sub>    | 11.8 MWh <sub>e</sub>  |
| 369 ENERGY FOR 7.8 MWe<br>TURBINE OPERATION                         | 148.0 MWh <sub>e</sub>   | 137.7 MWh <sub>e</sub> | 153.3 MWh <sub>e</sub>   | 142.8 MWh <sub>e</sub> |
| ELECTRICAL OUTPUT<br>( $\eta_c = .2435$ )                           | 36.0 MWh <sub>e</sub>    | 33.5 MWh <sub>e</sub>  | 37.3 MWh <sub>e</sub>    | 34.8 MWh <sub>e</sub>  |
| HOURS AT 7.8 MWe<br>GROSS (7.0 MWe NET)                             | 4.6 HR                   | 4.3 HR                 | 4.8 HR                   | 4.5 HR                 |
| COLLECTOR FIELD<br>HELIOSTAT REQ'TS                                 | STMP0<br>MARTIN<br>MDAC  | 1870<br>1926<br>1784   | STMP0<br>MARTIN<br>MDAC  | 1898<br>1956<br>1810   |

5/2/79  
1 OF 13  
2 PM

COMPARISON BETWEEN SUMMER 8AM AND WINTER 2PM  
PERFORMANCE

|  | SUMMER 8 AM  | WINTER 2 PM   |
|--|--|---|
|  | PERFORMANCE  | PERFORMANCE   |
|  | POWER  | POWER   |
| ABSORBED POWER                         | 33.8 MW <sub>e</sub>                               | 33.8 MW <sub>e</sub>                                |
| ABSORB. PWR + 4.8<br>LOST <sup>3</sup> | 38.6 MW <sub>e</sub>                               | 38.6 MW <sub>e</sub>                                |
| (RECEIVER ABSORPT)                     | (.93)  | (.93)   |
| (INTERCEPT) X (ATM<br>ATTENUATION)     | (.954)   | (.954)  |
| (COSINE)                               | (.749)   | (.7940)   |
| (BLOCK + SHADOW)                       | (.958)   | (.9020)   |
| (REFLECT)                              | (.86)  | (.86)   |
| IDEAL POWER                            | 70.924 MW <sub>e</sub>                             | 70.637 MW <sub>e</sub>                              |
| INSOLATION                             | 898 w/m <sup>2</sup>                               | 917 w/m <sup>2</sup>                                |
| GLASS AREA                             | 78980 m <sup>2</sup><br>(850,137 ft <sup>2</sup> ) | 77,030 m <sup>2</sup><br>(829,153 ft <sup>2</sup> ) |
| No HELIO (450 FT)                      | 1890   | 1842  |
| + 32 HELIO                             | <u>1922</u>  | <u>1874</u>   |
| MDAC                                   |  | (.9528)(1874) = 1786                                |
| MARTIN                                 |  | (1.03097)(1874) = 1932                              |

5/2/79  
2 OF 15

COMPARISON BETWEEN SUMMER 8AM AND WINTER 2PM

PERFORMANCE  
SUMMER LOSS

|                                    | SUMMER 8AM   |   | WINTER 2PM  |                        |
|------------------------------------|--|---|---|------------------------|
|                                    | PERFORMANCE  | POWER                                       | PERFORMANCE   | POWER                  |
| ABSORBED POWER                     |  | 33.8 MW <sub>E</sub>                        |   | 33.8 MW <sub>E</sub>   |
| 4.9<br>ABSORB. PWR + 4.8<br>LOSSES |  | 38.6 MW <sub>E</sub>                        |   | 38.6 MW <sub>E</sub>   |
| (RECEIVER ABSORPT.)                | (.93)  |   | (.93)   |                        |
| (INTERCEPT) X (ATM ATTENUATION)    | (.954)   |   | (.954)  |                        |
| (COSINE)                           | (.749)   |   | (.7940)   |                        |
| (BLOCK + SHADOW)                   | (.958)   |   | (.9020)   |                        |
| (REFLECT)                          | (.86)  |   | (.86)   |                        |
| IDEAL POWER                        |  | 71.108<br><del>70.924</del> MW <sub>E</sub> |   | 70.637 MW <sub>E</sub> |
| INSOLATION                         | 898 w/m <sup>2</sup>                               |   | 917 w/m <sup>2</sup>                                |                        |
| GLASS AREA                         | 78980 m <sup>2</sup><br>(850,137 ft <sup>2</sup> ) |   | 77,030 m <sup>2</sup><br>(829,153 ft <sup>2</sup> ) |                        |
| No. HELIO (450 FT <sup>2</sup> )   | 1874<br><del>1890</del>                            |   | 1842  |                        |
| + 32 HELIO                         | <u>1922</u> 1926                                   |   | <u>1874</u>   |                        |
| MDAC                               | 1926 (.9528)                                       | 1836  |   |                        |
| MPAC                               | 1926 (1.03077)                                     | 1986  |   |                        |



5/2/79  
3 OF 13

COMPARISON BETWEEN SUMMER 8AM AND WINTER 2PM

WINTER LOSS PERFORMANCE

|                                       | SUMMER 8AM   |                        | WINTER 2PM  |   |
|---------------------------------------|--|------------------------|---|---|
|                                       | PERFORMANCE  | POWER                  | PERFORMANCE   | POWER                                       |
| ABSORBED POWER                        |  | 33.8 MW <sub>e</sub>   |   | 33.8 MW <sub>e</sub>                        |
| ABSORB. PWR <del>+4.8</del><br>LOSSES |  | 38.6 MW <sub>e</sub>   |   | 38.5<br><del>38.6</del> MW <sub>e</sub>     |
| (RECEIVER ABSORPT.)                   | (.93)  |                        | (.93)   |   |
| (INTERCEPT) X (ATM<br>ATTENUATION)    | (.954)   |                        | (.954)  |   |
| (COSINE)                              | (.749)   |                        | (.7940)   |   |
| (BLOCK + SHADOW)                      | (.958)   |                        | (.9020)   |   |
| (REFLECT)                             | (.86)  |                        | (.86)   |   |
| IDEAL POWER                           |  | 70.924 MW <sub>e</sub> |   | 70.454<br><del>70.637</del> MW <sub>e</sub> |
| INSOLATION                            | 898 W/m <sup>2</sup>                               |                        | 917 W/m <sup>2</sup>                                |   |
| GLASS AREA                            | 78980 m <sup>2</sup><br>(850,137 ft <sup>2</sup> ) |                        | 77,030 m <sup>2</sup><br>(829,153 ft <sup>2</sup> ) |   |
| No HELIO (450 FT <sup>2</sup> )       | 1890   |                        | 1838<br><del>1842</del>                             |   |
| + 32 HELIO                            | <u>1922</u>  |                        | <del>1874</del> 1870                                |   |
| MDAL                                  |  |                        | 1870 (.952%) 179%                                   |   |
| MURKIN                                |  |                        | 1870 (1.03%) 172%                                   |   |

## SUMMER AND WINTER WINDS (AVE VALUES)

$$\bar{V} = \frac{\sum V_i P_i}{\sum P_i}$$

$V_i$  - VELOCITY

$P_i$  - PROBABILITY

### JUNE

- .0429 x .9 m/SEC
- .0767 x 2.6 m/SEC
- .2007 x 4.4 m/SEC
- .2147 x 6.95 m/SEC
- .1331 x 9.8 m/SEC
- .0538 x 13.4 m/SEC
- .0032 x 18.25 m/SEC

$$\sum P_i = .7251$$

$$\sum V_i P_i = 4.697$$

$$\bar{V} = \frac{4.697}{.7251} = 6.48 \text{ m/SEC}$$

$$\bar{V} = 14.5 \text{ mph}$$

$$\bar{T} = 87^\circ \text{F}$$

$$V_{REC} = 6.48 \left(\frac{80}{10}\right)^{.15}$$

$$V_R = 8.85 \text{ m/sec} \rightarrow 19.8 \text{ mph}_{374}$$

### DEC

- .0929 x .9 m/SEC
- .1034 x 2.6 m/SEC
- .1366 x 4.4 m/SEC
- .0487 x 6.95 m/SEC
- .0119 x 9.8 m/SEC
- .0085 x 13.4 m/SEC
- .0008 x 18.25 m/SEC

$$\sum P_i = .4028$$

$$\sum V_i P_i = 1.537$$

$$\bar{V} = \frac{1.537}{.4028} = 3.82 \text{ m/SEC}$$

$$\bar{V} = 8.5 \text{ mph}$$

$$\bar{T} = 55^\circ \text{F}$$

$$V_{REC} = 3.82 \left(\frac{80}{10}\right)^{.15}$$

$$V_R = 5.22 \text{ m/sec} \rightarrow 11.7 \text{ mph}$$

REF LOSS TEMP = 780°F

AREA FACTOR = 1.0976

WINTER LOSS

$$\text{WIND SCALE FACTOR} = \frac{11.7}{10.93} = 1.070$$

$$\text{TEMP FACTOR} = \frac{780-55}{780-73} = 1.025$$

$$\begin{aligned} \text{Loss} &= 3.2(1.0976) + \left[ .5^{(1.025)^{1/3}} + .5(1.070)^{.8}(1.025) \right] (1.0976) \\ &= 3.512 + 1.147 \\ &= 4.66 \text{ MWL} \end{aligned}$$

SUMMER LOSS

$$\text{WIND FACTOR} = \frac{19.8}{10.93} = 1.812$$

$$\text{TEMP FACTOR} = \frac{780-87}{780-73} = .9802$$

$$\begin{aligned} \text{Loss} &= 3.2(1.0976) + \left[ .5(.9802)^{1/3} + .5(1.812)^{.8}(.9802) \right] (1.0976) \\ &= 3.512 + 1.411 \\ &= 4.92 \text{ MWL} \end{aligned}$$

5/3/79  
60F13  
REVISED  
5/20/79

10° SUN LIMIT

15° SUN LIMIT

ENERGY AVAIL.  
FOR STORAGE

165.1 MWH<sub>e</sub>

156.2 MWH<sub>e</sub> (REVISED)

ENERGY FOR  
• CONDITIONING  
• HEAT LOSS  
• ROLL & LOAD TURB.

11.8 MWH<sub>e</sub>

11.8 MWH<sub>e</sub>

ENERGY FOR 7.8 MWe  
OPERATION

153.3 MWH<sub>e</sub>

144.4 MWH<sub>e</sub> (REVISED)

TURBINE HEAT RATE  
14,014 BTU/KWH

$\eta_c = .2435$

ELECTRICAL OUTPUT

37.3 MWH<sub>e</sub>

35.2 MWH<sub>e</sub> (REVISED)

HOURS AT 7.8 MWe GROSS  
(7 MWe NET)

4.8 HR

4.5 HR (REVISED)

(BASED ON SYSTEM SIZED FOR 8 HOUR SUMMER OPERATION


AT 10 MWe NET)

ANNUAL AVERAGE LOSS

376

70F13  
5/3/79

# BEST DAY ABSORBED ENERGY



5/31/79  
 REVISED  
 5/20/79  
 8 OF 13

(15°) SUN  
 (10° SUN)  $\sum$  (1/2 HR INCREM.)

THERMAL STORAGE SIZING

| DAY 93 (P <sub>inc</sub> /950) | P <sub>inc</sub> | P <sub>ABS</sub><br>[P <sub>inc</sub> + 73.4.8] |
|--------------------------------|------------------|---|
| Noon                           | .0520            | 42.98   |
| 1.05                           | .0514            | 42.57   |
| 2.09                           | .0502            | 40.63   |
| 3.14                           | .0488            | 38.36   |
| 4.18                           | .0461            | 34.09   |
| 5.23                           | .0395            | 25.10   |
| 6.28                           | .0286            | 9.48  |
| -1.05                          |                  | 42.74   |
| -2.09                          |                  | 41.57   |
| -3.14                          |                  | 37.77   |
| -4.18                          |                  | 33.57   |
| -5.23                          |                  | 24.48   |
| -6.28                          |                  | 10.63   |

6<sup>5</sup> 12 x .5 = 39.2  
 18.5 15.2 37.8  
 24.5 36.0  
 29.3 33.2  
 33.0 29.5  
 35.4 25.1  
 37.5 18.5 x 15.2  
 39.3 6<sup>1</sup> 12 x .5  
 41.0 871 ÷ 2 =  
 42.2 435.5 MWHZ  
 UNDER  
 CURVE  
 43.0  
 43.2 ENERGY UNDER TURBINE CURVE  
 43.0 33.8 x 8 = 270.4 MWHZ  
 →  $\Delta$  ENERGY FOR EXTENDED  
 OPER. 156.2

STORAGE CAPACITY = 165.1 MWHZ

41.4  
 40.5

10° SUN LIMIT

15° SUN LIMIT

ENERGY AVAIL  
FOR STORAGE

109.3 MWh<sub>e</sub>

97.8 MWh<sub>e</sub>

ENERGY FOR  
-CONDITIONING  
• HEAT LOSS  
• ROLL + LOAD TURB

11.0 MWh<sub>e</sub>

11.0 MWh<sub>e</sub>

ENERGY FOR 7.8 MWe  
OPERATION

98.3 MWh<sub>e</sub>

86.8 MWh<sub>e</sub>

379

$\eta_{\text{CYCLE}} = .2435$

ELECTRICAL OUTPUT

23.94 MWh<sub>e</sub>

21.14 MWh<sub>e</sub>

HOURS AT 7.8 MWe GROSS  
(7 MWe NET)

3.1 HR

2.7 HR

(BASED ON SYSTEM SIZED FOR 4 HOUR WINTER OPERATION  
AT 10 MWe NET) - ANNUAL AVERAGE LOSS MODEL

5/4/79  
10 OF 13

THEMAL STORAGE SIZED FOR 4 HOUR WINTER DAY

[.93 - 4.8]  
ABSORBED  
POWER  
(MW)

(.874/1922)  
SCALED  
INCIDENT  
PWR (MWE)

39.16

47.27

INCID  
PWR (MW)

48.482

INSOLATION

TIME

Noon

38.74

46.82

48.016

.64

964

37.41

45.38

46.547

1.28

953

34.60

42.36

43.447

1.92

924

2.00 → 42.765

29.58

36.97

37.921

2.56

873

22.54

29.40

30.154

3.20

793

13.14

19.29

19.784

3.85

625

38.65

46.72

47.916

-.64

962

37.41

45.38

46.547

-1.28

953

34.64

42.41

43.494

-1.92

925

30.02

37.44

38.399

-2.56

884

22.89

29.77

30.534

-3.20

803

14.89

21.17

21.715

-3.85

686



5/4/79  
11 OF 13

# Worst Day Absorbed Energy (Field Scaled to 4HR Worst Day)

50 mwe

40

30

20

10

Noon

2

4

8

4


6

8

(AM)

(PM)

TIME




5/4/79  
12 OF 13

THERMAL STORAGE SIZING

( SIZED FOR 4 HOUR WORST DAY OPERATION )

$\Sigma P_{ABSORB}$



15° SUN

$$\frac{466}{2} = 233 \text{ MWHr}$$

10° SUN

$$\frac{489.1}{2} = 244.5 \text{ MWHr}$$

10° SUN

TURBINE DEMAND

$$33.8 \times 4 \text{ HR} = 135.2 \text{ MWH}$$

ENERGY FOR STORAGE

$$(15^\circ) \quad 233 - 135.2 = 97.8 \text{ MWHr}$$

$$(10^\circ) \quad 244.5 - 135.2 = 109.3 \text{ MWHr}$$

TOTAL COLLECTION

466  
489.1

NUMBER OF HELIOSTATS

514179  
13 OF 13

| CONDITION                        | STMPO | MARTIN | MDAC |
|----------------------------------|-------|--------|------|
| SUMMER 8AM                       |       |        |      |
| • AVE ENVIRON <sup>(1)</sup>     | 1922  | 1982   | 1832 |
| • AVE JUNE ENVIR <sup>(2)</sup>  | 1926  | 1986   | 1836 |
| WINTER 2PM                       |       |        |      |
| • AVE ENVIRON <sup>(1)</sup>     | 1874  | 1932   | 1786 |
| • AVE DEC. ENVIR. <sup>(3)</sup> | 1870  | 1928   | 1782 |

(1) 11.7 mph 73°F

ANNUAL AVE

(2) 14.5 mph 87°F

SUMMER DAY AVE

(3) 8.5 mph 55°F

WINTER DAY AVE



ESTIMATED BLEED STEAM CONDITIONS ENTERING CONDENSER

1. PROBLEM: DEFINE THE STEAM TEMPERATURE ENTERING THE CONDENSER FROM


(1) BLEED FLOW FROM RECEIVER FLASH TANK  
(ASSUMED 300 LB/HR INITIALLY @ 960°F,  
1500 PSIA →  $h = 1465$  BTU/LB)

(2) FLOW LEAKAGE THROUGH PV-1001  
150 LB/HR INITIALLY @ 950°F  
1465 PSIA →  $h = 1465$  BTU/LB

WHICH EXPANDS TO CONDENSER PRESSURE

2.5 IN HG  $h = 1465$  BTU/LB →  $T = 870$ °F

2. HEAT LOSS THROUGH STEAM DUMP PIPE



10" PIPE  
2 1/2" INSULATION

ASSUME ALL FLOW IS  
INTRODUCED AT OR  
NEAR THE DESUPERHEATER

8/16/80  
ZDFG

REVIEW OF HEAT LOSS THROUGH STEAM DUMP LINE

$$Q = (UA)\Delta T$$

$$UA = \frac{1}{\left[ \frac{1}{(h_{STEAM})\pi D_i L} + \frac{\ln(R_2/R_1)}{k 2\pi L} + \frac{1}{(h_{amb})(\pi) D_{OUTSIDE} (L)} \right]}$$

ASSUME

$$h_{STEAM} = 1.0 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F} \quad \left( \text{REF } 0.85 \rightarrow 1.12 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F} \right)$$

NEGLECT TEMP DROP ACROSS PIPE ( $k_{PIPE} \rightarrow$  LARGE)  
STEVE MCCORMICK CALC

$$D_i = \text{INSIDE PIPE DIAMETER} = 0.835 \text{ FT}$$

$$D_{OUTSIDE} = \text{OUTSIDE INSULATION DIAMETER} = 15.75 \text{ IN} \\ = 1.3125 \text{ FT}$$

$$R_1 = \text{INSIDE INSULATION DIAMETER} = 5.0 \text{ IN}$$

$$R_2 = D_{OUTSIDE}/2 = 7.875 \text{ IN}$$

$$h_{amb} = 1.45 \text{ BTU/HR-FT}^2\text{-}^\circ\text{F}$$

$$k = 0.04 \text{ BTU/HR-FT-}^\circ\text{F}$$

$$UA = \frac{1}{\left[ \frac{1}{(1.0)(\pi)(.835)(73)} + \frac{\ln\left(\frac{7.875}{5.0}\right)}{(0.04)(2\pi)(73)} + \frac{1}{(1.45)(\pi)(1.3125)(73)} \right]}$$

$$UA = \frac{1}{5.222 \times 10^{-3} + 2.465 \times 10^{-2} + 2.29 \times 10^{-3}}$$

$$UA = 31.09 \text{ BTU/HR-}^\circ\text{F}$$

8/16/80  
3 OF 6

REFERENCE PIPING DISTANCE

2 1/2" INSULATION PORTION FROM STATION (460) TO (525)

LENGTH

- 2' 6"
- 6' 6"
- 6' 3"
- 2' 6"
- 10' 6"
- 1' 6"
- 6' 9"
- 1' 6"
- 12' 0"
- 8' 6"
- 21' 6"
- 2' 0"
- 5' 0"
- 6' 0"
- 2' 0"

---

- 95' 0"

INTERFACE 22 FT UPSTREAM OF  
CONDENSER INTERFACE

PIPE LENGTH TO INTERFACE  
95 - 22 FT = 73 FT

$$Nu_D = Re_D Pr^{1/3} \frac{f}{8}$$

$$Re_D = \frac{\rho V D}{\mu}$$

$$\rho = .00133 \frac{LB}{FT^3}$$

$$D = .835 FT$$

$$\mu = 1.64 \times 10^{-5} \frac{LB}{(SEC)(FT)}$$

$$V = \frac{\dot{m}}{\rho A} = \frac{450 \frac{LB}{HR}}{(.00133)(.574)(3600)}$$

$$V = 164 \frac{FT}{SEC}$$

$$Re_D = \frac{(.00133)(164)(.835)}{1.64 \times 10^{-5}} = 11106$$

$$f = .018 \text{ FROM CRANE}$$

$$h = \frac{k}{D} Re Pr^{1/3} \frac{f}{8}$$

$$= \left( \frac{9.2 \times 10^{-3}}{.835} \right) (11106) \left( \frac{.018}{8} \right)^{1/3}$$

$$h = .275 \text{ BTU/HR-FT}^2\text{-}^\circ F$$

OUTSIDE CONVECTION

5 mph WIND = 7.33 FT/sec  
 $\rho = 0.0765 \frac{LB}{FT^3}$   
 $\mu = 0.046 \frac{LB}{FT HR} = 1.278 \times 10^{-5} \frac{LB}{FT SEC}$   
 $D_o = 1.3125 FT$

$$\frac{D_o G}{\mu} = \frac{(1.3125 FT)(0.0765 \frac{LB}{FT^3})(7.33 \frac{FT}{SEC})}{1.278 \times 10^{-5} \frac{LB}{FT SEC}} = 5.76 \times 10^4$$

$$\frac{h_m D_o}{k} = 121$$

387

$$h_m = \frac{k}{D} (121) = (121) \left( \frac{.0157}{1.3125} \right) = 1.45 \frac{BTU}{HR-FT^2}$$

8/16/80  
HDF

$$Q_{LOSS} = UA \Delta T$$

$$= (31.09) (870 - 110) = 2.362 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 870^\circ \text{F})$$

$$= (31.09) (820 - 110) = 2.207 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 820^\circ \text{F})$$

$$= (31.09) (770 - 110) = 2.052 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 770^\circ \text{F})$$

$$= (31.09) (720 - 110) = 1.896 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 720^\circ \text{F})$$

$$= (31.09) (670 - 110) = 1.741 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 670^\circ \text{F})$$

$$= (31.09) (620 - 110) = 1.586 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 620^\circ \text{F})$$

$$= (31.09) (840 - 110) = 2.269 \times 10^4 \text{ BTU/HR} \quad (\bar{T} = 840^\circ \text{F})$$

$$Q_{STEAM} = \dot{m} C_p \Delta T$$

$$= (450 \text{ LB/HR}) (0.5 \text{ BTU/LB-}^\circ\text{F}) (T_{IN} - T_{OUT})$$


$$\rightarrow (T_{IN} - 2T_{AVE} + T_{IN})$$

$$2(T_{IN} - T_{AVE})$$

| $Q_{STEAM}$<br>BTU/HR | $\bar{T}$<br>°F |
|-----------------------|-----------------|
| 0                     | 870             |
| $2.25 \times 10^4$    | 820             |
| $4.5 \times 10^4$     | 770             |
| $1.35 \times 10^4$    | 840             |



8/16/80  
5 CF 6



$T_{INIT} = 870^{\circ}F$

$\therefore T_{AVE} = 822^{\circ}F$

$Q_{LOSS} = 2.21 \times 10^4 \text{ BTU/HR}$

→ STEAM AT JOINT POINT  
=  $774^{\circ}F$   
@ INTERFACE 60

Ave PIPE TEMP

$$UA = \frac{1}{\left[ \frac{1}{h_{STEAM}} \pi D L \right]} = \frac{1}{(1.0) \pi (1.835)(73)} = 191.5 \text{ BTU/HR-}^{\circ}F$$

$$\Delta T = \frac{Q}{UA} = \frac{2.21 \times 10^4 \text{ BTU/HR}}{191.5 \text{ BTU/HR-}^{\circ}F} = 115^{\circ}F \quad \text{FILM TEMP DROP}$$

8/14/80  
6 OF 6

PIPE TEMP AT AVE POINT =  $822 - 115 = 707^{\circ}\text{F}$

PIPE TEMP AT INTERFACE  $\text{\textcircled{60}}$  LOCATION =  $774 - 115^{\circ}\text{F} = 659^{\circ}\text{F}$

7/7/80  
1 OF 11

DAN

HERE IS THE INFORMATION YOU REQUESTED  
FOR THE AEROSPACE PLANT PERFORMANCE  
COMPUTER PROGRAM. IT COVERS ALL OF THE  
PARAMETERS YOU MENTIONED ON THE PHONE.  
MOST OF THESE WERE FAIRLY OBVIOUS WITH  
THE EXCEPTION OF ITEM No 5 "ENERGY  
STORAGE SYSTEM STARTUP REQUIREMENT".  
IF YOU HAVE QUESTIONS, GIVE ME A CALL.

John Raetz

7/5/80  
2 OF 11

INPUTS FOR AEROSPACE PILOT PLANT PERFORMANCE

COMPUTER PROGRAM

1. TOTAL HELIOSTAT REFLECTOR AREA

$(430 \text{ FT}^2)(1818)(1 - .0123) = 772125 \text{ FT}^2$

1.23% AREA LOSS  
DUE TO EDGE SEALS

2. RADIATION AND CONVECTION LOSS

4.7 MW<sub>E</sub>

ASSUMPTIONS :

- 1. AMBIENT TEMP = 55°F
  - 2. WIND SPEED = 8.5 mph
- } AVERAGE WINTER CONDITION

3. MAIN STEAM DOWNCOMER PIPE

- $L \approx 478 \text{ FT}$  (LENGTH FROM RECEIVER MANIFOLD TO TURBINE INLET)

- $OD = 6.625 \text{ IN}$   $ID = 4.897 \text{ IN}$   
(6 IN DOUBLE EXTRA STRONG PIPE)

- THERMAL LOSS  
 $0.1 \text{ MW}_E$

7/5/80  
3 CF 11

• PUMPING POWER

(SEE FIGURE 1)

4. ADMISSION STEAM PIPING

- |           |
|-----------|
| 155.87 FT |
| 129.86 FT |

 (TURBINE TO SUPERHEATER E-307)
- |           |
|-----------|
| 129.86 FT |
|-----------|

 (TURBINE TO SUPERHEATER E-308)

- |                                |
|--------------------------------|
| OD = 6.625 IN    ID = 5.761 IN |
|--------------------------------|

  
(6 IN SCH 40 PIPE)

- |                 |
|-----------------|
| LOSS = .015 MWL |
|-----------------|

NOTE : THE FOLLOWING DESIGN REVISION IS  
IN PROGRESS





FIG 1. RECEIVER FEED PUMP POWER REQUIREMENTS



7 OF 11

7/5/80  
50511

## 5. ENERGY STORAGE SYSTEM

- STARTUP REQUIREMENT

(NOT SURE WHAT THIS IS!)

ASSUME IT IS THERMAL STORAGE ENERGY  
REQUIRED TO START THE TURBINE FROM  
ADMISSION STEAM

|                                    |
|------------------------------------|
| 15 MWH <sup>*</sup> (WARM TURBINE) |
| 7.2 MWH <sup>*</sup> (HOT TURBINE) |

\* ESTIMATED VALUES — NO ADMISSION  
STEAM STARTUP GUIDELINES AND PROCEDURE  
HAVE YET BEEN SUPPLIED BY GE.

- THERMAL LOSS

THERMAL STORAGE TANK

|                               |
|-------------------------------|
| 2% ENERGY LOSS PER 20 HR HOLD |
|-------------------------------|

CHARGING OIL LOOP

|  |
|--|
| 0.5% POWER LOSS DURING CHARGING<br>LOOP OPERATING PERIODS (APPLIES TO FULL LOAD) |
|--|

EXTRACTION OIL LOOP

|  |
|--|
| 0.5% POWER LOSS DURING EXTRACTION<br>LOOP OPERATING PERIODS (APPLIES TO FULL LOAD) |
|--|

### 6. EPG S

- TURBINE RATING  
(GENERATOR OUTPUT)

|                     |
|---------------------|
| 12.5 MWe            |
| 13.4 MWe MAX OUTPUT |

- MINIMUM OPERATING POWER

|                        |
|------------------------|
| 2 MWe GENERATOR OUTPUT |
|------------------------|

(ESTIMATED VALUE FOR CONTINUOUS DUTY)

- GROSS CYCLE EFFICIENCY

|        |
|--------|
| 35.19% |
|--------|

@ 12.5 MWe OUTPUT

RECEIVER STEAM ONLY  
(112,140 LB/HR)

|        |
|--------|
| 25.36% |
|--------|

@ 8.001 MWe OUTPUT

ADMISSION STEAM ONLY  
(105,000 LB/HR)

|        |
|--------|
| 30.48% |
|--------|

@ 10.358 MWe OUTPUT

RECEIVER + ADMISSION STEAM  
 57,500 LB/HR      RECEIVER STEAM  
 52,500 LB/HR      ADMISSION STEAM

REF: GE STEAM TURBINE PROPOSAL  
 (SCE TRANSMITAL LETTER 9/26/79)



- PARASITIC POWER ESTIMATE

SEE TABLE 1

NOTE : TABLE 1 INCLUDES THE RECEIVER FEED PUMP + ALL OTHER PARASITIC LOADS. BE SURE NOT TO DOUBLE COUNT THE FEED PUMP SINCE IT WAS ALREADY PRESENTED IN FIGURE 1.

PARASITIC LOAD ESTIMATES ARE FOR "FULL POWER" OPERATION WITHIN EACH OPERATING MODE. AT PART POWER, SOME EQUIPMENT MAY BE SHUT DOWN.

## 7. COLLECTOR FIELD / RECEIVER

- COSINE  
(SEE TABLE 2)
- BLOCKING AND SHADOWING  
(SEE TABLE 3)

PLANT PARATIC LOAD ESTIMATE (KW) 1/29/79

TABLE 1

|  | <u>MODE</u> |          |          |          |          |          |          |          |
|--|-------------|----------|----------|----------|----------|----------|----------|----------|
|  | <u>1</u>    | <u>2</u> | <u>3</u> | <u>4</u> | <u>5</u> | <u>6</u> | <u>7</u> | <u>8</u> |
| COLLECTOR SYSTEM*                                      | 54          | 54       | 54       | 54       | 54       | —        | 54       | —        |
| MCC "A" & MCC "L"                                      |             |          |          |          |          |          |          |          |
| SCE ROTATING EQUIP.                                    | 1097        | 1097     | 1220     | 1220     | 1097     | 630      | 1220     | 139      |
| SF DI, CONTROL, DAS & EQUIP. ROOMS                     | 40          | 40       | 40       | 40       | 40       | 40       | 40       | 40       |
| WAREHOUSE †  | 22          | 22       | 22       | 22       | 22       | 22       | 22       | 2.8      |
| SCE CONTROL BLDG, AUX BAY }<br>A/C, LIGHTING, OTHER. } | 100         | 100      | 100      | 100      | 100      | 100      | 100      | 100      |
| SCE ADMINIST. BLDG                                     | 90          | 90       | 90       | 90       | 90       | 90       | 90       | 30       |
| <sup>398</sup> MCC "B" (TSS)                           | 13          | 337      | 337      | 661      | 337      | 337      | 661      | 38.3     |
| MCC "C" (WATER TR.)                                    | 149.7       | 149.7    | 149.7    | 149.7    | 149.7    | 149.7    | 149.7    | 185.0    |
| PPA (RECSIVER)   | 25.6        | 25.6     | 25.6     | 25.6     | 25.6     | 20.0     | 25.6     | 44.0     |
| OTHER**  | 100         | 100      | 100      | 100      | 100      | 60       | 100      | 50       |
| TOTALS   | 1691        | 2015     | 2138     | 2462     | 2015     | 1449     | 2462     | 529      |

\* MDAC FIELD @ .85 P.F. (AVE)  
 OR MMC FIELD @ .92 P.F.

\*\* THIS INCLUDES: (SPECIAL DAS INST (TBO), BCS, WEATHER STATION, I FORGOT 5.6 KW  
 AS SUMMER LOAD ESTIMATE. NA UNITARY BEE HOUSE. MODE CO

8 OF 11

TABLE 2. COLLECTOR FIELD COSINE

APPROX CALENDAR DAY

ANNUAL SUMMARY OF COSINES, UNIVERSITY OF HOUSTON

| U                  | HOUR =*   | 0.     | 1.05   | 2.09   | 3.14   | 4.18   | 5.23   | 6.28   |
|--------------------|-----------|--------|--------|--------|--------|--------|--------|--------|
| (JUNE 21)          | DAY = 93  | 0.8400 | 0.8339 | 0.8158 | 0.7865 | 0.7471 | 0.6996 | 0.6466 |
| (MAY 21 / JULY 21) | DAY = 124 | 0.8429 | 0.8370 | 0.8195 | 0.7910 | 0.7526 | 0.7061 | 0.6538 |
| (APR 21 / AUG 21)  | DAY = 155 | 0.8477 | 0.8424 | 0.8264 | 0.8004 | 0.7652 | 0.7220 | 0.6727 |
| (MAR 21 / SEPT 21) | DAY = 186 | 0.8484 | 0.8439 | 0.8305 | 0.8085 | 0.7785 | 0.7415 | 0.6987 |
| (FEB 21 / OCT 21)  | DAY = 216 | 0.8427 | 0.8392 | 0.8287 | 0.8115 | 0.7879 | 0.7585 | 0.7241 |
| (JAN 21 / NOV 21)  | DAY = 246 | 0.8343 | 0.8316 | 0.8236 | 0.8105 | 0.7925 | 0.7699 | 0.7431 |
| (DEC 21)           | DAY = 276 | 0.8303 | 0.8279 | 0.8209 | 0.8094 | 0.7936 | 0.7737 | 0.7500 |

TABLE 3. COLLECTOR FIELD BLOCKING AND SHADOWING

| U         | HOUR * | 0.     | 1.05   | 2.09   | 3.14   | 4.18   | 5.23   | 6.28   |
|-----------|--------|--------|--------|--------|--------|--------|--------|--------|
| DAY = 93  |        | 0.9909 | 0.9852 | 0.9822 | 0.9885 | 0.9849 | 0.9174 | 0.7507 |
| DAY = 124 |        | 0.9874 | 0.9843 | 0.9827 | 0.9887 | 0.9836 | 0.9135 | 0.7498 |
| DAY = 155 |        | 0.9836 | 0.9832 | 0.9852 | 0.9904 | 0.9816 | 0.9054 | 0.7418 |
| DAY = 186 |        | 0.9864 | 0.9867 | 0.9893 | 0.9912 | 0.9695 | 0.8879 | 0.7321 |
| DAY = 216 |        | 0.9912 | 0.9917 | 0.9912 | 0.9811 | 0.9460 | 0.8607 | 0.7208 |
| DAY = 246 |        | 0.9831 | 0.9825 | 0.9733 | 0.9554 | 0.9075 | 0.8226 | 0.7203 |
| DAY = 276 |        | 0.9717 | 0.9703 | 0.9602 | 0.9385 | 0.8898 | 0.8114 | 0.7201 |

\* "HOURS" MEASURED FROM NOON (SYMMETRIC MORNING AND AFTERNOON)

7/5/80  
10 OF 11

- RECEIVER SHADOW

$0.67\%$  OF HELIOSTAT AREA SHADOWED  
BY RECEIVER AND TOWER  
(ANNUAL AVERAGE VALUE, MIDDAY FROM  
EQUINOX THRU SUMMER, THE RECEIVER  
SHADOW FACTOR = 0)

- EDGE LOSSES

$0.$  (NO EDGE LOSS)

WOULD BE NON ZERO ONLY FOR SINGLE  
AXIS TRACKING COLLECTORS SUCH AS  
PARABOLIC CYLINDERS

- HELIOSTAT REFLECTIVITY

$0.89$  CLEAN

- ATMOSPHERIC LOSS FRACTION

$3\%$  ANNUAL AVERAGE LOSS

- RECEIVER INTERCEPTION FACTOR

$0.976$  (FRACTION OF REDIRECTED SUN LIGHT  
ACTUALLY STRIKING THE RECEIVER)

• SECONDARY CONCENTRATOR EFFICIENCY

100 % (NO SECONDARY CONCENTRATOR)

8. RECEIVER SURFACE

• TRANSMISSIVITY

100 % (NO TRANSPARENT COVER OVER RECEIVER)

• ABSORPTIVITY

95 % (PYROMARK ABSORPTIVE COATING)

1/14/80  
10F14

PLACEMENT OF MAIN STEAM PRESSURE CONTROL POINT

OBJECTIVE : DEFINE THE PROPER LOCATION FOR THE MAIN STEAM PRESSURE CONTROL POINT SUCH THAT  $\geq 1465$  psia CAN BE MAINTAINED AT THE INLETS TO THE TURBINE AND THERMAL STORAGE CHARGING CONTROL VALVE. ALSO DEFINE THE MAXIMUM PRESSURE TO BE EXPERIENCED AT THE TURBINE AND THERMAL STORAGE CHARGING INLET CONTROL VALVE DURING LOW FLOW CONDITIONS

CASES CONSIDERED :

- (i) PRESSURE CONTROL POINT IMMEDIATELY UPSTREAM OF THE TURBINE INLET
- (ii) PRESSURE CONTROL POINT IMMEDIATELY UPSTREAM OF THE THERMAL STORAGE CHARGING INLET VALVE (UV-3102)
- (iii)\* PRESSURE CONTROL POINT AT SPLIT POINT WHERE TURBINE, THERMAL STORAGE CHARGE, AND STEAM DUMP FLOWS SEPARATE  
(140 FT UPSTREAM OF TURBINE)  
(160 FT UPSTREAM OF TS CHARGING CONTROL VALVE)

\* SELECTED DESIGN APPROACH

STEAM PIPING CALC

1/14/80

2 OF 14

1. SPLIT TO TURBINE INLET

| LOCATION | LENGTH   | BEND    |
|----------|----------|---------|
| 175      |          | B (45°) |
| 180      | 10.88 FT |         |
| 182      | 1.77 FT  | B (45°) |
| 185      | 11.20 FT | B (90°) |
| 190      | 9.56 FT  | B (90°) |
| 195      | 3.00 FT  |         |
| 205      | 2.00 FT  |         |
| 210      | 2.00 FT  |         |
| 215      | 4.00 FT  |         |
| 220      | 19.00 FT |         |
| 235      |          | B (90°) |
| 240      | 14.42 FT |         |
| 250      | 7.00 FT  | B (90°) |
| 255      | 4.50 FT  | B (90°) |
| 260      | 20.00 FT |         |
| 270      | 4.50 FT  | B (90°) |
| 285      | 8.00 FT  | B (90°) |
| 287      | 2.00 FT  |         |
| 295      | 12.00 FT |         |
|          | 4.00 FT  | B (90°) |

(MOY - MS - 2 - 2)

(MSSV)

SUMMARY SPLIT TO TURBINE

1/14/80  
3 OF 14

TOTAL LENGTH = 139.83 FT (4 FT FOR VALVES)

RT ANGLE BENDS = 8

45° ANGLE BENDS = 2

FROM PAGE 5 →  $\Delta P_{FR} = 17.82 \text{ PSI}$

$\Delta P_K = 22.68 \text{ PSI}$

$\Delta P_{TOTAL} = 40.50 \text{ PSI}$

(@ ~ 950° F 1465 psia (1500 psia))

$\bar{V} = .515 \text{ FT}^3/\text{LB}$

$\dot{W} = 115,000 \text{ LB/HR}$



1/14/80  
4 OF 14

2. SPLIT TO THERMAL STORAGE CHARGE CONTROL VALVE

| LOCATION                     | LENGTH                  | BEND    |
|------------------------------|-------------------------|---------|
| 175                          | 1.5                     | B (45°) |
| 200                          | 6.21                    | B (45°) |
| 205                          | 14.36                   | B (90°) |
| 210                          | 9.56                    | B (90°) |
| 215                          | 3.00                    |         |
| 220                          |                         |         |
| 315                          | <del>2.00</del><br>2.00 |         |
| 320                          | 2.00                    |         |
| 325                          | 23.00                   |         |
| <del>345</del>               |                         | B (90°) |
|                              | 14.42                   | B (90°) |
| 350                          | 7.00                    | B (90°) |
| 360                          | 39.92                   | B (90°) |
| 380                          | 3.06                    | B (90°) |
| 385                          | 20.00                   | B (90°) |
| 390                          | 10.89                   | B (90°) |
| 395                          | 4.00                    |         |
| 400 (1 FT PAST INTERFACE II) |                         |         |

MOV-MS-3-1

1/14/80  
5 OF 14

SUMMARY SPLIT TO TS CHARGE

TOTAL LENGTH = 160.92 FT (2 FT FOR VALVE MOV-MS-3-1)

RT ANGLE BENDS = 9

45° ANGLE BENDS = 2

DATA : ID = 4.897 IN

$$\Delta P_{FR (PIPE)} = \frac{(3.4 \times 10^{-6})(f)(L)(\dot{W})^2(\bar{V})}{D^5}$$

$$\Delta P_K = \frac{(2.8 \times 10^{-7})(\bar{V})(\dot{W})^2(K)}{D^4}$$

|          |  |   |
|----------|--|---|
| K FACTOR | $\frac{T_0 \text{ TURBINE}}{8 - RT \text{ ANG}}$ | $\frac{T_0 \text{ TS}}{9 - RT \text{ ANG}}$ |
|          | @ .75 = 6  | @ .75 = 6.75                                |
|          | 2 - 45° ANG                                      | 2 - 45° ANG                                 |
|          | @ .42 = .84                                      | @ .42 = .84                                 |
|          | (NEGLECT VALVE)                                  | (NEGLECT VALVE)                             |
|          | TOTAL = 6.84                                     | TOTAL = 7.59                                |

TURBINE LEG REF

$$\bar{V} = .515 \text{ FT}^3/\text{LB}$$

$$\Delta P = \Delta P_{FR} + \Delta P_K$$

$$f = .0155$$

$$\dot{W} = 115,000 \text{ LB/HR}$$

$$\Delta P_{FR} = \frac{(3.4 \times 10^{-6})(.0155)(139.83 \text{ FT})(115,000)^2(.515)}{(4.897)^5}$$

$$= \underline{17.82 \text{ PSIA}}$$

$$\Delta P_K = \frac{(2.8 \times 10^{-7})(.515)(115,000)^2(6.84)}{(4.897)^4}$$

$$= \underline{22.68 \text{ PSIA}}$$

$$\Delta P_{TOTAL} = 40.50 \text{ PSIA TOTAL}$$

$$\bar{K}_1 = \frac{(\Delta P_{TOTAL})}{\dot{W}^2 \bar{V}} = \frac{40.5 \text{ PSIA}}{(115,000)^2 (.515)} = 5.946 \times 10^{-9}$$

TS CHARGE LEG

$\bar{V} = .342 \text{ FT}^3/\text{LB}$     130,000 LB/HR

$$\Delta P_{FR} = \frac{(3.4 \times 10^{-6})(.0155)(160.92 \text{ ft})(130000)^2(.342)}{(4.897)^5}$$

$$= \underline{17.40 \text{ PSIA}}$$

$$\Delta P_K = \frac{(2.8 \times 10^{-7})(.342)(130,000)^2(7.59)}{(4.897)^4}$$

$\Delta P_K = \underline{21.36 \text{ PSIA}}$

$\Delta P_{TOTAL} = \underline{38.76 \text{ PSIA}}$

$$\bar{K}_2 = \frac{\Delta P_{TOT}}{\dot{W}^2 \bar{V}} = \frac{38.76 \text{ PSIA}}{(130,000)^2 (.342)} = 6.706 \times 10^{-9}$$

$P_{REF} = P_T + \bar{K}_1 \dot{W}_1^2 \bar{V}$       TURBINE LEG

$P_{REF} = P_{TS} + \bar{K}_2 \dot{W}_2^2 \bar{V}$       TS CHARGE LEG

$\bar{K}_1 = \text{RCL00}$

$\bar{K}_2 = \text{RCL01}$

$\bar{V} = \text{RCL02}$

$\dot{W}_1 = \text{RCL03}$

$\dot{W}_2 = \text{RCL04}$

$P_{CONTROL (TURB)} = \text{RCL05}$   
(1465 PSIA)

LBL  
A  
RCL  
0 0  
0 1  
\*  
RCL  
0 0 4  
3 2 4  
X<sup>2</sup>  
\*  
RCL  
0  
2

=  
+  
RCL  
0  
5  
=  
HLT → PR  
-  
RCL  
0 0  
1 0  
\*

RCL  
0 0 3  
4 2 3  
X<sup>2</sup>  
\*  
RCL  
0  
2  
=  
HLT → P<sub>TS</sub>

CONTROL P  
AT TS  
INLET

1/14/80  
8 OF 14

CONTROL AT TURBINE INLET (P=1465 psia)

| $\dot{W}_{TOT}$ | $\dot{W}_1$ | $\dot{W}_2$ | $P_R$     | $P_{TS}$  |
|-----------------|-------------|-------------|-----------|-----------|
| 135,000         | 115,000     | 20,000      | 1505 psia | 1504 psia |
|                 | 105,000     | 30,000      | 1498.7    | 1495.6    |
|                 | 85,000      | 50,000      | 1487.1    | 1478.5    |
|                 | 65,000      | 70,000      | 1477.9    | 1461.0    |
|                 | 45,000      | 90,000      | 1471.2    | 1443.2    |
|                 | 30,000      | 105,000     | 1467.7    | 1429.7    |
| 115,000         | 95,000      | 20,000      | 1492.6    | 1491.3    |
|                 | 85,000      | 30,000      | 1487.1    | 1484.0    |
|                 | 65,000      | 50,000      | 1477.9    | 1469.3    |
|                 | 45,000      | 70,000      | 1471.2    | 1454.3    |
|                 | 25,000      | 90,000      | 1466.9    | 1438.9    |
| 100,000         | 80,000      | 20,000      | 1484.6    | 1483.2    |
|                 | 70,000      | 30,000      | 1480.0    | 1476.9    |
|                 | 50,000      | 50,000      | 1472.7    | 1464.0    |
|                 | 30,000      | 70,000      | 1467.8    | 1450.8    |
| 80,000          | 60,000      | 20,000      | 1476.0    | 1474.6    |
|                 | 50,000      | 30,000      | 1472.7    | 1469.5    |
|                 | 30,000      | 50,000      | 1467.8    | 1459.1    |
| 36,800          | 5,000       | 31,800      | 1465.1    | 1461.6    |
|                 | 31,800      | 5,000       | 1468.1    | 1468.0    |
| 50,000          | 30,000      | 20,000      | 1467.8    | 1466.4    |
|                 | 20,000      | 30,000 410  | 1466.2    | 1463.1    |

1/14/80  
9 OF 14

| CONTROL         | AT THERMAL STORAGE | INLET       | (P=1465 psia) |             |
|-----------------|--------------------|-------------|---------------|-------------|
| $\dot{W}_{TOT}$ | $\dot{W}_1$        | $\dot{W}_2$ | PR            |             |
|                 |                    |             | $P_{TURB}$    |             |
| 135000          | 115000             | 20000       | 1466.4 psia   | 1425.9 psia |
|                 | 105,000            | 30000       | 1468.1        | 1434.3      |
|                 | 85,000             | 50,000      | 1473.6        | 1451.5      |
|                 | 65,000             | 70,000      | 1481.9        | 1468.9      |
|                 | 45000              | 90,000      | 1493.0        | 1486.8      |
|                 | 30,000             | 105,000     | 1503.1        | 1500.3      |
| 115,000         | 95000              | 20000       | 1466.4        | 1438.7 psia |
|                 | 85,000             | 30,000      | 1468.1        | 1446.0      |
|                 | 65,000             | 50,000      | 1473.6        | 1460.7      |
|                 | 45,000             | 70,000      | 1481.9        | 1475.7      |
|                 | 25,000             | 90,000      | 1492.9        | 1491.0      |
| 100,000         | 80000              | 20000       | 1466.4        | 1446.8      |
|                 | 70000              | 30000       | 1468.1        | 1453.1      |
|                 | 50000              | 50000       | 1473.6        | 1466.0      |
|                 | 30000              | 70000       | 1481.9        | 1479.2      |
| 80000           | 60000              | 20000       | 1466.4        | 1455.4      |
|                 | 50000              | 30000       | 1468.1        | 1460.5      |
|                 | 30000              | 50000       | 1473.6        | 1470.9      |
| 36800           | 5000               | 31800       | 1468.5        | 1468.4      |
|                 | 31800              | 5000        | 1465.1        | 1462.0      |
| 50000           | 30000              | 20000       | 1466.4        | 1463.6      |
|                 | 20000              | 30000       | 1468.1        | 1466.9      |

1/14/80  
10 OF 14

CONTROL PRESSURE AT STEAM SPLIT

( $P_{SPLIT} = 1505 \text{ psia}$ )

| LBL            | $\dot{W}_{TOT}$ | $\dot{W}_1$ | $\dot{W}_2$ | $P_{TURB}$  | $P_{TS}$    |
|----------------|-----------------|-------------|-------------|-------------|-------------|
| B              |                 |             |             |             |             |
| RCL } SPLIT    | 135000          | 115000      | 20000       | 1464.5 psia | 1503.6 psia |
| 0 } CONTROL    |                 |             |             |             |             |
| 5 } PRESS      |                 | 105,000     | 30,000      | 1471.2      | 1501.9 psia |
| -              |                 |             |             |             |             |
| RCL            |                 | 85,000      | 50,000      | 1482.9      | 1496.4      |
| 0              |                 |             |             |             |             |
| 0              |                 | 65,000      | 70,000      | 1492.1      | 1488.1      |
| *              |                 |             |             |             |             |
| RCL            |                 | 45,000      | 90,000      | 1498.7      | 1477.0      |
| 0              |                 |             |             |             |             |
| 3              |                 | 30000       | 105,000     | 1502.2      | 1466.9      |
| X <sup>2</sup> |                 |             |             |             |             |
| *              |                 |             |             |             |             |
| RCL            | 115000          | 95000       | 20000       | 1477.4      | 1503.6      |
| 0              |                 |             |             |             |             |
| 2              |                 | 85000       | 30000       | 1482.8      | 1501.9      |
| =              |                 |             |             |             |             |
| HLT $P_{TURB}$ |                 | 65000       | 50000       | 1492.1      | 1496.4      |
| RCL            |                 | 45000       | 70000       | 1498.8      | 1488.1      |
| 0              |                 |             |             |             |             |
| 5              |                 | 25000       | 90000       | 1503.1      | 1477.0      |
| -              |                 |             |             |             |             |
| RCL            |                 |             |             |             |             |
| 0              | 100000          | 80000       | 20000       | 1485.4      | 1503.6      |
| 1              |                 |             |             |             |             |
| *              |                 | 70000       | 30000       | 1490.0      | 1501.9      |
| RCL            |                 | 50000       | 50000       | 1497.3      | 1496.4      |
| 0              |                 |             |             |             |             |
| 4              |                 | 30000       | 70000       | 1502.2      | 1488.1      |
| X <sup>2</sup> |                 |             |             |             |             |
| *              |                 |             |             |             |             |
| RCL            | 80000           | 60000       | 20000       | 1494.0      | 1503.6      |
| 0              |                 |             |             |             |             |
| 2              |                 | 50000       | 30000       | 1497.3      | 1501.9      |
| =              |                 |             |             |             |             |
| HLT $P_{TS}$   |                 | 30000       | 50000       | 1502.2      | 1496.4      |
|                | 36,800          | 5000        | 31800       | 1504.9      | 1501.5      |
|                |                 | 31800       | 5000        | 1501.9      | 1504.9      |
|                | 50,000          | 30000       | 20000       | 1502.2      | 1503.6      |
|                |                 | 20000       | 30000       | 1503.8      | 1501.9      |


CONTROL PRESSURE AT SPLIT (SLIDING PRESSURE CONTROL)

| $\dot{W}_{TOT}$     | $\dot{W}_1$ | $\dot{W}_2$ | $P_{TURB}$        | $P_{TS}$ |
|---------------------|-------------|-------------|-------------------|----------|
| 135000<br>(P=1505)  |             |             | (SEE DATA PAGE 9) |          |
| 115000<br>(P=1495)  | 95000       | 20000       | 1467              | 1493.6   |
|                     | 85000       | 30000       | 1472.9            | 1491.9   |
|                     | 65000       | 50000       | 1482.             | 1486.4   |
|                     | 45000       | 70000       | 1488.7            | 1478.1   |
|                     | 25000       | 90000       | 1493.1            | 1467.0   |
| 100,000<br>(P=1485) | 80000       | 20000       | 1465.4            | 1483.6   |
|                     | 70000       | 30000       | 1470.             | 1481.9   |
|                     | 50000       | 50000       | 1477.3            | 1476.4   |
|                     | 30000       | 70000       | 1482.2            | 1468.1   |
| 80000<br>(P=1476)   | 60000       | 20000       | 1465.0            | 1474.6   |
|                     | 50000       | 30000       | 1468.3            | 1472.9   |
|                     | 30000       | 50000       | 1473.2            | 1467.4   |
| 36800<br>(P=1469)   | 5000        | 31800       | 1468.9            | 1465.5   |
|                     | 31800       | 5000        | 1465.9            | 1468.9   |
| 50000<br>(P=1470)   | 30000       | 20000       | 1467.2            | 1468.6   |
|                     | 20000       | 30000       | 1468.8            | 1466.9   |



K.S. KENNEL & FRENCH CO. MANUFACTURERS  
10 X 10 TO THE CENTIMETER 19 1/2 X 20 CM

40 1211



ΔP CALCULATION SPECIFIC POINT TO T5 INLET

130,000 LB/HR DERATED STEAM

$$Q = 2.985 \text{ LB/FT}^2$$

6" X X S

$$A = 1306 \text{ FT}^2$$

$$Q = Q A V \rightarrow V = \frac{Q}{Q A} = \frac{130,000}{(2.985)(1306)} (36)$$

$$V = 92.5 \text{ FT/SEC MEAN}$$

$$Q = 130,000 \text{ LB/HR}$$

$$\Delta P = f \frac{L}{D} \frac{V^2}{2g} \rho \quad K \frac{V^2}{2}$$


$\underbrace{\hspace{10em}}$   
LINE
 $\underbrace{\hspace{10em}}$   
FITTINGS

SEE PAGE 6 FOR ΔP DERATED STEAM

$$\Delta P = 38.76 \left( \frac{W}{130,000} \right)^2$$

| W       | ΔP    | P            |
|---------|-------|--------------|
| 130,000 | 38.76 | 1466.47 psia |
| 100,000 | 22.93 | 1482.0       |
| 75,000  | 12.90 | 1492.1       |
| 50,000  | 5.73  | 1497.3       |
| 25,000  | 1.43  | 1503.6       |

14 OF 14



• DERATED STEAM

• INTERGAS 11" UPSTREAM

• OF CONTROL VALVE UV-3192

Thermal Storage Charging Inlet Pressure

JER  
6/10/80

PILOT PLANT ANNUAL ENERGY ESTIMATES

OBJECTIVE : DEVELOP ESTIMATES OF ELECTRICAL ENERGY PRODUCTION FOR SELECTED DAYS AND ON AN ANNUAL BASIS. ESTIMATE STATUS OF THERMAL STORAGE CHARGE AFTER COLLECTOR FIELD OPERATION ON TYPICAL DAYS.

## DAILY OPERATING SCENARIO

- STORE MORNING RAMP UNTIL A CAPABILITY TO PRODUCE 10 MWe EXISTS
- STORE AFTERNOON DOWN RAMP WHEN POWER OUTPUT FALLS BELOW 10 MWe
- STORE DAILY EXCESS ABOVE THAT REQUIRED TO PRODUCE 10 MWe
- OPERATE THE TURBINE AT 10 MWe FROM RECEIVER STEAM WHEN AVAILABLE POWER EXCEEDS THE 10 MWe DEMAND RATE
- POWER THE TURBINE FROM ADMISSION STEAM DURING ALL OTHER PERIODS

9/22/79  
2 OF 6

FIELD  
POWER  
INTEGRATION

WINTER DAY

THERMAL POWER  
10° ≤ E<sub>L</sub>  
(MWH)

|                              |   |           |                         |
|------------------------------|---|-----------|-------------------------|
| 48                           | } | 17        | 10AM - 2PM<br>153.3 MWH |
|                              |   | 31        |                         |
|                              |   | 37.2      |                         |
|                              |   | 39.5      |                         |
|                              |   | 39.4      |                         |
| 47.1<br>-----<br>95.1<br>MWH | } | 30.7      | Δ = 15.7 MWH            |
|                              |   | 16.4      |                         |
|                              |   | 248.4 MWH |                         |

34.4 MW x 4 HR = 137.6 MWH

SCENARIO

|                                |   |           |
|--------------------------------|---|-----------|
| RUN @ 10MWe NET<br>FOR 4 HOURS | — | 137.6 MWH |
| STORE EXCESS                   | — | 15.7 MWH  |
| STORE MORNING 2 < 10AM         | — | 48 MWH    |
| STORE AFTERNOON 2 > 2PM        | — | 47.1 MWH  |
| Σ STORED ENERGY =              |   | 110.8 MWH |

$\eta_{gross} = .245$  @ 7.8 MWe

$\eta_{net} = .219$  @ 7.0 MWe net

$P_{THERM} = 32$  MWE

TURBINE STARTUP PENALTY ~ 8 MWH

NET STORED ENERGY 102.8 MWH  
Hours = 3.21 HRS

x .95  
= 3.0

SCENARIO

|               |          |
|---------------|----------|
| STORE MORNING | 48 MWH   |
| STORE EXCESS  | 15.7 MWH |
|               | 63.7 MWH |

SUPPLEMENT MODE 3 (10-7 AFTER 2PM) (16.5 MW)  
STARTUP PENALTY (8)

NET 39.2 MWH  
HOURS @ 7 MW = 1.2 HRS

STOP COLLECTION  
AT 3.85 PM

9/22/79  
3 OF 6

FIELD  
POWER  
INTEGRATION

SUMMER DAY

THERMAL POWER  
10° ≤ EL  
(MWH<sub>E</sub>)

59.2 MWH {  
3.25  
21.2  
34.7

{  
33.0  
40  
41.8  
42.3  
42.1  
41.3  
39.7  
36.5

55.9 MWH {  
31.5  
21.4  
3

431.8 MWH<sub>E</sub>

34.4 x 7.85 = 270 MWH<sub>E</sub>

316.7 MWH<sub>E</sub>

Δ = 46.7 MWH<sub>E</sub>

SCENARIO

|                                  |   |                       |
|----------------------------------|---|-----------------------|
| RUN @ 10 MWE NET<br>FOR 7.85 HRS | — | 270 MWH <sub>E</sub>  |
| STORE EXCESS                     | — | 46.7 MWH              |
| STORE MORNING τ < 8 AM           | — | 59.2 MWH <sub>E</sub> |
| STORE EVENING τ > 4 PM           | — | 55.9 MWH <sub>E</sub> |

Σ STORED ENERGY = 161.8 MWH<sub>E</sub>

$\tau_{net} = \frac{10}{34.4} = .291$

TURBINE STARTUP PENALTY ~ 8 MWH<sub>E</sub>

NET STORED ENERGY = 153.8 MWH<sub>E</sub>  
HOURS = 4.8 HRS x .95 = 4.6

SCENARIO

|  |   |            |
|--|---|------------|
| STORE MORNING                          | — | 59.2 MWH   |
| STORE EXCESS                           | — | 46.7 MWH   |
|  |   | 105.9 MWH  |
| SUPPLEMENT (MODE 3)<br>10-7 AFTER 4 PM |   | (21.5 MWH) |
| STARTUP PENALTY                        |   | ( 8 )      |

STOP COLLECTION  
AT 6.28 HRS

NET 79.4 MWH  
HOURS @ 7 MWE 2.5 HRS


9/22/79  
HOF

| TIME   | EQUINOX<br>(72 MW) $\left(\frac{G_{00N}}{G_{00O}}\right) \left(\frac{I_{NEW}}{I_{OLD}}\right) \left(\frac{B_{TS\ NEW}}{B_{TS\ OLD}}\right) =$ | INCID<br>MWE | ABSORB<br>(I*93-4,8)<br>MWE |
|--------|---|--------------|-----------------------------|
| - 5.17 | 42.04 $\left(\frac{.6938}{.792}\right) \left(\frac{.621}{.917}\right) \left(\frac{.7113}{.898}\right)$  | 19.75        | 13.57                       |
| - 4.31 | 42.04 $\left(\frac{.7346}{.792}\right) \left(\frac{.783}{.917}\right) \left(\frac{.8842}{.898}\right)$  | 32.78        | 25.69                       |
| - 3.45 | 42.04 $\left(\frac{.7699}{.792}\right) \left(\frac{.825}{.917}\right) \left(\frac{.971}{.898}\right)$   | 42.17        | 34.41                       |
| - 2.59 | 42.04 $\left(\frac{.7984}{.792}\right) \left(\frac{.926}{.917}\right) \left(\frac{.988}{.898}\right)$   | 47.08        | 38.99                       |
| - 1.72 | 42.04 $\left(\frac{.8194}{.792}\right) \left(\frac{.954}{.917}\right) \left(\frac{.9865}{.898}\right)$  | 49.71        | 41.43                       |
| - 0.86 | 42.04 $\left(\frac{.8258}{.792}\right) \left(\frac{.971}{.917}\right) \left(\frac{.9836}{.898}\right)$  | 50.84        | 42.48                       |
| Noon   | 42.04 $\left(\frac{.8365}{.792}\right) \left(\frac{.973}{.917}\right) \left(\frac{.9823}{.898}\right)$  | 51.54        | 43.13                       |
| 0.86   |   | 50.84        | 42.48                       |
| 1.72   |   | 49.71        | 41.43                       |
| 2.59   |   | 47.08        | 38.99                       |
| 3.45   |   | 42.17        | 34.41                       |
| 4.31   |   | 32.78        | 25.69                       |
| 5.17   | (---)   | 19.75        | 13.57                       |

SYMMETRIC

EQUINOX (SYMMETRIC ABOUT NOON)

(COUNTING FROM NOON)



RUN PLANT  
10MW FOR  
6.9 HRS - 237 MWHZ

STORE EXCESS - 45.2 MWHZ

STOR MORNING - 44.9 MWHZ

STOR EVENING - 44.9 MWHZ

Σ STORED ENERGY = 135 MWH  
- 8 MWHZ TURBINE STARTUP

NET STORED ENERGY = 127 MWH  
HRS = 3.97



### ANNUAL SUMMARY

|         | HOURS 10 MW | HOURS 7 MW |
|---------|-------------|------------|
| SUMMER  | 7.8         | 4.8        |
| EQUINOX | 6.9         | 4.0        |
| WINTER  | 4           | 3.2        |

$$\frac{S + 2E + W}{4}$$

$$\frac{7.8 + 2(6.9) + 4}{4}$$

$$= 6.4 \text{ HRS}$$

$$\frac{4.8 + 2(4) + 3.2}{4}$$

$$= 4 \text{ HRS}$$

3.6 EQUIVALENT

\*.95 REDUCTION FOR

OTHER PARASITIC  
STEAM REQUIREMENTS

RESULT ANNUAL VALUE  
 6.4 HR @ 10 MWe  
 3.8 HR @ 7 MWe

MEMORANDUM

Subject: OFF DESIGN TURBINE STEAM CONDITIONS

To: R. G. Riedesel and J. E. Raetz

From: S. J. Scotti

Copies to: G. C. Coleman, P. I. Kawano, M. H. Lobell, D. W. Pearson  
J. E. Riel, W. P. Olson

This memorandum documents a modification of the "MDAC Solar Thermal Heat and Mass Balance Program" to analyze the 10 MW Solar Pilot Plant for cases in which the thermodynamic states at the turbine throttle valve and admission port are not the nominal design states. Also, data is presented to indicate the dependence of output power on several of these "off design" steam conditions for various combinations of throttle and admission flow rate. Several general results follow:

- 1) Power output increases fairly linearly with temperature (either throttle or admission).
- 2) Pressure variations have a minor effect on output power.
- 3) Throttle temperature has the greatest effect on output power with a coefficient of about .116 watt/°F-lbm.
- 4) Admission temperature has a lesser effect on output power with a .099 watt/°F-lbm coefficient.

A description of the program modifications and the case summary data sheets are included in an attachment to this memorandum.

*S. J. Scotti*

S. J. Scotti

Modification of Program for "Off Design" Steam Conditions

The Heat and Mass Balance program has been modified by adding a block of code which corrects the turbine expansion line end point for "off design" steam conditions at the throttle and admission ports. Both high and low pressure section end points are corrected. Also, a density dependent correction is applied to the windage loss term that is present when operating with admission flow only. The details of the modifications are treated in General Electric communication LTSD4159C-14, "Approximate Performance Corrections for Variant Steam Conditions".

Results of "Off Design" Cases

Tables 1 to 4 list output power as a function of flow rates for "off design" throttle temperature, throttle pressure, admission temperature, admission pressure, respectively. Included in these tables are the nominal output power and the output power for steam conditions below and above nominal conditions.

In summary, the temperature dependence of the output power (in watts) can be approximately expressed as the linear combination.

$$DPT = WTHR (TTHR-950.0) .116 \\ + WADM (TADM-525.0) .099$$

where the throttle and admission flow rates (WTHR and WADM) are in lbm/hr, and the throttle and admission temperatures (TTHR and TADM) are in °F. Table 5 gives an indication of the accuracy of this expression.

The pressure dependences are smaller but more difficult to model. For a throttle pressure varying  $\pm 100$  psi from nominal, the output power varies less than  $+ .03$  MW with the lower pressures giving the higher output power. For an admission pressure varying  $\pm 50$  psi from nominal, the output power varies less than  $+ .09$  MW with lower pressures giving higher output power only when the total flowrate (admission plus throttle) was less than about 100000 lbm/hr.

The three cases listed in Table 1 for throttle flow only are plotted in Figure 1. These curves give an illustration of the magnitude of the change in output power that can result from "off design" temperatures.

TABLE 1

VARIATION OF OUTPUT POWER WITH "OFF-DESIGN" THROTTLE TEMPERATURE

| <u>WTHR(1b/hr)</u> | <u>WADM(1b/hr)</u> | <u>P-(MWe)</u> | <u>P(MWe)</u> | <u>P+(MWe)</u> |
|--------------------|--------------------|----------------|---------------|----------------|
| 114635             | 0                  | 11.21          | 12.52         | 13.82          |
| 102000             | 0                  | 9.99           | 11.18         | 12.35          |
| 90000              | 0                  | 8.81           | 9.87          | 10.89          |
| 60000              | 0                  | 5.58           | 6.31          | 7.01           |
| 30000              | 0                  | 2.32           | 2.69          | 3.04           |
| 90000              | 5000               | 9.19           | 10.21         | 11.25          |
| 90000              | 15000              | 9.90           | 10.95         | 11.98          |
| 90000              | 25000              | 10.64          | 11.67         | 12.71          |
| 60000              | 5000               | 6.18           | 6.90          | 7.61           |
| 60000              | 20000              | -              | 7.96          | 8.68           |
| 60000              | 40000              | 8.79           | 9.50          | 10.20          |
| 60000              | 54000              | 9.85           | 10.54         | 11.24          |
| 30000              | 5000               | 2.78           | 3.16          | 3.51           |
| 30000              | 20000              | 4.09           | 4.45          | 4.82           |
| 30000              | 40000              | 5.84           | 6.21          | 6.56           |
| 30000              | 60000              | -              | 7.68          | 8.03           |
| 30000              | 85000              | 9.27           | 9.63          | 9.97           |

Notes:

- 1) P Computed for design conditions  
 Throttle Temperature = 950°F  
 Throttle Pressure = 1465 psia  
 Admission Temperature = 525°F  
 Admission Pressure = 384.7 psia
- 2) P- Computed for same conditions as 1)  
 except Throttle Temperature = 850°F
- 3) P+ Computed for same conditions as 1)  
 except Throttle Temperature = 1050°F

TABLE 2

VARIATION OF OUTPUT POWER WITH "OFF-DESIGN" THROTTLE PRESSURE

| <u>WTHR(1b/hr)</u> | <u>WADM(1b/hr)</u> | <u>P-(MWe)</u> | <u>P(MWe)</u> | <u>P+(MWe)</u> |
|--------------------|--------------------|----------------|---------------|----------------|
| 114635             | 0                  | 12.52          | 12.52         | 12.51          |
| 102000             | 0                  | 11.19          | 11.18         | 11.16          |
| 90000              | 0                  | 9.90           | 9.87          | 9.84           |
| 60000              | 0                  | 6.34           | 6.31          | 6.28           |
| 30000              | 0                  | 2.71           | 2.69          | 2.67           |
| 90000              | 5000               | 10.23          | 10.21         | 10.18          |
| 90000              | 15000              | 10.96          | 10.95         | 10.92          |
| 90000              | 25000              | 11.69          | 11.67         | 11.64          |
| 60000              | 5000               | 6.92           | 6.90          | 6.87           |
| 60000              | 20000              | -              | 7.96          | -              |
| 60000              | 40000              | 9.52           | 9.50          | 9.48           |
| 60000              | 54000              | 10.55          | 10.54         | 10.52          |
| 30000              | 5000               | 3.18           | 3.16          | 3.14           |
| 30000              | 20000              | 4.47           | 4.45          | 4.43           |
| 30000              | 40000              | 6.22           | 6.21          | 6.19           |
| 30000              | 60000              | 7.69           | 7.68          | 7.66           |
| 30000              | 85000              | 9.65           | 9.63          | 9.62           |

Notes:

- 1) P Computed for design conditions
- 2) P- Computed for same conditions as 1)  
except Throttle Pressure = 1365 psia
- 3) P+ Computed for same conditions as 1)  
except Throttle Pressure = 1565 psia

TABLE 3

VARIATION OF OUTPUT POWER WITH "OFF-DESIGN" ADMISSION TEMPERATURE

| <u>WTHR(1b/hr)</u> | <u>WADM(1b/hr)</u> | <u>P-(MWe)</u> | <u>P(MWe)</u> | <u>P+(MWe)</u> |
|--------------------|--------------------|----------------|---------------|----------------|
| 0                  | 30000              | 1.47           | 1.62          | 1.76           |
| 0                  | 45000              | 2.75           | 2.99          | 3.20           |
| 0                  | 60000              | 4.03           | 4.36          | 4.65           |
| 0                  | 90000              | -              | 6.74          | 7.19           |
| 0                  | 110000             | 7.84           | 8.39          | 8.90           |
| 90000              | 5000               | 10.18          | 10.21         | 10.23          |
| 90000              | 15000              | 10.87          | 10.95         | 11.01          |
| 90000              | 25000              | 11.54          | 11.67         | 11.79          |
| 60000              | 5000               | 6.90           | 6.90          | 6.95           |
| 60000              | 20000              | -              | 7.96          | -              |
| 60000              | 40000              | 9.31           | 9.50          | 9.69           |
| 60000              | 54000              | 10.30          | 10.54         | 10.80          |
| 30000              | 5000               | 3.14           | 3.16          | 3.19           |
| 30000              | 20000              | 4.38           | 4.45          | 4.57           |
| 30000              | 40000              | 6.04           | 6.21          | 6.42           |
| 30000              | 60000              | -              | 7.68          | 7.96           |
| 30000              | 85000              | 9.22           | 9.63          | 9.99           |

Notes:

- 1) P Computed for design conditions
- 2) P- Computed for same conditions as 1)  
except Admission Temperature = 475°F
- 3) P+ Computed for same conditions as 1)  
except Admission Temperature = 575°F

TABLE 4

VARIATION OF OUTPUT POWER WITH "OFF-DESIGN" ADMISSION PRESSURE

| <u>WTHR(1b/hr)</u> | <u>WADM(1b/hr)</u> | <u>P-(MWe)</u> | <u>P(MWe)</u> | <u>P+(MWe)</u> |
|--------------------|--------------------|----------------|---------------|----------------|
| 0                  | 30000              | 1.69           | 1.62          | 1.56           |
| 0                  | 45000              | 3.06           | 2.99          | 2.92           |
| 0                  | 60000              | 4.42           | 4.36          | 4.30           |
| 0                  | 90000              | 6.78           | 6.74          | 6.70           |
| 0                  | 110000             | 8.37           | 8.39          | 8.37           |
| 90000              | 5000               | 10.24          | 10.21         | 10.17          |
| 90000              | 15000              | 10.95          | 10.95         | 10.92          |
| 90000              | 25000              | 11.61          | 11.67         | 11.67          |
| 60000              | 5000               | 6.99           | 6.90          | 6.86           |
| 60000              | 20000              | -              | 7.96          | -              |
| 60000              | 40000              | 9.50           | 9.50          | 9.49           |
| 60000              | 54000              | 10.47          | 10.54         | 10.56          |
| 30000              | 5000               | 3.24           | 3.16          | 3.11           |
| 30000              | 20000              | 4.54           | 4.45          | 4.41           |
| 30000              | 40000              | 6.29           | 6.21          | 6.19           |
| 30000              | 60000              | 7.69           | 7.68          | 7.66           |
| 30000              | 85000              | 9.59           | 9.63          | 9.65           |

Notes:

- 1) P Computed for design conditions
- 2) P- Computed for same conditions as 1)  
except Admission Pressure = 334.7 psia
- 3) P+ Computed for same conditions as 1)  
except Admission Pressure = 434.7 psia

TABLE 5

CHECK CASES FOR EQUATION (1)


| <u>WTHR(1b/hr)</u> | <u>WADM(1b/hr)</u> | <u>DP<sub>TE</sub>(MWe)</u> | <u>DP<sub>T</sub>(MWe)</u> | <u>%ERROR</u> |
|--------------------|--------------------|-----------------------------|----------------------------|---------------|
| 90000              | 5000               | 1.06                        | 1.07                       | 0.9           |
| 90000              | 15000              | 1.10                        | 1.12                       | 1.8           |
| 90000              | 25000              | 1.16                        | 1.17                       | 0.9           |
| 60000              | 5000               | .76                         | .72                        | 5.3           |
| 60000              | 20000              | .82                         | .80                        | 2.5           |
| 60000              | 40000              | .89                         | .89                        | 0.0           |
| 60000              | 54000              | .97                         | .96                        | 1.0           |
| 30000              | 5000               | .38                         | .37                        | 2.6           |
| 30000              | 20000              | .49                         | .45                        | 8.2           |
| 30000              | 40000              | .57                         | .55                        | 3.5           |
| 30000              | 60000              | .63                         | .65                        | 3.2           |
| 30000              | 85000              | .72                         | .77                        | 6.9           |

Notes:

- 1) The off design conditions used were Throttle Temperature = 1050°F  
 Admission Temperature = 575°F  
 Pressures were design condition pressures
- 2) DP<sub>TE</sub> were computed "exactly" using the Heat and Mass Balance Program and are equal to off design output power minus design output power.
- 3) DP<sub>T</sub> were computed using equation (1)



Figure 1 -- OUTPUT POWER VS THROTTLE FLOW RATE



MEMORANDUM

Subject: SYSTEM BLANKETING AND SEALING STEAM REQUIREMENTS

To: R.G. Riedesel

From: J.E. Raetz

Copies to: G.C. Coleman, H.H. Eby, C.M. Finch, K.R. Knox, M.H. Lobe],  
R.J. Perkins

The blanketing and sealing steam requirements influence the design and component selection of both the thermal storage subsystem and the auxiliary electric boiler. The steam conditions which must be produced from either of these two sources must match the temperature, pressure (saturated steam), and flow-rate requirements as established by the conditioned components. These include (1) the receiver during subfreezing periods, (2) turbine steam seals during non operating periods, (3) the deaerator and high pressure feedwater heaters, and (4) other steam pipes, components, and heat exchangers located throughout the system.

The maximum blanketing steam pressure (and temperature) is established on the basis of heat exchanger blanketing requirements for the thermal storage heat exchangers (both charging and discharging). During non operating periods, it is desirable to maintain a high pressure on the water/steam side of the heat exchangers to minimize the potential for oil leakage into the feedwater circuit. Estimates carried out during the PDR indicated that pressure differentials of 2-3 atmospheres would be sufficient to minimize the potential for such leakage.

The PDR design assumed that this differential pressure would be provided on a nightly basis by a source of  $\text{GN}_2$ . An option which is recommended for the pilot plant design is to provide this pressure from the blanketing steam which would be available on an as required basis throughout the night. Since no  $\text{GN}_2$  would be introduced into the system, the daily problem of removing the  $\text{GN}_2$  by a combination of local venting and vacuum removal from the condenser would be eliminated. The  $\text{GN}_2$  pressurization option would still be used for prolong periods of shutdown when condenser vacuum is broken and the balance of the system is changed with  $\text{GN}_2$ .

The blanketing steam pressure requirement must be sufficient to provide the 2-3 atmosphere pressure differential over the Caloria side pressure which is set by the sum of the ullage and hydrostatic pressures in the thermal storage tank (TSU). Since a combined ullage and hydrostatic pressure of 30-35 psia is anticipated, a blanketing steam pressure of 75 psia is recommended.

The potential impact of using 75 psia blanketing steam pressure on other components was reviewed with Al McKenzie of Stearns Roger. Al indicated that the turbine seals and deaerator normally require 5 psig steam. Since these pressures are controlled by inlet pressure regulating stations, there is no problem operating with a 75 psia upstream inlet pressure. He pointed out that during startup, the blanketing and sealing steam pressure is supplied from the receiver or thermal storage at a substantially higher upstream pressure than the 75 psia value. Al also pointed out that no problem exists in matching an auxiliary electric boiler to the 75 psia steam condition. Other high pressure hardware (H.P. heaters, douncomers, etc.) will have no problem accepting the 75 psia blanketing steam since they normally experience higher pressure during operation. The 75 psia steam should also enhance system startup because of the higher component temperature maintained during nighttime periods in comparison to the level produced by the more conventional 5 psig blanketing steam.

The detailed blanketing steam generation process is shown in figure 1 (pinch point diagram). The figure shows the steam generation line and indicates the high temperature and low temperature (range of values) extremes for the Caloria. The exact low temperature condition must be defined by Rocketdyne during their detailed design since it will influence the location of the intermediate extraction manifold, the Caloria flowrate, and the minimum Caloria temperature which will subsequently enter the charging heat exchanger when charging operation first resumes.

Preliminary estimates of blanketing and sealing steam quantity requirements are contained in the following tabulation.

|  |                          |  |
|--|--------------------------|--|
| Receiver freeze protection                   | $2.3 \times 10^6$ BTU/HR | (1) $\times 8 \text{ HR} = 18.4 \times 10^6$   |
| Turbine seal steam                           | $1.0 \times 10^6$ BTU/HR | (2)  |
| Deaerator and HP heater                      | $15 \times 10^3$ BTU/HR  | (3) $\left. \begin{array}{l} \\ \\ \end{array} \right\} \times 16 = 17.04 \times 10^6$ |
| Other pipes, components, and heat exchangers | $50 \times 10^3$ BTU/HR  | (4)  |

35.44  $\times 10^6$  BTU

(3)

A3-228-JER-EP-249  
April 3, 1979


These values are currently being reevaluated to reflect the latest design and operating information. Due to the conservative assumptions regarding receiver freeze protection, the necessary thermal power shall be provided for an 8 hour period. The last three items in the tabulation shall be provided for an assumed 16 hour thermal conditioning period.

- (1) Scaled from PDR receiver—9°F ambient temp, 40 mph wind
- (2) PDR value (may be substantially less if other than GE turbine selected)
- (3) PDR value
- (4) Assumed value—currently being evaluated

*JE Raetz*

JE Raetz

FIG 1 PINCH POINT DIAGRAM FOR SEALING STEAM (THERMAL STORAGE STEAM GENERATOR)



# AUXILIARY BOILER

|                                 |            |   |                            |
|---------------------------------|------------|---|----------------------------|
| TURBINE SEALS                   | 1000 LB/HR | — | $1 \times 10^6$ BTU/HR     |
| HP HEATERS<br>(PDR)             | 10 LB/HR   | — | $10 \times 10^3$ BTU/HR    |
| DEAERATOR BLANKETING<br>(PDR)   | 15 LB/HR   | — | $15 \times 10^3$ BTU/HR    |
| OTHER PIPES AND COM-<br>PONENTS |            |   | $2 \times 10^5$ BTU/HR     |
| TOTAL                           |            |   | $1.225 \times 10^6$ BTU/HR |

$$\text{ELECTRIC POWER CAPACITY} = \frac{1.225 \times 10^6}{3.413 \times 10^6 (0.9)} = 399 \text{ KWe}$$





STMP0 201

Department of Energy  
San Francisco Operations Office  
1333 Broadway  
Oakland, California 94612

Reply To: DOE Solar One Project Office  
P.O. Box 366  
Daggett, CA 92327

Mr. Robert L. Gervais  
Solar One Project Office  
McDonnell Douglas Astronautics Corp.  
P.O. Box 366  
Daggett, CA 92327

**OCT 19 1984**

Subject: Contractor Clearance of Contract DE-AC03-79SF10499  
Solar One Reports for DOE/TIC Inclusion.

Dear Bob:

Enclosed are copies of covers and title pages of nine reports prepared by McDonnell Douglas Astronautics Corporation for the Solar One Project under the above referenced contract. In preparation for delivery of these documents to DOE/TIC, I have prepared a SAN form 70 "Request for Patent Clearance" and a DOE form RA-426 "Recommendations for Announcement and Distribution of Documents" for each document.

Please have the appropriate MDAC personnel complete and sign these forms. As agreed, SAN form 70 should be forwarded to SAN/OPC by your office with copies of the completed SAN form 70 and the transmittal letter being sent to me. The completed DOE form RA-426 should be sent directly back to me.

The documents covered by this letter are:

| <u>Primary Document No.</u> | <u>Secondary No.</u> | <u>Brief Title</u>                               |
|-----------------------------|----------------------|--|
| DOE/SF/10499-T108           | STMP0 193            | PSS Final Design Calculations<br>(Book 18 of 26) |
| DOE/SF/10499-T109           | STMP0 194            | PSS Final Design Calculations<br>(Book 19 of 26) |
| DOE/SF/10499-T110           | STMP0 195            | PSS Final Design Calculations<br>(Book 20 of 26) |
| DOE/SF/10499-T111           | STMP0 196            | PSS Final Design Calculations<br>(Book 21 of 26) |
| DOE/SF/10499-T112           | STMP0 197            | PSS Final Design Calculations<br>(Book 22 of 26) |



|                   |           |  |
|-------------------|-----------|--|
| DOE/SF/10499-T113 | STMPO 198 | PSS Final Design Calculations<br>(Book 23 of 26) |
| DOE/SF/10499-T114 | STMPO 199 | PSS Final Design Calculations<br>(Book 24 of 26) |
| DOE/SF/10499-T115 | STMPO 200 | PSS Final Design Calculations<br>(Book 25 of 26) |
| DOE/SF/10499-T116 | STMPO 201 | PSS Final Design Calculations<br>(Book 26 of 26) |

If you should have any questions or concerns please do not hesitate to contact me by telephone at, (619) 254-2672.

Sincerely,



S.D. Elliott, Jr., Director  
DOE Solar One Project Office

SDE/aks  
Project File: CCC010.RNO(SA3:)

Encl: Nine Document Covers W/forms 70 and RA-426

cc: Roger Gaither, SAN/OPC  
W.D. Matheny, DOE/TIC  
Mike Lopez, DOE/SAN (FGS)  
Mary Soderstrum, B&McD



**DEPARTMENT OF ENERGY  
SAN FRANCISCO OPERATIONS OFFICE**

**CONTRACTOR REQUEST FOR PATENT CLEARANCE  
FOR RELEASE OF UNCLASSIFIED DOCUMENT**

**TO:** Roger S. Gaither, Asst. Chief for Prosecution  
Office of Patent Counsel/Livermore Office  
P.O. Box 808, L-376  
Livermore, California 94550

**FROM:** McDonnell Douglas Corporation  
3855 Lakewood Blvd.  
Long Beach, CA 90846

|  |
|--|
| Prime Contract No.<br>DE-AC03-79SF10499  |
| Subcontract No.<br>(N/A)   |
| Report No. (STMP0 201)<br>DOE/SF/10499-T116  |
| Date of Report<br>September 1980   |
| Name & Phone No. of DOE<br>Technical Representative<br>S.D. Elliott, Jr.<br>(619) 254-2672 |

- Document Title: Plant Support Subsystem Final Design Calculations  
(Book 26 of 26)
- Type of Document:  Technical Report,  Conference Paper,  Journal Article,  Abstract or Summary,  
 Copy of Oral Presentation,  Other (please specify): \_\_\_\_\_  
(Routine)
- In order to meet a publication schedule or submission deadline, patent clearance by \_\_\_\_\_  
would be desired.

**SENDER IS TO CHECK BOX #4 OR #5 BELOW.**

4. I have reviewed (or have had reviewed by technically knowledgeable personnel) this document for possible inventive subject matter (Subject Inventions) and that no inventions or discoveries (Subject Inventions) are deemed to be disclosed in this document except as stated below:
- Attention should be directed to pages \_\_\_\_\_ of this document.
  - This document describes matter relating to an invention:
    - Contractor Invention Docket No. \_\_\_\_\_
    - A disclosure of the invention was submitted to DOE on \_\_\_\_\_ (date)
    - A disclosure of the invention will be submitted shortly \_\_\_\_\_ (approximate date)
    - A waiver of DOE's patent rights to the contractor:
 

has been granted,  has been applied for; or  will be applied for \_\_\_\_\_ (date)
5. This document is being submitted, but no review has been made of this document for possible inventive subject matter.  
Provide copy of clearance to: Solar One Project Office  
P.O. Box 366, Daggett, CA 92327
6. Remarks:

Reviewing/Submitting Official: Name (Print/Type) \_\_\_\_\_  
Title \_\_\_\_\_  
Signature \_\_\_\_\_ Date \_\_\_\_\_

**TO:** INITIATOR OF REQUEST  
**FROM:** ASSISTANT CHIEF FOR PROSECUTION  
Office of Patent Counsel/Livermore Office

- No patent objection to above-identified release.  
 Please defer release until advised by this office.

Signed \_\_\_\_\_ Date Mailed \_\_\_\_\_

DOE AND MAJOR CONTRACTOR RECOMMENDATIONS FOR  
ANNOUNCEMENT AND DISTRIBUTION OF DOCUMENTS

See Instructions on Reverse Side

|  |   |   |
|--|---|---|
| 1. DOE Report No.<br><u>DOE/SF/10499-T116 (STMPO 201)</u>  | 2. Contract No.<br><u>DE-AC03-79SF10499</u> | 3. Subject Category No.<br><u>UC-62, 62c, 62d</u> |
| 4. Title<br><u>Plant Support Subsystem Final Design Calculations (Book 26 of 26)</u>   |   |   |
| 5. Type of Document ("x" one)<br><input checked="" type="checkbox"/> a. Scientific and technical report<br><input type="checkbox"/> b. Conference paper: Title of conference _____<br><br>Date of conference _____<br>Exact location of conference _____ Sponsoring organization _____<br><input type="checkbox"/> c. Other (specify planning, educational, impact, market, social, economic, thesis, translations, journal article manuscript, etc.) _____  |   |   |
| 6. Copies Transmitted ("x" one or more)<br><input type="checkbox"/> a. Copies being transmitted for standard distribution by DOE-TIC.<br><input type="checkbox"/> b. Copies being transmitted for special distribution per attached complete address list.<br><input checked="" type="checkbox"/> c. Two completely legible, reproducible copies being transmitted to DOE-TIC. (Classified documents, see instructions)<br><input type="checkbox"/> d. Twenty-seven copies being transmitted to DOE-TIC for TIC processing and NTIS sales.   |   |   |
| 7. Recommended Distribution ("x" one)<br><input type="checkbox"/> a. Normal handling (after patent clearance): no restraints on distribution except as may be required by the security classification.<br>Make available only <input type="checkbox"/> b. To U.S. Government agencies and their contractors. <input type="checkbox"/> c. within DOE and to DOE contractors.<br><input type="checkbox"/> d. within DOE. <input type="checkbox"/> e. to those listed in item 13 below.<br><input checked="" type="checkbox"/> f. Other (Specify) <u>Archive/Issue on request</u>   |   |   |
| 8. Recommended Announcement ("x" one)<br><input checked="" type="checkbox"/> a. Normal procedure may be followed. <input type="checkbox"/> b. Recommend the following announcement limitations:  |   |   |
| 9. Reason for Restrictions Recommended in 7 or 8 above.<br><input type="checkbox"/> a. Preliminary information. <input type="checkbox"/> b. Prepared primarily for internal use. <input type="checkbox"/> c. Other (Explain) _____   |   |   |
| 10. Patent, Copyright and Proprietary Information<br>Does this information product disclose any new equipment, process or material? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify page nos. _____<br>Has an invention disclosure been submitted to DOE covering any aspect of this information product? <input type="checkbox"/> No <input type="checkbox"/> Yes<br>If so, identify the DOE (or other) disclosure number and to whom the disclosure was submitted.<br>Are there any patent-related objections to the release of this information product? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, state these objections.<br>Does this information product contain copyrighted material? <input type="checkbox"/> No <input type="checkbox"/> Yes<br>If so, identify the page number _____ and attach the license or other authority for the government to reproduce.<br>Does this information product contain proprietary information? <input type="checkbox"/> No <input type="checkbox"/> Yes If so, identify the page numbers _____<br>("x" one <input type="checkbox"/> a. DOE patent clearance has been granted by responsible DOE patent group.<br><input type="checkbox"/> b. Document has been sent to responsible DOE patent group for clearance. |   |   |
| 11. National Security Information (For classified document only; "x" one)<br>Document <input type="checkbox"/> a. does <input type="checkbox"/> b. does not contain national security information  |   |   |
| 12. Copy Reproduction and Distribution<br>Total number of copies reproduced _____ Number of copies distributed outside originating organization _____  |   |   |
| 13. Additional Information or Remarks (Continue on separate sheet, if necessary)   |   |   |
| 14. Submitted by (Name and Position) (Please print or type)<br><u>S.D. Elliott, Jr., Director, DOE Solar One Project Office</u><br>Organization _____<br><u>P.O. Box 366, Daggett, CA 92327</u> (619) 254-2672<br>Signature _____ Date _____   |   |   |

# DOE FILE COPY

10 MWe Solar Thermal  
Central Receiver Pilot Plant


SOLAR FACILITIES DESIGN INTEGRATION

PSS FINAL DESIGN CALCULATIONS  
BOOK 26 OF 26--MDAC GENERAL ANALYSIS AND  
BACKGROUND DATA (RADL ITEM 7-8)

September 1980

WORK PERFORMED UNDER CONTRACT  
DE-AC03-79SF10499

MCDONNELL DOUGLAS ASTRONAUTICS COMPANY  
5301 BOLSA AVENUE  
HUNTINGTON BEACH, CA 92647



## U.S. Department of Energy

MCDONNELL  
DOUGLAS  
CORPORATION



Solar Energy

**10 MWe Solar Thermal  
Central Receiver Pilot Plant  
Solar Facilities Design Integration**

---

**PSS FINAL DESIGN CALCULATIONS  
BOOK 26 OF 26--MDAC GENERAL ANALYSIS AND  
BACKGROUND DATA (RADL ITEM 7-8)**

---

**September 1980**

**DISCLAIMER**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

**MCDONNELL DOUGLAS ASTRONAUTICS COMPANY  
5301 BOLSA AVENUE  
HUNTINGTON BEACH, CA 92647**

**PREPARED FOR THE  
U.S. DEPARTMENT OF ENERGY  
SOLAR ENERGY  
UNDER CONTRACT DE-AC-03-79SF10499**

U.S. DEPARTMENT OF ENERGY

DOE AND MAJOR CONTRACTOR RECOMMENDATIONS FOR  
ANNOUNCEMENT AND DISTRIBUTION OF DOCUMENTS

See Instructions on Reverse Side

|  |   |   |
|--|---|---|
| 1. DOE Report No.<br><u>DOE/SF/10499-T116 (STMPO 201)</u>  | 2. Contract No.<br><u>DE-AC03-79SF10499</u> | 3. Subject Category No.<br><u>UC-62, 62c, 62d</u> |
| 4. Title<br><u>Plant Support Subsystem Final Design Calculations (Book 26 of 26)</u>   |   |   |
| 5. Type of Document ("x" one)<br><input checked="" type="checkbox"/> a. Scientific and technical report<br><input type="checkbox"/> b. Conference paper: Title of conference _____<br><br>_____ Date of conference _____<br><br>Exact location of conference _____ Sponsoring organization _____<br><input type="checkbox"/> c. Other (specify planning, educational, impact, market, social, economic, thesis, translations, journal article manuscript, etc.) _____  |   |   |
| 6. Copies Transmitted ("x" one or more)<br><input type="checkbox"/> a. Copies being transmitted for standard distribution by DOE-TIC.<br><input type="checkbox"/> b. Copies being transmitted for special distribution per attached complete address list.<br><input checked="" type="checkbox"/> c. Two completely legible, reproducible copies being transmitted to DOE-TIC. (Classified documents, see instructions)<br><input type="checkbox"/> d. Twenty-seven copies being transmitted to DOE-TIC for TIC processing and NTIS sales.   |   |   |
| 7. Recommended Distribution ("x" one)<br><input type="checkbox"/> a. Normal handling (after patent clearance): no restraints on distribution except as may be required by the security classification. Make available only<br><input type="checkbox"/> b. To U.S. Government agencies and their contractors. <input type="checkbox"/> c. within DOE and to DOE contractors.<br><input type="checkbox"/> d. within DOE. <input type="checkbox"/> e. to those listed in item 13 below.<br><input checked="" type="checkbox"/> f. Other (Specify) <u>Archive/Issue on request</u>   |   |   |
| 8. Recommended Announcement ("x" one)<br><input checked="" type="checkbox"/> a. Normal procedure may be followed. <input type="checkbox"/> b. Recommend the following announcement limitations:  |   |   |
| 9. Reason for Restrictions Recommended in 7 or 8 above.<br><input type="checkbox"/> a. Preliminary information. <input type="checkbox"/> b. Prepared primarily for internal use. <input type="checkbox"/> c. Other (Explain)   |   |   |
| 10. Patent, Copyright and Proprietary Information<br>Does this information product disclose any new equipment, process or material? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes If so, identify page nos. _____<br>Has an invention disclosure been submitted to DOE covering any aspect of this information product? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes<br>If so, identify the DOE (or other) disclosure number and to whom the disclosure was submitted.<br>Are there any patent-related objections to the release of this information product? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes If so, state these objections.<br>Does this information product contain copyrighted material? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes<br>If so, identify the page number _____ and attach the license or other authority for the government to reproduce.<br>Does this information product contain proprietary information? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes If so, identify the page numbers _____<br>("x" one <input type="checkbox"/> a. DOE patent clearance has been granted by responsible DOE patent group.<br><input checked="" type="checkbox"/> b. Document has been sent to responsible DOE patent group for clearance. |   |   |
| 11. National Security Information (For classified document only; "x" one)<br>Document <input type="checkbox"/> a. does <input type="checkbox"/> b. does not contain national security information  |   |   |
| 12. Copy Reproduction and Distribution<br>Total number of copies reproduced <u>10</u> Number of copies distributed outside originating organization <u>4</u>   |   |   |
| 13. Additional Information or Remarks (Continue on separate sheet, if necessary)   |   |   |
| 14. Submitted by (Name and Position) (Please print or type)<br><u>S.D. Elliott, Jr., Director, DOE Solar One Project Office</u><br>Organization<br><u>P.O. Box 366, Daggett, CA 92327</u> (619) 254-2672<br>Signature _____ Date _____   |   |   |



DEPARTMENT OF ENERGY  
SAN FRANCISCO OPERATIONS OFFICE

CONTRACTOR REQUEST FOR PATENT CLEARANCE  
FOR RELEASE OF UNCLASSIFIED DOCUMENT

TO: Roger S. Gaither, Asst. Chief for Prosecution  
Office of Patent Counsel/Livermore Office  
P.O. Box 808, L-376  
Livermore, California 94550

FROM: McDonnell Douglas Corporation  
3855 Lakewood Blvd.  
Long Beach, CA 90846

|  |
|--|
| Prime Contract No.<br>DE-AC03-79SF10499  |
| Subcontract No.<br>(N/A)   |
| Report No. (STMP0 201)<br>DOE/SF/10499-T116  |
| Date of Report<br>September 1980   |
| Name & Phone No. of DOE<br>Technical Representative<br>S.D. Elliott, Jr.<br>(619) 254-2672 |

- Document Title: Plant Support Subsystem Final Design Calculations  
(Book 26 of 26)
- Type of Document:  Technical Report,  Conference Paper,  Journal Article,  Abstract or Summary,  
 Copy of Oral Presentation,  Other (please specify): \_\_\_\_\_  
(Routine)
- In order to meet a publication schedule or submission deadline, patent clearance by \_\_\_\_\_  
would be desired.

SENDER IS TO CHECK BOX #4 OR #5 BELOW.

- I have reviewed (or have had reviewed by technically knowledgeable personnel) this document for possible inventive subject matter (Subject Inventions) and that no inventions or discoveries (Subject Inventions) are deemed to be disclosed in this document except as stated below:
  - Attention should be directed to pages \_\_\_\_\_ of this document.
  - This document describes matter relating to an invention:
    - Contractor Invention Docket No. \_\_\_\_\_.
    - A disclosure of the invention was submitted to DOE on \_\_\_\_\_ (date)
    - A disclosure of the invention will be submitted shortly \_\_\_\_\_ (approximate date)
    - A waiver of DOE's patent rights to the contractor:
  has been granted,  has been applied for; or  will be applied for \_\_\_\_\_ (date)
- This document is being submitted, but no review has been made of this document for possible inventive subject matter.  
Provide copy of clearance to: Solar One Project Office  
P.O. Box 366, Daggett, CA 92327

Reviewing/Submitting Official: Name (Print/Type) John P. Scholl  
 Title Asst. Chief Patent Counsel, MDC (MS 122-23)  
 Signature [Signature] Date 6 NOV 84

TO: INITIATOR OF REQUEST

FROM: ASSISTANT CHIEF FOR PROSECUTION  
Office of Patent Counsel/Livermore Office

- No patent objection to above-identified release.
- Please defer release until advised by this office.