

SAN-1483-1/3

CONCEPTUAL DESIGN OF ADVANCED CENTRAL RECEIVER POWER
SYSTEMS SODIUM-COOLED RECEIVER CONCEPT


Final Report. Volume 2, Book 2. Appendix

CONFIDENTIAL ACCOUNTABILITY REMOVED
1986
4322
C1

March 1979

Work Performed Under Contract No. EG-77-C-03-1483

Rockwell International
Energy Systems Group
Canoga Park, California



U.S. Department of Energy



Solar Energy

22-0013 VOL 2, BK 2

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

This report has been printed directly from copy supplied by the originating organization. Although the copy supplied may not in part or whole meet the standards for acceptable reproducible copy, it has been used for reproduction to expedite distribution and availability of the information being reported.

Available from the National Technical Information Service, U. S. Department of Commerce, Springfield, Virginia 22161.

Price: Paper Copy \$15.25
Microfiche \$3.00

**CONCEPTUAL DESIGN
OF
ADVANCED CENTRAL RECEIVER POWER SYSTEMS
SODIUM-COOLED RECEIVER CONCEPT
FINAL REPORT**

**VOLUME II
BOOK 2
APPENDICES**

MARCH 1979

**PREPARED FOR THE
U.S. DEPARTMENT OF ENERGY
AS PART OF
CONTRACT NO. EG-77-C-03-1483**



Rockwell International
Energy Systems Group



Salt River Project
WATER ↔ POWER



PREFACE

This report is submitted by the Energy Systems Group to the Department of Energy under Contract EG-77-C-03-1483 as final documentation. This Conceptual Design Report summarizes the analyses, design, planning, and cost efforts performed between October 1, 1977, and September 1, 1978. The report is submitted in four volumes, as follows:

- Volume I Executive Summary
- Volume II Book 1, Commercial Plant Conceptual Design
 Book 2, Appendices
- Volume III Development Plan and Pilot Plant Description
- Volume IV Commercial and Pilot Plant Cost Data



CONTENTS

	Page
Appendices	
A. Design Data Sheets and P&I Drawing for 100-MWe Commercial Plant Design, for All-Sodium Storage Concept	A-1
B. Design Data Sheets and P&I Drawing for 100-MWe Commercial Plant Design, for Air-Rock Bed Storage Concept	B-1
C. Electric Power Generating Water-Steam System P&I Drawing and Equipment List, 100-MWe Commercial Plant Design	C-1
D. Design Data Sheets and P&I Drawing for 281-MWe Commercial Plant Design	D-1
E. Steam Generator System Conceptual Design	E-1
F. Heat Losses from Solar Receiver Surface	F-1
G. Heat Transfer and Pressure Drop for Rock Bed Thermal Storage	G-1
H. A Comparison of Alternative Ways of Recovering the Hydraulic Head From the Advanced Solar Receiver Tower	H-1
I. Central Receiver Tower Study	I-1
J. A Comparison of Mechanical and Electromagnetic Sodium Pumps	J-1
K. Pipe Routing Study of Sodium Downcomer	K-1
L. Sodium-Cooled Advanced Central Receiver System Simulation Model	L-1

APPENDIX A

**DESIGN DATA SHEETS AND P&I DRAWING FOR 100-MW_e COMMERCIAL
PLANT DESIGN, FOR ALL-SODIUM STORAGE CONCEPT**

CONTENTS:

1. Design Data Sheets
2. Piping and Instrument Drawing

ADVANCED CENTRAL RECEIVER
100 MWe SYSTEM SUMMARY DATA
(Sheet 1 of 2)

Net Electrical Power (MWe)	100
Parasitic Power (MWe)	
Daytime	12
Nighttime	6
Insolation (W/m ²)	950
Maximum Solar Power Absorbed (MWt)	390
Nominal Solar Power Absorbed for Direct Operating (MWt)	260
Plant Net Efficiency (%)	22.9
Collector Field Configuration	Single 360 ⁰ , North Biased
Solar Multiple, Equinox Noon	1.5
Number of Heliostats	14,100
Heliostat Shape and Size [m (ft)]	~Square, 7.38 x 7.42 (24.2 x 24.3)
Number of Towers/Receivers	1
Land Area (acre)	780
Receiver Mid-Point Elevation [m (ft)]	174 (571)
Receiver Configuration	External Cylinder
Number of Receiver Panels	24
Receiver Height and Diameter [m (ft)]	16.1 x 16.1 (52.8 x 52.8)
Receiver Maximum Heat Flux (MW/m ²)	1.53
Sodium Temperatures [°C (°F)]	288/593 (550/1100)
Receiver Sodium Flow Rate [kg/hr (1b/hr)]	3.66 x 10 ⁶ (8.07 x 10 ⁶)
Steam Generator Sodium Flow Rate (Direct Operation) [kg/hr (1b/hr)]	2.34 x 10 ⁶ (5.29 x 10 ⁶)

ADVANCED CENTRAL RECEIVER
100 MWe SYSTEM SUMMARY DATA
(Sheet 2 of 2)

Thermal Storage Capacity (MWth)	805
Total Sodium Inventory kg (lb)	7.6×10^6 (16.8×10^6)
Steam Generator and Reheater Type	Modular Steam Generator
Steam Conditions [MN/m^2 , $^{\circ}\text{C}$ (psia, $^{\circ}\text{F}$)]	
Initial	12.51, 538 (1815, 1000)
Reheated	2.72, 538 (394, 1000)
Steam Flow Rate [kg/hr (lb/hr)]	
Daytime	3.32×10^5 (7.32×10^5)
Nighttime	3.15×10^5 (6.95×10^5)
TSS Sodium Flow Rate [kg/hr (lb/hr)]	2.31×10^6 (5.09×10^6)
Feedwater Temperature [$^{\circ}\text{C}$ ($^{\circ}\text{F}$)]	234 (453)
Turbine Back Pressure [MN/m^2 (in. Hg)]	0.007 (2.0)
Heat Rejection [MW (Btu/hr)]	
Daytime	158 (540×10^6)
Nighttime	150 (511×10^6)

RECEIVER SUBSYSTEM



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

WBS NO.

NUMBER

PAGE 1 of 14

DATE 5/16/78

PREPARED BY

APPROVED BY

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Receiver Subsystem</u>					
		Nominal Thermal Power	MWt	260			
		Maximum Thermal Power	MWt	390			
		Receiver Temperature					
		- In	°C (°F)	288 (550)			
		- Out	°C (°F)	593 (1100)			
		Flow Rate - Max Receiver					
		- Max Steam Generator	Kg/hr (lb/hr)	3.66 x 10 ⁶ (8.07 x 10 ⁶)			
			Kg/hr (lb/hr)	2.34 x 10 ⁶ (5.29 x 10 ⁶)			
		Volume of Sodium in Subsystem	m ³ (gals)	341 (90,000)			
		Weight of Sodium in Subsystem	kg (lbs)	291,000 (641,000)			
		Pump Outlet Pressure	MN/m ² (psia)	2.38 (345)			
		Pump Inlet Pressure	MN/m ² (psia)	0.10 (15)			
		Total Radiation and Convection Loss	%	9% at Peak Power 12.5% at 50% Power			

ESG-79-2, Vol II, Book 2
A-5



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Receiver Subsystem (Cont.)					
		Steam Generator Units Sodium Side					
		Superheat - Temp In	°C (°F)	593 (1100)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	462 (864)			
		- Power	MWt	76.1			
		Reheat - Temp In	°C (°F)	593 (1100)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	462 (864)			
		- Power	MWt	35.3			
		Evaporator - Temp In	°C (°F)	462 (864)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	288 (550)			
		- Power	MWt	148.6			
		Pumps - Number and Type		1			Fixed Speed, Double Suction Centrifugal, Single Stage
		Receiver - Size and Type	m x m (ft x ft)	16.1 x 16.1 (53 x 53)			External 24 Panel
		Large Valves, 61 cm (24") Block		2			CS, Riser and Pump Return
		61 cm (24") Check		1			CS, Riser
		46 cm (18") Block		1			SS, Downcomer
		41 cm (16") Control		1			SS, Superheater Control
		20 cm (8") Control		24			SS, Receiver Panel Control
		15 cm (6") Control		1			SS, Reheater Control



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Receiver Subsystem (Cont.)</u>					
		Large Pipe Length, 61 cm (24")	m (ft)	305 (1000)			CS
		46 cm (18")	m (ft)	366 (1200)			CS and SS
		41 cm (16")	m (ft)	18 (60)			SS
		20 cm (8")	m (ft)	512 (1680)			CS and SS
		15 cm (6")	m (ft)	18 (60)			SS
		<u>Receiver Assembly</u>					
		Diameter	m (ft)	16.1 (53)			
		Height	m (ft)	16.1 (53)			
		Receiver Mid-Point Elevation	m (ft)	211 (692)			
		Receiver Maximum Elevation	m (ft)	219 (720)			
		Number of Absorber Panels		24			
		<u>Receiver Weight, Dry</u>					
		Total	Kg (lb)	275,000 (606,000)			
		Pressure Parts	Kg (lb)	60,200 (132,500)			
		Total Sodium in Receiver	Kg (lb)	66,400 (146,000)			
		<u>Absorber Panel</u>					
		Height	m (ft)	16 (53)			
		Width	m (ft)	2.1 (6.9)			
		Dry Weight, Pressure Parts	Kg (lb)	1,638 (3,600)			
		Number of Tubes		110			
		Tube OD	cm (in.)	1.91 (0.75)			
		Tube ID	cm (in.)	1.65 (0.65)			



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 4 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Absorber Panel (Cont)</u>					
		Tube Material		CRES 304H			
		Solar Surface Coating		Pyromark			
		Panel Insulation	cm (in.)	15.2 (6)			Closed-Pore Fiberglass Flexible Tube Bends
		Thermal Expansion	cm (in.)	12.7 (5)			
		Absorptivity, Minimum		0.95			
		Peak Heat Flux	MW/m ² (Btu/in ² - sec	1.37 (0.84)			
		Outlet Temperature	°C (°F)	593 (1100)			
		Inlet Temperature	°C (°F)	288 (550)			
		Maximum Tube Surface Temperature	°C (°F)	635 (1175)			
		<u>Tower Assembly</u>					
		Construction					Slip formed concrete
		Concrete Height	m (ft)	157 (516)			
		Diameter - Base	m (ft)	24 (80)			
		- Top	m (ft)	9.1 (30)			
		Wall Thickness - Base	m (ft)	0.46 (1.5)			
		- Top	m (ft)	0.25 (.83)			
		Mat - OD	m (ft)	39.6 (130)			
		- ID	m (ft)	9.1 (30)			
		- Thickness	m (ft)	3.0 (10)			

FORM 706-A REV 2-74

ESG-79-2, VOL II, BOOK 2
A-8



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 5 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Riser</u>					
		Nominal Pipe OD	cm (in.)	61 (24)			
		Nominal Wall Thickness		TBD			
		Material		CS			
		Design Temperature	°C (°F)	371 (700)			
		Design Pressure ANSI B31.1		2.76 (400)			
		Maximum Flow Rate	kg/hf (lb/hr)	3.66 x 10 ⁶ (8.07 x 10 ⁶)			
		Velocity at Maximum Flow Rate	m/sec (ft/sec)	4.99 (16.3)			
		<u>Downcomer</u>					
		Nominal Pipe OD	cm (in.)	45.7 (18)			
		Nominal wall thickness		TBD			
		Material		304H			
		Design Temperature	°C (°F)	593 (1100)			
		Design Pressure ANSI B31.1		2.76 (400)			
		Maximum Flow Rate	kg/hf (lb/hr)	3.66 x 10 ⁶ (8.07 x 10 ⁶)			
		Velocity at Maximum Flow Rate	m/sec (ft/sec)	7.45 (24.5)			



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 6 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Receiver Pump					
		<u>Physical Description</u>					
		Quantity		1			
		Number of Stages		2			
		Height, w/motor	m (ft)	7.6 (25)			
		Tank Size	m (ft)	2.3 x 4.2 (7.8 x 14)			
		Inlet Nozzle	m (in.)	0.91 (36)			
		Outlet Nozzle	m (in.)	0.61 (24)			
		Dry Weight Pump	kg (lb)	44,600 (98,300)			
		<u>Motor</u>					
		Size	MW (hp)	3.36 (4,500)			
		Dimensions w/coupling	m (ft)	1.8 x 3.6 (6 x 11)			
		Voltage	v	4160			
		Cooling		TBD			
		Weight	kg (lb)	9,545 (21,000)			



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 7 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Pump Operating Conditions</u>					
		Developed Head	m (ft)	251 (824)			
		Flow Rate	kg/hr (lb/hr)	3.66 x 10 ⁶ (8.07 x 10 ⁶)			
		Speed	rpm	700			
		Temperature	°C (°F)	288 (550)			
		Sodium Volume	m ³ (gal)	5.9 (1562)			
		NPSH	m (ft)	9.1 (30)			
		Speed Control	%	Fixed Speed			
		Pump Power ($\eta = 78\%$)	MW (hp)	3.2 (4,321)			
		<u>Design Conditions</u>					
		Developed Head	m (ft)	257 (844)			
		Flow Rate	m ³ /s (gpm)	1.3 (20,000)			
		Speed	rpm	700			
		Temperature	°C (°F)	300 (600)			
		NPSH (Minimum Required)	m (ft)	9.1 (30)			
		Code					Sect. VIII, Div. 1

ESG-79-2, Vol II, Book 2
A-11



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PAGE 8 of 14
DATE 5/16/78

PREPARED BY

APPROVED BY

WBS NO.

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Steam Generator - Evaporator					
		<u>Physical Description</u>					
		Quantity		1			
		Type					Tube & Shell Hockey Stick
		Height	m (ft)	29.0 (95)			
		Width	m (ft)	4.87 (16)			
		Shell diameter	m (in.)	1.22 (48)			
		Heat Transfer Area	m ² (ft ²)	1305 (14039)			
		Number of Tubes		1100			
		Tube Size	cm (in.)	1.59 (5/8)			
		Tube Wall Thickness	cm (in.)	0.19 (0.075)			
		Material		2-1/4 Cr - 1 Mo			
		Sodium Nozzle OD/Thickness	cm (in.)	91/2.5 (36/1.0)			
		Tubesheet Diameter/Thickness	cm (in.)	122/30.5 (48/12)			
		Steam Nozzle OD/Thickness	cm (in.)	201/3.8 (8/1.5)			
		Weight	kg (ton)	58,000 (64)			

ESG-79-2, Vol II, Book 2
A-12



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 9 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Operating Conditions</u>					
		Sodium Side:					
		Flow	kg/hr (lb/hr)	2.34 x 10 ⁶ (5.29 x 10 ⁶)			
		Inlet Temperature	°C (°F)	462 (864)			
		Outlet Temperature	°C (°F)	288 (500)			
		Pressure Drop	MN/m ²	0.207 (30)			
		Duty	MWt	148.6			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	3.32 x 10 ⁵ (7.32 x 10 ⁵)			
		Inlet Temperature	°C (°F)	234 (453)			
		Outlet Temperature	°C (°F)	341 (646)			
		Pressure	MN/m ²	15.06 (2185)			
		Pressure Drop	MN/m ² (psi)	2.07 (300)			
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psig)	2.07 (300)			
		Pressure-Steam Side	MN/hr ² (psig)	16.55 (2400)			
		Temperature	°C (°F)	482 (900)			
		Code					ASME Section VIII, Div. 1

ESG-79-2, Vol II, Book 2
A-13



Atomics International Division
Rockwell International

DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 10 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Steam Generator - Superheater					
		<u>Physical Description</u>					
		Quantity		1			Tube & Shell Hockey-Stick
		Type					
		Height	m (ft)	27.7 (91)			
		Width	m (ft)	4.57 (15)			
		Shell Diameter	m (in.)	0.76 (30)			
		Heat Transfer Area	m ² (ft ²)	402.8 (4334)			
		Number of Tubes		283			
		Tube Size	cm (in.)	1.90 (3/4)			
		Tube Wall Thickness	cm (in.)	0.335 (0.132)			
		Material		SS 316			
		Sodium Nozzle OD/Thickness	cm (in.)	45.7/2.54 (18/1.0)			
		Tubesheet Diameter/Thickness	cm (in.)	76.2/20.3 (30/8)			
		Steam Nozzle OD/Thickness	cm (in.)	20.3/3 (8/1.2)			
		Weight	kg (ton)	20,000 (22)			

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
A-14



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 11 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Operating Conditions</u>					
		Sodium Side					
		Flow	kg/hr (lb/hr)	1.65 x 10 ⁶ (3.61 x 10 ⁶)			
		Inlet Temperature	°C (°F)	594 (1100)			
		Outlet Temperature	°C (°F)	462 (864)			
		Pressure Drop	MN/m ² (psi)	0.207 (30)			
		Duty (MWt)		76.1			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	3.32 x 10 ⁵ (7.32 x 10 ⁵)			
		Inlet Temperature	°C (°F)	341 (646)			
		Outlet Temperature	°C (°F)	538 (1000)			
		Pressure	MN/m ² (psig)	12.96(1880)			
		Pressure Drop	MN/m ² (psi)	1.77 (256)			

ESG-79-2, Vol II, Book 2
A-15



Atomics International Division
Rockwell International

DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 12 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Superheater (Cont.)					
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psig)	2.07 (300)			
		Pressure-Steam Side	MN/m ² (psig)	15.2 (2200)			
		Temperature	°C (°F)	593 (1100)			
		Code					ASME, Section VIII, Division I
		Steam Generator - Reheat					
		<u>Physical Description</u>					
		Quantity		1			
		Type					Tube & Shell Hockey-Stick
		Height	m (ft)	20.1 (66)			
		Width	m (ft)	5.49 (18)			
		Shell Diameter	m (in.)	0.81 (32)			
		Heat Transfer Area	m ² (ft ²)	309.4 (3329)			
		Number of Tubes		163			
		Tube Size	cm (in.)	3.81 (1-1/2)			
		Tube Wall Thickness	cm (in.)	0.272 (0.107)			
		Material		SS 316			

DESIGN DATA SHEET

TITLE

Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 13 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Reheat (Cont.)					
		<u>Physical Description (Cont.)</u>					
		Sodium Nozzle OD/Thickness	cm (in.)	30.5/1.9 (12/.75)			
		Tubesheet Diameter/Thickness	cm (in.)	81.3/12.7 (32/5)			
		Steam Nozzle OD/Thickness	cm (in.)	16.8/1.5 (6.6/.6)			
		Weight	kg (ton)	22,000 (24)			
		<u>Operating Conditions</u>					
		Sodium Side:					
		Flow	kg/hr (lb/hr)	0.755 x 10 ⁶ (1.68 x 10 ⁶)			
		Inlet Temperature	°C (°F)	594 (1100)			
		Outlet Temperature	°C (°F)	462 (864)			
		Pressure Drop	MN/m ² (psi)	0.207 (30)			
		Duty	MWt	35.3			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	2.89 x 10 ⁵ (6.36 x 10 ⁵)			
		Inlet Temperature	°C (°F)	342 (647)			
		Outlet Temperature	°C (°F)	538 (1000)			
		Pressure	MN/m ² (psig)	2.80 (406)			
		Pressure Drop	MN/m ² (psi)	0.15 (22)			



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 14 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Reheat (Cont.)					
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psig)	2.07 (300)			
		Pressure-Steam Side	MN/m ² (psig)	3.65 (530)			
		Temperature	°C (°F)	593 (1100)			
		Code					ASME, Section VIII, Division I

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
A-18

THERMAL STORAGE SUBSYSTEM

ALL-SODIUM STORAGE



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 1 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Thermal Storage Subsystem</u>					
		Storage Material		Sodium			
		Number of Tanks		2			
		Thermal Storage Capacity	MWth	812.5			Includes 62.5 MW _t for Startup and Shutdown
		Maximum Charging Rate	MWt	390			
		Maximum Extraction Rate	MWt	250			
		Time at Maximum Extraction Rate	hr	3			
		Weight of Sodium in Subsystem	kg (lb)	7.6 x 10 ⁶ (16.8 x 10 ⁶)			
		Temperature - Hot Tank Storage	°C (°F)	593 (1100)			
		- Cold Tank Storage	°C (°F)	288 (550)			
		Pump - Number and Type		1			Variable Speed, Single Stage Centrifugal
		Large Valves - 46 cm (18 in.) Block		2			CS and SS
		- 46 cm (18 in.) Drag		1			SS
		Large Pipe Length - 46 cm (18 in.)	in (ft)	73 (240)			CS, Standard Wall
		- 46 cm (18 in.)	in (ft)	107 (350)			SS, Standard Wall

ESG-79-2, Vol 11, Book 2
A-20



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER
PAGE 2 of 5
DATE 5/16/78

PREPARED BY
APPROVED BY

WBS NO.

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Low Temperature Sodium Tank</u>					
		Number		1			
		Type					Cylindrical API Type
		Diameter	m (ft)	30.5 (100)			
		Height	m (ft)	12.3 (41)			
		Wall Thickness					
		Top	cm (in.)	0.64 (0.25)			
		Bottom	cm (in.)	2.5 (1.0)			
		Volume	m ³ (gal)	8,700 (2.3 x 10 ⁶)			
		Tank Material					Carbon Steel
		Insulation, Roof and Walls	cm (in.)	15.2 (6)			Calcium Silicate with Aluminum Weather Protection
		Base Insulation	m (ft)	1 (3)			Perlitic Concrete
		Electric Preheat-Temperature Maintenance	kw	274			
		Low Sodium Temperature	°C (°F)	288 (550)			
		Ullage Maintenance Unit					
		Ullage Pressure	Pa (psi)	0.0069 (1)			
		Pressurization Media		Argon			

ESG-79-2, Vol II, Book 2
A-21



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>High Temperature Sodium Tank</u>					
		Type		Cylindrical API Type			
		Diameter	m (ft)	30.5 (100)			
		Height	m (ft)	13.6 (45)			
		Wall Thickness					
		Top	cm (in.)	0.64 (0.25)			
		Bottom	cm (in.)	5.1 (2.0)			
		Volume	m ³ (gal)	9460 (2.5 x 10 ⁶)			
		Tank Material, Thickness	cm (in.)	0.64 (0.25 - 2.5 (1.0)			Type 304 SS
		Insulation, Roof and Walls	cm (in.)	30.5 (12)			Calcium Silicate with Aluminum Weather Protection
		Base Insulation	m (ft)	1 (3) Perlitic Concrete			
		Electric Preheat-Temperature Maintenance	kw	540			
		Number of High Temperature Tanks		1			
		High Sodium Temperature	°C (°F)	593 (1100°F)			
		Ullage Maintenance Unit		Argon			



DESIGN DATA SHEET

TITLE
 Advanced Central Receiver
 Thermal Storage Subsystem
 WBS NO.

NUMBER
 PAGE 4 of 5
 DATE 5/16/78

PREPARED BY

APPROVED BY

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		STEAM GENERATOR PUMP					
		<u>Physical Description</u>					
		Quantity		1			
		Number of Stages		1			
		Height, w/motor	m (ft)	7.3 (24)			
		Tank Size	m (ft)	1.0 x 3.6 (3.5 x 12)			
		Inlet Nozzle	m (in.)	0.61 (24)			
		Outlet Nozzle	m (in.)	0.46 (18)			
		Dry Weight, Pump	kg (lb)	8,600 (19,000)			
		<u>Motor</u>					
		Size	MW (hp)	0.56 (750)			
		Dimensions w/coupling	m (ft)	1.5 x 3.7 (5 x 12)			
		Voltage	v	4160			
		Cooling		TBD			
		Weight	kg (lb)	3860 (8500)			

ESG-79-2, Vol II, Book 2
A-23



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER
PAGE 5 of 5
DATE 5/16/78

PREPARED BY

APPROVED BY

WBS NO.

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Pump Operating Conditions</u>					
		Developed Head	m (ft)	76.7 (250)			
		Flow Rate	kg/hr (lb/hr)	2.34 x 10 ⁶ (5.29 x 10 ⁶)			
		Speed	rpm	1160			
		Temperature	°C (°F)	593 (1100)			
		Sodium Volume	m ³ (gal)	5.7 (1500)			
		NPSH	m (ft)	9.1 (30)			
		Speed Control	%	10-100			
		Pump Power ($\eta = 80\%$)	MW (hp)	0.53 (706)			
		<u>Design Conditions</u>					
		Developed Head	m (ft)	76 (250)			
		Flow Rate	m ³ /sec (gpm)	0.95 (15,000)			
		Speed	rpm	1160			
		Temperature	°C (°F)	593 (1100)			
		NPSH (Minimum Required)	m (ft)	7.6 (25)			
		Code					Section VIII, Div. I

ESG-79-2, Vol II, Book 2
A-24



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

PAGE 6

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Drag Valve</u>					
		Location					Upstream of High Temperature Sodium Storage Tank
		Type		Stacked Disc			
		Size (nominal)	inches	18			
		Flow Rate	m ³ /sec (gpm)	1.26 (20,000)			
		Pressure Drop	mm/m ² (psi)	1.74 (253)			
		Pressure Rating	mm/m ² (psi)	2.75 (400)			
		Temperature	°C (°F)	649 (1200)			
		Flow Coefficient, C _v	m ³ /sec/ √mm/m ² (gpm/ √psi)	.955 (1258)			
		Operator					
		Insulation	in.	8			
		Material					Yes--Type TBD Calcium Silicate Stainless Steel; Inconel Velocity Control Elements ANSI 2500 1b
		Pressure Class					

FORM 706-A REV 2-74

ESG-79-2, Vol I, Book 2
A-25

COLLECTOR

DESIGN DATA SHEET

TITLE
**ADVANCED CENTRAL RECEIVER
 COLLECTOR SUBSYSTEM**

NUMBER

PREPARED BY

APPROVED BY

PAGE 1 of 3

WBS NO.

DATE May 19, 1978

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>GENERAL</u>					
		TOTAL FIELD AREA (EXCLUDING CENTRAL EXCLUSION)	10 ⁶ m ² (10 ⁶ ft ²)	3.06 (32.9)			
		NUMBER OF HELIOSTATS	--	14,106			
		TOTAL MIRROR AREA	10 ⁶ m ² (10 ⁶ ft ²)	.6916 (7.44)			
		PEAK POWER @ 950 w/m ²	MW	390			
		ANNUAL COLLECTABLE ENERGY	MWH _t	0.995 x 10 ⁶			
		TOWER HEIGHT	m (ft)	159 (522)			
		RECEIVER CENTERLINE ELEVATION	m (ft)	174 (571)			
		HELIOSTAT ARRANGEMENT	--	RADIAL STAGGER			
		AIM STRATEGY	--	1-POINT EQUATOR			
		PEAK RECEIVER HEAT FLUX	MW/m ²	1.37			
		CENTRAL EXCLUSION DIAMETER	m (ft)	364 (1200)			

ESG-79-2, Vol I, Book 2
 A-27



DESIGN DATA SHEET

TITLE
 ADVANCED CENTRAL RECEIVER
 COLLECTOR SUBSYSTEM
 (100 MWe SYSTEM)

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 3

WBS NO.

DATE August 20, 1978

NEW REV.	NO.	ITEM	DESIGN POINT		TENTATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>HELIOSTAT</u>					
		REFLECTOR SHAPE	--	RECTANGULAR			
		REFLECTOR ENVELOPE	m (ft)	7.38 x 7.42 (24.21 x 24.33)			
		MIRROR TYPE		SECOND SURFACE, SILVERED FUSION/FLOAT LAMINATED GLASS			
		MIRROR AREA	m ² (ft ²)	49.05 (528)			
		AVERAGE REFLECTIVITY		0.91			
		DRIVE SYSTEM		DUAL SCREW JACKS			
		ELEVATION		3 Ø, 480V ac			
		AZIMUTH		HARMONIC DRIVE			
		REFLECTED BEAM ACCURACY	(mr)	2.83			
		DRIVE RATE					
		ELEVATION	Deg/min	15			
		AZIMUTH	Deg/min	15			



DESIGN DATA SHEET

TITLE ADVANCED CENTRAL RECEIVER
COLLECTOR SUBSYSTEM
(100 MWe SYSTEM)

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 3

WBS NO.

DATE August 20, 1978

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		CANT RANGE	m (ft)	1190 (3900)			
		ELECTRICAL DRAW					
		MOTOR RUNNING (STEADY STATE)	amp	1.5			
		MOTOR START SURGE CURRENT	amp	3.0			
		TIME AVERAGE POWER DRAW (PER HELIOSTAT INCL ELECTRONICS)	WATTS	~ 39			
		INDIVIDUAL HELIOSTAT AVAILABILITY	--	0.9999			
		<u>FIELD ELECTRONICS</u>					
		PRIMARY FEEDER POWER	VOLTAGE	4160			
		PRIMARY FEEDER CABLE	AWG	#4			
		SECONDARY FEEDER POWER	VOLTAGE	480			
		DATA NETWORK	--	FIBER OPTICS			

ELECTRIC POWER GENERATION



DESIGN DATA SHEET

TITLE Advanced Central Receiver Electrical Power Generation Subsystem	NUMBER PAGE 1 of 3 DATE
PREPARED BY APPROVED BY	WBS NO.

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Turbine</u>					
		Type					Tandem Compound, Double-Flow, Extraction, Condensing Turbine
		Rating (kWe)		112,000			
		Heater Extractions		6			
		Shaft Speed (rpm)		3,600			
		Last Stage Bucket Size [cm (in.)]		58.4 (23)			
		Throttle Flow Control Mode					Steam Generator/Turbine Coordinated Control
		<u>Generator</u>					
		Generator Rating (kVA)		135,000			
		Power Factor		0.9			
		Output Voltage (volts)		13,800			
		Frequency (Hz)		60			
		Cooling					Hydrogen Cooled
		Exciter					Static Excitation System
		Shaft Speed (rpm)		3,600			
		<u>Condenser</u>					
		Type					Shell and Tube, 2-Pass
		Surface [m ² (ft ²)]		8,365 (90,000)			
		Tube Material		90-10 Copper-Ni			ASTM BIII, Alloy 706
		Tube Diameter OD [mm (in.)]		25.4 (1.00)			
		Tube Wall Thickness, 20 BWG [mm (in.)]		0.89 (0.035)			

ESG-79-2, Vol II, Book 2
 A-31



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Electrical Power Generation
Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 3

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Condenser (Continued)</u>					
		Tube Length, Effect [m (ft)]		8.54 (28)			
		Condenser Pressure [kPa (in.-HgA)]		7.0 (2.0)			
		Heat Rejection [MW (Btu/hr)]		1.58 (540 x 10 ⁶)			
		Cooling Water Flow [m ³ (gpm)]		5.9 (93,100)			
		Water Velocity [m/s (fps)]		2.18 (7.16)			
		Cooling Water In [°C (°F)]		28.9 (84.0)			
		Cooling Water Out [°C (°F)]		35.3 (95.6)			
		Condenser Air Removal		-			Mechanical Vacuum Pump (2-full capacity)
		<u>Cooling Tower</u>					
		Quantity		1			
		Type					Mechanical Draft, Cross Flow
		Number of Cells		5			
		Fan Motor Size [kW (hp)]		5-150 (200)			
		Design Wet Bulb Temperature [°C (°F)]		23 (74.0)			
		Cold Water Temperature [°C (°F)]		28.9 (84.0)			
		Hot Water Temperature [°C (°F)]		35.3 (95.6)			
		Circulating Water Flow [m ³ /s (gpm)]		6.1 (96,000)			
		Heat Rejection [MW (Btu/hr)]		163 (555 x 10 ⁶)			

ESG-79-2, Vol II, Book 2
A-32



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Electrical Power Generation
Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 3

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Feedwater Heaters</u>					
		Low Pressure Heater Quantity		2			Horizontal, Stainless Steel Tubes, Carbon Steel Shell with Drain Cooler, Maximum Tube Side Pressure: 2.2 kPa (315 psia)
		Deaerator Quantity		1			Stainless Steel Trays and Vent Condenser, Carbon Steel Shell, Horizontal Condensate Storage Section [62.5 m ³ (16,500 gal.)], Pressure Rating; 0.45 MPa (65 psia)
		High Pressure Heaters Quantity		3			Horizontal, Carbon Steel Tubes, Carbon Steel Shell with Drain Cooler, Maximum Tube Side Pressure: 20.68 MPa (3,000 psia)
		<u>Feedwater Treatment</u>					
		Equipment					
		- Inline Polishing Demineralizers					2 Full-Capacity Units
		- Makeup Water Demineralizers					2 Full-Capacity Units
		Chemicals					
		- pH Control					Ammonia
		- Oxygen Scavenger					Hydrazine

ESG-79-2, Vol II, Book 2
A-33

MASTER CONTROL

ESG-79-2, Vol II, Book 2

A-34



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (100 MW)

PAGE 1

WBS NO.

DATE 8-21-78

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	1	PLANT CENTRAL CONTROL CONSOLE (1)					
		LENGTH	FT.	25	X		
		DEPTH	FT.	2	X		
		HEIGHT	FT.	4	X		
R	2	CONTROL PROCESSORS (5)					
		THROUGHPUT	KOPS/SEC	350	X		
		PRIMARY STORAGE CAPACITY	16BIT WORDS	48,000	X		
R	3	SECONDARY CONTROL PROCESSOR STORAGE (5)					
		CAPACITY	MEGABITS	.25	X		
		ACCESS TIME	MSEC.	35	X		
		LATENCY	MSEC.	15	X		
N	4	HARDCOPY LOGGER (2)					
		CHARACTERS	PER LINE	132	X		
		SPEED	LINES/MIN	300	X		
N	5	RECORDERS, MAGNETIC (2)					
		DENSITY	BITS/INCH	500/800	X		
		SPEED	IN/SEC	45			
N	6	SAFING - CONTROL PANEL (1)	TBD	TBD			
N	7	SERIAL DIGITAL DATA BUS (2)					
		THROUGHPUT	KBITS/SEC	1500	X		
R	8	COLOR CRT DISPLAYS (5)					
		RASTER SCAN	NO. LINES	256 x 512	X		
		COLORS	NO.	4			

ESG-79-2, Vol II, Book 2
A-35



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (100 MW)

PAGE 2

WBS NO.

DATE 8-21-76

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	9	PID CONTROLLERS (100)					
		MICROPROCESSOR LOOP UPDATE RATE	PER SEC.	3	X		
		SCALING	%	0 - 100	X		
		RESOLUTION	BITS	12			
		OUTPUT	MV	4-20			
N	10	DISCRETE CONTROLLERS (125)					
		RESOLUTION	BITS	12	X		
		OUTPUT	MV	4 - 20			
N	11	ANALOG DATA ACQUISITION (350)			X		
		NORMAL RATE	CHAN/SEC	350			
		EMERGENCY RATE	CHAN/SEC	200,000			
		RESOLUTION	BITS	12			
		MULTIPLEXING	TYPE	SEQUENTIAL			
N	12	ANALOG OUTPUTS (TBD)	TBD	TBD	X		
N	13	CLOSED CIRCUIT TELEVISION (4)			X		
		MONITOR SIZE	IN	19			
		CAMERA	TBD	TBD			
		AUTO PAN/TILT	DEGREES	90			
		ZOOM	TBD	TBD			
N	14	UNINTERRUPTIBLE POWER SOURCE					
		10 INPUT	VAC	115 ± 10%			
		REGULATED 10 OUTPUT	VAC	115 ± 2%			
		STORAGE BATTERY	HRS	.5			
		CAPACITY					
		DERATED POWER	KVA	TBD			



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (100 MW)

PAGE 3

WBS NO.

DATE 8-21-78

NEW REV	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	15	TIME OF DAY REFERENCE					
		INPUT-WWV SYNCH.	HERTZ	1000	X		
		OUTPUT - TIME OF DAY BCD FORMAT	BITS	32	X		
N	16	ANNUNCIATOR PANEL	FUNCTIONS	25	X		
N	17	LOCAL WEATHER STATION WIND	MPH	80	X		
			DEGREES	360			
		BAROMETRIC PRESSURE	IN/HG	26 - 34			
		HUMIDITY	PERCENT/REL	0 - 100			
		SOLAR RADIATION	9M/CM ² /MIN	36 - 2.0 MICRONS			
		PRECIPITATION	IN	20			
		TEMPERATURE	DEG F	-15, +50			

ESG-79-2, Vol II, Book 2
A-37

DESIGN DATA SHEET

TITLE	NUMBER
BEAM CHARACTERIZATION SUBSYSTEM	
WBS NO.	PAGE 1
	DATE 8-21-78

PREPARED BY	APPROVED BY

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	1	VIDEO CAMERA SYSTEM (4) SELF CONTAINED CAMERA INCLUDING ENVIRONMENTAL HOUSING AND SYNC GENERATOR	AMBIENT TEMP °C	-20 TO +60			
			WEIGHT -#	27			
			VOLUME -M3	.34			
		LENS	SPEED	f 2.8			
			FOCAL LENGTH	32 - 320 MM ZOOM			
N	2	VIDEO SIGNAL PROCESSING SYSTEM. COMPOSITE VIDEO INPUT, SERIAL DIGITAL OUTPUT. (4)					
		A/D CONVERSION	WORD LENGTH-BIT	10			
			CONVERSION TIME-μS	32			
		CONTROLLER	TBD				
		LINE DRIVER	LEVEL - DIFF VOLTS	0.25			
			DISTANCE- M.	1500			
N	3	TARGET PANELS, TOWER MOUNTED 1/4" STEEL, PAINTED (4)	SIZE - M.	APPROX. 12 X 12			

ESG-79-2, Vol II, Book 2
A-38



DESIGN DATA SHEET

TITLE
BEAM CHARACTERIZATION
SUBSYSTEM

NUMBER

PREPARED BY

APPROVED BY


PAGE 2

WBS NO.

DATE 8-21-78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	5	TARGET INSTRUMENTATION SYSTEM (4) RADIANCE SENSORS SHUTTER CONTROLLER MUX - A/D	TBD TBD TBD				
N	6	DATA LINE - RG-11/U (5)	AVG. LENGTH M.	1000			

ADVANCED CENTRAL RECEIVER BUILDING LAYOUT, 100 MWe COMMERCIAL CONCEPTUAL DESIGN



ESG-79-2, Vol 11, Book 2
A-40

APPENDIX B

**DESIGN DATA SHEETS AND P&I DRAWING FOR 100-MW_e COMMERCIAL
PLANT DESIGN, FOR AIR-ROCK BED STORAGE CONCEPT**

CONTENTS:

1. Design Data Sheets for Air-Rock Storage System
2. Piping and Instrument Drawing



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem Design
Data (Air/Rocks Alternative)

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 9

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>SUBSYSTEM COMPONENTS</u>					
		Storage Device					
		Number		1			
		Type		Square, Rock Bed			
		Active length = width	[m(ft)]	85, 280			
		Height, overall	[m(ft)]	11 (36)			
		Volume, Container	[m ³ , gals ft ³ x 10 ⁻⁶]	0.080, 21.1 2.82			
		Volume, Rock Bed	[m ³ , gals ft ³ x 10 ⁻⁶]	.043, 12.7 1.50			
		Mass, Rock Bed	[Kg(tons)]	6.8 x 10 ⁷ (75,000)			
		Container - Top		Sand and CS			
		- Bottom		Rock			
		- Wall		Earth and rock			
		<p>NOTICE CONFIDENTIAL PROPRIETARY INFORMATION OF ROCKWELL INTERNATIONAL CORPORATION</p>					

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
B-3

TABLE 5-4



PREPARED BY		APPROVED BY		DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
NEW REV.	NO.	ITEM	UNIT	VALUE				
		Insulation - Top		Sand or soil				
		- Thickness	[m(ft)]	3 (10)				
		- Walls and Bottom		Rock				
		- Thickness	[m(ft)]	1 (3)				
		Temperature - Top of Bed	°C (°F)	613 (1135)				
		- Bottom	°C (°F)	357 (675)				
		<u>HEAT EXCHANGER</u>						
		Type		Finned tube; counter flow sodium-to-air/air-to-sodium				
		Number of Modules		54				
		Size	[m(ft)]	Parallelepiped 2.4 x 2.4 x 0.85 (8 x 8 x 2.8)				
		Effective Surface Area	[m ² (ft)]	52800 (568000)				
		Tube OD	cm(in.)	2.60 (1.02)				

ESG-79-2, Vol II, Book 2
B-4

TABLE 5-4



DESIGN DATA SHEET

TITLE
Advanced Central Receiver
Thermal Storage Subsystem Design
Data (Air/Rocks Alternative)

NUMBER

PREPARED BY

APPROVED BY

PAGE 4 of 9

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Wall Thickness	mm(in.)	1.24 (0.049)			
		Material		9% Cr 1% Mo Ferritic Steel			
		Fin Height	mm(in.)	9.1 (0.36)			
		Material		9% Cr 1% Mo Ferritic Steel			
		Fin Thickness	mm(in.)	0.61 (0.024)			
		Fan					
		Number		54			
		Type		Vane-axial, 2 stage, Joy Fan Co.			
		Size - Diameter	cm(in.)	152 (60)			
		Max Air Flow (390 MWt)	KG/S (lbs)	1580 (3470)			
		Nominal Air Flow (250 MWt)	KG/S (lbs)	1010 (2220)			
		Maximum Fan ΔP (390 MWt)	KPa (psi)	1.31 (0.19)			
		Operating Temperature	°C (°F)	> 371 (700)			
		Maximum for Power (390 MWt)	MWe	5.32			

ESG-79-2, Vol 11, Book 2
B-5

TABLE 5-4



NEW REV.		NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
				UNIT	VALUE			
			Fan Motor					
			Number		54			
			Type		Variable speed			
			Power (max)	kW (hp)	100 (123)			
			Voltage/Phase		460 V/3Ø			
			Cooling		Air cooled, ducted motor			
			Coupling		TBD			(Either fixed motor speed plus coupling; or variable speed motor without coupling.)
			Mixing Tee 1					See Design Data Sheet
			Mixing Tee 2					See Design Data Sheet

Atomics International Division
Rockwell International

PREPARED BY

DESIGN DATA SHEET

APPROVED BY

TITLE
Advanced Central Receiver
Thermal Storage Subsystem Design
Data (Air/Rocks Alternative)

WBS NO.

NUMBER

PAGE 5 of 9

DATE

ESG-79-2, Vol II, Book 2
B-6



DESIGN DATA SHEET

TITLE
 Mixing Tee -1
 Air/Rock Thermal
 Storage System

NUMBER
 PAGE 6 of 9
 DATE

PREPARED BY

APPROVED BY

WBS NO.

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Mixing Tee -1 (Na)					Upstream of Steam Generators - function with thermal storage
		Location		See Remarks			
		Type		Mixing			
		Size (Run/Branch)	in./in.	18/10			
		Wall Thickness	in./cm	0.400 (1.02)			
		Max Flow Velocity	ft/sec	18			
		Run Flow/Branch Flow	lb/sec/ lb/sec	1345/410			
		Operating Pressure					
		Normal	psi (mm/m ²)	230 (1.6)			
		Maximum	psi (mm/m ²)	253 (1.7)			
		Design Pressure	psi (mm/m ²)	400 (2.7)			

ESG-79-2, Vol II, Book 2
 B-7



DESIGN DATA SHEET

TITLE
 Mixing Tee -1
 Air/Rock Thermal
 Storage System

NUMBER

PREPARED BY

APPROVED BY

PAGE 7 of 10

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Operating Temperature					
		Normal Hot Leg/Cold Leg	°F (°C)	1165/715 (629/379)			
		Preheat	°F (°C)	400 (204)			
		Maximum	°F (°C)	1165 (629)			
		Design Temperature	°F (°C)	1200 (649)			
		Material (Body/Liner)		Type 304H/304H			
		Code Classification		Section VIII			Division 1
		Insulation	in.	8			Calcium Silicate
		Size OD x Length	in. x ft	18 x 15			
		glb:511					

ESG-79-2, Vol II, Book 2
B-8



DESIGN DATA SHEET

TITLE
 Mixing Tee -2
 Air/Rock Thermal
 Storage System

NUMBER

PREPARED BY

APPROVED BY

PAGE 8 of 9

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Mixing Tee -2 (Na)					Downstream of Steam Generators - function with thermal storage
		Location		See Remarks			
		Type		Mixing			
		Size (Run/Branch)	in./in.	18/10			
		Wall Thickness	in./cm	0.125/0.317			
		Max Flow Velocity	ft/sec				
		Run Flow/Branch Flow	lb/sec/ lb/sec	1755/492			
		Operating Pressure					
		Normal	psi (mn/m ²)	100 (0.68)			
		Maximum	psi (mn/m ²)	125 (0.84)			
		Design Pressure	psi (mn/m ²)	125 (0.84)			

ESG-79-2, Vol I, Book 2
 B-9



Atomica International Division
Rockwell International

DESIGN DATA SHEET

TITLE
Mixing Tee -2
Air/Rock Thermal
Storage System

NUMBER

PREPARED BY

APPROVED BY

PAGE 9 of 9


WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Operating Temperature					
		Normal Hot Leg/Cold Leg	°F (°C)	715/600 (379/316)			
		Preheat	°F (°C)	400 (204)			
		Maximum	°F (°C)	725 (385)			
		Design Temperature	°F (°C)	750 (399)			
		Material (Body/Liner)					
		Code Classification		Section VIII			Division 1
		Insulation	in.	5			Calcium Silicate
		Size OD x Length	in. x ft	18 x 15			
		glb:511					

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
B-10



SECTIONAL ELEVATION

SCALE: 1/80" = 1'-0"

HEAT STORAGE CONCEPT

T. E. CONVELL 5-30-78



APPENDIX C
ELECTRIC POWER GENERATING WATER-STEAM SYSTEM
P&I DRAWING AND EQUIPMENT LIST,
100-MW_e COMMERCIAL PLANT DESIGN

CONTENTS:

1. Auxiliary Power Requirements
2. Equipment List
3. Piping and Instrumentation Drawing for the EPG system
4. EPGS Process Data List

PAGE 1 OF 1
 JOB NO. C20325 DATE 5/10/78 BY AWM CH'K.
 CUSTOMER ATOMICS INTL PROJECT ADVANCED CENTRAL RECEIVER
 SUBJECT AUXILIARY POWER REQUIREMENTS

REFERENCE: S-R HEAT BALANCE DAC-01D 4/10/78
 MAX. GUAR. LOAD (TURBINE RATING) 112,000 KW @ 2" H₂O
 1800 PSIG - 1000°/1000°F THROTTLE FLOW 731,800 LB/HR

1. BOILER FEED PUMP	2100 KW INPUT TO MOTOR
2. COND. HOTWELL PUMP	150
3. CIRCULATING WATER PUMPS	1870
4. COOLING TOWER FANS	850
5. CONDENSER VACUUM PUMP	35
6. GLAND STEAM CONDENSER EXHAUSTER	5
7. GENERATOR VAPOR EXTRACTOR	5
8. EQUIPMENT COOLING WATER PUMP	20
9. BEARING COOLING WATER PUMP	40
10. INSTRUMENT AIR COMPRESSOR	30
11. SERVICE AIR COMPRESSOR	40
12. RAW WATER PUMP	60
13. COOLING TOWER MAKEUP PUMP	35
14. WATER TREATING SYSTEMS (LOT)	25
15. PLANT HVAC	175
16. MISC. A.C.	<u>100</u>
TOTAL AUX. POWER (EPGS)	5540 KW

4.94% OF GROSS GENERATION

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 1 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Turbine - Generator	1		112,000 kW Tandum Compound Double Flow (TC2F), re-heat, condensing turbine with 58.4 cm (28 in) last stage blades, 3600 RPM. Inlet Pressure 12.51 MPa (1815 psia), Inlet Temperature 538°C (1000°F), re-heat temperature 538°C (1000°F). Turbine exhaust pressure 6.77 kPa (2.0 in. Hg. A). Turbine rating (max. guar.) 112,000 kW. Max. Expected Output 116,471 kW at Rated Pressure, Valves Wide Open. Generator: 135,000 kVA, 0.90 P.F., 13,800 V., Hydrogen Cooled, Static Exciter, 3600 RPM.	
			Accessories:	
			Turbine Gland Steam Condenser w/Exhauster	
			Generator Vapor Extractor	
			A.C. Lube Oil Pump	
			D.C. Lube Oil Pump	
			Lube Oil Reservoir w/Exhauster	
			Lube Oil Coolers	
			Generator Hydrogen Coolers	
			Electro-Hydraulic Control System	

ESG-79-2, Vol II, Book 2
C-3

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 2 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Condenser	1		8365 m ² (90,000 ft. ²) surface condenser,	H.E.I. Std.
			2-pass, 25.4 mm (1 in.) O.D. x 20 BWG, 90-10 Cu-Ni	
			Tubes x 8.54m (28 ft.) Effective Length, 158 MWt	
			(540 x 10 ⁶ Btu/hr)	
			Heat Rejection, 6.77 kPa (2.0 in. Hg A)	
			Design Pressure, 28.9 ^o C (84.0 F) inlet	
			Water Temperature, 5.9 m ³ /s (93,100 GPM)	
Condenser Vacuum Pumps	2		Circulating Water Flow, 2.18 m/s (7.16 fps) velocity.	
			0.35 m ³ /min. (12.5 SCFM) @ 25.4 mm (1 in. HgA)	H.E.I. Std.
Cooling Tower	1		Nash Mechanical Vacuum Pump, 700 RPM, 37 kW (50HP)	Ea. Full Size
			460 V. - 3 Ph. - 60 Hz. motor	
			5-Cell, Mechanical Draft, Cross Flow, 150 kW (200 H.P.) Fans, per cell, 163 MWt (555 x 10 ⁶ Btu/hr Heat Rejection, 23 ^o C (74 ^o F) Wet Bulb, 5.6 ^o C (10 ^o F) Approach,	
Circulating Water Pumps	2		6.1 m ³ /s (96,000 GPM) Circ. Water Flow	
			Horizontal, centrifugal, double suction, single stage, Cast Iron Case, Bronze Impeller, 3.05 m ³ /s	Ea. Half Size

ESG-79-2, Vol II, Book 2
C-4

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 3 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Circulating Water Pumps (Cont'd)	2		(48,000 GPM) @ 23.2m (76.0 ft.) Head, 930 kW (1250 HP), 4160 v., 514 RPM Motor	
Condensate Hotwell Pumps	2		Vertical Turbine Can Type, Steel can, cast iron bowls, bronze impellers, stainless steel shaft, 5 stages, 0.10 m ³ /s (1540 GPM), @ 136m (446 ft.) Head, 186 kw (250 H.P.), 460 V., 1800 RPM Motor	Ea. Full Size
Boiler Feed Pumps	2		Horizontal centrifugal, double case barrel type, carbon steel outer case, alloy steel inner case and impellers, stainless steel shaft, 9 stages, 3440 RPM, 0.115m ³ /s (1825 GPM) @ 1681m (5515 ft.) head, 80.5% Efficiency, Hy- draulic coupling . Variable speed drive, 2250 kW (3000 HP) 4160 V., 3600 RPM Motor	Ea. Full Size
Equipment Cooling Water Pumps	2		Horizontal, centrifugal, double suction, single stage, cast iron case, bronze impeller, 0.015 m ³ /s (2365 GPM) @ 9.2m(30 ft.) head, 22.5kW (30 H.P.),	Ea. Full Size

ESG-79-2, Vol II, Book 2
C-5

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 4 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Equipment Cooling Water Pumps				
Cont'd			460 V., 1800 RPM motor	
Condensate Transfer Pumps	2		Horizontal End Suction, Centrifugal, Cast Iron case, bronze impeller, single stage, 0.019 m ³ /s (300 GPM) @ 67m (220 ft.) head, 25 kW (30 H.P.), 460V., 3500 RPM motor.	
Low Pressure Heater No. 1	1		Horizontal, Shell & Tube, Carbon Steel shell, Stainless Steel Tubes, with drain cooler, 185m ² (1990 ft. ²) surface, 2.2 MPa (315 PSIA) Tube Design Pressure, (Located in Condenser neck).	ASME Code Sect. VIII
Low Pressure Heater No. 2	1		Horizontal Shell & Tube, Carbon Steel Shell, Stainless Steel Tubes, with drain cooler, 197m ² (2120 ft. ²) surface. 2.2 MPa (315 PSIA) Tube Design Pressure	ASME Code Sect. VIII
Deaerator Heater No. 3	1		Horizontal, Spray-Tray Type with internal stainless steel vent condenser and trays, 363,000 kg/hr capacity, 0.005 cc/liter O ₂ in Effluent,	ASME Code Sect. VIII

ESG-79-2, Vol II, Book 2
C-6

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 5 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Deaerator Heater No. 3, Cont'd			Horizontal Storage Tank 62.5m ³ (16,500 gal.) capacity, 0.45 MPa (65 PSIA) Design Pressure.	
High Pressure Heater No. 4	1		Horizontal, shell & tube, carbon steel shell and tubes, with desuperheat section and drain cooler section, 266 m. ² (2865 ft. ²) surface, 20.7 MPa (3015 PSIA) Tube Design Pressure.	ASME Code Sect. VIII
High Pressure Heater No. 5	1		Horizontal, shell & tube, carbon steel shell and tubes, with desuperheat section and drain cooler section, 212 m. ² (2280 ft. ²) surface, 20.7 MPa (3015 PSIA) Tube Design Pressure.	ASME Code Sect. VIII
High Pressure Heater No. 6	1		Horizontal, shell & tube, carbon steel shell and tubes, with desuperheat section and drain cooler section, 293 m. ² (3150 ft. ²) surface, 20.7 MPa (3015 PSIA) Tube Design Pressure	ASME Code Sect. VIII
Condensate Storage Tank	2		378 m ³ (100,000 Gal.), Carbon Steel w/Plasite Lining 8.5m (28'-0") Dia. x 6.7m x (22'-0") Hi., Wt. 24,000 kg (53,000 lb.)	

ESG-79-2, Vol 11, Book 2
C-7

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 6 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Turbine Lube Oil Filter Set	1		Cartridge Type, Dual Filter Pump Set 0.057 m ³ /min. (15GPM). Gear Pump 0.5kW (3/4HP), 460V.-3Ph-60Hz. Motor	
Turbine Lube Oil Purifier	1		Centrifuge Separator, 0.057 m ³ /min. (15 GPM), 0.75 kW (1HP), 460V.-3Ph-60Hz. Motor	
Turbine Lube Oil Storage Tank	1		22.7 m ³ (6000 Gal.), 2 Compartment, Carbon Steel 4.3m(14'-0") x 2.4m(8'-0") x 2.4m(8'-0"), Wt. 4,550 kg (10,000 lb).	
Turbine Lube Oil Transfer Pump	1		0.19 m ³ /min. (50GPM) Gear Pump 0.75 kW (1HP) Motor	
Makeup Demineralizer System	2		0.38 m ³ /min. (100 GPM) Capacity	Ea. Full Size
Inline Demineralizer System	2		0.076 m ³ /s (1200 GPM) Capacity	Ea. Full Size
Cooling Tower Acid Tank	1		22.7 m ³ (6000 Gal), Horizontal 2.4m.(8'0") Dia x (16'1") Str. Shell 0.95 cm. (3/8") PL, Wt. 3950 kg (8700 lb)	
Cooling Tower Chlorinator	1		2,720 kg/day (6000 lb/day) V-Notch Chlorinator w/ Evaporator	
Cooling Tower Chem Feed Tank	1		0.19m ³ (50 Gal.), Type 304 Stainless Steel	
Bearing Water Heat Exch	2		Horiz Shell and Tube, Carbon Steel Shell, Cu-Ni Tubes, 0.038 m ³ /s (600 GPM)	Ea. Full Size
Cooling Tower Chem. Feed Pump	2		0.0075 m ³ /hr (2 GPH), Posit. Displ. w/0.19kW (1/4 HP). D.C. Motor	Ea. Full Size

ESG-79-2, Vol II, Book 2
C-8

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 7 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Bearing Cooling Water Pumps	2		Horizontal, End Suction Centrifugal, Single Stage, 22kW(30HP), 460V.-3Ph.-60Hz. Motor 0.038 m ³ /s (600 GPM) @ 39.6m (130Ft.) TDH	Ea. Full Size
Bearing Cooling Water Head Tank	1		Vertical Tank, 0.6m (2'-0") O.D. x 1.2m (4'-0") Hi	
Potable Water Pump	2		Horizontal, End Suction, Centrifugal, 0.19m ³ /min. (50GPM) @ 18.3m (60 Ft.) TDH, 1.1kW (1.5HP) Motor	
Potable Water Heater	1		0.57 m ³ (150 Gal.) Electric 440V.-3Ph.-60Hz.	
Potable Water Storage Tank	1		37.8 m ³ (10,000 Gal.) Vertical 3.65m (12'-0") Dia. x 3.65m (12'-0") Hi (Lined) 0.95cm (3/8") PL Wt. 6800 kg (15,000 lb)	
Sewage Treatment Plant	1		4000 GPD, Aeration Unit	
Service Air Compressor	2		9.9 m ³ /s (350SCFM) @ 0.79 MPa (115 PSIA), Recipro- cating, Double Acting, Two Stage, 56kW(75HP)Motor	Ea. Full Size
Service Air Aftercooler	2		Shell and Tube Type with Moist. Separator	Ea. Full Size
Service Air Receiver	1		4.2m ³ (150 CU.Ft.) Carbon Steel ASME Code, Wt. 1720 kg (3800 lb)	
Instrument Air Compressor	2		8.5 m ³ /s (300SCFM) @ 0.79MPa (115 PSIA), Recipro- cating, Double Acting Single Stage, Oil-Free Air, 38kW(50HP) Motor, 460V.-3Ph.-60Hz.	Ea. Full Size
Instrument Air Aftercooler	2		Shell and Tube Type with Moist. Separator	Ea. Full Size

ESG-79-2, Vol 11, Book 2
C-9

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 8 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Instrument Air Receiver	1		4.2m ³ (150 Cu.Ft.) Carbon Steel, ASME Code, Wt 1720 kg (3800 lb)	
Instrument Air Dryer	2		8.5 m ³ /s (300SCFM) Desiccant Type, Dual Column, Electric Regeneration, -40°C (-40°F) Dew Point, ASME Code	Ea. Full Size
Instrument Air Prefilter	2		8.5 m ³ /s (300SCFM) Cartridge Filter, ASME Code	
Instrument Air Afterfilter	2		8.5 m ³ /s (300SCFM), Cartridge Filter, ASME Code	
Raw Water Clarifier (Lime Soft.)	1		0.11 m ³ /s (1800 GPM), 15.2m(50'-0") Dia.	
Make-up Demineralizer Sand Filter	2		0.38 m ³ /min. (100 GPM), 2.0m (6'-6") Dia.	
Demineralizer Caustic Storage Tank	1		22.7m ³ (6000 Gal.) Carbon Steel, Horiz. 2.4m (8'-0") Dia x 4.9m (16'-1"), Shell 0.95 cm. (3/8") PL, Wt. 3950 kg (8700 lb)	
Demineralizer Caustic Pump	4		0.45 m ³ /hr (120 GPH), Posit. w/0.56kW (3/4 H.P.), 460V-3Ph-60Hz Motor	
Demineralizer Acid Storage Tank	1		27.7 m ³ (6000 Gal) Carbon Steel, Horiz. 2.4m (8'-0") Dia. x 4.9m (16'-1") Shell 0.95 cm. (3/8") PL, Wt 3950 kg (8700 lb)	
Demineralizer Acid Pump	2		0.38 m ³ /hr (100 GPH) Posit Displ w/0.56kW (3/4 HP), 460V-3Ph-60 Hz Motor	In-line Demin.
Feedwater Chem. Feed Tank	2		0.19m ³ (50 Gal.), Type 304 S.S., Hydrazine and Ammonia	

ESG-79-2, Vol. II, Book 2
C-10

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 9 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Feedwater Chem. Feed Pump	3		0.0075 m ³ /hr (2 GPH), Posit. Displ. W/0.19 kW (1/4 H.P.), 460V-3Ph-60 Hz Motor.	1 Spare
Fire Pump (Motor Driven)	1		0.095 m ³ /s (1500 GPM) @ 97.5m (320Ft) TDH, Horiz. Centrifugal 150 kW(200HP), 460V-3Ph.-60Hz. Elect. Motor	NFPA Code
Fire Pump (Engine Driven)	1		0.095 m ³ /s (1500 GPM) @ 97.5m (320 Ft.) TDH, Horiz. Centrifugal 150kW (200HP) Diesel Engine	NFPA Code
Jockey Pump (Fire Maint.)	1		0.19 m ³ /min. (50 GPM) @ 97.5m (320 Ft) TDH, Horiz. Centrifugal 7.5 kW (10 HP) 460V.-3Ph.-60Hz. Motor	
Diesel Generator	2		500 kW Diesel Engine Generator Unit, 4160V.	Emerg. Shutdown
Station Battery	1		125 V.D.C., 400 Amp. - Hr.	
Battery Charger	1		75 Amp 125V.D.C./460V A.C. 3-Ph-60Hz.	
Evaporative Cooler	4		33m ³ /s (70,000 CFM) EA. Unit	
Demineralizer Acid Pump	2		0.76 m ³ /hr (200 GPH) Posit, Displ., 0.75kW(1 HP), 460V-3Ph-60Hz Motor	Makeup Demin.
Raw Water Pump	2		Vertical Turbine, 0.13 m ³ /s (2000 GPM) @ 30.5m (100 Ft.), 56kW(75 HP) Motor	Ea. Full Size
Clarified Water Pump	2		Vertical Turbine, 0.12m ³ /s (1800 GPM) @ 24.4m (80 Ft.), 37 kW (50 HP) Motor	Ea. Full Size
Demineralizer Feedwater Pump	2		Horiz. End Suct., 0.016 m ³ /s (250 GPM) @ 33.5m (110 Ft) 11.2kW (15 H.P.) Motor	

ESG-79-2, Vol II, Book 2
C-11

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN

JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 10 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
Boiler Water Sample Panel	1		Boiler Water Sampling & Monitoring Panel	
Control Room Air Conditioner	1		40 Ton Chiller Unit	
Cooling Tower Acid Feed Pumps	2		0.01 m ³ /hr (3 GPH), Posit. Displ., 0.56 kW (3/4 HP), D.C. Motor	1 Spare
Lime Silo	1		113 m ³ (4000 Cu. Ft.), 5.5m (18'-0") Dia. x 10.6m (35'-0") Hi, carbon steel	
Lime Unloading/Conveying System	1 Lot		Railcar and/or Truck Lime Unloading System	
Lime Feeder	2		453 kg/hr (1000 lb/hr)	1 Spare
Lime Slaker	2		453 kg/hr (1000 lb/hr)	1 Spare
Clarifier Chem Feed Equipment	Lot		Polymer/Coagulant/Alum. Feed Equipment	
Turbine Room Crane	1		36,288 kg (40 Ton) Bridge Crane 15.2m (50'-0") Span, 9,070 kg (10 Ton) Aux. Hook	
Aux. Steam Boiler	1		22,680 kg/hr (50,000 lb/hr), 310 kPa(45 PSIA), Oil-Fired, ASME Code.	
Fuel Oil Storage Tank	1		Vertical Above Ground Tank, 7.6m (25'-0") Dia x 5.5m (18'-0") Hi, 250 m ³ (65,940 Gal.) No. 2 Fuel Oil	API Std 650
Main Power Transformer	1		130 MVA, FOA, 115-13.2 kV, Wye Grounded-Delta	
Aux. Power Transformer	1		10.0/13.3/16.6 MVA, OA/FA/FA, 13.2-4.16 kV, Delta-Wye Resistance Grounded.	
Start-Up Transformer	1		10.0/13.3/16.6 MVA, OA/FA/FA, 115-4.16 kV, Wye Grounded, Wye Resistance Grounded	

ESG-79-2, Vol I, Book 2
C-12

EQUIPMENT LIST

(ELECTRICAL POWER GENERATION SUBSYSTEM)

PROJECT 100 MW Advanced Central Receiver

CUSTOMER AI/DOE

PHASE I - CONCEPTUAL DESIGN


JOB NO. C-20325

REV./DATE 0 / 8-1-78

PAGE 11 OF 11

EQUIPMENT	QUANTITY	I.D. NUMBER	DESCRIPTION	REMARKS
4160 Volt Switchgear	1		Metal Clad Switchgear with 22-5kV, 1200A., 250 MVA Circuit Breakers	
480 Volt Load Center	2		Load Center, Double-Ended, 2-1250 kVA, 4160-480V. Transformers	
480 Volt Load Center	2		Load Center, Double-Ended, 2-1250 kVA, 4160-480V. Transformers	
Outdoor Oil Circuit Breaker	1		121kV, 1200 Amp., 20,000 Amp. short circuit current	
Disconnect Switches	2		121kV, 1200 Amp., 3 Pole Gang Operation	
Steel Structure	1		For 2-121kV, 1200 Amp. Disconnect Switches & Circuit Switcher	
Circuit Switcher	1		115kV, 1200 Ampere	
480 Volt Motor Control Center	2		Circuit Breaker & Circuit Breaker Combination Starters.	
480/120/208 V. Transformer	6		30kVA, Dry Type, 3 Phase	
120/208V. Distribution Panel	9			
D.C./A.C. Inverter	2		15kVA, 480 V., A.C., 3 Phase, 125 V.D.C.	
Isolated Phase Bus	1		15kV, 6000 Amp., with Surge Protection & V.T. Cubicle.	

ESG-79-2, Vol II, Book 2
C-13



NO.	REVISIONS	REFERENCE DRAWINGS	PRINT RECORD
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			
41			
42			
43			
44			
45			
46			
47			
48			
49			
50			

Stearns-Roger

ROCKWELL INTERNATIONAL
 ATOMICS INTERNATIONAL DIV.
 CANOGA PARK, CALIF.

Advanced Central Receiver Power System - P&I Diagram - Electric Power Generation Subsystem
 ESG-79-2, Vol II, Book 2

PRELIM. FOR COMMENTS
 1/77

APPENDIX D

**DESIGN DATA SHEETS AND P&I DRAWING FOR 281-MWe
COMMERCIAL PLANT DESIGN**

CONTENTS:

Design Data Sheets

**281 MWe COMMERCIAL PLANT
RECEIVER SUBSYSTEM**

ADVANCED CENTRAL RECEIVER SYSTEM
 281 MWe COMMERCIAL PLANT
 SUMMARY DATA
 (Sheet 1 of 2)

Net Electrical Power (MWe)	281
Parasitic Power (MWe)	
Daytime	31
Nighttime	16
Insolation (W/m ²)	950
Maximum Solar Power Absorbed (MWt)	1084
Nominal Solar Power Absorbed for Direct Operating (MWt)	723
Plant Net Efficiency (%)	25
Collector Field Configuration	Single 360 ^o , North Biased
Solar Multiple, Equinox Noon	1.5
Number of Heliostats	40,591
Heliostat Shape and Size [m (ft)]	Square, 7.38 x 7.42 (24.2 x 24.3)
Number of Towers/Receivers	1
Land Area (acre)	2220
Receiver Mid-Point Elevation [m (ft)]	268 (879)
Receiver Configuration	External Cylinder
Number of Receiver Panels	24
Receiver Height and Diameter [m (ft)]	22.8 x 22.8 (74.8 x 74.8)
Receiver Maximum Heat Flux (MW/m ²)	1.94
Sodium Temperatures [°C (°F)]	288/593 (550/1100)
Receiver Sodium Flow Rate [kg/hr (lb/hr)]	10.2 x 10 ⁶ (22.6 x 10 ⁶)
Steam Generator Sodium Flow Rate (Direct Operation) [kg/hr (lb/hr)]	6.82 x 10 ⁶ (15.0 x 10 ⁶)

ADVANCED CENTRAL RECEIVER SYSTEM
281 MWe COMMERCIAL PLANT

SUMMARY DATA
(Sheet 2 of 2)

Thermal Storage Capacity (MWth)	2350*
Total Sodium Inventory [kg (lb)]	23 x 10 ⁶ (50.4 x 10 ⁶)
Steam Generator and Reheater Type	Modular Steam Generator
Steam Conditions [MN/m ² , °C (psia, °F)]	
Initial	16.6, 538 (2400, 1000)
Reheated	538 (1000)
Steam Flow Rate [kg/hr (lb/hr)]	
Daytime	9.3 x 10 ⁵ (20.5 x 10 ⁵)
Nighttime	8.80 x 10 ⁵ (19.5 x 10 ⁵)
TSS Sodium Flow Rate [kg/hr (lb/hr)]	6.82 x 10 ⁶ (15.0 x 10 ⁶)
Feedwater Temperature [°C (°F)]	242 (468)
Turbine Back Pressure [MN/m ² (in. Hg)]	0.007 (2.0)
Heat Rejection [MW (Btu/hr)]	
Daytime	442 (1500 x 10 ⁶)
Nighttime	420 (1430 x 10 ⁶)

*Includes 180 MWt for startup/shutdown



DESIGN DATA SHEET

TITLE
281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem
WBS NO.

NUMBER
PAGE 1 of 14
DATE 5/16/78

PREPARED BY
APPROVED BY

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Receiver Subsystem</u>					
		Nominal Thermal Power	MWt	723			
		Maximum Thermal Power	MWt	1084			
		Receiver Temperature					
		- In	°C (°F)	288 (550)			
		- Out	°C (°F)	593 (1100)			
		Flow Rate - Max Receiver	Kg/hr (lb/hr)	10.2 x 10 ⁶ (22.6 x 10 ⁶)			
		- Max Steam Generator	Kg/hr (lb/hr)	7 x 10 ⁶ (15 x 10 ⁶)			
		Volume of Sodium in Subsystem	m ³ (gals)	459 (121,400)			
		Weight of Sodium in Subsystem	kg (lb)	.37x10 ⁶ (.823x10 ⁶)			
		Pump Outlet Pressure	MN/m ² (psia)	2.69 (390)			
		Pump Inlet Pressure	MN/m ² (psia)	0.10 (15)			
		Total Radiation and Convection Loss	%	9% @ Peak Power 12.5% @ 50% Power			

ESG-79-2, Vol II, Book 2
D-5



DESIGN DATA SHEET		TITLE 281 MWe Commercial Advanced Central Receiver Receiver Subsystem	NUMBER
		WBS NO.	DATE 5/16/78

PREPARED BY	APPROVED BY
--------------------	--------------------

PAGE 2 of 14

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Receiver Subsystem (Cont.)					
		Steam Generator Units Sodium Side					
		Superheat - Temp In	°C (°F)	593 (1100)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	462 (864)			
		- Power	MWt	212			
		Reheat - Temp In	°C (°F)	593 (1100)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	462 (864)			
		- Power	MWt	98			
		Evaporator - Temp In	°C (°F)	462 (864)			Tube and Shell Hockey Stick
		- Temp Out	°C (°F)	288 (550)			
		- Power Each Unit	MWt	206.5			
		Pumps - Number and Type		1			Two Units Fixed Speed, Double Suction Centrifugal, Single Stage
		Receiver - Size and Type	m x m (ft x ft)	22.8 x 22.8 (74.8 x 74.8)			External 24 Panel
		Large Valves, 97 cm (38) Block		2			CS, Riser and Pump Return
		97 cm (38) Check		1			CS, Riser
		71 cm (28) Block		1			SS, Downcomer
		61 cm (24) Control		1			SS, Superheater Control
		31 cm (12) Control		24			SS, Receiver Panel Control
		25 cm (10) Control		1			SS, Reheater Control

ESG-79-2, Vol 11, Book 2
D-6



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TER- MINATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Receiver Subsystem (Cont.)</u>					
		Large Pipe Length, 97 cm (38)	m (ft)	488 (1600)			CS
		52 cm (22)	m (ft)	549 (1800)			CS and SS
		30 cm (12)	m (ft)	249 (500)			SS
		<u>Receiver Assembly</u>					
		Diameter	m (ft)	22.8 (74.8)			
		Height	m (ft)	22.8 (74.8)			
		Receiver Mid-Point Elevation	m (ft)	268 (879)			
		Receiver Maximum Elevation	m (ft)	280 (918)			
		Number of Absorber Panels		24			
		Receiver Weight					
		Total	Kg (lb)	611 x 10 ³ (1.345 x 10 ⁶)			
		Pressure Parts	Kg (lb)				
		<u>Absorber Panel</u>					
		Height	m (ft)	22.8 (74.8)			
		Width	m (ft)	3.0 (9.8)			
		Dry Weight, Pressure Parts	kg (lb)				
		Number of Tubes					
		Tube OD	cm (in.)				3.2 (1.25)
		Tube ID	cm (in.)				2.9 (1.15)



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 4 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Absorber Panel (Cont.)</u>					
		Tube Material		CRES 304H			
		Solar Surface Coating		Pyromark			
		Panel Insulation	cm (in.)	15.2 (6)			Closed-Pore Fiberglass
		Thermal Expansion	cm (in.)	18.3 (7.2)			Flexible Tube Bends
		Absorptivity, Minimum		0.95			
		Peak Heat Flux ₂ (Btu/in ² - sec)	MW/m ²	1.60			
		Outlet Temperature	°C (°F)	593 (1100)			
		Inlet Temperature	°C (°F)	288 (550)			
		Maximum Tube Surface Temperature	°C (°F)	635 (1175)			
		<u>Tower Assembly</u>					
		Construction					Slip Formed Concrete
		Concrete Height	m (ft)	248 (813)			
		Diameter - Base	m (ft)	(130)			
		- Top	m (ft)	(50)			
		Wall Thickness - Base	m (ft)	0.5 (1.7)			
		- Top	m (ft)	0.3 (.9)			
		Mat - OD	m (ft)	61 (200)			
		- ID	m (ft)	23 (75)			
		- Thickness	m (ft)	4 (13)			

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
D-8



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 5 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Riser</u>					
		Nominal Pipe ID	cm (in.)	97 (38)			
		Nominal Wall Thickness		TBD			
		Material		CS			
		Design Temperature	°C (°F)	371 (700)			
		Design Pressure ANSI B31.1		2.76 (400)			
		Maximum Flow Rate	kg/hf (lb/hr)	10.2 x 10 ⁶ (22.6 x 10 ⁶)			
		Velocity at Maximum Flow Rate	m/sec (ft/sec)	4.42 (14.5)			
		<u>Downcomer</u>					
		Nominal Pipe ID	cm (in.)	52 (22)			
		Nominal Wall Thickness		TBD			
		Material		304H			
		Design Temperature	°C (°F)	593 (1100)			
		Design Pressure ANSI B31.1		2.76 (400)			
		Maximum Flow Rate	kg/hf (lb/hr)	10.2 x 10 ⁶ (22.6 x 10 ⁶)			
		Velocity at Maximum Flow Rate	m/sec (ft/sec)	14.3 (46.9)			
		<u>Surge Tank</u>					
		Diameter	m (ft)	7.6 (25)			
		Height	m (ft)	4.5 (15)			
		Wall	cm (in.)	1 (.5)			



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 6 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Receiver Pump					Double Suction
		<u>Physical Description</u>					
		Quantity		1			
		Number of Stages		1			
		Height, w/motor	m (ft)	10.6 (35)			
		Tank Size	m (ft)	4 (13.7)			
		Inlet Nozzle	m (in.)	97 (38)			
		Outlet Nozzle	m (in.)	97 (38)			
		Dry Weight Pump	kg (lb)	117,132 (258,000)			
		<u>Motor</u>					
		Size	MW (hp)	13 (18,000)			
		Dimensions w/coupling	m (ft)	2.6/3.3 (8.6/11)			
		Voltage	v	4160			
		Cooling		TBD			
		Weight	kg (lb)	16 (30,000)			

ESG-79-2, Vol 11, Book 2
D-10



DESIGN DATA SHEET

TITLE
281 MWE Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 7 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Pump Operating Conditions</u>					
		Developed Head	m (ft)	310 (1016)			
		Flow Rate	kg/hr (lb/hr)	10.2 x 10 ⁶ 22.5 x 10 ⁶			
		Speed	rpm	1130			
		Temperature	°C (°F)	288 (550)			
		Sodium Volume	m ³ (gal)	10.3 (366)			
		NPSH	m (ft)	9.1 (30)			
		Speed Control	%	Fixed Speed			
		Pump Power ($\eta = 78\%$)	kW (hp)	12.6 (17,000)			
		<u>Design Conditions</u>					
		Developed Head	m (ft)	325 (1066)			
		Flow Rate	m ³ /s (gpm)	3.8 (60,000)			
		Speed	rpm	1130			
		Temperature	°C (°F)	300 (600)			
		NPSH (Minimum Required)	m (ft)	9.1 (30)			
		Code					Sect. VIII, Div. 1



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 8 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Steam Generator-Evaporator					
		<u>Physical Description</u>					
		Quantity		2			
		Type					Tube & Shell Hockey Stick
		Height	m (ft)	29 (95)			
		Width	m (ft)	4.9 (16)			
		Shell diameter	m (in.)	1.6 (62)			
		Heat Transfer Area	m ² (ft ²)	1812 (19500)			For each unit
		Number of Tubes		1530			For each unit
		Tube Size	cm (in.)	1.6 (5/8)			
		Tube Wall Thickness	cm (in.)	.21 (0.082)			
		Material		2-1/4 Cr - 1 Mo			
		Tubesheet Diameter/Thickness	cm (in.)	157/36 (62/14)			
		Weight	kg (ton)	82,000 (90)			

ESG-79-2, Vol II, Book 2
D-12



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 9 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Operating Conditions (Evaporator)</u>					
		Sodium Side:					
		Flow	kg/hr (lb/hr)	6.8 x 10 ⁶ (15 x 10 ⁶)			2 Units
		Inlet Temperature	°C (°F)	462 (864)			
		Outlet Temperature	°C (°F)	288 (550)			
		Pressure Drop	MN/m ²	0.207 (30)			
		Duty Each Unit	MWt	206			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	0.92 x 10 ⁶ (2.02 x 10 ⁶)			
		Inlet Temperature	°C (°F)	242 (468)			
		Outlet Temperature	°C (°F)	364 (687)			
		Pressure	MN/m ²	19.50 (2830)			
		Pressure Drop	MN/m ² (psi)	2.07 (300)			
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psi)	2.07 (300)			
		Pressure-Steam Side	MN/hr ² (psig)	20 (2900)			
		Temperature	°C (°F)	482 (900)			
		Code				ASME Section VIII, Div. 1	

ESG-79-2, Vol II, Book 2
D-13



Atomics International Division
Rockwell International

DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 10 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Steam Generator - Superheater					
		<u>Physical Description</u>					
		Quantity		1			
		Type					Tube & Shell Hockey-Stick
		Height	m (ft)	27.7 (91)			
		Width	m (ft)	4.57 (15)			
		Shell Diameter	m (ft)	1.02 (40)			
		Heat Transfer Area	m ² (ft ²)	735 (7920)			
		Number of Tubes		620			
		Tube Size	cm (in.)	1.6 (5/8)			
		Tube Wall Thickness	cm (in.)	0.3 (0.135)			
		Material		SS 316			
		Tubesheet Diameter/Thickness	cm (in.)	1.01 x 28 (40 x 11)			
		Weight	kg (ton)	38,000 (36)			

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
D-14



DESIGN DATA SHEET

TITLE **281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem**

NUMBER

PREPARED BY

APPROVED BY

PAGE 11 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Operating Conditions - Superheater</u>					
		Sodium Side:					
		Flow	kg/hr (lb/hr)	4.6 x 10 ⁶ (10.25 x 10 ⁶)			
		Inlet Temperature	°C (°F)	594 (1100)			
		Outlet Temperature	°C (°F)	462 (864)			
		Pressure Drop	MN/m ² (psi)	0.207 (30)			
		Duty (Mwt)		210			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	9.2 x 10 ⁵ (2.02 x 10 ⁶)			
		Inlet Temperature	°C (°F)	353 (668)			
		Outlet Temperature	°C (°F)	538 (1000)			
		Pressure	MN/m ² (psig)	17 (2500)			
		Pressure Drop	MN/m ² (psi)	1.77 (256)			

ESG-79-2, Vol. II, Book 2
D-15



DESIGN DATA SHEET

TITLE
281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER
PAGE 12 of 14
DATE 5/16/78

PREPARED BY
APPROVED BY

WBS NO.

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Superheater: (Continued)</u>					
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psig)	2.07 (300)			
		Pressure-Steam Side	MN/m ² (psig)	19.3 (2800)			
		Temperature	°C (°F)	593 (1100)			
		Code					ASME, Section VIII, Division 1
		Steam Generator - Reheat					
		<u>Physical Description</u>					
		Quantity		1			
		Type					Tube & Shell Hockey-Stick
		Height	m (ft)	21.9 (72)			
		Width	m (ft)	4.27 (14)			
		Shell Diameter	m (ft)	1.02 (40)			
		Heat Transfer Area	m ² (ft ²)	521 (5610)			
		Number of Tubes		264			
		Tube Size	cm (in.)	3.49 (1-3/8)			
		Tube Wall Thickness	cm (in.)	0.28 (0.11)			
		Material		SS 316			

ESG-79-2, Vol II, Book 2
D-16



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 13 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Reheat (Continued)					
		Physical Description (Continued)					
		Tubesheet Diameter/Thickness	cm (in.)	101x15 (40x6)			
		Weight	kg (ton)	36,000 (40)			
		Operating Conditions					
		Sodium Side:					
		Flow	kg/hr (lb/hr)	2.15 x 10 ⁶ 4.74 x 10 ⁶			
		Inlet Temperature	°C (°F)	594 (1100)			
		Outlet Temperature	°C (°F)	462 (864)			
		Pressure Drop	MN/m ² (psi)	0.207 (30)			
		Duty	MWt	98			
		Water/Steam:					
		Flow	kg/hr (lb/hr)	8 x 10 ⁵ (17.6 x 10 ⁵)			
		Inlet Temperature	°C (°F)	342 (647)			
		Outlet Temperature	°C (°F)	538 (1000)			
		Pressure	MN/m ² (psig)	3.36 (487)			
		Pressure Drop	MN/m ² (psi)	.18 (26)			



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Receiver Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 1412 of 14

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		Reheat (Continued)					
		Design Conditions:					
		Pressure-Sodium Side	MN/m ² (psig)	2.07 (300)			
		Pressure-Steam Side	MN/m ² (psig)	3.65 (530)			
		Temperature	°C (°F)	593 (1100)			
		Code					ASME, Section VIII, Division 1

ESG-79-2, Vol II, Book 2
D-18

281 MWe COMMERCIAL PLANT
THERMAL STORAGE SUBSYSTEM
ALL-SODIUM STORAGE



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 1 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Thermal Storage Subsystem</u>					
		Storage Material		Sodium			
		Number of Tanks		2			
		Thermal Storage Capacity	MWt hr	2350			Includes 180 MW _{th} for Startup and Shutdown (15 min. @ 723 MWt)
		Maximum Charging Rate	MWt	1084			
		Maximum Extraction Rate	MWt	723			
		Time at Maximum Extraction Rate	hr	3			
		Weight of Sodium in Subsystem	kg (lb)	22.16 x 10 ⁶ (48.75 x 10 ⁶)			
		Temperature - Hot Tank Storage	°C (°F)	593 (1100)			
		- Cold Tank Storage	°C (°F)	288 (550)			
		Pump - Number and Type		1			Variable Speed, Single Stage Centrifugal
		Large Valves - 97 cm (38) Block		2			CS and SS
		- 52 cm (22) Drag		1			SS
		Large Pipe Length - 97 cm (38)	m (ft)	91 (300)			CS, Standard Wall
		- 52 cm (22)	m (ft)	122 (400)			SS, Standard Wall



Atomics International Division
Rockwell International

DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Low Temperature Sodium Tank</u>					
		Number		1			
		Type					Cylindrical API Type
		Diameter	m (ft)	42.7 (140)			
		Height	m (ft)	213 (70)			
		Wall Thickness					
		Top	cm (in.)	0.64 (0.25)			
		Bottom	cm (in.)	4.4 (1.75)			
		Volume	m ³ (gal)	3.05 x 10 ⁴ (8.05 x 10 ⁶)			
		Tank Material					Carbon Steel
		Insulation, Roof and Walls	cm (in.)	15.2 (6)			Calcium Silicate with Aluminum Weather Protection
		Base Insulation	m (ft)	1 (3)			Perlitic Concrete
		Electric Preheat-Temperature Maintenance	kw	274			
		Low Sodium Temperature	°C (°F)	288 (550)			
		Ullage Maintenance Unit					
		Ullage Pressure	Pa (psi)	0.0069 (1)			
		Pressurization Media		Argon			

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
D-21



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 3 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>High Temperature Sodium Tank</u>					
		Type		Cylindrical API Type			
		Diameter	m (ft)	42.7 (140)			
		Height	m (ft)	21.3 (70)			
		Wall Thickness					
		Top	cm (in.)	0.64 (0.25)			
		Bottom	cm (in.)	4.4 (1.75)			
		Volume	m ³ (gal)	3.05 x 10 ⁴ (8.05 x 10 ⁶)			Includes capacity for receiver subsystem plus 10% ullage
		Tank Material					Type 304 SS
		Insulation, Roof and Walls	cm (in.)	30.5 (12)			Calcium Silicate with Aluminum Weather Protection
		Base Insulation	m (ft)	1 (3) Perlitic Concrete			
		Electric Preheat-Temperature Maintenance	kw	540			
		Number of High Temperature Tanks		1			
		High Sodium Temperature	°C (°F)	593 (1100°F)			
		Ullage Maintenance Unit		Argon			



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 4 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEM- TATNE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		STEAM GENERATOR PUMP					
		<u>Physical Description</u>					
		Quantity		1			
		Number of Stages		1			
		Height, w/motor	m (ft)	10 (34)			
		Tank Size	m (ft)	1.6 (5.4)			
		Inlet Nozzle	m (in.)	97 (38)			
		Outlet Nozzle	m (in.)	71 (28)			
		Dry Weight, Pump	kg (lb)	14,000 (31,000)			
		<u>Motor</u>					
		Size	MW (hp)	2.2 (3000)			
		Dimensions w/coupling	m (ft)	2.2 x 5 (7.2 x 17)			
		Voltage	v	4160			
		Cooling		TBD			
		Weight	kg (lb)	5556 (12,240)			



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Thermal Storage Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 5 of 5

WBS NO.

DATE 5/16/78

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Pump Operating Conditions</u>					
		Developed Head	m (ft)	65 (215)			
		Flow Rate	kg/hr (lb/hr)	7 x 10 ⁶ (15 x 10 ⁶)			
		Speed	rpm	1160			
		Temperature	°C (°F)	593 (1100)			
		Sodium Volume	m ³ (gal)	8 (2000)			
		NPSH	m (ft)	9.1 (30)			
		Speed Control	%	10-100			
		Pump Power ($\eta = 85\%$)	MW (hp)	2.64 (2510)			
		<u>Design Conditions</u>					
		Developed Head	m (ft)	76 (250)			
		Flow Rate	m ³ /sec (gpm)	2.63 (42,000)			
		Speed	rpm	1160			
		Temperature	°C (°F)	593 (1100)			
		NPSH (Minimum Required)	m (ft)	7.6 (25)			
		Code					Section VIII, Div. I

ESG-79-2, Vol II, Book 2
D-24



DESIGN DATA SHEET

TITLE 281 MWe Commercial

NUMBER

PREPARED BY

APPROVED BY

PAGE

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Drag Valve</u>					
		Location					Upstream of High Temperature Sodium Storage Tank
		Type					Babcock-Wilcox Drag Valve with Velocity Control Elements Type SL 11
		Size (nominal)	inches	22			
		Flow Rate	$\frac{m^3}{5 \text{ (gpm)}}$	3.79 (60,000)			
		Pressure Rate	$\frac{mn}{m^2 \text{ (psi)}}$	2.24 (326)			
		Pressure Rating	$\frac{mn}{m^2 \text{ (psi)}}$	3.44 (500)			
		Temperature	$^{\circ}C \text{ (}^{\circ}F)$	649 (1200)			
		Flow Coefficient, C_v	$\frac{m^3/sec}{\sqrt{mn/m^2}}$ ($\frac{gpm}{\sqrt{psi}}$)	2.52 (3323)			
		Operator					Yes--Type TBD
		Insulation	inches	8			Calcium Silicate
		Material					Stainless Steel; Inconel
		Pressure Class					Velocity Control Elements ANSI 2500 1b

**281 MW COMMERCIAL PLANT
COLLECTOR**



DESIGN DATA SHEET

TITLE
 ADVANCED CENTRAL RECEIVER
 COLLECTOR SUBSYSTEM
 (281 MWe SYSTEM)

NUMBER

PREPARED BY

APPROVED BY

PAGE 1 of 3


WBS NO.

DATE August 20, 1978

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>GENERAL</u>					
		TOTAL FIELD AREA (EXCLUDING CENTRAL EXCLUSION)	10 ⁶ m ² (10 ⁶ ft ²)	8.86 (95.3)			
		NUMBER OF HELIOSTATS	--	40,591			
		TOTAL MIRROR AREA	10 ⁶ m ² (10 ⁶ ft ²)	1.989 (21.4)			
		PEAK POWER @ 950 w/m ²	MW	1,087			
		ANNUAL COLLECTABLE ENERGY	MWh _t	2.685 x 10 ⁶			
		TOWER HEIGHT	m (ft)	249.5 (818)			
		RECEIVER CENTERLINE ELEVATION	m (ft)	268 (879)			
		HELIOSTAT ARRANGEMENT	--	RADIAL STAGGER			
		AIM STRATEGY	--	MULTI POINT VERTICAL AIM			
		PEAK RECEIVER HEAT FLUX	MW/m ²	1.60			

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
 D-27



DESIGN DATA SHEET

TITLE
**ADVANCED CENTRAL RECEIVER
 COLLECTOR SUBSYSTEM
 (281 MWe SYSTEM)**

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 3

WBS NO.

DATE August 20, 1978

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FORM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>HELIOSTAT</u>					
		REFLECTOR SHAPE	--	RECTANGULAR			
		REFLECTOR ENVELOPE	m (ft)	7.38 x 7.42 (24.21 x 24.33)			
		MIRROR TYPE		SECOND SURFACE, SILVERED FUSION/FLOAT LAMINATED GLASS			
		MIRROR AREA	m ² (ft ²)	49.05 (528)			
		AVERAGE REFLECTIVITY		0.91			
		DRIVE SYSTEM		DUAL SCREW JACKS			
		ELEVATION		3 Ø, 480V ac			
		AZIMUTH		HARMONIC DRIVE 3 Ø, 480V ac			
		REFLECTED BEAM ACCURACY	(mr)	2.83			
		DRIVE RATE					
		ELEVATION	Deg/min	15			
		AZIMUTH	Deg/min	15			



DESIGN DATA SHEET

TITLE
 ADVANCED CENTRAL RECEIVER
 COLLECTOR SUBSYSTEM
 (281 MWe SYSTEM)

NUMBER
 PAGE 3 of 3

PREPARED BY

APPROVED BY

WBS NO.

DATE August 20, 1978

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		CANT RANGE	m (ft)	∞			
		ELECTRICAL DRAW					
		MOTOR RUNNING (STEADY STATE)	amp	1.5			
		MOTOR START SURGE CURRENT	amp	3.0			
		TIME AVERAGE POWER DRAW (PER HELIOSTAT INCL ELECTRONICS)	WATTS	~39			
		INDIVIDUAL HELIOSTAT AVAILABILITY	--	0.9999			
		<u>FIELD ELECTRONICS</u>					
		PRIMARY FEEDER POWER	VOLTAGE	4160			
		PRIMARY FEEDER CABLE	AWG	#4			
		SECONDARY FEEDER POWER	VOLTAGE	480			
		DATA NETWORK	--	FIBER OPTICS			

ESG-79-2, Vol I I, Book 2
 D-29

**281 MW COMMERCIAL PLANT
ELECTRIC POWER GENERATION**



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Electrical Power Generation
Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 1 of 3

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Turbine</u>					
		Type	Initial Pressure	MPa (psig)	16.5 (2400)		Tandem Compound, Double-Flow, Extraction, condensing Turbine $\eta = .4316$
			Initial Temperature	$^{\circ}\text{C}$ ($^{\circ}\text{F}$)	538 (1000)		
		Rating	Reheat Temperature	$^{\circ}\text{C}$ ($^{\circ}\text{F}$)	538 (1000)		
				kWe	312,200		
		Heater Extractions			7		
		Shaft Speed		rpm	3,600		
		Last Stage Bucket Size		cm (in.)	85.1 (33.5)		
		Throttle Flow Control Mode					
		Heat Rate		Btu/KWH	7,907		Steam Generator/Turbine Coordinated Control
		<u>Generator</u>					
		Generator Rating		(kVA)	365		
		Power Factor			0.9		
		Output Voltage		volts	22,000		
		Frequency		Hz	60		
		Cooling					Hydrogen Cooled
		Exciter					Static Excitation System
		Shaft Speed		rpm	3,600		
		<u>Condenser</u>					
		Type					Shell and Tube, 2-Pass
		Surface		m^2 (ft^2)	23,875 (257,000)		
		Tube Material			90-10 Copper-Ni		ASTM BIII, Alloy 706
		Tube Diameter OD			28.6 (1.125)		
		Tube Wall Thickness, 20 BWG [m (in.)]			0.89 (0.035)		

FORM 706-A REV 2-74

ESG-79-2, Vol II, Book 2
D-31



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Electrical Power Generation
Subsystem

NUMBER

PREPARED BY

APPROVED BY

PAGE 2 of 3

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Condenser (Continued)</u>					
		Tube Length, Effect	[m (ft)]	9.75 (32.0)			
		Condenser Pressure	[kPa (in.-HgA)]	6.77 (2.0)			
		Heat Rejection	[MW (Btu/hr)]	453 (1546 x 10 ⁶)			
		Cooling Water Flow	[m ³ /s (gpm)]	16.8 (266,500)			
		Water Velocity	[m/s (fps)]	2.1 (7.0)			
		Cooling Water In	[°C (°F)]	28.9 (84.0)			
		Cooling Water Out	[°C (°F)]	35.3 (95.6)			
		Condenser Air Removal		-			Mechanical Vacuum Pump (2-full capacity)
		<u>Cooling Tower</u>					
		Quantity		1			
		Type					Mechanical Draft, Cross Flow
		Number of Cells		15			
		Fan Motor Size	[kW (hp)]	5-150 (200)			
		Design Wet Bulb Temperature	[°C (°F)]	23 (74.0)			
		Cold Water Temperature	[°C (°F)]	28.9 (84.0)			
		Hot Water Temperature	[°C (°F)]	35.3 (95.6)			
		Circulating Water Flow	[m ³ /s (gpm)]	17.4 (275,800)			
		Heat Rejection	[MW (Btu/hr)]	469 (1600 x 10 ⁶)			



DESIGN DATA SHEET

TITLE 281 MWe Commercial
Advanced Central Receiver
Electrical Power Generation
Subsystem

NUMBER

PAGE 3 of 3

PREPARED BY

APPROVED BY

WBS NO.

DATE

NEW REV.	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
		<u>Feedwater Heaters</u>					
		Low Pressure Heater Number	3				Horizontal, Stainless Steel Tubes, Carbon Steel Shell with Drain Cooler, Maximum Tube Side Pressure: 2.2 kPa (315 psia)
		Deaerator Number	1				Stainless Steel Trays and Vent Condenser, Carbon Steel Shell, Horizontal Condensate Storage Section 165 m ³ (43,600 gal)
		High Pressure Heaters Number	3				Pressure Rating; 0.45 MPa (65 psia) Horizontal, Carbon Steel Tubes, Carbon Steel Shell with Drain Cooler, Maximum Tube Side Pressure: 27.6 MPa (4,000 psia)
		<u>Feedwater Treatment</u>					
		Equipment					
		- Inline Polishing Demineralizers					2 Full-Capacity Units
		- Makeup Water Demineralizers					2 Full-Capacity Units
		Chemicals					
		- pH Control					Ammonia
		- Oxygen Scavenger					Hydrazine

ESG-79-2, Vol II, Book 2
D-33

281 MWe COMMERCIAL PLANT

MASTER CONTROL



Atomic International Division
Flackwell International

DESIGN DATA SHEET

TIT.

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (281 MW)

PAGE 1

WBS NO.

DATE 8-21-78

NEW REV	NO.	ITEM	DESIGN POINT		TEN- TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	1	PLANT CENTRAL CONTROL CONSOLE (1)					
		LENGTH	FT.	25	X		
		DEPTH	FT.	2	X		
		HEIGHT	FT.	4	X		
N	2	CONTROL PROCESSORS (6)					
		THROUGHPUT	KOPS/SEC	350	X		
		PRIMARY STORAGE CAPACITY	16BIT WORDS	48,000	X		
N	3	SECONDARY CONTROL PROCESSOR STORAGE (6)					
		CAPACITY	MEGABITS	.25	X		
		ACCESS TIME	MSEC.	35	X		
		LATENCY	MSEC.	15	X		
N	4	HARDCOPY LOGGER (2)					
		CHARACTERS	PER LINE	132	X		
		SPEED	LINES/MIN	300	X		
N	5	RECORDERS, MAGNETIC (2)					
		DENSITY	BITS/INCH	500/800	X		
		SPEED	IN/SEC	45			
N	6	SAFING - CONTROL PANEL (1)	TBD	TBD			
N	7	SERIAL DIGITAL DATA BUS (2)					
		THROUGHPUT	KBITS/SEC	1500	X		
N	8	COLOR CRT DISPLAYS (6)					
		RASTER SCAN	NO. LINES	256 x 512	X		
		COLORS	NO.	4			

ESG-79-2, Vol II, Book 2
D-35



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (281 MW)


PAGE 2

WBS NO.

DATE 8-21-78

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	9	PID CONTROLLERS (100)					
		MICROPROCESSOR LOOP UPDATE RATE	PER SEC.	3	X		
		SCALING	%	0 - 100	X		
		RESOLUTION	BITS	12			
		OUTPUT	MV	4-20			
N	10	DISCRETE CONTROLLERS (125)					
		RESOLUTION	BITS	12	X		
		OUTPUT	MV	4 - 20			
N	11	ANALOG DATA ACQUISITION (350)					
		NORMAL RATE	CHAN/SEC	350	X		
		EMERGENCY RATE	CHAN/SEC	200,000			
		RESOLUTION	BITS	12			
		MULTIPLEXING	TYPE	SEQUENTIAL			
N	12	ANALOG OUTPUTS (TBD)	TBD	TBD	X		
N	13	CLOSED CIRCUIT TELEVISION (4)					
		MONITOR SIZE	IN	19	X		
		CAMERA	TBD	TBD			
		AUTO PAN/TILT	DEGREES	90			
		ZOOM	TBD	TBD			
N	14	UNINTERRUPTIBLE POWER SOURCE					
		10 INPUT	VAC	115 ± 10%			
		REGULATED 10 OUTPUT	VAC	115 ± 2%			
		STORAGE BATTERY	HRS	.5			
		CAPACITY					
		DERATED POWER	KVA	TBD			

ESG-79-2, Vol II, Book 2
D-36



DESIGN DATA SHEET

TITLE

NUMBER

PREPARED BY

APPROVED BY

MASTER CONTROL (281 MW)

PAGE 3

WBS NO.

DATE 8-21-78

NEW REV	NO.	ITEM	DESIGN POINT		TEN-TATIVE	FIRM	REFERENCES AND REMARKS
			UNIT	VALUE			
N	15	TIME OF DAY REFERENCE INPUT-WWV SYNCH. OUTPUT - TIME OF DAY BCD FORMAT	HERTZ	1000	X		
			BITS	32	X		
			FUNCTIONS	25	X		
N	16	ANNUNCIATOR PANEL			X		
N	17	LOCAL WEATHER STATION WIND BAROMETRIC PRESSURE HUMIDITY SOLAR RADIATION PRECIPITATION TEMPERATURE	MPH	80	X		
			DEGREES	360			
			IN/HG	26 - 34			
			PERCENT/REL	0 - 100			
			9M/CM ² /MIN	.36 - 2.0 MICRONS			
			IN DEG F	20 -15, +50			

ESG-79-2, Vol II, Book 2
D-37

APPENDIX E
STEAM GENERATOR SYSTEM CONCEPTUAL DESIGN


AI Technical Information

Document N272TI000002

ESG-79-2, Vol II, Book 2

E-1

APPENDIX E

 Rockwell International <small>Aerospace International Division</small>		SUPPORTING DOCUMENT		NUMBER N272TI000002	REV LTR/CHG NO. SEE SUMMARY OF CHG												
PROGRAM TITLE Advanced Central Receiver Power System (ACRPS)				DOCUMENT TYPE Technical Information													
DOCUMENT TITLE Steam Generator System Conceptual Design				KEY NOUNS Solar, Steam Generator													
PREPARED BY/DATE M. J. Gabler <i>M. J. Gabler</i>				ORIGINAL ISSUE DATE March 8, 1978													
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				GO NO. 09272	S/A NO. 12000												
APPROVALS <i>T. Johnson 3/2/78</i> <i>E. Moody 2/27/78</i> <i>T. H. Springer 3/7/78</i>				PAGE 1 OF 30 TOTAL PAGES 31 REL. DATE 3-9-78 BK													
DISTRIBUTION				SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)													
<table border="1"> <thead> <tr> <th>* NAME</th> <th>MAIL ADDR</th> </tr> </thead> <tbody> <tr> <td>* M. Gabler</td> <td></td> </tr> <tr> <td>* L. Glasgow</td> <td></td> </tr> <tr> <td>* T. Johnson</td> <td></td> </tr> <tr> <td>* E. Moody</td> <td></td> </tr> <tr> <td>* T. Springer (3)</td> <td></td> </tr> </tbody> </table>				* NAME	MAIL ADDR	* M. Gabler		* L. Glasgow		* T. Johnson		* E. Moody		* T. Springer (3)		ERDA <input checked="" type="checkbox"/> DOD <input type="checkbox"/> UNCL <input checked="" type="checkbox"/> CONF. <input type="checkbox"/> SECRET <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/> DEFENSE INFO. <input type="checkbox"/>
* NAME	MAIL ADDR																
* M. Gabler																	
* L. Glasgow																	
* T. Johnson																	
* E. Moody																	
* T. Springer (3)																	
ABSTRACT The conceptual design of the steam generator modules for the ACRPS is presented. Supporting materials used in the selection of the reference steam cycle are included. The ACRPS employs liquid sodium as a heat transfer medium, so the steam generators are sodium heated.				AUTHORIZED CLASSIFIER _____ DATE _____													
RESERVED FOR PROPRIETARY/LEGAL NOTICES																	
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																	

FORM 734-C REV. 11-75

CONTENTS

I.	Introduction	2
II.	Steam Cycle Selection	2
	A. Review of Prior Trade Studies	2
	1. "Reheat vs Nonreheat Trade Study," November 1971 (Reference 1)	2
	2. "Status of LMFBR Reheat in Western Europe - 1972" (Reference 2)	3
	3. "Steam Pressure Selection for Demonstration Plant," January 1973 (Reference 3)	6
	4. "PLBR/CBR Design Point Trade Study," July 1976 (Reference 4)	6
	B. Economic/Comparison	9
	1. Steam Generator Material	9
	2. Reheat	12
	3. Optimization	14
III.	Operating Considerations	19
	A. Normal Power Operation	19
	B. Basic Transients	25
	C. Startup/Shutdown	25
IV.	Reference System Design	26
V.	References	30

I. INTRODUCTION

This study considers various aspects of the steam generator system for the Advanced Central Receiver Power System (ACRPS). The ACRPS employs sodium as a heat transfer medium, so the steam operators are sodium heated. Requirements for the steam generator system are somewhat similar to those of the Liquid Metal Fast Breeder Reactor (LMFBR) systems resulting in a broad base for design of the steam generator system for the ACRPS. However, the ACRPS steam generator application places some new requirements on the steam generator system and on the steam generator modules in particular. These requirements in the areas of steam cycle, transients, startup/shutdown, and component design are discussed in this report.

II. STEAM CYCLE CONSIDERATIONS

A. PAST TRADE STUDIES

Previous trade studies and applicable reports on the subject of reheat and steam cycle selection were reviewed. The earlier AI studies always showed the sodium reheat cycle to be the most advantageous, but the desire for a high probability of success led DOE to select a non-reheat cycle approach in 1972 for the demonstration plant. Since that time sodium reheat has not been seriously considered by AI for LMFBR application. A brief synopsis of several reports and trade studies follows.

1. "Reheat vs Nonreheat Trade Study," November 1971 (Reference 1)

This trade study compared sodium reheat, steam reheat, and nonreheat cycles with the objective of presenting relative merits regarding the selection of the steam cycle for the FBR Demonstration Plant. The sodium reheat cycle was shown to have advantages relative to (1) efficiency and (2) capital and operating costs relative to the steam reheat and nonreheat. The steam reheat cycle traded off risk in sodium components for risk in steam components, while the nonreheat cycle was shown to have an advantage in control and operational simplicity.

The study considered five cycles:

- 1) sodium reheat (2500 psig/900⁰F/900⁰F)
- 2) live steam reheat (2400 psig/900⁰F/635⁰F)
- 3) extraction steam reheat (2400 psig/900⁰F/600⁰F)
- 4) no reheat (2400 psig/900⁰F)
- 5) no reheat (1450 psig/900⁰F)

The fourth cycle, high pressure/nonreheat, was eliminated due to required turbine development and external moisture separator complexity required for that cycle. The fifth cycle, low pressure/nonreheat, was found to require the minimum overall sodium-to-steam heat transfer surface area due to larger sodium-to-steam temperature difference.

It was concluded that the only cycle considered that could employ a standard turbine was the sodium reheat cycle. The other cycles would require significant changes to standard turbine designs.

The report also summarized previous studies, showing that most prior studies had concluded that commercial plants should employ sodium reheat because of improved overall economics. This summary is presented in Table 1.

2. "Status of LMFBR Reheat in Western Europe - 1972" (Reference 2)

This trip report discussed the findings of a US delegation during a trip to France, Germany, Netherlands, and UK. The purpose of the trip was to determine the status of European LMFBR sodium/steam cycles as input to US selection for the Demonstration Plant (CRBRP).

Initial use of sodium reheat by the Europeans was based upon the availability of turbines. (As noted in the prior trade study, sodium reheat was necessary to utilize a standard turbine.) Subsequent re-evaluation of the selection of sodium reheat was made by the SNR consortium and the French, and showed both economic and reliability advantages

TABLE I. SUMMARY OF PREVIOUS STEAM CYCLE STUDIES

STUDY	ALTERNATIVES CONSIDERED	PREFERRED CYCLE		REMARKS
United Engineers 500 Mw and 1000 Mw 1966 - Ref. 3	<p>Sodium Reheat { 1. 3500/1000/1000 2. 2400/1000/1000 3. 2400/950/950 4. 1800/900/900</p> <p>Non-Reheat { 1. 1450/1000 2. 1000/Dry and saturated</p>	Demonstration Plant Sodium reheat: 2400/ 1000/1000 (lowest \$/kw)	Commercial Plant -Same-	
Westinghouse 1000 Mw 1968 - Ref. 4	<p>Sodium Reheat (2400/900/900) Non-reheat (2400/900) Steam Reheat (2400/900/1800) less depth</p>		Non-Reheat (2400/900), with external and internal moisture separation	Sodium reheat case penalized since steam generator combined evaporator and superheater (small LMTD in reheater). See also Ref. 6, 10, below. Steam reheat was as same as non-reheat, ∴ non-reheat selected. Cross compound turbine for sodium reheat (3600/1800 rpm), tandem compound for non-reheat (further penalizes cost of sodium reheat).
Brown-Boveri 500 Mw 1968 - Ref. 5	<p>Sodium Reheat (2400/900/900) Evaporator Steam Reheat (2400/900/635)</p>	Sodium Reheat: 2400/ 900/900		Evaporator Steam { (Best steam cycle (Brown Boveri) (Worst steam cycle (Bechtel - Ref. 9))
AI - Internal Report 500 Mw 1968 - Ref. 6	<p>Sodium Reheat (2400/900/900) Non-Reheat (2400/900)</p>	Sodium Reheat: 2400/900/900		Non-reheat preferred if evaporator and superheater are combined into single unit (see also Ref. 2 above)
Babcock and Wilcox 1000 Mw 1968 - Ref. 7	<p>Sodium Reheat { 1. 3500/1000/1000 2. 2400/1000/1000 3. 2400/950/950 4. 1800/900/900</p> <p>Live Steam Reheat (2400/950/850)</p> <p>Non-Reheat { 1. 2400/950 2. 1450/1000 3. 1000/dry and saturated</p>		Sodium Reheat: 2400/950/950	Only brief attention to steam reheat and here they put the high pressure steam (2700 psig) on the shell side....? Reactor outlet temp. varied from 1050 to 1156F. There exists a "definite incentive for reheat" for the 2400/950/NRH cycle.
General Electric 1200 Mw 1969 - Ref. 8	<p>Sodium Reheat (2400/950/950) Non-Reheat (2400/variable (975P optimum))</p>		Sodium Reheat: 2400/950/950	Separate evap/sup. allowed optimum Na reheater arrangement.
Bechtel 500 Mw 1970 - Ref. 9	<p>Sodium Reheat (2400/900/900) Live steam reheat (2400/900/635) Internal steam reheat (2400/900/600) Evaporator steam reheat (2400/900/635)</p>	Sodium Reheat: (2400/900/900)		"While the sodium reheat cycle is more complex than a non-reheat cycle, the control problems involved appear to be manageable." Internal reheat is the "best" steam steam reheat cycle and is still inferior to a non-reheat cycle. (Reason appears to be mainly due to low capital cost estimate from <u>1</u> on turbine price quote).
Westinghouse 1000 Mw 1971 - Ref. 10	<p>Many (15 total): All variations of sodium reheat, including reheat. vs. once-through, combined vs. separate evap/superheater. Also, internal steam reheat and non-reheat (no moisture separator since its 2400/1000)</p>			Only a new steam generator concept was recommended (modular units, J-tube, separate evap/S.H. modules). This report also summarizes principal reasons why conclusions in Ref. 4 above are no longer valid. (Early once-through, single shell, serpentine tube steam generator not advised anymore).

TABLE I. SUMMARY OF PREVIOUS STEAM CYCLE STUDIES (Cont.)

STUDY	ALTERNATIVES CONSIDERED	PREFERRED CYCLE		REMARKS
		Demonstration Plant	Commercial Plant	
Ferratom (SNR) 500 Mwe 1971 - Ref. 11	Sodium Reheat (2400/930/930) Live Steam Reheat (2400/930/785) Internal Steam Reheat (2400/930/590) Non-reheat (2400/930 + External Moist. Sep.) Non-reheat (2400/930 + Internal moist. sep.)	"Push"		"As there are no major technical difficulties in the cycles compared here, the choice has to be based on the kw-hr price". Authors' opinion is that sodium reheat should be discarded since economics is a draw.
General Electric 550 Mwe 1971 - Ref. 12	Sodium Reheat { 1. 2400/900/900 2. 1800/900/900 3. 1450/900/900 Non-Reheat { 1. 2400/900 2. 1800/900 3. 1450/900	Non-Reheat (1450/900)		Economics favored 1800 & 2400 psig sodium reheat systems. Concept selected was more costly than four others. Reason stated was "conservative design, favoring reliability over economics." Note: Least expensive system in trade study had 1050F reactor outlet, 900F initial and reheat steam, at 2400 psig employing sodium reheat.
French (CEA et al), - Geneva Conference - 1971 - Ref. 13	?	Sodium Reheat: (Phenix)	Two steam cycles are suitable for fast reactor plants: 1. Sodium reheat (a'la Phenix) 2. Internal steam reheat	"The choice can only be made by studying the power plant as a whole and preliminary steam generator studies have been conducted around the two solutions."
European Trip Report - AEC Components Team (France) 1971 - Ref. 14	---		Indications are that 1000 Mwe commercial plants will not use sodium reheat	The alternate to be selected was apparently not mentioned. They will keep temperatures down and probably use ferritic metals for both evap. and superheater. (Recent French visitors to AI, however, see no reason to drop sodium reheat since tests at La Renardiere have revealed no technical problem areas).
Interatom (SNR) 300 Mw, 1000 Mw -Geneva Conference 1971 - Ref. 15, 16	Sodium Reheat (2500/variable/variable-5 cases) Live Steam Reheat (2500/930/?) Thermal drying (after IP stage) with extraction steam (2400/875-900/sat.(?)) Non-Reheat (1765/950)	Thermal drying: 2500/930/sat.(?)	-same-	Until recently SNR was to employ sodium reheat recent Trip Report (see Ref. 14) indicated that they plan to drop it. "In spite of the reduced efficiency, the cost savings with thermal drying or steam reheat are larger than with sodium reheat. This is true if one uses the expected fuel costs of large breeders as the basis."
Westinghouse 550 Mw 1971 - Ref. 17	?	Non-Reheat: (2400/900) with two external moisture separators		Unless HP steam expands all the way down to ~25-50 psia, there is not sufficient moisture to merit removal. Since these pressures are far removed from conventional practice (~180-200 psi), the whole cycle is somewhat "suspicious."
	Totals (where applicable):	Sodium Reheat: 5 Non-reheat: 2 Thermal Drying: 1	Sodium Reheat: Internal Steam Reheat: Thermal Drying: Non-Reheat	4-5 1 1 1-0

ESG-79-2, Vol II, Book 2
E-7

N2721000002

Page 5

of steam reheat over sodium reheat. Nonreheat was considered too costly an option.

Turbine development for steam reheat was not considered to be a significant problem, and in fact a steam reheat turbine was considered to be lower in cost than a sodium reheat turbine.

3. "Steam Pressure Selection for Demonstration Plant,"
January 1973 (Reference 3)

This trade study assessed the effects of steam pressure on the steam generator design and performance, and recommended a reference AI steam pressure for CRBRP. Sodium reheat was excluded from consideration, but not based upon AI's technical conclusions. Nonreheat, extraction-steam reheat, and main-stream reheat were considered. Steam pressures of 1450, 1800 and 2400 were considered.

The recommended steam cycle for the Demonstration Plant was 2400 psig/900⁰F with extraction-steam reheat. The second choice was the 1450 psig/900⁰F nonreheat cycle (which was selected for CRBRP by WARD).

Main-steam reheat was rejected because of the opinion that the higher temperature and pressure moisture separator/steam reheater design represented considerable extrapolation from proven LWR experience. High pressure (above 1800 psi) nonreheat was rejected because of high moisture in the turbine exhaust.

4. "PLBR/CBR Design Point Trade Study," July 1976 (Reference 4)

This trade study selected the design point for PLBR, Phases I and II. The design point was selected based upon detailed evaluation of economics, safety and licensability, reliability and availability, maintainability, inspectability, operability, risk, development requirements, and schedule. From a consideration of all these constraints, reactor outlet temperature, steam cycle, and material selections were made. Reactor outlet temperature was the dominant feature selected, and steam cycle was selected second. The steam cycle studies excluded sodium reheat, as a result of the general

swing away from sodium reheat throughout the world, and the desire of DOE not to consider sodium reheat for the commercial LMFBR program. Steam reheat and nonreheat cycles were considered ranging in steam pressure from 1300 to 2400 psig and in steam temperature from 750 to 950°F.

The selection of reactor outlet temperature included consideration of overall economics, fuel cycle cost and breeding gain variations, upper internals considerations, reliability and availability, maintainability, and structural analysis. Economics, including fuel cycle costs and the effects of unavailability and inelastic analysis, favored operation at the highest possible reactor outlet temperature (1050°F). Optimizing the breeding gain for mature CBR's with advanced cladding alloys suggested a reactor outlet temperature of about 940-950°F. Upper internals problems favored low temperature operation. The component activity due to mass transfer in the primary loop is minimized at low reactor outlet temperatures. The design flexibility consideration suggested a reactor outlet temperature of 950°F or lower. Also, the plant should generally be easier to license at lower temperatures. Considering all these factors, a reactor outlet temperature of 950°F was selected for PLBR/CBR as the best compromise. (Subsequent program decisions modified this number to 930°F.)

Economic optima for the various steam cycles studied are shown in Figure 1. For the recommended PLBR/CBR reactor outlet temperatures of 950°F, optimum economics narrow the desirable steam cycles to those with the following turbine conditions:

- 1) 2400 psig/800-850°F steam
- 2) 1800 psig/800-850°F steam
- 3) 1100 psig/saturated steam

The prime advantage of the 1100 psi cycle is that it uses available LWR turbine technology. However, this cycle was rejected because of (1) the desire to utilize the developed LMFBR steam generator technology, (2) to minimize steam generator tube wall thermal stress, and (3) to minimize thermal pollution.

FORM 719-P REV. 3-75




FIGURE I.1
ECONOMIC COMPARISON OF SS SYSTEMS

In the remaining cycles, 850°F steam is preferred over 800°F steam because thermal stresses, thermal pollution and plant control requirements are minimized. Factors affecting the pressure selection include relative economics, steam generator tube-to-tubesheet weldability and turbine generator availability. Relative economics, as seen in Figure 1, slightly favor the 2400 psi cycle (5.5×10^6 1976 dollars). Only Allis Chalmers has indicated interest in developing a large 1800 psi/850°F tandem compound turbine for delivery to PLBR/CBR whereas Allis Chalmers, GE, and Westinghouse all indicated that they could supply 2400 psi tandem compound turbines. Therefore, it appears at present that a 2400 psi/850°F turbine with steam reheat would be preferable. (Subsequent program decisions resulted in a selection of 2200 psig/850°F steam conditions.)

B. CONSIDERATIONS FOR ARCPS STEAM CYCLE SELECTION

Due to the relatively high capital cost of the ARCPS, high efficiency is a strict necessity. For this reason, high temperatures and sodium reheat are strongly favored. The selection of the 2200 psi/850°F steam cycle with steam reheat for PLBR is based upon significantly different requirements, and thus is not necessarily indicative of the direction in which the ARCPS steam system should proceed.

Consideration of four factors is made here for use in steam cycle selection in the ARCPS:

- 1) Steam generator material selection
- 2) Effect of sodium reheat/steam reheat/non reheat
- 3) Benson vs Sulzer Cycle
- 4) Steam cycle pressure

1. Steam Generator Material

The structural materials listed in Table 2 are considered as candidate materials for steam generator construction. Reviews of alternate structural materials are given in References 4, 5, and 6. The selection of material for the ARCPS steam generator modules is more difficult than for the current

TABLE 2
STRUCTURAL MATERIAL CANDIDATES

Ferritic	2-¼ Cr - 1 Mo, unstabilized Advanced Ferritics (9 Cr)
Austenitic	304 stainless steel 316 stainless steel
Nickel Base	Alloy 800 H

generation of LMFBR's since the trend there is to lower temperatures (<900°F) in the steam generator system, while for ARCPS the desired temperatures are 1100°F sodium and 1000°F steam.

Unstabilized 2-1/4 Cr - 1 Mo ferritic material has had the greatest application in LMFBR steam generators both in the U.S. and abroad. This is due to its excellent chloride stress corrosion cracking (SCC) resistance, thermal properties, relative economics, and experience. It is ASME coded to 1200°F, but due to poor properties at the higher temperatures it has little design application for normal operating temperatures in excess of 950°F. For this reason, it is unacceptable as a material in the ACRPS steam generator modules except for use in an evaporator module.

Advanced ferritic materials have been extensively used in European steam generators. The advanced ferritic alloys of interest are 8-14%-Cr. Specifically, the European alloys are 9 Cr alloys (R-8 and EM-12) and 12 Cr alloys (HT-9). A development program (Reference 6) at CE is being conducted to optimize the 9-12 Cr ferritic steel composition. CE has found that EM-12 and HT-9 have excessively low ductility. This and other factors such as poor weldability and higher Cr usage have eliminated the 12 Cr alloy from consideration. At present, the CE study indicated 9 Cr - 1 Mo to be the preferred candidate.

The advanced ferritic 9 Cr - 1 Mo appears to be an attractive alternate to 2-1/4 Cr - 1 Mo for temperatures in excess of ~900°F. The limiting

design temperature for 9 Cr - 1 Mo is higher than that for 2-1/4 Cr - 1 Mo, but may not be much over 1000°F. Thus, it is not clear whether the 9 Cr - 1 Mo alloy would be acceptable for other than evaporator application. In addition, 9 Cr - 1 Mo will probably take 5-10 years to develop as an ASME Section III Class 1 material. While the steam generator for the ACRPS system will probably be designed to Section VIII of the code, critical components in the steam-sodium pressure boundary will be analyzed to the intent of 1592, so a complete set of material properties will be required. Advantages of 9 Cr - 1 Mo relative to 2-1/4 Cr - 1 Mo include similar SCC resistance, higher strength, similar conductivity, and less inelastic analysis.

The austenitic materials, types 316 and 304 stainless steel, are excellent materials for the ARCPS steam generators from the standpoint of the high operating temperature. In addition, they are state-of-the-art steels with well established records. A significant problem exists with austenitic materials - they are prone to chloride and caustic SCC. This requires that if they are used in a steam generator application, careful consideration must be given to water chemistry. Slight through wall cracks in a sodium-heated steam generator have been shown to grow, and eventually lead to sudden large leaks (Reference 7). Under normal operating conditions the feedwater in a plant can be controlled to maintain very low chlorine content, but off normal operation and startup would make use of austenitics in the evaporator module unwise. The use of austenitics would be feasible in a superheater or reheater unit if special precautions were taken. Since chlorine is almost insoluble in steam, a steam separator could be used to minimize the amount of carryover by water droplets from the evaporator to the superheater. In addition, protective sleeves could be used in the steam inlet end of the superheater and reheater to collect the remaining chloride carried over into these units.

The nickel based alloy 800H provides both elevated temperature strength and improved resistance to chloride stress-corrosion cracking.

The resistance to SCC is higher than that of the austenitics, but worse than that of 2-1/4 Cr - 1 Mo. Thus, it would seem that the same SCC protective measures would be taken for alloy 800H as would be applicable to the austenitics. Also, the cost of alloy 800H is significantly greater than that of the other materials. While prototype material costs would not vary significantly with alloy selection, the costs for multiple plant unit type production are expected to vary as shown in Table 3. Material costs for alloy 800H appear to be excessive, and alloy 800H doesn't appear to have a significant advantage over stainless steel.

Considerations for material selection are summarized in Table 4.

TABLE 3
RELATIVE MATERIAL COSTS

Material	Material Cost	Fabrication Cost
2-1/4 Cr - 1 Mo	1.0 (base)	1.0 (base)
9 Cr - 1 Mo	2.0	1.0
316 stainless steel/304 stainless steel	2.0	0.8
Alloy 800H	6.0	0.8

2. Reheat

Reheat, and in particular sodium reheat, is evaluated in this study from the standpoint of its effect on steam generator design. Sodium reheat is considered necessary, along with high inlet temperatures, to produce high efficiencies and minimize the capital cost of the plant. The steam cycles considered in this study have gross efficiencies from 42 to 44%, utilizing 1100^oF sodium to produce 1000^oF steam and a single reheat.

The use of a second, low pressure reheat stage could be employed to boost efficiency, or alternatively decrease sodium temperatures without decreasing efficiency. For example, a cycle has been designed (Reference 8) that would produce 42% efficiency with a sodium inlet temperature of

TABLE 4
STEAM GENERATOR MATERIAL CONSIDERATIONS

	2-1/4 Cr - 1 Mo	9 Cr - 1 Mo	I-800H	Type 304ss/ 316ss
Current Status	Widely used and accepted for LMFBRs or application	Being Developed by CE Use in Europe (EM12)	Limited use in steam generators	Some use in steam generators
ASME Code Approval	Yes	No	Yes	Yes
CREEP Properties	Poor	Fair?	Good	Good
Operating Temperature Limit (for practical design)	950°F	1100	1200	1200
SCC Resistance	Virtually immune	Virtually immune	Better than austenitics	Very sensitive—chloride or caustic
Metallurgical Stability in Sodium	Decarburizes, which lowers design properties	Good	Good	Good
Compatibility with S.H. Steam	Excellent	Good	Good	Good (if no chloride carryover)
Compatibility with Feedwater	Excellent	Good	Poor-Fair	Poor
Cost	Low	Medium	High	Medium

FORM 718P REV. 3/78

ESG-79-2, Vol II, Book 2
E-15

900°F and two reheat stages. Such a cycle would allow use of 2-1/4 Cr - 1 Mo throughout much of the sodium systems, but would increase the size of the heat storage system. Additionally, the low pressure reheater would require a new design, perhaps looking similar to a FFTF DHX, and the turbine may require development if a second reheat stage is not standard.




3. Optimization

Optimization studies were performed for three representative steam cycles selected from Reference 9, which are presented in Table 5. The cycles are called the 2400, 1800, and 1450 psig cycles in this report. The steam generator module designs were optimized for these three cycles on the basis of capital cost. The steam generator designs were calculated using the STEAM subroutine of SOC-II, and the capital cost were calculated with the COSTSG subroutine of SOC-II (Reference 10). The following assumptions were made in the optimization process:

- 1) Evaporator material is 2-1/4 Cr - 1 Mo.
- 2) Reheater and superheater material is either 316 SS or I-800H.
- 3) Only costs considered are the evaporator, superheater, and sodium reheater.
- 4) The efficiency with and without sodium reheat is assumed the same for purposes of sizing and costing the steam generator modules since this information was not available. This produces a maximum error of 5% for a 2% efficiency improvement.

Three system arrangements were employed, as shown in Figure 2. For sodium reheat, only a separate evaporator/superheater arrangement was considered, since the inlet steam temperature to the reheater is significantly hotter than the desired sodium cold leg temperature (550°F). The separate evaporator and superheater concepts are called Sulzer arrangements, although these cycles could be operated in either the once through (i.e., slight superheat in the evaporator) or in the True Sulzer Mode

FIGURE 2
ALTERNATIVE SYSTEM ARRANGEMENTS



FORM 719-P REV. 3-75


TABLE 5
STEAM CYCLES CONSIDERED

Cycle # (Reference 10)	1	2	6
Throttle Pressure (psig)	1450	1800	2400
Throttle Temperature (°F)	1000	1000	1000
Throttle Flow (lbm/h)	776,417	765,396	762,350
Reheat Pressure (psig)	374.1	440.6	528.7
Reheat Temperature (°F)	1000	1000	1000
Reheat Flow (lbm/h)	681,474	668,601	671,385
Final Feedwater Temperature (°F)	433.1	449.7	467.5
Gross Cycle Efficiency (%)	42.25	43.09	43.94

(5-10% moisture in the evaporator exit steam). The combined evaporator and superheater arrangement is called the Benson arrangement. Temperature profiles for the with and without sodium reheat are presented in Figure 2A.


Results of the economic evaluation for steam pressure, Benson vs Sulzer, sodium reheat, and superheater/reheater material are shown in Figure 3 and Table 6. Figure 3 summarizes the economic trends for the six variations of the above variables. Sodium reheat is shown to cost an additional \$1 - 3 million in module costs, but this does not take into account other system costs, such as sodium valves (for the sodium reheat cases) nor the loss in efficiency, higher turbine cost, or steam reheater costs (for the non-sodium reheat cases). For non-sodium reheat, the Sulzer arrangement is most attractive economically, since it can employ a 2-1/4 Cr - 1 Mo evaporator, where as the steam generator unit in the Benson arrangement is all of I-800H or Type 316 stainless steel. Alloy 800H is significantly more expensive, by \$1-4 million, than Type 316 stainless steel as a material for construction in the superheater and reheater modules.

FIGURE 2A
STEAM GENERATOR
TEMPERATURE PROFILES
(1800 psf CYCLE)



FORM 719-P REV. 3-75

FIGURE 3.
ECONOMIC COMPARISONS AS
FUNCTION OF STEAM PRESSURE



CURVE	SODIUM RH	ARRANGEMENT	MATERIALS
①	YES	SULZER	2 1/4 Cr-1Mo, 316 SS, 316 SS
②	YES	SULZER	2 1/4 Cr-1Mo, I800H, I800H
③	NO	SULZER	2 1/4 Cr-1Mo, 316 SS
④	NO	SULZER	2 1/4 Cr-1Mo, I800H
⑤	NO	BENSON	316 SS
⑥	NO	BENSON	I800H

FORM 719-P REV. 3-75

Table 6 gives a breakdown of the module costs for each option considered as well as sizing information. Optimum tube sizes are shown in the table for each case. Due to the high temperature of operation, the tube wall thicknesses for the superheater are significantly greater (20-30%) with the Type 316 stainless steel material than the wall thickness that is welded on the CRBRP steam generator (0.109-in) with an autogenous - butt weld from the ID. Tube-to-tubesheet weld development is probably necessary for either Type 316 stainless steel or I-800H, but additional measures such as using larger than optimum diameter tubes may be necessary for the Type 316 stainless steel superheater.

Results of an evaluation of sodium loop ΔT as it affects the steam generator module cost are shown in Figure 4 and Table 7. Economics tends to favor the lower steam pressure due to the larger sodium-steam temperature difference that exists at saturation in the evaporator. For the same reason, the lower sodium loop ΔT (higher cold leg temperature) is favored.

III. OPERATING CONSIDERATIONS


A. NORMAL POWER OPERATION

Normal power operation of the solar plant steam generator system will be desirable over a wide load range, probably 20-100% power. The steam generator modules should have no difficulty achieving this requirement, but the lower limit in operating range will probably be set by flow meters, pumps, and valves. In the solar plant, the sodium inlet temperature to the steam generator system is essentially fixed at storage temperature, or 1100°F, for normal power operation, and sodium flowrate can be adjusted for part power operation.

For the Sulzer cycle, operation at part power will result in the outlet steam temperature approaching the sodium inlet temperature (because sodium inlet temperature is fixed).

FORM 719-P REV. 3-75

FIGURE 4.
EFFECT OF LOOP ΔT ON STEAM
GENERATOR ECONOMICS
(1100°F HOT LEG)



FORM 719-P REV. 3-75

TABLE 6
DESIGN AND ECONOMIC OPTIMIZATION SUMMARY
(Sheet 1 of 2)

Benson/ Sulzer*	Sodium Reheat	Material			Steam Pressure	Optimum Tube Size			Optimum Tube Length (Active)			Number Tubes		
		EV	SH	RH		EV	SH	RH	EV	SH	RH	EV	SH	RH
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	5/8 x 0.082	5/8 x 0.135	1-3/8 x 0.110	78.1	77.7	58.3	1491	376	160
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	5/8 x 0.075	3/4 x 0.132	1-1/2 x 0.107	78.1	67.6	52.9	1100	276	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	5/8 x 0.070	7/8 x 0.132	1-3/4 x 0.108	78.3	67.1	56.9	775	220	132
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	2400	5/8 x 0.082	5/8 x 0.123	1-1/4 x 0.096	78.1	78.4	52.4	1491	367	192
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1800	5/8 x 0.075	3/4 x 0.121	1-1/2 x 0.098	78.1	71.7	53.6	1100	252	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	5/8 x 0.070	3/4 x 0.112	1-1/2 x 0.093	78.3	55.4	47.1	775	296	184
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	2400	5/8 x 0.091	5/8 x 0.135	-	78.5	65.4	-	874	444	-
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	1800	5/8 x 0.087	3/4 x 0.132	-	77.9	59.8	-	866	320	-
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	1450	3/4 x 0.092	3/4 x 0.122	-	78.0	46.9	-	684	372	-
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	2400	5/8 x 0.091	5/8 x 0.123	-	78.5	71.3	-	874	392	-
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	1800	5/8 x 0.087	5/8 x 0.111	-	77.9	46.7	-	866	464	-
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	1450	3/4 x 0.092	3/4 x 0.112	-	78.0	49.8	-	684	340	-
Benson	No	Type 326 SS		-	2400	5/8 x 0.135		-	77.8		-	1868		-
Benson	No	Type 326 SS		-	1800	5/8 x 0.121		-	77.8		-	1658		-
Benson	No	Type 326 SS		-	1450	5/8 x 0.113		-	78.2		-	1322		-
Benson	No	I800H		-	2400	5/8 x 0.123		-	77.6		-	1846		-
Benson	No	I800H		-	1800	5/8 x 0.111		-	78.0		-	1632		-
Benson	No	I800H		-	1450	5/8 x 0.103		-	78.1		-	1301		-

* Used to denote combined SH/EV or separate EV and SH

FORM 719-P REV. 3/75

ESG-79-2, Vol II, Book 2
E-23

TABLE 6
DESIGN AND ECONOMIC OPTIMIZATION SUMMARY
(Sheet 2 of 2)

Benson/ Sulzer*	Sodium Reheat	Material			Steam Pressure	Shell Diameter			H.T. Area (Ft ³ x 10 ⁻³)				Capital Cost			
		EV	SH	RH		EV	SH	RH	Total	EV	SH	RH	Total			
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	54.4	31.3	31.0	19.1	4.8	3.4	27.3	3.38	1.51	1.30	6.19
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	48.1	30.5	32.3	14.1	3.7	3.2	21.0	2.70	1.33	1.32	5.35
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	42.3	30.3	33.3	9.9	3.4	3.4	16.7	2.09	1.23	1.30	4.62
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	2400	54.4	31.1	31.5	19.1	4.7	3.3	27.1	3.38	2.74	2.40	8.52
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1800	48.1	29.6	31.9	14.1	3.5	3.2	20.8	2.70	2.36	2.47	7.53
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	42.3	31.3	34.6	9.9	3.2	3.4	16.5	2.09	2.19	2.43	6.71
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	2400	44.0	35.0	-	11.2	4.8	-	16.0	2.36	1.65	-	4.01
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	1800	43.9	34.7	-	11.0	3.8	-	14.8	2.33	1.48	-	3.81
Sulzer	No	2-1/4 Cr - 1 Mo	Type 316 SS	-	1450	43.7	35.6	-	10.5	3.4	-	13.9	2.13	1.39	-	3.52
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	2400	44.0	34.0	-	11.2	4.6	-	15.8	2.36	2.90	-	5.26
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	1800	43.9	35.6	-	16.0	3.5	-	14.8	2.33	2.68	-	5.01
Sulzer	No	2-1/4 Cr - 1 Mo	I800H	-	1450	43.7	35.3	-	10.5	3.3	-	13.8	2.13	2.46	-	4.59
Benson	No	Type 316 SS		-	2400	60.0			23.8			23.8	4.73			4.73
Benson	No	Type 316 SS		-	1800	57.1			21.1			21.1	4.22			4.22
Benson	No	Type 316 SS		-	1450	52.1			16.9			16.9	3.40			3.40
Benson	No	I800H		-	2400	59.7			23.4			23.4	9.03			9.03
Benson	No	I800H		-	1800	56.7			20.8			20.8	7.95			7.95
Benson	No	I800H		-	1450	51.8			16.6			16.6	6.28			6.28

*Used to denote combined SH/EV or separate EV and SH.

FORM 719P REV. 3/75

TABLE 7
EFFECT OF SODIUM LOOP ΔT ON STEAM GENERATOR DESIGN AND COST
(Sheet 1 of 2)

Benson/ Sulzer	Sodium Reheat?	Material			Steam Pressure	Sodium Loop ΔT ($^{\circ}F$)	Optimum Tube Size (in.)			Optimum Tube Length (ft)			Number Tubes		
		EV	SH	RH			EV	SH	RH	EV	SH	RH	EV	SH	RH
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	550	5/8 x 0.082	5/8 x 0.135	1-3/8 x 0.110	78.1	77.7	58.3	1491	376	160
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	500	5/8 x 0.085	5/8 x 0.135	1-3/8 x 0.110	78.7	71.2	54.6	515	376	160
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	450	5/8 x 0.090	5/8 x 0.135	1-3/8 x 0.110	63.1	65.8	51.4	436	376	160
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	550	5/8 x 0.075	3/4 x 0.132	1-1/2 x 0.107	78.1	67.6	51.9	1100	276	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	500	5/8 x 0.079	3/4 x 0.132	1-1/2 x 0.107	70.0	63.9	49.9	624	276	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	450	3/4 x 0.096	3/4 x 0.132	1-1/2 x 0.107	66.7	60.7	47.3	436	276	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	575	5/8 x 0.068	7/8 x 0.132	1-5/8 x 0.105	78.2	68.8	53.2	1257	220	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	550	5/8 x 0.070	7/8 x 0.132	1-3/4 x 0.108	78.3	67.1	56.9	757	220	132
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	500	3/4 x 0.083	7/8 x 0.132	1-5/8 x 0.105	70.1	64.3	49.0	524	220	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	450	7/8 x 0.099	7/8 x 0.132	1-5/8 x 0.105	67.5	61.7	46.6	392	220	156
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	2400	550	5/8 x 0.082	5/8 x 0.123	1-1/4 x 0.096	78.1	78.4	52.4	1491	367	192
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	2400	500	5/8 x 0.085	5/8 x 0.123	1-1/4 x 0.096	78.7	77.5	49.1	515	332	192
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	2400	450	5/8 x 0.090	5/8 x 0.123	1-1/4 x 0.096	63.1	71.7	46.1	436	332	192
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1800	550	5/8 x 0.075	3/4 x 0.121	1-1/2 x 0.098	78.1	71.7	53.6	1100	252	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1800	500	5/8 x 0.079	3/4 x 0.121	1-1/2 x 0.098	70.0	67.9	50.6	624	252	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1800	450	3/4 x 0.096	5/8 x 0.111	1-1/2 x 0.098	66.7	47.5	48.0	436	400	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	575	5/8 x 0.068	7/8 x 0.121	1-5/8 x 0.096	78.2	72.2	53.9	1257	204	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	550	5/8 x 0.070	3/4 x 0.112	1-1/2 x 0.093	78.3	55.4	47.1	757	296	184
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	500	3/4 x 0.083	3/4 x 0.112	1-5/8 x 0.096	70.2	52.9	49.7	524	296	152
Sulzer	Yes	2-1/4 Cr - 1 Mo	I800H	I800H	1450	475	7/8 x 0.099	3/4 x 0.112	1-5/8 x 0.096	67.5	50.6	47.3	392	296	152

TABLE 7
EFFECT OF SODIUM LOOP AT ON STEAM GENERATOR DESIGN AND COST
(Sheet 2 of 2)

Benson/ Sulzer	Sodium Reheat?	Material			Steam Pressure	Sodium Loop AT (°F)	Shell Diameter (ID) (in.)			H.T. Area (Ft x 10 ⁻³)				Capital Cgst (\$ x 10 ⁻⁶)			
		EV	SH	RH			EV	SH	RH	Total	EV	SH	RH	Total			
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	550	54.4	31.3	31.0	19.1	4.8	3.4	27.3	3.38	1.51	1.30	6.19
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	500	37.0	31.8	31.2	6.6	4.4	3.1	14.1	1.71	1.47	1.27	4.45
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	2400	450	36.6	32.3	31.4	4.5	4.0	3.0	12.5	1.51	1.46	1.26	4.23
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	550	48.1	30.5	32.3	14.1	3.7	3.2	21.0	2.70	1.33	1.32	5.35
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	500	39.5	30.9	32.5	7.1	3.4	3.1	13.6	1.84	1.31	1.31	4.46
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1800	450	38.2	32.0	32.7	5.7	3.3	2.9	11.9	1.62	1.33	1.28	4.23
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	575	50.8	30.1	33.9	16.1	3.5	3.5	23.1	2.87	1.23	1.32	5.42
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	550	42.3	30.3	33.3	9.9	3.4	3.4	16.7	2.09	1.23	1.30	4.62
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	500	40.2	31.4	34.2	7.2	3.2	3.3	13.7	1.76	1.23	1.28	4.27
Sulzer	Yes	2-1/4 Cr - 1 Mo	Type 316 SS	Type 316 SS	1450	450	39.5	32.6	34.4	6.1	3.1	3.1	12.3	1.60	1.27	1.28	4.15
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	2400	550	54.4	31.1	31.5	19.1	4.7	3.3	27.1	3.38	2.74	2.40	8.52
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	2400	500	37.0	30.5	31.7	6.6	4.2	3.1	13.9	1.71	2.60	2.34	6.65
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	2400	450	36.6	31.2	32.0	4.5	3.9	2.9	11.3	1.51	2.56	2.32	6.39
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1800	550	48.1	29.6	31.9	14.1	3.5	3.2	20.8	2.70	2.36	2.47	7.53
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1800	500	39.5	30.5	32.1	7.1	3.4	3.0	13.5	1.84	2.38	2.44	6.66
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1800	450	38.2	33.0	32.4	5.7	3.1	2.9	11.7	1.62	2.41	2.40	6.43
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1450	575	50.8	29.6	33.5	16.1	3.4	3.5	23.0	2.87	2.18	2.44	7.49
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1450	550	42.3	31.3	34.6	9.9	3.2	3.4	16.5	2.09	2.19	2.43	6.71
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1450	500	40.2	31.7	33.8	7.2	3.1	3.2	13.5	1.76	2.19	2.38	6.33
Sulzer	Yes	2-1/4 Cr - 1 Mo	1800H	1800H	1450	475	39.5	32.6	34.1	6.1	3.0	3.1	12.2	1.60	2.22	2.37	6.17

FORM 719a REV. 3/75

ESG-79-2, Vol II, Book 2
E-26

the steam outlet temperature will rise from 1000⁰F power to 1100⁰F at part load. Unless this is acceptable to the turbine, attemperators will be required on the outlet of the superheater and sodium reheater.

The Benson cycle is advantageous in that the steam and sodium flows can be adjusted to produce the desired power level and steam temperature at part load without use of an attemperator.

B. TRANSIENTS

Plant transients that affect the steam generator are listed in Table 8. These were obtained by reviewing the CRBRP transient lists. Most accident events that affect the receiver portion of the plant will not directly impose a transient, other than a normal shutdown, on the steam generator system, because the steam generator takes sodium from the storage tank. Operation of the steam generator system is not required in the solar plant following an accident event, as it is in an LMFBR to provide decay heat removal. The preferred approach following an accident event in the steam generator system is to stop both the sodium and steam flows, thereby minimizing any down transients for the hot end of the superheater and reheater or up transients for the cold end of the superheater and reheater and the evaporator. The large loop ΔT (550⁰F) poses the potential for severe transients, but the number of such transients can be minimized by stopping flows.

C. STARTUP/SHUTDOWN

Startup and shutdown of the steam generator system is desired (from an overall plant viewpoint) on a daily basis. The preferred approach from the standpoint of the steam generator system is to continue steaming during the night hours using stored heat, since this would greatly reduce the number of startup and shutdown events. The steam generator modules can be shut down leaving them hot by a rapid stoppage of flow from a low power condition. Temperature profiles will not significantly change in the following 12-hour period due to heat losses through the insulation. For example, cooldown rates of a typical superheater module are shown in Figure 5. Using 12-in of

FORM 719-P REV. 3-75

TABLE 8
PRELIMINARY TRANSIENT LIST FOR THE STEAM GENERATOR SYSTEM

NORMAL

1. Dry System Heatup and Fill
2. Startup/Shutdown
3. Load Swing

UPSET

1. Loss of Sodium Pump Power
2. Isolation and Blowdown of Evaporator
3. Isolation and Blowdown of Superheater
4. Isolation and Blowdown of Reheater
5. Inadvertent opening of steam relief valve
6. FW Throttle Valve fails open
7. Loss of FW flow
8. Loss of Power

EMERGENCY

TBD


insulation, the hot end of the superheater decreases by 100°F in the 12-hour period.

Startup would therefore be simplified as the component would be "at temperature," and once proportional flows were established, power level could be increased rapidly.

IV. REFERENCE SYSTEM DESIGN

The reference steam cycle was selected based upon overall system considerations as the 1800 psi steam cycle with sodium reheat and a 550°F sodium loop ΔT, (Reference 11). A description of the steam generator design and operating conditions is presented in Table 9.

FIGURE 5.
SUPERHEATER COOLDOWN



FORM 719-P REV. 3-75

TABLE 9
DESIGN AND OPERATING CONDITIONS FOR THE
STEAM GENERATOR MODULES

	Evaporator	Superheater	Reheater
<u>Physical Description</u>			
Quantity	1	1	1
Type	Tube & Shell Hockey Stick	Tube & Shell Hockey Stick	Tube & Shell Hockey Stick
Height (ft)	95	91	66
Width (ft)	16	15	18
Shell Diameter (ID) (in.)	48	30	32
Heat Transfer Area (ft ²)	14039	4334	3329
Active Heat Transfer Length (ft)	78	78	53
No. Tubes	1100	283	163
Tube Diameter (in.)	5/8	3/4	1-1/2
Tube Wall Thickness (in.)	0.075	0.132	0.107
Material	2-1/4 Cr - 1 Mo	Type 316 ss	Type 316 ss
Tubesheet Diameter (in.)	48	30	32
Tubesheet Thickness (in.)	12	8	5
Module Weight Dry (Tons)	64	22	24
<u>Operating Conditions</u>			
Sodium Side:			
Flow (lbm/h)	5,542,000	3,785,000	1,757,000
Inlet Temperature (°F)	864	1100	1100
Outlet Temperature (°F)	550	864	864
Pressure Drop (psi)	30	30	30
Duty (Mwt)	155.7	79.7	37.0
Water/Steam Side:			
Flow (lbm/h)	765,396	765,396	668,601
Inlet Temperature (°F)	450	646	657
Outlet Temperature (°F)	646	1000	1000
Pressure Drop (psi)	30*	256	22
Outlet Pressure (psia)	2170	1865	463
Exit Steam Velocity (fps)	27	250	250

*Includes Orifices.

The best choice for evaporator material is clearly 2-1/4 Cr - 1 Mo, considering operating conditions and economics. The choice of material for the superheater and reheater is more difficult. Type 316 stainless steel was selected due to the significant cost advantage it shows over alloy 800H. However, alloy 800H remains a viable alternative, especially in light of its increased resistance to SCC. It is recommended that a thorough evaluation of the candidate materials be carried out by the Materials and Processes group during preliminary design of the steam generator system.

The steam generator modules should be designed and constructed in accordance with Section VIII, Class 1 of the ASME BPVC, with adders included to cover analysis of critical components for cyclic events and construction of the steam-sodium boundary. The critical components should include as a minimum the tubes and the tubesheets.


V. REFERENCES

1. H. L. Sletten and P. M. Gresho, "Reheat vs Nonreheat Trade Study," TSR-095-330-005, November 5, 1971.
2. "Status of LMFBR Reheat in Western Europe --1972," WASH - 1219, March 1973.
3. E. B. Baumeister, "Steam Pressure Selection for Demonstration Plant," TI-070-330-003, January 25, 1973.
4. N. G. Galluzzo, "PLBR/CBR Design Point Trade Study," N222TSR122001. July 13, 1976.
5. R. T. King, et al., "Report of the Task Force on Alternate Structural Materials for Liquid Metal Fast Breeder Reactors, Phase I, II, III," ORNL Report, 1975.
6. P. Patriaca, et al., "U.S. Advanced Materials Development Program for Steam Generators," Nuclear Technology, Vol. 28, 1976, p 516.
7. J. A. Gudahl, et al., "Self Wastage Phenomena," GEFR-00051 (L) -1, -2, February 1977.
8. Personal Communications with W. E. Schenewerk, January 1978.
9. Letter, A. W. McKenzie (SR) to T. H. Springer (AI), "Advanced Receiver Power System," December 1, 1977.
10. N. G. Galluzzo, "SOC-II System Optimization Code, Description and User's Manual," AI -N222TI123-001, October 15, 1976.
11. Personal Communications with T. L. Johnson, January 27, 1978.

APPENDIX F

HEAT LOSSES FROM SOLAR RECEIVER SURFACE

**AI Technical Information
Document N272TI000004**

 Rockwell International <small>Aeronic International Division</small>		SUPPORTING DOCUMENT		NUMBER N272TI000004	REV LTR/CHG NO. SEE SUMMARY OF CHG
PROGRAM TITLE Solar Central Receiver Power Systems				DOCUMENT TYPE Technical Information	
DOCUMENT TITLE Heat Losses from Solar Receiver Surface				KEY NOUNS Solar Power, Receiver Heat Losses	
PREPARED BY/DATE E. M. Mouradian <i>E. M. Mouradian</i>				DEPT 731	MAIL ADDR LB35
IR&D PROGRAM? YES <input type="checkbox"/> NO <input type="checkbox"/> IF YES, ENTER TPA NO. _____				GO NO. 09272	S/A NO. 14000
APPROVALS <i>L. G. Rico</i> L. G. Rico				ORIGINAL ISSUE DATE _____	
DATE 4/13/78				GO NO. TOTAL PAGES 09272 66	REL. DATE 4-14-78
SECURITY CLASSIFICATION					
(CHECK ONE BOX ONLY)		(CHECK ONE BOX ONLY)			
UNCL	ERDA <input checked="" type="checkbox"/>	DOD	RESTRICTED DATA <input type="checkbox"/>		
CONF.	<input type="checkbox"/>	<input type="checkbox"/>	DEFENSE INFO. <input type="checkbox"/>		
SECRET	<input type="checkbox"/>	<input type="checkbox"/>			
AUTHORIZED CLASSIFIER					DATE
DISTRIBUTION			ABSTRACT		
*	NAME	MAIL ADDR	Calculations have been made to determine the heat losses from the surface of the receiver of the Central Receiver Solar Power System. The heat losses considered are: reflection of incident heat flux, combined natural and forced convection, and thermal radiation. The receiver analyzed is in the form of a vertical cylinder, 16 meters (52.5 ft) in diameter, and 16 meters (52.2 ft) in height--the reference dimensions at the time the analysis was made. Sodium is circulated through the receiver as a heat transport medium. The tube surface properties are: α (absorptivity) = 0.95 and ϵ (emissivity) = 0.90. The ambient temperature is 60°F. The heat losses, in megawatts and as a percentage of thermal power incident on the receiver, have been determined for a variety of conditions: thermal power absorbed by the sodium up to 429 MWt, wind velocities up to 16.3 meters/second (= 53.4 fps = 36.4 mph), and sodium inlet/outlet temperatures ranging from 550°/1100°F to 850°/1400°F.		
	W. V. Botts	LA02			
	C. C. Conners	LB30			
*	A. Z. Frangos	LA19			
*	L. E. Glasgow	LB39			
*	T. L. Johnson	LA19			
	B. Katz	LA19			
*	P. E. McCourt	LA02			
*	L. G. Rico	LB35			
*	T. H. Springer (3)	LB35			
*	W. B. Thomson (2)	LA19			
RESERVED FOR PROPRIETARY/LEGAL NOTICES					
			NOTICE		
			This report contains information of a preliminary nature prepared in the course of work for the United States Government. Since it is transmitted in advance of patent clearance, it is made available in confidence solely for use in performance of work under contracts with the U. S. Government. This document is not to be published nor its contents otherwise disseminated or used for purposes other than specified above before patent approval for such release or use has been secured, upon request, from the cognizant Government Patent Council.		
731-W.24/mlm					
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY					

FORM 734-C REV. 11-78

CONTENTS

	<u>Page</u>
INTRODUCTION.....	4
SUMMARY.....	5
ANALYSIS.....	7
CONCLUSIONS.....	13
REFERENCES.....	14
APPENDIX: CALCULATIONS AND RESULTS.....	15

FIGURES

<u>Figure</u>	<u>Page</u>
1. Normalized Receiver Heat Flux Profiles.....	16
2. Tube Wall and Sodium Film T	26
3. Axial Temperature Distribution on Tubes.....	27
4. Forced Convection Heat Transfer Correlation.....	38
5-(a-1) to 5-(d-3) Heat Losses from Receiver.....	48
6-a, b, c, d Heat Losses from Receiver.....	60
7-a, b, c Heat Losses from Receiver.....	64

TABLES

<u>Table</u>		
I-a, b, c	Heat Flux Integrations.....	17
II.	Sodium Side and Combined Wall "h" Values.....	24
III.	Tube Wall and Sodium Film T	25
IV-(a-1) to C-2)	Axially Averaged Temperatures.....	28
V.	Effective Mean Temperatures.....	34
VI.	Radiation Heat Losses.....	36
VII.	Convection Heat Transfer Coefficients.....	41
VIII.	Convection Heat Losses.....	42
IX.	Combined Radiation and Convection Losses.....	43
X-a, b, c, d	Heat Loss Calculations.....	44

INTRODUCTION

The central receiver solar power system is planned to have a central tower placed in the midst of a field of mirrors. The mirrors are moved by heliostats throughout the course of the day and year such that sunlight is continuously reflected to the receiver at the top of the tower (258 meters above the ground). The receiver analyzed is comprised of 2,640 tubes of 3/4 in. OD, vertically oriented and forming a cylindrical shape, 16 meters in diameter, and 16 meters in height (reference configuration at the time that the analysis was performed).

The tubes are sodium cooled. That is, cool sodium (e.g., 550°F) enters at the bottom, is heated by the concentrated solar heat flux directed to the tube surface, and hot sodium (e.g., 1100°F) leaves at the top. Sodium inlet/outlet temperature pairs of 650°/1200°F, 750°/1300°F, and 850°/1400°F are also considered. The receiver has a high-temperature surface area of approximately 8,664 ft², exposed to winds and "seeing" the surroundings at ambient temperature. Part of the concentrated solar heat flux incident on the surface of the receiver does not get absorbed in the sodium stream--it is lost.

The losses occur by three modes: 1) reflection of a portion of the solar radiation heat flux incident on the receiver, 2) thermal radiation emitted from the receiver surface, and 3) thermal convection, either forced (wind) or natural.

Sodium flow in the tubes is assumed to be adjusted such that the desired inlet/outlet temperatures are maintained. However, there is a temperature drop across the tube wall and sodium film dependent on the magnitude of the heat flux. Thus, at high power, the outside surface temperature of the tubes is somewhat higher (and consequently somewhat higher losses) than at lower powers, for the same sodium temperature distribution within the tubes.

SUMMARY

Calculations of heat losses from the receiver of the Central Receiver Solar Power System have been made. Three modes of heat transfer are considered:

- 1) Reflection of heat flux radiation incident on the receiver (absorptivity, $\alpha = 0.95$). This amounts to 5% of the incident thermal energy.
- 2) Thermal radiation from the surface of the receiver (effective emissivity $\epsilon = 0.90$).
- 3) Convection, - both forced convection (for wind velocities up to 16.3 meters/sec = 53.4 ft/sec = 36.4 mph) and natural convection.

A range of sodium inlet/outlet temperatures for the receiver is taken into account. The reference condition is for sodium inlet at the bottom of the receiver tubes at 550°F, and sodium outlet at the top of the receiver tubes at 1100°F. The sodium flow rate in the various tubes is varied so as to maintain the desired inlet/outlet temperatures. Cases with sodium inlet/outlet temperatures of 650°/1200°F, 750°/1300°F, and 850°/1400°F are also investigated.

Heat flux distribution to the receiver surface is based on University of Houston data (Reference 1). Axial and circumferential heat flux distribution for "equinox noon" is used, but total heat loads to the sodium stream ranging from 100 Mwt to 429 Mwt are accounted for.

Values of heat losses (in Mwt) are determined, with a summary presented in Tables X-a, X-b, X-c, and X-d of the appendix.

Heat losses, as a percentage of thermal power incident on the receiver surface are shown in Figures 5, 6, and 7. Figure 5 has 12 plots. Heat loss percentage versus heat absorbed is shown for the three individual modes of heat loss. Each sheet is for a different wind velocity and sodium temperature profile.

Figure 6 has four plots. Percent total heat loss is shown versus wind velocity for various sodium absorbed powers. Each sheet is for a different sodium temperature profile.

Figure 7 has three plots. Percent heat loss versus sodium operation temperature range is shown for various sodium absorbed powers. Each sheet is for a different wind condition.

The heat loss percentage is quite high for the low power conditions. This is because for a given operating temperature condition, the heat loss variation as a function of incident power is small. Thus, at low incident power levels, the heat losses are a sizable fraction of the total; whereas, at high operating powers, the loss can be a relatively small fraction of the total.

ANALYSIS

The heat flux distribution has been obtained by the University of Houston researchers, Reference 1. It is shown in a normalized form in Figure 1. The normalized heat flux is shown as a function of axial position and by quadrant (circumferential position) on the receiver. The normalization is based on having the heat flux equal to 1.0 at mid-elevation on the north face. The curves were based on "equinox noon," and the heat flux is lower at other times of the day and year. However, it has been assumed that the normalized curves maintain the same relative position to each other, regardless of the actual magnitude of the heat flux.

In the three charts of Table I (I-a, I-b, and I-c), the heat flux curves are integrated. The axial temperature distribution of sodium in the tubes is determined on the basis of assuming that the thermal power entering the sodium is proportional to the local heat flux. (This neglects the fact that the upper portion of the tube has higher heat losses due to its higher temperature.) On Page A-5 of the appendix, the fraction of the total power going into each quadrant is determined, as well as the sodium flow rate required for a sodium thermal power of 429 MWt and temperature rise of 550°F. The calculations are carried out on the basis of assuming four quadrants on the receiver. (Actually, the receiver cylinder is formed of 24 flat panels, each with 110 tubes.)

Because of the heat flow from the tube surface to the sodium within the tube, there is a surface-to-sodium temperature drop. This is made up of sodium film convection drop, and a conduction drop through the tube wall.

The effective heat transfer coefficients for conduction and sodium convection have been determined on Pages A-7 through A-9. They are tabulated in Table II for each quadrant, and at three locations axially.

In Table III, the ΔT (wall and Na) are determined for each quadrant, at a series of axial locations. The ΔT values indicate how much hotter the outside tube surface is relative to the local sodium temperature. Figure 2 shows this ΔT value versus axial position, by quadrant. Figure 3 presents the axial temperature profiles for the receiver for the inlet/outlet sodium temperatures of 550°/1100°F, for a heat input to the sodium of 429 Mwt. The solid lines represent the sodium temperature, as determined in Tables I-a, I-b, and I-c. The dashed curves represent the receiver external surface temperatures for a 429 Mwt heat input to the sodium ($T_{Na}(x) + \Delta T(x)$), that is, the "Full Power" condition. The solid curves represent the receiver surface temperature for $Q(Na) = 0$, that is, the "No Power" condition. Of course, the "No Power" condition has no steady-state significance; it is used in making linear interpolations for intermediate powers; $Q(Na)$ between 0 and 429 Mwt.

In Table IV, the axially averaged temperatures of the receiver are determined. $T(Na)$ represents the surface temperature at the "No Power" condition, and $T(surf)$ represents the surface temperature at the "full power" condition. For example, consider the calculations for the North quadrant. Table IV-(a-1) shows the mean sodium and full power surface temperatures for 20 axial segments. The table applies to the sodium 550°F inlet/1100°F outlet case. (For higher inlet/outlet temperatures, it is assumed that the same profile shape is maintained, merely raised the appropriate number of degrees.) Then, on Table IV-(a-2), the axially averaged temperatures are determined. Notice that different mean temperatures are obtained for convection and for radiation calculations. The mean temperatures are defined by:

$$\bar{T}_{(CONV)} = \frac{\sum_{i=1}^n T_i (°F)}{n}$$

$$\bar{T}_{(RAD)} = \left(\frac{\sum_{i=1}^n (T_{i \cdot R})^4}{n} \right)^{\frac{1}{4}} - 460°$$

where $n = 20$ (20 axial segments). Axially averaged temperatures are determined for both convection and radiation, for "no power" ($Q = 0$) and "full power" ($Q = 429$) conditions, and for a series of sodium inlet/outlet temperatures. This is done for all quadrants.

In Table V, the effective mean surface temperatures for the receiver are determined. Actually this represents the circumferential averaging. Thus, for each sodium inlet/outlet temperature condition, the mean convection and mean radiation temperatures are determined and shown.

On Page A-20, the calculation of radiation heat losses are set up, and the results are shown in Table VI. Radiation heat losses are shown for sink temperatures of 60°F and 0°R . The 60°F sink temperature results are circled, and used in further tabulation and plots. The 0°R sink temperature calculations were made merely to show that radiation heat losses are very insensitive to the assumed sink temperature.

On Page A-22, calculations are made for the natural convection heat loss coefficients. A value of $h(\text{Nat. Conv.}) = 1.40 \text{ Btu/hr ft}^2 \text{ }^{\circ}\text{F}$ is to be used for all cases.

Figure 4 shows a forced convection heat transfer correlation for vertical cylindrical geometry. The plot goes to rather high Reynolds numbers. This is necessary because of the large characteristic length ($D = 16 \text{ meters} = 52.5 \text{ ft}$) of the receiver. Even so, some extrapolation was required. The data is extracted from References 5 and 6.

The Reference 5 data (Achenbach) given Nusselt number for several surface roughness conditions. The receiver surface, being composed of 3/4-in. OD tubes, has an equivalent surface roughness of 60×10^{-5} . The Nu vs Re curve for surface roughness of 100×10^{-5} , with an extrapolation, was used in the forced convection calculation.

On Pages A-25 and A-26, forced convection heat loss coefficients are determined for a variety of wind speeds, using the correlation of Figure 4.

As a matter of conservatism, it was assumed that both natural and forced convection heat losses could occur simultaneously. If either natural or forced convection were to be used alone, there is the possibility of underestimating the convective heat loss. Therefore, an effective convection heat loss coefficient was determined according to the expression

$$h = \sqrt{h_{\text{forced conv.}}^2 + h_{\text{nat. conv.}}^2}$$

effective convection loss
forced conv.
nat. conv.

In Table VIII, the calculated convection heat losses are shown. There are the "combined convection" losses. Values are shown for a range of wind velocities, and sodium inlet/outlet temperatures. Three different wind velocities have been considered: 5.70 meters/sec, 16.28 meters/sec, and an intermediate velocity. The lower and upper limit velocities are based on "ground" (elevation = 10 meters) velocities of 3.5 and 10.0 meters/sec. There, velocities are translated to the receiver elevation of 258 meters by the expression:

$$V(H) = V(H = 10m) \left(\frac{H}{H(10m)} \right)^{0.15}$$

This gives limiting wind velocities of 5.70 meters/sec (18.70 fps) and 16.28 meters/sec (53.42 ft/sec) as shown on Page A-25.

In Table IX, the combined radiation and convection heat losses are shown. "No power" and "full power" cases are shown (which refer to different tube surface temperatures due to temperature drop across the tube wall and sodium film). A range of wind velocities and sodium inlet/outlet temperatures are covered.

In Tables X (Xa through Xd) additional heat loss calculations are made. Sodium input powers from 100 MWt to 429 MWt are considered. For these intermediate powers, linear interpolations were made of the heat loss values in Table IX. Heat losses by radiation and convection are shown. In addition, the heat loss by reflection from the receiver surface (based on $\alpha_s = 0.95$) is also shown. The total heat loss and the total heat power incident on the receiver surface are determined. Heat losses are also shown as a percentage of the thermal power incident on the receiver surface. Calculations are shown for a range of wind velocities and sodium inlet/outlet temperatures.

In Figure 5 (12 plots), heat losses as a percent of incident power are shown as a function of thermal power input to the sodium. Heat losses by convection, reflection and radiation are plotted, as well as the total loss. Each plot is for a different combination of wind velocity and sodium inlet/outlet temperature.

In Figure 6 (4 plots), heat losses as a function of wind velocity are shown for various sodium thermal power inputs. There is one plot for each sodium inlet/outlet temperature condition.

In Figure 7 (3 plots), heat losses vs sodium inlet/outlet temperature ranges are shown. There is one sheet for each wind velocity considered.

Notice that the plots of Figures 5, 6, and 7 are all based on the data presented in Tables X, with the data crossed plotted in different ways.

CONCLUSIONS

The results of the analysis are presented in Tables X (4 charts) and Figures 5 (12 plots), Figures 6 (4 plots), and Figures 7 (3 plots).

It is observed that convection heat losses are relatively low, so that wind velocity is not a particularly strong contributor to receiver operation degradation. Radiation losses tend to be higher than convection losses, particularly when the receiver is being operated at the higher temperatures. Reflection loss is constant at 5% of the total losses (as a direct consequence of assuming $\alpha = 0.95$).

The percentage heat losses increase markedly with decreasing system power. This is because even when the total thermal power incident on the receiver decreases sharply, the sodium flow is assumed to be adjusted so that the inlet/outlet temperatures remain unchanged. Thus, the receiver surface temperatures and the heat loss remain approximately the same. But now, this essentially unchanged heat loss becomes a much higher percentage of the greatly reduced incident power. Therefore, one observes that the receiver thermal efficiency declines substantially as the system operating power goes down.

FORM 719-P REV 3-75

REFERENCES

1. "Liquid Metal Cooled Solar Central Receiver Feasibility Study and Heliostat Field Analysis," ORO 5178-78-1, October 1977, Pages 5-32 (University of Houston data)
2. G. H. Golden and J. V. Tokav, "Thermophysical Properties of Sodium," ANL-7323, August 1967, Pages 78-88
3. J. G. Knudsen and D. L. Katz, Fluid Dynamics and Heat Transfer, McGraw-Hill, 1958, Page 463
4. S. E. Knaus, O. Esquivel and W. E. Collier, Jr., "Nuclear Systems Material Handbook Properties of AI Steam Generator Materials," N036TI550-005, November 1975, Page 52 (304 Stainless Steel)
5. Elmar Achenbach, "Heat Transfer from Smooth and Rough Surfaced Circular Cylinders in a Cross-Flow"
6. W. R. Wagner, "Solar Receiver Wind Convective Heat Transfer Coefficients Analysis," Rockwell International internal letter to J. Friedman, ASR-77-20, January 21, 1977, quotes data from:
 - 6a. A. Zukauskas, et al., "Local Heat Transfer in Tubes in the Critical Flow Region," Fifth International Heat Transfer Conference, Tokyo, Volume IV, 1974
 - 6b. W. H. McAdams, Heat Transmission, Third Edition, McGraw-Hill, 1954, Pages 266-267
7. E. M. Mouradian, personal notes on thermal properties of air, including natural convection behavior. Based on correlations from Reference 6b, Pages 172-180; and:
 - 7a. F. Kreith, Principles of Heat Transfer, Second Edition, International Text Book Company, 1966, Page 595

APPENDIX

Calculations and Results




FIGURE 1 NORMALIZED RECEIVER HEAT FLUX PROFILES; BASED ON EQUINOX NOON.

(Ref. 1) University of Houston, 1979.

TABLE I-a NORTH QUADRANT
HEAT FLUX INTEGRATION

NORTH
INTEGRATION OF HEAT FLUX CURVES
(Figure 1)

$q''(z)$ (sparses) Amplitude	$\int_0^{x/L} q'' dz$ Σ Amp (a) Running Summation	$\frac{\int_0^{x/L} q'' dz}{\int_0^{x/L} dz}$ $\frac{\Sigma \text{ Amp (a)}}{\Sigma \text{ Amp}}$	T_{No} OF $x/L = 0 \rightarrow .5$ $[550 + 550 (\frac{\Sigma \text{ Amp}}{\Sigma \text{ Amp}})]$	T_{No} OF $x/L = 1.0 \rightarrow .5$ $[1100 - 550 (\frac{\Sigma \text{ Amp}}{\Sigma \text{ Amp}})]$
3.3	3.3	0.0127	550.0	1100.0
3.6	6.9	0.0266	550.0	1099.3
3.7	10.6	0.0405	550.0	1098.6
4.2	14.7	0.0544	550.0	1097.9
4.0	18.7	0.0683	550.0	1097.2
3.5	22.4	0.0822	550.0	1096.5
3.4	25.8	0.0961	550.0	1095.8
6.4	32.2	0.1100	550.0	1095.1
7.0	39.2	0.1239	550.0	1094.4
8.4	47.6	0.1378	550.0	1093.7
9.0	56.6	0.1517	550.0	1093.0
10.0	66.6	0.1656	550.0	1092.3
11.0	77.6	0.1795	550.0	1091.6
11.4	89.0	0.1934	550.0	1090.9
12.4	101.4	0.2073	550.0	1090.2
13.0	114.4	0.2212	550.0	1089.5
13.5	127.9	0.2351	550.0	1088.8
16.0	143.9	0.2490	550.0	1088.1
17.0	160.9	0.2629	550.0	1087.4
18.0	178.9	0.2768	550.0	1086.7
20.0	198.9	0.2907	550.0	1086.0
21.0	219.9	0.3046	550.0	1085.3
23.0	242.9	0.3185	550.0	1084.6
24.0	266.9	0.3324	550.0	1083.9
27.0	293.9	0.3463	550.0	1083.2
29.0	322.9	0.3602	550.0	1082.5
30.0	352.9	0.3741	550.0	1081.8
32.0	384.9	0.3880	550.0	1081.1
33.0	417.9	0.4019	550.0	1080.4
34.0	451.9	0.4158	550.0	1079.7
37.0	488.9	0.4297	550.0	1079.0
40.0	528.9	0.4436	550.0	1078.3
41.0	569.9	0.4575	550.0	1077.6
42.0	611.9	0.4714	550.0	1076.9
43.0	654.9	0.4853	550.0	1076.2
44.0	698.9	0.4992	550.0	1075.5
45.0	743.9	0.5131	550.0	1074.8
46.0	790.9	0.5270	550.0	1074.1
47.0	838.9	0.5409	550.0	1073.4
48.0	887.9	0.5548	550.0	1072.7
49.0	937.9	0.5687	550.0	1072.0
49.2	987.1	0.5826	550.0	1071.3
49.6	1036.7	0.5965	550.0	1070.6
49.8	1086.5	0.6104	550.0	1069.9
49.9	1136.4	0.6243	550.0	1069.2
50.0	1186.4	0.6382	550.0	1068.5

AVERAGE VALUE: 25.92
TOTAL $\int_0^1 q'' dz$: 2591.8

$\frac{x}{L} \uparrow$

TABLE I-b EAST/WEST QUADRANTS
HEAT FLUX INTEGRATION

A-3

EAST/WEST
INTEGRATION OF HEAT FLUX CURVES
(Figure 1)

$q(z)$ (Sources) Amplitude z	$\int_0^z q dz$ Σ Amp (z) Running Summation	$\int_0^z q dz$ Σ Amp (z) Σ Amp	T_{No} OF $\% = 0 \rightarrow .5$ $[550 + 350(\frac{\Sigma A}{\Sigma Amp})]$	T_{No} OF $\% = 1.0 \rightarrow .5$ $[1100 - 350(\frac{\Sigma A}{\Sigma Amp})]$
2.5	2.5	0.00175	550.0	1099.5
2.6	5.1	0.00356	550.1	1099.4
2.8	7.9	0.00532	550.2	1099.3
3.0	10.9	0.00706	550.3	1099.2
3.2	14.1	0.00875	550.4	1099.1
3.5	17.6	0.01123	550.5	1099.0
3.8	21.4	0.01419	550.6	1098.9
4.0	25.4	0.01774	550.7	1098.8
4.2	29.6	0.02208	550.8	1098.7
4.7	34.3	0.02741	550.9	1098.6
5.2	39.7	0.03316	551.0	1098.5
5.6	45.3	0.03953	551.1	1098.4
6.0	51.3	0.04650	551.2	1098.3
6.4	57.7	0.05410	551.3	1098.2
6.7	64.4	0.06240	551.4	1098.1
7.1	71.6	0.07130	551.5	1098.0
7.6	79.1	0.08083	551.6	1097.9
8.0	87.1	0.09100	551.7	1097.8
8.5	95.6	0.09666	551.8	1097.7
9.1	104.5	0.09773	551.9	1097.6
10.0	114.0	0.09430	552.0	1097.5
10.5	124.3	0.08640	552.1	1097.4
11.0	134.3	0.07410	552.2	1097.3
11.8	144.9	0.05850	552.3	1097.2
12.2	155.8	0.04050	552.4	1097.1
13.0	166.9	0.02000	552.5	1097.0
13.6	178.3	0.00700	552.6	1096.9
14.4	190.0	0.00000	552.7	1096.8
15.1	202.0	0.00000	552.8	1096.7
16.0	214.0	0.00000	552.9	1096.6
16.6	226.6	0.00000	553.0	1096.5
17.6	239.0	0.00000	553.1	1096.4
18.5	251.1	0.00000	553.2	1096.3
19.6	262.7	0.00000	553.3	1096.2
20.6	273.3	0.00000	553.4	1096.1
21.7	283.0	0.00000	553.5	1096.0
23.0	292.0	0.00000	553.6	1095.9
24.0	300.0	0.00000	553.7	1095.8
25.1	307.1	0.00000	553.8	1095.7
26.3	313.4	0.00000	553.9	1095.6
27.0	319.0	0.00000	554.0	1095.5
27.7	323.7	0.00000	554.1	1095.4
28.4	327.7	0.00000	554.2	1095.3
28.8	331.0	0.00000	554.3	1095.2
29.3	333.7	0.00000	554.4	1095.1
29.5	335.9	0.00000	554.5	1095.0
29.7	337.6	0.00000	554.6	1094.9
29.8	338.8	0.00000	554.7	1094.8
29.9	339.5	0.00000	554.8	1094.7
30.0	340.0	0.00000	554.9	1094.6
30.0	340.0	0.00000	555.0	1094.5

AVERAGE VALUE 14.31


TOTAL $\int_0^z q dz$ 1431.4

TABLE I-c SOUTH QUADRANT
HEAT FLUX INTEGRATION

SOUTH

INTEGRATION OF HEAT FLUX CURVES
(Figure 1)

$q(\xi)$ Amplitude ξ	$\int_0^{\xi} q d\xi$ Σ Amp (ξ) Running Summation	$\frac{\int_0^{\xi} q d\xi}{\int_0^{\xi} d\xi}$ $\frac{\Sigma \text{ Amp} (\xi)}{\xi \text{ Amp}}$	T_{No} of $\% = 0 \rightarrow 5$ $[550 + 550(\frac{\Sigma \text{ Amp}}{\xi \text{ Amp}})]$	T_{No} of $\% = 100 \rightarrow 5$ $[1100 - 550(\frac{\Sigma \text{ Amp}}{\xi \text{ Amp}})]$
0.0	0.0	0.0	550	1100
0.0	0.0	0.0	550	1100
0.0	0.0	0.0	550	1100
0.0	0.0	0.0	550	1100
0.1	0.1	0.001	549.5	1099.5
0.2	0.2	0.002	549.0	1099.0
0.3	0.4	0.001	548.5	1098.5
0.4	0.7	0.001	548.0	1098.0
0.5	1.1	0.002	547.5	1097.5
0.6	1.7	0.003	547.0	1097.0
0.7	2.3	0.003	546.5	1096.5
0.8	3.4	0.004	546.0	1096.0
0.9	4.4	0.005	545.5	1095.5
1.0	5.5	0.005	545.0	1095.0
1.1	6.5	0.005	544.5	1094.5
1.2	7.5	0.006	544.0	1094.0
1.3	8.5	0.006	543.5	1093.5
1.4	9.5	0.007	543.0	1093.0
1.5	10.5	0.007	542.5	1092.5
1.7	12.0	0.007	542.0	1092.0
2.0	14.2	0.007	541.5	1091.5
2.2	16.7	0.008	541.0	1091.0
2.5	19.5	0.008	540.5	1090.5
2.8	22.6	0.008	540.0	1090.0
3.1	25.9	0.009	539.5	1089.5
3.5	29.4	0.009	539.0	1089.0
3.8	33.1	0.009	538.5	1088.5
4.2	37.0	0.009	538.0	1088.0
4.7	41.1	0.009	537.5	1087.5
5.2	45.4	0.009	537.0	1087.0
5.7	50.0	0.009	536.5	1086.5
6.4	54.7	0.009	536.0	1086.0
7.0	59.7	0.009	535.5	1085.5
7.6	64.7	0.009	535.0	1085.0
8.1	69.7	0.009	534.5	1084.5
8.6	74.4	0.009	534.0	1084.0
9.5	79.9	0.009	533.5	1083.5
10.0	85.0	0.009	533.0	1083.0
10.5	90.0	0.009	532.5	1082.5
11.4	95.0	0.009	532.0	1082.0
12.1	100.0	0.009	531.5	1081.5
13.0	105.0	0.009	531.0	1081.0
13.6	110.0	0.009	530.5	1080.5
14.1	115.0	0.009	530.0	1080.0
14.6	120.0	0.009	529.5	1079.5
15.0	125.0	0.009	529.0	1079.0
15.4	130.0	0.009	528.5	1078.5
15.6	135.0	0.009	528.0	1078.0
16.0	140.0	0.009	527.5	1077.5
16.2	145.0	0.009	527.0	1077.0
16.3	150.0	0.009	526.5	1076.5
16.4	155.0	0.009	526.0	1076.0
16.5	160.0	0.009	525.5	1075.5

DESIGNED BY: EMM.	 Rockwell International Atomic International Division	PAGE NO. 20 OF
CHECKED BY:		N272 T I 000004
DATE:		REPORT NO.
		MODEL NO. A-5

SODIUM FLOW RATE, Enthalpy Rise

Dimensionless Power Input Distribution: (See Tables I)

NORTH	2591.8	÷ 6101.8 =	0.424 760 0	Fraction of Total Energy Into Each Quadrant.
EAST/WEST	1431.4		0.234 586 5	
EAST/WEST	1431.4		0.234 586 5	
SOUTH	647.2		0.106 067 0	
TOTAL	6101.8		1.00	

Deal with average energy in each quadrant, without looking for finer θ direction variation.

Consider Sodium Flow:

$$\text{Thermal Power: } 429 \text{ MW}_{\text{th}} = 1.46418 \times 10^9 \frac{\text{BTU}}{\text{hr}}$$

$$\text{Sodium Temperature Rise} = 1100 - 550 = 550^\circ\text{F}$$

$$\text{Enthalpy Rise: out } T = 1100^\circ \quad h_{\text{Na}} = 486.88 \text{ BTU/lb}_m \quad (\text{R.F. 2})$$

$$\text{in } T = 550^\circ \quad h_{\text{Na}} = 319.44 \text{ BTU/lb}_m$$

$$\Delta T = 550^\circ\text{F} \quad \Delta h = 167.44 \text{ BTU/lb}_m$$


$$\bar{C}_p = \frac{\Delta h}{\Delta T} = \frac{167.44}{550} = 0.304436 \text{ BTU/lb}_m^\circ\text{F}$$

$$Q = \dot{W} \Delta h, \quad \dot{W}_{\text{Na}} = \frac{Q}{\Delta h_{\text{Na}}}$$

$$\dot{W}_{\text{Na}} = \frac{Q}{\Delta h} = \frac{1.46418 \times 10^9 \text{ BTU/hr}}{167.44 \text{ BTU/lb}_m} = 8,744,500 \frac{\text{lb}_m}{\text{hr}}$$

$\dot{W}_{\text{Na}} = 8,744,500 \frac{\text{lb}_m}{\text{hr}}$ TOTAL SODIUM FLOW
--

$Q = 429 \text{ MW}_t = 1.46418 \times 10^9 \frac{\text{BTU}}{\text{hr}}$ TOTAL
--

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>21</u> OF
CHECKED BY:		N272TI000004
DATE:		MODEL NO. <u>A-6</u>

SODIUM PROPERTIES: (Ref. 2) $\frac{1}{4}(1100) + \frac{1}{2}(825) + \frac{1}{4}(550)$

	T = 1100°F	T = 550°F	T = $\frac{1100+550}{2} = 825^\circ$	MEAN PROPERTY
$\rho \frac{\text{lb}_m}{\text{ft}^3}$	50.553	55.116	52.845	52.84
$h \frac{\text{BTU}}{\text{lb}_m \cdot \text{ft}^2 \cdot \text{hr}}$	486.88	319.44		
$\mu \frac{\text{lb}_m}{\text{ft} \cdot \text{hr}}$	0.5039	0.8591	0.62855	.65503
$k \frac{\text{BTU}}{\text{hr} \cdot \text{ft} \cdot \text{ft}^2 \cdot \text{ft}^2 \cdot \text{hr}}$	36.17	44.60	40.23	40.308
P_r	.0041766	.0060176	.0046701	0.004917
C_p	0.2998	0.3124	.3035	.304436


24 panels, 4 quadrants. ∴ 6 panels per quadrant.
 Each panel has 110 tubes.
 ∴ Each quadrant has 660 tubes. (Ref. 1)
 Total = 2640 tubes.

Tube:
 BWG 18, 3/4" $\begin{cases} \text{OD} = 0.75" \\ \text{tw} = 0.049" \\ \text{ID} = 0.652" \end{cases}$

Flow Area; 1 tube:
 $A_{\text{FLOW}} = \frac{\pi}{4} (\text{ID})^2 = \frac{\pi}{4} \left(\frac{.652}{12} \right)^2 = .0023186 \text{ ft}^2$

Flow Area; 1 Quadrant (660 tubes)
 $A_{\text{FLOW QUAD}} = 1.5302645 \text{ ft}^2 \quad 1.5303 \text{ ft}^2$

Total Flow Area: (2640 Tubes)
 $A_{\text{FLOW QUAD}} = 6.12106 \text{ ft}^2$

PREPARED BY: <i>Emm</i>	 Rockwell International Atomics International Division	PAGE NO. <u>22</u> of
CHECKED BY:		N272TI000004
DATE:		SECRET NO.
		MODEL NO. <u>A-7</u>

QUADRANT	Flow Fraction	\dot{W}^{QUAD} Flow in Quadrant lbm/hr	$G = \frac{\dot{W}}{A_{Flow}}$ $\frac{lbm}{hr ft^2}$ $\frac{\dot{W}^{QUAD}}{1.53026}$	Heat Input into each Quadrant? $\dot{Q}_{quad} = frac \times (1.4648 \times 10^9)$ BTU/hr
NORTH	0.424760	3,714,314	2,427,237	6.219238×10^8
EAST/WEST	0.2345865	2,051,342	1,340,515	3.434762×10^8
EAST/WEST	0.2345865	2,051,342	1,340,515	3.434762×10^8
SOUTH	<u>0.106067</u>	<u>927,502</u>	606,106	1.553009×10^8
		8,744,500		

$$G_{QUAD} = \frac{\dot{W}}{A_{FLOW_{QUAD}}}$$

$$Vel = \frac{G}{\rho}$$

$$Re = \frac{G d_{in}}{\mu}$$

$$Nu = 7 + \frac{1}{40} (Pr Re)^{0.8}$$

$$h_{Na} = \frac{Nu k}{d_{in}} = \frac{Nu k}{(\frac{.652}{12})} = 18.40491 (Nu) (k)$$

Reference 3
Liquid Metal Heat
Transfer Correlation

Based on ID.

$$h_{Na}^{BASED ON OD} = \frac{.652}{.75} h_{Na}^{BASED ON ID}$$

Assume that $\frac{1}{2}$ of circumference of tube is acting for heat transfer through tube into sodium.

$$A_{(Effective Inner Surface)} = (n_{TUBES_{QUAD}} \ln) \left(\frac{180^\circ}{360^\circ} \right) \pi d_{in} L = (660) \left(\frac{1}{2} \right) (\pi) \left(\frac{.652}{12} \right) L = 56.3288 L ft^2$$

$$A_{(Effective Outer Surface)} = n \left(\frac{180^\circ}{360^\circ} \right) \pi d_{out} L = (660) \left(\frac{1}{2} \right) (\pi) \left(\frac{.75}{12} \right) L = 64.79535 L ft^2$$

FOR CONDUCTION THROUGH WALL:

$$q = \frac{2\pi k L}{\ln \frac{r_o}{r_i}} \Delta T = h_{\text{eff, cond OUTER}} A_{\text{OUT}} \Delta T$$

$$h_{\text{eff (COND OUTER)}} = \frac{2k}{D_o \ln \frac{D_o}{D_i}} = \frac{2k}{\frac{.75}{12} \ln \frac{.75}{.652}} = 228.5247 \text{ k}$$

Effective h for conduction through, based on outer area.

304 STAINLESS STEEL: (REF. 4, Pg. 52)

T °F	k $\frac{\text{BTU}}{\text{hr ft}^2 \text{ }^\circ\text{F}}$	$h_{\text{eff cond}} = 228.5247 \text{ k}$ BASED ON OD.
550°	10.48	2395 BTU/hr ft ² °F
825°	11.68	2669
1100°	12.88	2943

$$h_{\text{COMBINED Based on OD}} = \frac{1}{\frac{1}{h_{\text{NA CONV}}} + \frac{1}{h_{\text{COND}}}}$$

Effective outer surface area of one quadrant of tubes.

$$\text{OD} = 0.75" = \frac{1}{16} \text{ ft.}$$

Assume $\frac{1}{2}$ of tube circumference is effective.

$$N_T (\text{TUBES in one quadrant}) = 660$$

$$A_{\text{surface}} = N_T (.5) \pi D_o L$$

$$L = 16 \text{ meters} = 52.5 \text{ ft}$$

$$A = 660 (.5) \pi \left(\frac{.75}{12}\right) (52.5) = 3401.8 \text{ ft}^2$$

Effective Outer Surface Area of one quadrant of tubes for heat transport to Na
3400 ft²

"Average Heat Flux"

QUAD	$\Sigma Q \text{ BTU/hr}$	$(Q/A)_{\text{AVG}} = \frac{\Sigma Q}{3400} \frac{\text{BTU}}{\text{hr ft}^2}$
N	6.21924×10^8	182,900
E/W	3.434762×10^8	101,000
S	1.553009×10^8	45,680

TABLE II

CALCULATION OF SODIUM SIDE h and COMBINED h .

(To determine ΔT through wall and Na film.)

		W_{Na} lb/hr	$G = \frac{W}{A}$ lbm/hr ft ²	e_{Na} lbm/ft ³	VELOCITY G/p ft/sec	μ_{Na} lbm/hr ft	$Re = \frac{GD_{inner}}{\mu}$	Pr_{Na}	$NU_{D, inner}$ $\frac{h_{Na} D_{inner}}{k_{Na}}$	k_{Na} (No) BTU/hr ft °F	h_{Na} BTU/hr ft ² °F BASED ON ID.	$h_{eff, COND}$ BTU/hr ft ² °F BASED ON OD.	h COMBINED	
NORTH Quadrant														
HOT	1100°F	3,714,314	2,427,237	50.553	13.34	.5039	261,720	.0041766	13.743	36.17	9149	7953	2943	2148
MEAN	"	"	"	52.845	12.76	.6550	201,330	.0049473	13.260	40.31	9837	8552	2669	2034
COLD	550°F	"	"	55.116	12.23	.8591	153,510	.0060176	12.894	44.60	10,584	9201	2395	1900
EAST/WEST (2 Quadrants)														
HOT	1100°F	2,051,342	1,340,515	50.553	7.37	.5039	144,540	.0041766	11.194	36.17	7452	6478	2943	2024
MEAN	"	"	"	52.845	7.05	.6550	111,190	.0049473	10.893	40.31	8081	7025	2669	1934
COLD	550°F	"	"	55.116	6.76	.8591	84,780	.0060176	10.665	44.60	8755	7611	2395	1822
SOUTH Quadrant														
HOT	1100°F	927,502	606,106	50.553	3.33	.5039	65,350	.0041766	9.222	36.17	6139	5337	2943	1897
MEAN	"	"	"	52.845	3.19	.6550	59275	.0049473	9.063	40.31	6724	5847	2669	1832
COLD	550°F	"	"	55.116	3.06	.8591	38,330	.0060176	8.942	44.60	7340	6381	2395	1741

ESG-79-2, Vol II, Book 2
F-25

N272TI000004

TABLE III.

DETERMINATION OF ΔT THROUGH TUBE WALL & N_a FILM

QUADRANT: NORTH

$(Q/A)_{AVG} = 182,900 \text{ BTU/hr ft}^2$

Ⓐ Axial Location %L		Ⓑ 1/2 Amp See Fig.	Ⓒ HEAT FLUX RATIO $\frac{Q/A \text{ Local}}{Q/A \text{ Avg}}$		Ⓓ LOCAL HEAT FLUX Q/A_{avg}	Ⓔ LOCAL h_{eff} BTU/hr ft ² F		$\Delta T_F = \frac{Q/A \text{ Local}}{h_{LOCAL}}$	
↓	↑		$\frac{Q/A}{Q/A \text{ Avg}}$	Local		COLD END	HOT END	COLD END	HOT END
0	1.0	3.3	0.127	23,219	1900	2150	12.2	10.8	
.125	.875	10.0	0.3858	70,534	1933	2121	36.5	33.3	
.25	.75	25.25	0.9742	178,108	1967	2092	90.5	85.1	
.375	.625	41.6	1.605	293,434	2000	2063	146.7	142.2	
.50	50.0	1.929	352,699	2034			173.4		

QUADRANT: EAST/WEST

$(Q/A)_{AVG} = 101,000 \text{ BTU/hr ft}^2$

Ⓐ Axial Location %L		Ⓑ 1/2 Amp See Fig.	Ⓒ HEAT FLUX RATIO $\frac{Q/A \text{ Local}}{Q/A \text{ Avg}}$		Ⓓ LOCAL HEAT FLUX Q/A_{avg}	Ⓔ LOCAL h_{eff} BTU/hr ft ² F		$\Delta T_F = \frac{Q/A \text{ Local}}{h_{LOCAL}}$	
↓	↑		$\frac{Q/A}{Q/A \text{ Avg}}$	Local		COLD END	HOT END	COLD END	HOT END
0	1.0	2.5	.1747	17640	1822	2024	9.7	8.7	
.125	.875	6.0	.4193	42336	1850	2002	22.9	21.1	
.25	.75	12.0	.8386	84672	1878	1979	45.1	42.8	
.375	.625	23.0	1.6073	162,287	1906	1957	85.1	82.9	
.50	30.0	2.0964	211,679	1934			109.5		

QUADRANT: SOUTH

$(Q/A)_{AVG} = 45,680 \text{ BTU/hr ft}^2$

Ⓐ Axial Location %L		Ⓑ 1/2 Amp See Fig.	Ⓒ HEAT FLUX RATIO $\frac{Q/A \text{ Local}}{Q/A \text{ Avg}}$		Ⓓ LOCAL HEAT FLUX Q/A_{avg}	Ⓔ LOCAL h_{eff} BTU/hr ft ² F		$\Delta T_F = \frac{Q/A \text{ Local}}{h_{LOCAL}}$	
↓	↑		$\frac{Q/A}{Q/A \text{ Avg}}$	Local		COLD END	HOT END	COLD END	HOT END
0	1.0	0	0	0	1741	1897	0	0	
.125	.875	1.0	0.15456	7056	1764	1881	4.0	3.8	
.25	.75	4.45	0.6878	31,400	1787	1865	17.6	16.8	
.375	.625	12.1	1.8702	85,379	1809	1848	47.2	46.2	
.50	16.5	2.5502	114,426	1832			63.6		

FIGURE 2
 ΔT THROUGH TUBE WALL & Na FILM




FIGURE 3
AXIAL TEMPERATURE DISTRIBUTION Sodium & Surface
ON TUBES. For $T_{in} = 550^{\circ} \rightarrow 1100^{\circ}F.$




TABLE IV - (a-1)
 DETERMINE AXIALLY AVERAGED TEMPERATURE

A-13

FOR $T_{Na} = 550^\circ\text{F} \rightarrow 1100^\circ\text{F}$

QUADRANT: NORTH

	X/L	T_{Na} °F Surface Temp at Zero Power	ΔT °F Across Wall & Na Film	T_{surf} °F at $Q = 429 \text{ MW}$
BOTTOM				
1	0 — .05	552	13	565
2	.05 — .10	558	22	580
3	.10 — .15	567	36	603
4	.15 — .20	581	56	637
5	.20 — .25	601	80	681
6	.25 — .30	628	103	731
7	.30 — .35	663	127	790
8	.35 — .40	705	147	852
9	.40 — .45	752	161	913
10	.45 — .50	804	172	976
11	.50 — .55	846	172	1018
12	.55 — .60	898	158	1056
13	.60 — .65	945	140	1085
14	.65 — .70	987	119	1106
15	.70 — .75	1022	97	1119
16	.75 — .80	1049	75	1124
17	.80 — .85	1069	53	1122
18	.85 — .90	1083	34	1117
19	.90 — .95	1092	23	1115
20 TOP	.95 — 1.00	1098	13	1111

For $T_{Na} = 650^\circ\text{F} \rightarrow 1200^\circ\text{F}$, Add 100°F .For $T_{Na} = 750^\circ\text{F} \rightarrow 1300^\circ\text{F}$, Add 200°F .For $T_{Na} = 850^\circ\text{F} \rightarrow 1400^\circ\text{F}$, Add 300°F .

TABLE IV - (a-2)

AXIALLY AVERAGED TEMPERATURES:

A-14

n = 20 Axial Divisions.

QUADRANT: NORTH

* Based on Na Temp.

** Based on Surface Temp.

For $T_{Na} = 550^{\circ}\text{F} \rightarrow 1100^{\circ}\text{F}$,			
$\bar{T}_{CONV} = \frac{\sum T_i}{20}$	=	$\left. \begin{array}{l} Q=0^* \quad 825^{\circ}\text{F} \\ Q=429^{**} \quad 915.1^{\circ}\text{F} \end{array} \right\}$	FOR CONVECTION
$\bar{T}_{RAD} = \left(\frac{\sum (T_{OR})^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 870.4^{\circ}\text{F} \\ Q=429 \quad 958.1^{\circ}\text{F} \end{array} \right\}$	FOR RADIATION
For $T_{Na} = 650^{\circ}\text{F} \rightarrow 1200^{\circ}\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 100$	=	$\left. \begin{array}{l} Q=0 \quad 925^{\circ}\text{F} \\ Q=429 \quad 1015.1^{\circ}\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{OR} + 100)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 967.4^{\circ}\text{F} \\ Q=429 \quad 1055.5^{\circ}\text{F} \end{array} \right\}$	FOR RAD
For $T_{Na} = 750^{\circ}\text{F} \rightarrow 1300^{\circ}\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 200$	=	$\left. \begin{array}{l} Q=0 \quad 1025^{\circ}\text{F} \\ Q=429 \quad 1115.1^{\circ}\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{OR} + 200)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 1064.7^{\circ}\text{F} \\ Q=429 \quad 1153.2^{\circ}\text{F} \end{array} \right\}$	FOR RAD
For $T_{Na} = 850^{\circ}\text{F} \rightarrow 1400^{\circ}\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 300$	=	$\left. \begin{array}{l} Q=0 \quad 1125^{\circ}\text{F} \\ Q=429 \quad 1215.1^{\circ}\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{OR} + 300)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 1162.4^{\circ}\text{F} \\ Q=429 \quad 1251.2^{\circ}\text{F} \end{array} \right\}$	FOR RAD

TABLE IV - (b-1)

DETERMINE AXIALLY AVERAGED TEMPERATURE

A-15

For $T_{Na} = 550^{\circ}\text{F} \rightarrow 1100^{\circ}\text{F}$

QUADRANT: EAST/WEST

	X/L	T_{Na} °F Surface Temp at Zero Power	ΔT °F Across Wall & Na Film	T_{surf} °F at $Q = 429 \text{ MW}$
BOTTOM				
1	0 — .05	553	11	564
2	.05 — .10	560	16	576
3	.10 — .15	570	23	593
4	.15 — .20	584	31	615
5	.20 — .25	602	39	641
6	.25 — .30	626	52	678
7	.30 — .35	653	68	721
8	.35 — .40	693	86	779
9	.40 — .45	746	99	845
10	.45 — .50	802	108	910
11	.50 — .55	848	108	956
12	.55 — .60	904	97	1001
13	.60 — .65	954	83	1037
14	.65 — .70	997	65	1062
15	.70 — .75	1024	50	1074
16	.75 — .80	1048	38	1086
17	.80 — .85	1066	28	1094
18	.85 — .90	1080	22	1102
19	.90 — .95	1090	14	1104
20	.95 — 1.00	1097	10	1107
TOP				

For $T_{Na} = 650^{\circ}\text{F} \rightarrow 1200^{\circ}\text{F}$, Add 100°F .For $T_{Na} = 750^{\circ}\text{F} \rightarrow 1300^{\circ}\text{F}$, Add 200°F .For $T_{Na} = 850^{\circ}\text{F} \rightarrow 1400^{\circ}\text{F}$, Add 300°F .

TABLE IV - (b-2)

AXIALLY AVERAGED TEMPERATURES:

A-16

$n = 20$ Axial Divisions.

QUADRANT: EAST/WEST

For $T_{Na} = 550^\circ\text{F} \rightarrow 1100^\circ\text{F}$,			
$\bar{T}_{\text{CONV}} = \frac{\sum T_i}{20}$	$= \begin{cases} Q=0 & 825^\circ\text{F} \\ Q=429 & 877.3^\circ\text{F} \end{cases}$		FOR CONVECTION
$\bar{T}_{\text{RAD}} = \left(\frac{\sum (T_{OR})^4}{20} \right)^{1/4}$	$= \begin{cases} Q=0 & 870.5^\circ\text{F} \\ Q=429 & 920.8^\circ\text{F} \end{cases}$		FOR RADIATION
For $T_{Na} = 650^\circ\text{F} \rightarrow 1200^\circ\text{F}$			
$\bar{T}_{\text{CONV}} = \frac{\sum T_i}{20} + 100$	$= \begin{cases} Q=0 & 925^\circ\text{F} \\ Q=429 & 977.3^\circ\text{F} \end{cases}$		FOR CONV
$\bar{T}_{\text{RAD}} = \left(\frac{\sum (T_{OR} + 100)^4}{20} \right)^{1/4}$	$= \begin{cases} Q=0 & 967.5^\circ\text{F} \\ Q=429 & 1018.1^\circ\text{F} \end{cases}$		FOR RAD
For $T_{Na} = 750^\circ\text{F} \rightarrow 1300^\circ\text{F}$			
$\bar{T}_{\text{CONV}} = \frac{\sum T_i}{20} + 200$	$= \begin{cases} Q=0 & 1025^\circ\text{F} \\ Q=429 & 1077.3^\circ\text{F} \end{cases}$		FOR CONV
$\bar{T}_{\text{RAD}} = \left(\frac{\sum (T_{OR} + 200)^4}{20} \right)^{1/4}$	$= \begin{cases} Q=0 & 1064.8^\circ\text{F} \\ Q=429 & 1115.7^\circ\text{F} \end{cases}$		FOR RAD
For $T_{Na} = 850^\circ\text{F} \rightarrow 1400^\circ\text{F}$			
$\bar{T}_{\text{CONV}} = \frac{\sum T_i}{20} + 300$	$= \begin{cases} Q=0 & 1125^\circ\text{F} \\ Q=429 & 1177.3^\circ\text{F} \end{cases}$		FOR CONV
$\bar{T}_{\text{RAD}} = \left(\frac{\sum (T_{OR} + 300)^4}{20} \right)^{1/4}$	$= \begin{cases} Q=0 & 1162.5^\circ\text{F} \\ Q=429 & 1213.5^\circ\text{F} \end{cases}$		FOR RAD

TABLE IV - (C-1)
 DETERMINE AXIALLY AVERAGED TEMPERATURE

For $T_{Na} = 550^\circ\text{F} \rightarrow 1100^\circ\text{F}$

QUADRANT: SOUTH

	x/L	T_{Na} °F Surface Temp at Zero Power	ΔT °F Across Wall & No Film	T_{surf} °F at $Q = 429$ MW
BOTTOM				
1	0 — .05	550	1	551
2	.05 — .10	551	2	553
3	.10 — .15	554	4	558
4	.15 — .20	560	8	568
5	.20 — .25	572	13	585
6	.25 — .30	593	22	615
7	.30 — .35	625	33	658
8	.35 — .40	670	47	714
9	.40 — .45	730	57	787
10	.45 — .50	797	62	859
11	.50 — .55	853	62	915
12	.55 — .60	920	55	975
13	.60 — .65	980	45	1025
14	.65 — .70	1025	33	1058
15	.70 — .75	1057	22	1079
16	.75 — .80	1078	13	1091
17	.80 — .85	1090	7	1097
18	.85 — .90	1096	3	1099
19	.90 — .95	1099	2	1101
20 TOP	.95 — 1.00	1100	1	1101

For $T_{Na} = 650^\circ\text{F} \rightarrow 1200^\circ\text{F}$, Add 100°F .

For $T_{Na} = 750^\circ\text{F} \rightarrow 1300^\circ\text{F}$, Add 200°F .

For $T_{Na} = 850^\circ\text{F} \rightarrow 1400^\circ\text{F}$, Add 300°F .

TABLE IV - (c-2)

AXIALLY AVERAGED TEMPERATURES:

A-18

n = 20 Axial Divisions.

QUADRANT: SOUTH

For $T_{Na} = 550^\circ\text{F} \rightarrow 1100^\circ\text{F}$,			
$\bar{T}_{CONV} = \frac{\sum T_i}{20}$	=	$\left. \begin{array}{l} Q=0 \quad 825 \text{ }^\circ\text{F} \\ Q=0.429 \quad 849.6 \text{ }^\circ\text{F} \end{array} \right\}$	FOR CONVECTION
$\bar{T}_{RAD} = \left(\frac{\sum (T_{iR})^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 878.6 \text{ }^\circ\text{F} \\ Q=0.429 \quad 901.8 \text{ }^\circ\text{F} \end{array} \right\}$	FOR RADIATION
For $T_{Na} = 650^\circ\text{F} \rightarrow 1200^\circ\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 100$	=	$\left. \begin{array}{l} Q=0 \quad 925 \text{ }^\circ\text{F} \\ Q=0.429 \quad 949.6 \text{ }^\circ\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{iR}+100)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 975.1 \text{ }^\circ\text{F} \\ Q=0.429 \quad 998.5 \text{ }^\circ\text{F} \end{array} \right\}$	FOR RAD
For $T_{Na} = 750^\circ\text{F} \rightarrow 1300^\circ\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 200$	=	$\left. \begin{array}{l} Q=0 \quad 1025 \text{ }^\circ\text{F} \\ Q=0.429 \quad 1049.6 \text{ }^\circ\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{iR}+200)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 1072.1 \text{ }^\circ\text{F} \\ Q=0.429 \quad 1095.6 \text{ }^\circ\text{F} \end{array} \right\}$	FOR RAD
For $T_{Na} = 850^\circ\text{F} \rightarrow 1400^\circ\text{F}$			
$\bar{T}_{CONV} = \frac{\sum T_i}{20} + 300$	=	$\left. \begin{array}{l} Q=0 \quad 1125 \text{ }^\circ\text{F} \\ Q=0.429 \quad 1149.6 \text{ }^\circ\text{F} \end{array} \right\}$	FOR CONV
$\bar{T}_{RAD} = \left(\frac{\sum (T_{iR}+300)^4}{20} \right)^{1/4}$	=	$\left. \begin{array}{l} Q=0 \quad 1169.3 \text{ }^\circ\text{F} \\ Q=0.429 \quad 1193.0 \text{ }^\circ\text{F} \end{array} \right\}$	FOR RAD

TABLE V

N272T1000004

34

A-19

EFFECTIVE MEAN TEMPERATURES (All Four Quadrants)

$$\bar{T}_{RAD} = \left\{ \frac{(\bar{T}_{RAD} + 460)^4 + 2(\bar{T}_{RAD} + 460)^4 + (\bar{T}_{RAD} + 460)^4}{4} \right\}^{1/4} - 460$$

$$\bar{T}_{CONV} = \left\{ \frac{\bar{T}_{CONV} + 2\bar{T}_{CONV} + \bar{T}_{CONV}}{4} \right\}$$

		"No Power" (RAD)	"Full Power" (RAD)	"No Power" (CONV)	"Full Power" (CONV)
550°	N	870.4	958.1	825	915.1
	E/W	870.5	920.8	825	877.3
1100°	E/W	870.5	920.8	825	877.3
	S	878.6	901.8	825	849.6
		$\bar{T}_{RAD} = \begin{cases} 1332.5^{\circ}R \\ 872.5^{\circ}F \end{cases}$	$\bar{T}_{RAD} = \begin{cases} 1385.8^{\circ}R \\ 925.8^{\circ}F \end{cases}$	$\bar{T}_{CONV} = 825^{\circ}F$	$\bar{T}_{CONV} = 879.8^{\circ}F$

		"No Power" (RAD)	"Full Power" (RAD)	"No Power" (CONV)	"Full Power" (CONV)
650°	N	967.4	1055.5	925	1015.1
	E/W	967.5	1018.1	925	977.3
1200°	E/W	967.5	1018.1	925	977.3
	S	975.1	998.5	925	949.6
		$\bar{T}_{RAD} = \begin{cases} 1429.4^{\circ}R \\ 969.4^{\circ}F \end{cases}$	$\bar{T}_{RAD} = \begin{cases} 1483.0^{\circ}R \\ 1023.0^{\circ}F \end{cases}$	$\bar{T}_{CONV} = 925^{\circ}F$	$\bar{T}_{CONV} = 979.8^{\circ}F$

		"No Power" (RAD)	"Full Power" (RAD)	"No Power" (CONV)	"Full Power" (CONV)
750°	N	1064.7	1153.2	1025	1115.1
	E/W	1064.8	1115.7	1025	1077.3
1300°	E/W	1064.8	1115.7	1025	1077.3
	S	1072.1	1095.6	1025	1049.6
		$\bar{T}_{RAD} = \begin{cases} 1526.6^{\circ}R \\ 1066.6^{\circ}F \end{cases}$	$\bar{T}_{RAD} = \begin{cases} 1580.5^{\circ}R \\ 1120.5^{\circ}F \end{cases}$	$\bar{T}_{CONV} = 1025^{\circ}F$	$\bar{T}_{CONV} = 1079.8^{\circ}F$

		"No Power" (RAD)	"Full Power" (RAD)	"No Power" (CONV)	"Full Power" (CONV)
850°	N	1162.4	1251.2	1125	1215.1
	E/W	1162.5	1213.5	1125	1177.3
1400°	E/W	1162.5	1213.5	1125	1177.3
	S	1169.3	1193.0	1125	1149.6
		$\bar{T}_{RAD} = \begin{cases} 1629.2^{\circ}R \\ 1164.2^{\circ}F \end{cases}$	$\bar{T}_{RAD} = \begin{cases} 1678.2^{\circ}R \\ 1218.7^{\circ}F \end{cases}$	$\bar{T}_{CONV} = 1125^{\circ}F$	$\bar{T}_{CONV} = 1179.8^{\circ}F$

DESIGNED BY: <i>EMM</i>	 Rockwell International Atomic International Division	PAGE NO. <i>35</i> OF
CHECKED BY:		N272-TI000004
DATE:		REPORT NO. <i>A-20</i>
		MODEL NO.

HEAT LOSSES:

RADIATION HEAT LOSSES:

For radiation heat loss, considered projected surface area of receiver.

24 panels:

Each panel;

Length = 52.5 ft

Width = 110 tubes \times $0.75 \frac{\text{inch width}}{\text{tube}} \times \frac{1 \text{ ft}}{12 \text{ inch}} = 6.875 \text{ ft.}$

Projected area of one panel:

$$A = (52.5 \text{ ft})(6.875 \text{ ft}) = 360.94 \text{ ft}^2/\text{per panel}$$

Each quadrant has 6 panels: $6 \times 360.94 = 2165.6 \text{ ft}^2/\text{Quad.}$

RADIATION HEAT LOSS PROJECTED AREA, FOR ONE QUADRANT	$= 2166 \text{ ft}^2$
--	-----------------------

Total Radiation Area, $= 8664 \text{ ft}^2$
 4 Quadrants

$$\text{RADIATION HEAT LOSS} = F \epsilon_{\text{eff}} \sigma A (\bar{T}_H^4 - T_{\text{SINK}}^4)$$

$$F = 1.0$$

$$\epsilon_{\text{eff}} = 0.90$$

$$A (1 \text{ Quad}) = 2166 \text{ ft}^2 \quad A (\text{All 4 Quad}) = 8664 \text{ ft}^2$$

$$T_{\text{SINK}} = 60^\circ \text{F} = 520^\circ \text{R}$$

$$\sigma = .1713 \times 10^{-8} \text{ BTU/hr}^\circ \text{R}^4 \text{ ft}^2$$

$$Q_{\text{LOSS}}^{\text{RAD}} = (1.0)(.90)(.1713 \times 10^{-8}) (8664) \left[\bar{T}_{\text{RAD}}^4 - (520)^4 \right]$$

$$Q_{\text{MW}} = 3.9365 \times 10^{-12} (T_{\text{UR}}^4 - 520^4)$$

$$Q_{\text{RAD LOSS}} = \frac{Q_{\text{BTU/hr}}}{3.413 \times 10^6}$$

$$Q = 3.9365 \times 10^{-12} (T^4 - 7316 \times 10^{10})$$

M 123-2-2 REV. 2-78

$$\left\{ \begin{array}{l} \text{LOSS TO } 60^{\circ}\text{F.} \\ \text{LOSS TO } 0^{\circ}\text{R.} \end{array} \right. \begin{array}{l} Q_{\text{RAD LOSS MW}} = 3.91365 \times 10^{-11} (\bar{T}_{\text{OR}}^4 - 520^4) \\ Q_{\text{RAD}} = 3.91365 \times 10^{-11} (\bar{T}_{\text{OR}}^4) \end{array}$$

TABLE VI
RADIATION HEAT LOSSES.


TEMPERATURE CASE	"NO POWER"				"FULL POWER"			
	\bar{T}_{RAD} °F	$Q_{\text{RAD LOSS}}$ (To 60°F) MW _E	$Q_{\text{RAD LOSS}}$ (To 0°R)	$\frac{Q(\text{TO } 60^{\circ}\text{F})}{Q(\text{TO } 0^{\circ}\text{R})}$	\bar{T} °F	$Q_{\text{RAD LOSS}}$ (To 60°F) MW _F	$Q_{\text{RAD LOSS}}$ (To 0°R)	$\frac{Q(\text{TO } 60^{\circ}\text{F})}{Q(\text{TO } 0^{\circ}\text{R})}$
550° - 1100°F	872.5	12.052	12.338	.97681	925.8	14.148	14.434	.98018
650° - 1200°F	969.4	16.052	16.338	.98249	1023.0	18.644	18.930	.98488
750° - 1300°F	1066.6	20.970	21.256	.98654	1120.5	24.135	24.421	.98828
850° - 1400°F	1164.2	26.950	27.236	.98949	1218.2	30.756	31.043	.99078

ESG-79-2, VOL II, BOOK 2
F-37

N272TI000004

A-21

36

PREPARED BY: <u>EMM</u>	 Rockwell International Atomic International Division	PAGE NO. <u>37</u> OF
CHECKED BY:		REPORT NO. <u>N272 TI 000004</u>
DATE:		MODEL NO. <u>A-22</u>

NATURAL CONVECTION: (Vertical Cylinder)

$$Nu = 0.13 (Gr Pr)^{1/3}$$

$$h_{\text{NAT CONV}} \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}} = (.13 \text{ FACT}) \Delta T^{1/3}$$

Ref. 7 $(.13 \text{ FACT}) = 0.13 k \left(\frac{g \beta \rho^2}{\mu^2} Pr \right)^{1/3}$

"No Power"

CASE	\bar{T}_{CONV}	T_f $\left(\frac{T+60}{2}\right)$	ΔT $(T-60)$	(.13 FACT) Based on T_f	$h_{\text{NAT CONV}} = (.13 \text{ FACT}) \Delta T^{1/3}$ BTU/hr ft ² °F
550-1100°	825	442	765	0.152	1.390
650-1200°	925	492	865	0.147	1.401
750-1300°	1025	542	965	0.142	1.403
850-1400°	1125	592	1065	0.137	1.399
"FULL POWER"					
550-1100°	880	470	820	0.149	1.395
650-1200	980	520	920	0.144	1.401
750-1300	1080	570	1020	0.139	1.399
850-1400	1180	620	1120	0.1345	1.397



$\bar{h} \approx 1.40$
BTU/hr ft² °F


SAY: $h = 1.40 \frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$
NAT CONV

FIGURE 4 FORCED CONVECTION HEAT TRANSFER CORRELATION

Nu_f versus Re_f
Flow normal to cylinder axis

From: Ref 5 (Achenbach)
Ref 6 (Wagner)



PREPARED BY: E.M.M.	 Rockwell International Atomic International Division	PAGE NO. 39 of
CHECKED BY:		N272 TI 000004
DATE:		MODEL NO. A-24

FORCED CONVECTION HEAT LOSSES:

For convection heat loss, do not consider the actual "bumpy" surface area ($\pi/2 d l$ of each tube), but only the projected area ($d l$ of each tube). The arc of the tube can be considered a "surface roughness", and influence h in that way.

Notice that the protuberance ($d/2$) of each tube in a panel is very small when compared to the diameter of the receiver as a whole.

RECEIVER DIAMETER $D = 52.5 \text{ ft} = 630 \text{ inches}$

"SURFACE ROUGHNESS", $k = d/2 = \frac{0.75}{2} = 0.375 \text{ inch}$

(SURFACE ROUGHNESS) PARAMETER $= \frac{0.375}{630} = .000595 = 60 \times 10^{-5}$

(SURFACE ROUGHNESS) $= 60 \times 10^{-5}$

FORCED CONVECTION:

Evaluate air properties at "FILM" temperature. Average film temperature varies from 440° to 620°F.

Say: $T_F \cong 500^\circ\text{F}$

$D = 16 \text{ meters} = 52.5 \text{ ft.}$

Ref. 7

$\rho = 0.04133 \text{ lb}_m/\text{ft}^3 \text{ (1.0 atm)}$

$k = 0.02310 \text{ BTU/hr ft }^\circ\text{F}$

$C_p = 0.24700 \text{ BTU/lb}_m \text{ }^\circ\text{F}$

$\mu = 0.06804 \text{ lb}_m/\text{ft hr}$

$Z = 1.6465 \text{ ft}^2/\text{hr}$

$P_r = 0.7272$

$$\text{Re}_{\text{REYNOLDS}} = \frac{V \frac{\text{ft}}{\text{SEC}} D \text{ ft } 3600 \frac{\text{SEC}}{\text{HR}}}{Z \frac{\text{ft}^2}{\text{HR}}} = \frac{V_{\text{FPS}} (52.5 \text{ ft}) (3600 \frac{\text{SEC}}{\text{HR}})}{1.6465 \frac{\text{ft}^2}{\text{HR}}} = 114,790 \frac{V}{\text{FPS}}$$

$$\text{Nu}_{\text{NUSSELT}} = \frac{h D}{k} \quad h = \text{Nu} \frac{k}{D} = \frac{\text{Nu} (0.02310)}{52.5} = 0.00044 \text{ Nu}$$

WIND VELOCITIES TO CONSIDER:

Note: $(\frac{258}{10})^{0.15} = 1.628332$

① $3.5 \frac{\text{m}}{\text{SEC}}$ at Elev = 10 meters.

$1.0 \frac{\text{m}}{\text{SEC}} = 3.28084 \frac{\text{ft}}{\text{SEC}}$

At Elev = 258m, $V = V_0 (\frac{H}{H_0})^{0.15}$

$V = 3.5 (\frac{258}{10})^{0.15} = 5.70 \frac{\text{m}}{\text{SEC}} = \underline{18.70 \text{ ft/sec}} \text{ ①}$

② Intermediate:

$\underline{36.06 \text{ ft/sec}} \text{ ②}$

③ $10.0 \frac{\text{m}}{\text{SEC}}$ at Elev = 10 meters

At Elev = 258m, $V = 10.0 (\frac{258}{10})^{0.15} = 16.28 \frac{\text{m}}{\text{SEC}} = \underline{53.42 \text{ ft/sec}} \text{ ③}$


TABLE VII CONVECTION HEAT TRANSFER COEFFICIENTS

V VELOCITY FPS	Re 114790 V _{FPS}	Nu FROM PLOT	h FORCED CONV BTU/hr ft ² °F .00044 Nu	}	FORCED CONVECTION COEFFICIENT
(5.71 $\frac{1}{3}$) 18.70	2.15 x 10 ⁶	4200	1.848		
(11.0 $\frac{1}{3}$) 36.06	4.14 x 10 ⁶	7400	3.256		
(16.28 $\frac{1}{3}$) 53.42	6.13 x 10 ⁶	11,000	4.840		

To take some account for additional losses occurring due to natural convection, the following relationship has been assumed:

$$h_{EFF} \cong \sqrt{h_{FORCED\ CONV}^2 + h_{NAT\ CONV}^2}$$

V FPS	h FORCED CONV	h NAT CONV	h EFF $\frac{BTU}{hr\ ft^2\ ^\circ F}$	}	"COMBINED" CONVECTION COEFFICIENT
18.70	1.848	1.40	2.318		
36.06	3.256	1.40	3.544		
53.42	4.840	1.40	5.038		

PREPARED BY: EMM	 Rockwell International Atomic International Division	PAGE NO. 42 OF
CHECKED BY:		REPORT NO. N272T1000004
DATE:		MODEL NO. A-27

$Q = h A \Delta T$ **TABLE VIII**
CONVECTION HEAT LOSSES.


$$Q_{\text{CONV LOSS}} = h \frac{\text{RTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}} \frac{1}{\text{ft}^2} \frac{\Delta T}{^\circ\text{F}} \frac{1}{3.413 \times 10^6 \text{ BTU}} \text{ hr MW}$$

$$Q_{\text{MW}} = 0.0025385 h \Delta T_{\text{EFF}}$$

TEMP CASE	VEL ft/spl	h $\frac{\text{BTU}}{\text{hr ft}^2 \text{ } ^\circ\text{F}}$	"NO POWER"			"FULL POWER"		
			\bar{T}_{CONV}	$\Delta T (\bar{T} - 60)$	$Q_{\text{LOSS MW}}$	\bar{T}	ΔT	$Q_{\text{LOSS MW}}$
550-1100	18.70	2.318	825	765	4.501	880	820	4.825
	36.06	3.544	"	"	6.882	"	"	7.377
	53.42	5.038	"	"	9.784	"	"	10.487
550-1200	18.70	2.318	925	865	5.090	980	920	5.414
	36.06	3.544	"	"	7.782	"	"	8.277
	53.42	5.038	"	"	11.063	"	"	11.766
550-1300	18.70	2.318	1025	965	5.678	1080	1020	6.002
	36.06	3.544	"	"	8.682	"	"	9.176
	53.42	5.038	"	"	12.341	"	"	13.045
550-1400	18.70	2.318	1125	1065	6.267	1180	1120	6.590
	36.06	3.544	"	"	9.581	"	"	10.076
	53.42	5.038	"	"	13.620	"	"	14.324

CONVECTION HEAT LOSSES.
 "COMBINED" Natural & Forced.

N 152-R-2 REV. 2-79

PREPARED BY: <i>emm</i>	 Rockwell International Atomic International Division	PAGE NO. <i>43</i> OF
CHECKED BY:		REPORT NO. <i>N272 T I 000004</i>
DATE:	TABLE IX	MODEL NO. <i>A-28</i>

COMBINED RADIATION & CONVECTION LOSSES.

TEMP CASE	WIND VEL. Ft/sec	$Q_{Na} = 0$ "NO POWER"			$Q_{Na} = 429 \text{ MW}_e$ "FULL POWER"		
		Q CONV MW	Q RAD MW	Q RAD+CONV MW	Q CONV MW	Q RAD MW	Q RAD+CONV MW
550 } 1100 }	18.7	4.501	12.052	16.553	4.825	14.148	18.973
	36.06	6.882	"	18.934	7.377	"	21.525
	53.12	9.784	"	21.836	10.487	"	24.635
650 } 1200 }	18.7	5.090	16.052	21.142	5.414	18.644	24.058
	36.06	7.782	"	23.834	8.277	"	26.921
	53.12	11.063	"	27.115	11.766	"	30.410
750 } 1300 }	18.7	5.678	20.970	26.648	6.002	24.128	30.130
	36.06	8.682	"	29.652	9.176	"	33.304
	53.12	12.341	"	33.311	13.045	"	37.173
850 } 1400 }	18.7	6.267	26.950	33.217	6.590	30.756	37.346
	36.06	9.581	"	36.531	10.076	"	40.832
	53.12	13.620	"	40.570	14.324	"	45.080

COMBINED RADIATION and CONVECTION LOSSES.
MW_e

SI 1000.2 REV. 2-76

TABLE X - a. HEAT LOSS CALCULATIONS

TEMP RANGE (550°F + 1100°F)

LOW VELOCITY (5.7 $\frac{m}{s}$ = 18.70 fpm)

INTERMEDIATE VELOCITY (11.0 $\frac{m}{s}$ = 36.06 fpm)

HIGH VELOCITY (16.28 $\frac{m}{s}$ = 53.42 fpm)

Q No. MWs Required By Source	LOW VELOCITY (5.7 $\frac{m}{s}$ = 18.70 fpm)						INTERMEDIATE VELOCITY (11.0 $\frac{m}{s}$ = 36.06 fpm)						HIGH VELOCITY (16.28 $\frac{m}{s}$ = 53.42 fpm)					
	Q _{RAD} LOSS MWs (% of Total)	Q _{CONV} LOSS MWs (% of Total)	Q ₁ = Q _R + Q _C + Q _W MWs	Q _{REFLEC} Σ Q _i (% of Total)	Q _{INCLD} Q + Q _{REF} (TOTAL LOSS)	Q _W Q _{INCLD} %	Q _{RAD} LOSS MWs (% of Total)	Q _{CONV} LOSS MWs (% of Total)	Q ₁ = Q _R + Q _C + Q _W MWs	Q _{REFLEC} Σ Q _i (% of Total)	Q _{INCLD} Q + Q _{REF} (TOTAL LOSS)	Q _W Q _{INCLD} %	Q _{RAD} LOSS MWs (% of Total)	Q _{CONV} LOSS MWs (% of Total)	Q ₁ = Q _R + Q _C + Q _W MWs	Q _{REFLEC} Σ Q _i (% of Total)	Q _{INCLD} Q + Q _{REF} (TOTAL LOSS)	Q _W Q _{INCLD} %
429	14.15 (1.00)	4.83 (1.02)	447.48	23.58 (5.00)	471.56 (42.56)	70.17 (1.01)	14.15 (2.46)	7.38 (1.56)	450.53 (5.0)	23.71 (5.0)	474.24 (45.24)	90.46 (9.54)	14.15 (2.46)	10.49 (2.20)	453.64 (5.0)	23.88 (5.0)	477.52 (48.52)	89.84 (10.16)
400	14.01 (1.0)	4.81 (1.0)	418.82	22.04 (5.00)	440.86 (48.86)	70.73 (9.22)	14.01 (3.16)	7.35 (1.6)	421.36 (5.00)	22.18 (5.00)	443.54 (42.54)	90.18 (9.22)	14.01 (3.16)	10.44 (2.30)	424.45 (5.0)	22.34 (5.0)	446.79 (46.79)	89.53 (10.27)
350	13.76 (3.51)	4.77 (1.23)	368.53	19.40 (5.00)	387.93 (37.93)	90.22 (9.72)	13.76 (3.33)	7.29 (1.87)	371.05 (5.0)	19.53 (5.0)	390.58 (40.58)	89.61 (10.31)	13.76 (3.43)	10.36 (2.63)	374.12 (5.0)	19.69 (5.0)	393.81 (43.81)	88.88 (11.12)
300	13.52 (4.04)	4.73 (1.41)	318.25	16.75 (5.00)	335.00 (35.00)	89.55 (10.45)	13.52 (4.00)	7.23 (2.14)	320.75 (5.00)	16.88 (5.00)	337.63 (37.63)	88.85 (11.15)	13.52 (3.97)	10.28 (3.02)	323.80 (5.0)	17.04 (5.0)	340.84 (40.84)	88.02 (11.98)
250	13.27 (4.70)	4.69 (1.66)	267.96	14.10 (5.00)	282.06 (32.06)	88.63 (11.37)	13.27 (4.66)	7.17 (2.52)	270.44 (5.00)	14.23 (5.00)	284.67 (34.67)	87.82 (12.18)	13.27 (4.6)	10.19 (3.54)	273.46 (5.0)	14.39 (5.0)	287.85 (37.85)	86.85 (13.15)
200	13.03 (5.49)	4.65 (2.03)	217.68	11.46 (5.00)	229.14 (29.14)	87.28 (12.72)	13.03 (6.02)	7.11 (3.07)	220.14 (5.00)	11.59 (5.00)	231.73 (31.73)	86.31 (13.69)	13.03 (5.15)	10.11 (4.30)	223.14 (5.0)	11.74 (5.0)	234.88 (34.88)	85.15 (14.85)
150	12.78 (7.75)	4.62 (2.61)	167.40	8.81 (5.00)	176.21 (26.21)	85.13 (14.87)	12.78 (7.45)	7.05 (3.44)	169.83 (5.00)	8.94 (5.00)	178.77 (28.77)	83.91 (16.09)	12.78 (7.01)	10.03 (5.5)	172.81 (5.0)	9.10 (5.0)	181.91 (31.91)	82.46 (17.54)
100	12.54 (10.15)	4.58 (3.71)	117.12	6.16 (5.00)	123.28 (23.28)	81.12 (18.88)	12.54 (9.07)	7.00 (3.56)	119.54 (5.00)	6.29 (5.00)	125.83 (25.83)	79.47 (20.53)	12.54 (9.71)	9.95 (7.72)	122.49 (5.0)	6.45 (5.0)	128.94 (28.94)	77.56 (12.44)
0	12.05	4.50					12.05	6.88					12.05	9.78				

ESG-79-2, Vol II, Book 2
F-45

N 27271000004

44

A. 21

TABLE X HEAT LOSS CALCULATIONS

TEMP RANGE (650°F → 1200°F)

Q No. MWs Absorbed by Section	LOW VELOCITY (5.7 $\frac{ft}{min}$ = 18.70 fpm)						INTERMEDIATE VELOCITY (11.0 $\frac{ft}{min}$ = 36.06 fpm)						HIGH VELOCITY (16.28 $\frac{ft}{min}$ = 53.42 fpm)					
	Q RAD LOSS MWs (% of Sum)	Q CONV LOSS MWs (% of Inert)	Q ₁ = Q _g + Q _c + Q _{wa} MWs	Q _{REFL} $\sum_{25} Q_i$ (% of Inert)	Q _{INCLD} Q + Q _{REFL} (TOTAL LOSS)	Q _{wa} Q _{INCLD} % (1 - $\frac{Q_{wa}}{Q_{INCLD}}$)	Q RAD LOSS MWs (% of Sum)	Q CONV LOSS MWs (% of Inert)	Q ₁ = Q _g + Q _c + Q _{wa} MWs	Q _{REFL} $\sum_{25} Q_i$ (% of Inert)	Q _{INCLD} Q + Q _{REFL} (TOTAL LOSS)	Q _{wa} Q _{INCLD} % (1 - $\frac{Q_{wa}}{Q_{INCLD}}$)	Q RAD LOSS MWs (% of Sum)	Q CONV LOSS MWs (% of Inert)	Q ₁ = Q _g + Q _c + Q _{wa} MWs	Q _{REFL} $\sum_{25} Q_i$ (% of Inert)	Q _{INCLD} Q + Q _{REFL} (TOTAL LOSS)	Q _{wa} Q _{INCLD} % (1 - $\frac{Q_{wa}}{Q_{INCLD}}$)
429	18.64 (9.9)	5.41 (8.5)	453.05	23.81 (5.0)	476.89 (47.89)	89.96 (10.04)	18.64 (10.0)	5.28 (8.9)	455.92	24.00 (5.0)	479.92 (50.0)	89.39 (10.0)	18.64 (10.0)	11.77 (7.4)	459.41	24.18 (5.0)	483.59 (54.5)	88.71 (11.0)
400	18.46 (4.1)	5.39 (7.1)	423.85	22.31 (5.0)	446.16 (46.16)	89.65 (10.3)	18.46 (4.0)	5.25 (7.2)	426.71	22.46 (5.0)	449.17 (49.7)	89.05 (10.0)	18.46 (4.0)	11.72 (8.5)	430.18	22.64 (5.0)	452.82 (52.8)	88.34 (11.6)
350	18.16 (4.4)	5.35 (7.3)	373.51	19.66 (5.0)	393.17 (43.17)	89.02 (10.9)	18.16 (4.3)	8.19 (7.0)	376.35	11.81 (5.0)	396.16 (46.1)	88.35 (11.0)	18.16 (4.3)	11.64 (7.0)	379.80	19.99 (5.0)	399.79 (49.7)	87.55 (12.4)
300	17.86 (5.1)	5.31 (7.1)	323.17	17.01 (5.0)	340.18 (40.18)	88.19 (11.0)	17.86 (5.0)	8.13 (7.3)	325.99	17.16 (5.0)	343.15 (43.1)	87.93 (11.0)	17.86 (5.0)	11.56 (7.3)	329.42	17.39 (5.0)	346.76 (46.7)	86.52 (12.4)
250	17.56 (6.0)	5.28 (7.2)	272.84	14.36 (5.0)	287.20 (37.2)	87.05 (11.0)	17.56 (6.0)	8.07 (7.2)	275.63	14.51 (5.0)	290.14 (40.1)	86.17 (11.0)	17.56 (6.0)	11.47 (8.0)	279.03	14.69 (5.0)	293.72 (43.7)	85.12 (12.8)
200	17.26 (7.3)	5.24 (7.3)	222.50	11.71 (5.0)	234.21 (34.2)	85.39 (14.1)	17.26 (7.3)	8.01 (7.3)	225.27	11.86 (5.0)	237.13 (37.1)	84.34 (11.0)	17.26 (7.3)	11.39 (8.3)	228.65	12.03 (5.0)	240.68 (40.6)	83.10 (16.0)
150	16.96 (9.3)	5.20 (7.2)	172.17	9.06 (5.0)	181.22 (31.2)	82.77 (17.2)	16.96 (9.3)	7.95 (8.3)	174.91	9.21 (5.0)	184.12 (34.1)	81.97 (12.0)	16.96 (9.3)	11.31 (8.3)	178.27	9.38 (5.0)	187.65 (37.6)	79.93 (20.0)
100	16.65 (11.0)	5.16 (8.0)	121.81	6.41 (5.0)	128.22 (18.2)	77.99 (22.0)	16.65 (11.0)	7.90 (8.0)	124.55	6.56 (5.0)	131.11 (31.1)	76.27 (23.7)	16.65 (11.0)	11.23 (8.3)	127.88	6.73 (5.0)	134.61 (34.6)	74.29 (25.7)
0	16.05	5.09					16.05	7.8				16.05	11.06					

ESG-79-2, Vol II, Book 2
F-46

N 2727 I 000004
45
A-30

TABLE X-C HEAT LOSS CALCULATIONS

TEMP RANGE (750°F → 1300°F)

LOW VELOCITY (5.75 = 18.70 fpm)							INTERMEDIATE VELOCITY (11.05 = 36.06 fpm)							HIGH VELOCITY (16.285 = 53.42 fpm)						
Q No. MW/LB ABSORBED BY SODIUM	Q RAD LOSS MW _L (% of Total)	Q CONV LOSS MW _C (% of Total)	Q ₁ = Q _R + Q _C + Q _{NA} MW _T	Q _{RETRN} Σ Q _i (% of Total)	Q _{INCID} Q + Q _{RET} (TOTAL LOSS)	Q _{LOSS} Q _{INCID} % (1 - $\frac{Q_{NA}}{Q_{INCID}}$)	Q RAD LOSS MW _L (% of Total)	Q CONV LOSS MW _C (% of Total)	Q ₁ = Q _R + Q _C + Q _{NA} MW _T	Q _{RETRN} Σ Q _i (% of Total)	Q _{INCID} Q + Q _{RET} (TOTAL LOSS)	Q _{LOSS} Q _{INCID} % (1 - $\frac{Q_{NA}}{Q_{INCID}}$)	Q RAD LOSS MW _L (% of Total)	Q CONV LOSS MW _C (% of Total)	Q ₁ = Q _R + Q _C + Q _{NA} MW _T	Q _{RETRN} Σ Q _i (% of Total)	Q _{INCID} Q + Q _{RET} (TOTAL LOSS)	Q _{LOSS} Q _{INCID} % (1 - $\frac{Q_{NA}}{Q_{INCID}}$)		
429	24.13 (1.00)	6.00 (1.74)	459.13	24.16 (5.0)	483.29 (54.74)	88.77 (18.37)	24.13 (1.00)	9.18 (2.89)	462.31	24.33 (5.0)	486.64 (52.69)	88.16 (18.01)	24.13 (1.00)	13.05 (2.66)	466.18	24.54 (5.0)	490.72 (51.75)	87.42 (17.58)		
400	23.92 (5.74)	5.98 (1.32)	429.90	22.63 (5.0)	452.53 (57.55)	88.39 (11.6)	23.92 (5.74)	9.15 (2.0)	433.07	22.79 (5.0)	455.86 (55.84)	87.75 (12.25)	23.92 (5.29)	13.00 (2.85)	436.92	23.00 (5.0)	459.92 (50.2)	86.97 (13.03)		
350	23.55 (5.90)	5.94 (1.44)	379.49	19.97 (5.0)	399.46 (64.4)	87.62 (11.38)	23.55 (5.81)	9.09 (2.26)	382.64	20.14 (5.0)	402.78 (52.78)	86.90 (12.0)	23.55 (5.74)	12.92 (1.16)	386.47	20.34 (5.0)	406.81 (66.8)	86.04 (11.96)		
300	23.18 (6.6)	5.90 (1.70)	329.08	17.32 (5.0)	346.40 (66.4)	86.61 (12.39)	23.18 (6.63)	9.03 (2.28)	332.21	17.48 (5.0)	349.69 (47.69)	85.79 (12.2)	23.18 (6.55)	12.84 (2.63)	336.02	17.69 (5.0)	353.71 (53.7)	84.82 (15.21)		
250	22.81 (7.28)	5.87 (2.0)	278.68	14.67 (5.0)	293.35 (62.35)	85.22 (12.78)	22.81 (7.64)	8.97 (5.0)	281.78	14.83 (5.0)	296.61 (46.6)	84.29 (15.77)	22.81 (7.57)	12.75 (4.24)	285.56	15.03 (5.0)	300.59 (50.39)	83.17 (12.83)		
200	22.44 (9.31)	5.83 (2.4)	228.27	12.01 (5.0)	240.28 (60.28)	83.23 (16.77)	22.44 (9.2)	8.91 (2.6)	231.35	12.18 (5.0)	243.53 (62.53)	82.13 (12.87)	22.44 (9.07)	12.67 (6.12)	235.11	12.37 (5.0)	247.48 (61.48)	80.81 (16.19)		
150	22.07 (11.14)	5.74 (3.0)	177.86	9.36 (5.0)	187.22 (37.22)	80.12 (12.82)	22.07 (12.5)	8.85 (6.0)	180.92	9.52 (5.0)	190.44 (60.44)	78.76 (12.24)	22.07 (12.5)	12.59 (8.48)	184.66	9.72 (5.0)	194.38 (64.38)	77.17 (12.45)		
100	21.71 (16.4)	5.75 (4.2)	127.46	6.71 (5.0)	134.17 (64.17)	74.53 (15.47)	21.71 (15.2)	8.80 (6.4)	130.51	6.87 (5.0)	137.38 (67.38)	72.79 (12.2)	21.71 (16.37)	12.51 (7.25)	134.22	7.06 (5.0)	141.28 (61.28)	70.78 (14.0)		
0	20.47	5.68					20.47	8.68					20.47	12.34						

ESG-79-2, VOL I, BOOK 2
F-47

N 27211 000004
46
A.31

TABLE X-d HEAT LOSS CALCULATIONS

TEMP RANGE (850°F + 1400°F)

Q No. MW ABSORBED BY SOURCE	LOW VELOCITY (5.77 = 18.70 fpm)						INTERMEDIATE VELOCITY (11.07 = 36.06 fpm)						HIGH VELOCITY (16.28 = 53.42 fpm)					
	Q RAD LOSS MW (% of Sum)	Q CONV LOSS MW (% of Inlet)	Q ₁ = Q _R + Q _C + Q _{MA} MW	Q RETUR Σ Q _i (% of Inlet)	Q INLET Q + Q _{REF} (TOTAL LOSS)	Q _{MA} Q _{INLET} (1 - $\frac{Q_{RAD}}{Q_{INLET}}$)	Q RAD LOSS MW (% of Sum)	Q CONV LOSS MW (% of Inlet)	Q ₁ = Q _R + Q _C + Q _{MA} MW	Q RETUR Σ Q _i (% of Inlet)	Q INLET Q + Q _{REF} (TOTAL LOSS)	Q _{MA} Q _{INLET} (1 - $\frac{Q_{RAD}}{Q_{INLET}}$)	Q RAD LOSS MW (% of Sum)	Q CONV LOSS MW (% of Inlet)	Q ₁ = Q _R + Q _C + Q _{MA} MW	Q RETUR Σ Q _i (% of Inlet)	Q INLET Q + Q _{REF} (TOTAL LOSS)	Q _{MA} Q _{INLET} (1 - $\frac{Q_{RAD}}{Q_{INLET}}$)
429	30.76 (1.27)	6.59 (1.34)	466.35	24.54 (5.0)	490.89 (34.89)	87.39 (17.61)	30.76 (6.22)	10.08 (2.07)	469.81	24.73 (5.0)	494.57 (65.57)	86.74 (17.26)	30.76 (6.4)	14.32 (2.87)	474.08	24.95 (5.0)	499.03 (17.03)	85.97 (17.03)
400	30.50 (6.63)	6.57 (1.43)	437.07	23.00 (5.0)	460.07 (60.07)	86.94 (18.06)	30.50 (6.57)	10.05 (2.17)	440.55	23.19 (5.0)	463.74 (63.74)	86.26 (17.34)	30.50 (6.57)	14.27 (3.07)	444.77	23.41 (5.0)	468.18 (68.18)	85.44 (14.54)
350	30.06 (7.24)	6.53 (1.60)	386.59	20.35 (5.0)	406.94 (56.94)	86.01 (19.99)	30.06 (6.32)	9.99 (2.43)	390.05	20.53 (5.0)	410.58 (60.58)	85.25 (16.75)	30.06 (7.24)	14.19 (3.42)	394.25	20.75 (5.0)	415.00 (65.0)	84.34 (15.64)
300	29.61 (8.37)	6.49 (1.83)	336.10	17.69 (5.0)	353.79 (53.79)	84.80 (65.20)	29.61 (8.37)	9.93 (2.78)	339.34	17.87 (5.0)	357.41 (67.41)	83.94 (16.04)	29.61 (8.37)	14.11 (3.91)	343.72	18.09 (5.0)	361.81 (61.81)	82.92 (17.02)
250	29.17 (9.00)	6.46 (2.15)	285.63	15.03 (5.0)	300.66 (50.66)	83.15 (66.85)	29.17 (8.45)	9.87 (2.74)	289.04	15.21 (5.0)	304.25 (59.25)	82.17 (17.83)	29.17 (8.45)	14.03 (4.55)	293.20	15.43 (5.0)	308.63 (62.63)	81.00 (6.00)
200	28.73 (11.4)	6.42 (2.34)	235.15	12.38 (5.0)	247.53 (47.53)	80.80 (17.20)	28.73 (8.44)	9.81 (2.81)	238.54	12.55 (5.0)	251.09 (51.09)	79.65 (20.35)	28.73 (8.25)	13.95 (4.4)	242.68	12.77 (5.0)	255.45 (53.45)	78.29 (17.7)
150	28.28 (6.55)	6.38 (2.28)	184.66	9.72 (5.0)	194.38 (44.38)	77.17 (27.83)	28.28 (8.47)	9.75 (2.85)	188.03	9.90 (5.0)	197.93 (47.93)	76.79 (6.27)	28.28 (11.42)	13.86 (4.8)	192.14	10.11 (5.0)	202.25 (57.25)	74.16 (15.81)
100	27.84 (6.7)	6.34 (2.4)	134.18	7.06 (5.0)	141.24 (41.24)	70.80 (29.20)	27.84 (8.15)	9.70 (2.79)	137.54	7.24 (5.0)	144.78 (44.78)	69.07 (30.93)	27.84 (8.22)	13.78 (3.4)	141.62	7.45 (5.0)	149.07 (49.07)	67.08 (21.08)
0	26.95	6.27					26.95	9.58				26.95	12.62					

ESG-79-2, Vol II, Book 2
F-48

N 272 T 000004

47
A.32

Na TEMP: 550° → 1100°F


WIND:
 $5.7 \frac{m}{s} = 18.70 \frac{ft}{sec} = 12.75 mph$

A-33

FIGURE 5-(a-1)
HEAT LOSSES FROM RECEIVER

Wind Velocity: 18.7 ft/sec
Na Temperature: 550°F - 1100°F

(Losses are in percentage of energy incident on receiver.)



N272TI000004 49

Na TEMP: 550° → 1100°F

WIND:

$$11.0 \frac{m}{s} = 36.1 \frac{ft}{sec} = 24.6 \text{ mph}$$

A-34




FIGURE 5- (a-2)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 36.1 ft/sec

Na Temperature: 550°F - 1100°F

(Losses are in percentage of energy incident on receiver.)

N27211000000

50

Na TEMP: 550° → 1100°F

WIND:

16.28 $\frac{m}{s}$ = 53.4 $\frac{ft}{sec}$ = 36.4 mph

A 35


FIGURE 5-(a-3)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 53.4 ft/sec

Na Temperature: 550°F - 1100°F

(Losses are in percentage of energy incident on receiver.)



N 612 12 00004 51


Na TEMP: 650° → 1200°F


WIND:
 $5.7 \frac{m}{s} = 18.7 \frac{ft}{sec} = 12.75 mph$

A-36

FIGURE 5-(b-1)
HEAT LOSSES FROM RECEIVER

Wind Velocity: 18.7 ft/sec
Na Temperature: 650°F - 1200°F
(Losses are in percentage of energy incident on receiver.)





Na TEMP: 650° → 1200°F

WIND:

$16.28 \frac{m}{s} = 53.4 \frac{ft}{sec} = 36.4 \text{ mph}$

A-38


FIGURE 5-(b-3)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 53.4ft/sec

Na Temperature: 650°F - 1200°F

(Losses are in percentage of energy incident on receiver.)



Na TEMP: 750° → 1300°F

WIND:

$5.7 \frac{m}{s} = 18.7 \frac{ft}{sec} = 12.75 \text{ mph}$

A-39


FIGURE 5-(c-1)


HEAT LOSSES FROM RECEIVER

Wind Velocity: 18.7 ft/sec

Na Temperature: 750°F - 1300°F

(Losses are in percentage of energy incident on receiver.)





Na TEMP: 750° → 1300°F

WIND:

$16.28 \frac{m}{s} = 53.4 \frac{ft}{sec} = 36.4 \text{ mph}$

A-41


FIGURE 5-(c-3)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 53.4 ft/sec

Na Temperature: 750°F - 1300°F

(Losses are in percentage of energy incident on receiver.)



N272TI000004 57

Na TEMP: 850° → 1400°F

WIND:

$$5.7 \frac{m}{s} = 18.7 \frac{ft}{sec} = 12.75 \text{ mph}$$

A-42


FIGURE 5-(d-1)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 18.7 ft/sec

Na Temperature: 850°F - 1400°F

(Losses are in percentage of energy incident on receiver.)



Na TEMP: 850° → 1400°F

WIND:

$11.0 \frac{m}{s} = 36.1 \frac{ft}{sec} = 24.6 \text{ mph}$

A-43


FIGURE 5-(d-2)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 36.1 ft/sec

Na Temperature: 850°F - 1400°F

(Losses are in percentage of energy incident on receiver.)



Na TEMP: 850° → 1400°F

WIND:

16.28 $\frac{m}{s}$ = 53.4 $\frac{ft}{sec}$ = 36.4 mph

A-44


FIGURE 5-(d-3)

HEAT LOSSES FROM RECEIVER

Wind Velocity: 53.4 ft/sec

Na Temperature: 850°F - 1400°F

(Losses are in percentage of energy incident on receiver.)




550°F → 1100°F

N272TI000004

60


A-45



650°F → 1200°F

N272T100004 61

A.46




750°F → 1300°F

N272 T1000004

62

A-47



850°F → 1400°F

N 272 T I 000004

63

A-48




FIGURE 6-d

HEAT LOSSES FROM RECEIVER


Percentage (of incident energy) Heat Losses versus Wind Velocity (meter/sec) and Q_{na} (heat absorbed by sodium - MW).

Na Temperature: 850°F - 1400°F

HEAT LOSS % vs. OPER. TEMP.

WIND:

$5.7 \frac{m}{s} = 18.7 \text{ FPS} = 12.75 \text{ mph.}$



HEAT LOSS % VS. OPER. TEMP.


WIND:

11.0 $\frac{m}{s}$: 36.1 FPS : 24.6mph.

FIGURE 7-b

HEAT LOSS FROM RECEIVER
vs. Na inlet/outlet Temp.

Q_{Na} = Heat absorbed in Na (MW)



HEAT LOSS % vs. OPER. TEMP.


WIND:

$16.28 \frac{m}{s} = 53.4 \text{ FPS} = 36.4 \text{ mph.}$

FIGURE 7-C

HEAT LOSS FROM RECEIVER vs. Na inlet/outlet Temp.


Q_{Na} = Heat absorbed in Na (MW)



APPENDIX G
HEAT TRANSFER AND PRESSURE DROP
FOR ROCK BED THERMAL STORAGE

AI Technical Information
Document N272TI000003

650-78-094

 SUPPORTING DOCUMENT		NUMBER N272TI000003	REV LTR/CHG NO. SEE SUMMARY OF CHG
PROGRAM TITLE Solar Central Receiver Power Systems		DOCUMENT TYPE Technical Information	
DOCUMENT TITLE Heat Transfer and Pressure Drop for Rock Bed Thermal Storage (for Solar Power System)		KEY NOUNS Thermal Storage, Solar Power, Pebble Bed	
PREPARED BY/DATE E. M. Mouradian <i>E. M. Mouradian</i>		DEPT 731	MAIL ADDR LB35
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____		GO NO. 09272	S/A NO. 14000
APPROVALS L. G. Rico <i>LGRico</i>		ORIGINAL ISSUE DATE PAGE 1 OF TOTAL PAGES 65 REL. DATE 4-14-78 <i>14</i>	
SECURITY CLASSIFICATION (CHECK ONE BOX ONLY)			
UNCL <input type="checkbox"/>		DOE <input checked="" type="checkbox"/>	
CONF. <input type="checkbox"/>		DOD <input type="checkbox"/>	
SECRET <input type="checkbox"/>		RESTRICTED DATA <input type="checkbox"/>	
		DEFENSE INFO. <input type="checkbox"/>	
		AUTHORIZED CLASSIFIER _____ DATE _____	
DISTRIBUTION		ABSTRACT	
* NAME MAIL ADDR	Heat transfer and pressure drop correlations for air flow through a "fixed pebble bed" are investigated and presented. This is part of the study of a rock-air thermal storage system under investigation for possible use in a central receiver solar power system.		
* W. V. Botts LA02	Equations and a time-share computer program have been set up to determine the heat transfer parameter (UA), pressure drop (Δp), and fan electric power (P), for a variety of bed capacities, thermal power rates, bed sizes and porosities, particle diameters, and sphericities, etc.		
* C. C. Conners LB30			
* A. Z. Frangos LA19			
* L. E. Glasgow LB39			
* T. L. Johnson LA19			
* B. Katz LA19			
* P. E. McCourt LA02			
* B. L. McFarland LA19			
* M. P. Moriarty LA19			
* E. M. Mouradian LB35			
* J. K. Rosemary LA19			
* L. G. Rico LB35			
* T. H. Springer(2) LA29			
* W. B. Thomson(2) LA19			
RESERVED FOR PROPRIETARY/LEGAL NOTICES		_____	
731-W-39/abg			
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY			

FORM 734-C REV. 11-77

CONTENTS

	<u>Page</u>
I. INTRODUCTION	3
II. HEAT TRANSFER CORRELATIONS	4
III. PRESSURE DROP AND FAN POWER CORRELATIONS	8
IV. ANALYSIS	9
V. CALCULATIONAL RESULTS	10
VI. NOMENCLATURE	15
VII. REFERENCES	20

APPENDICES

Appendix

A. Heat Transfer Correlations	(21)	A-1
B. Sphericity	(30)	B-1
C. Pressure Drop and Fan Power Correlations	(31)	C-1
D. Analysis Procedure	(35)	D-a-1
a. Program Logic	(35)	D-a-1
b. Influence of Input Variables	(38)	D-b-1
c. Partial Numerical Evaluation	(44)	D-c-1
E. Conduction Through Upper Layer of Rock	(45)	E-1
F. Time Share Program	(46)	F-1
G. Calculational Output	(53)	G-1
H. Material Properties	(65)	H-1

I. INTRODUCTION

A pebble bed thermal storage device has been proposed for possible use in a central receiver solar power system. The device is to be composed of a bed of rock pebbles, each of diameter d . The bed configuration is a right circular cylinder of diameter D , and vertical height L . The heat transport medium is air at atmospheric pressure. The air flow is downward through the bed during the charging process (heating rocks: hot air in, cool air out), and upward during discharge (cooling rocks and heating air; cool air in, hot air out).

In this report, correlations are selected and calculational method established to determine a pebble bed's heat transfer (UA), pressure drop (Δp), and fan (blower) electrical power parameters. The pebble diameter and sphericity, pebble matrix porosity (void fraction), bed theoretical energy content, thermal power rate (of energy removal or insertion), pebble bed diameter, rock and air properties, and the operating temperature range are among the system parameters taken into consideration.

The variables to be determined include the bed height, mass, and total surface area; air flow rate, velocity, transit time, Reynolds number and pressure drop; fan (blower) electrical power; heat transfer coefficients h and U , and bed UA (U times total pebble surface area).

A number of correlations for a fixed pebble bed pressure drop and heat transfer coefficient were investigated and are discussed. The correlations and basic equations employed are shown, as well as logic and listing of the time share computer program set up, and a summary of results from several cases run.

II. HEAT TRANSFER CORRELATIONS

A number of heat transfer correlations for gas flow through a fixed pebble bed have been considered for use in this analysis. These correlations are shown in Appendix A in the form that they are presented in the referenced documents. Also shown in Appendix A are the algebraic steps taken to try to reduce all the correlations to the same form: $Nu = \alpha Re^B$.

In Appendix A, as well as in Table I, a summary of these heat transfer correlations is shown. Unfortunately, there appears to be some disagreement among them, particularly with respect to the influence on heat transfer coefficient of particle sphericity and particle diameter. Note that heat transfer coefficient (h) varies with the (+0.6), (-0.5), (-0.31), (+0.3), (+0.08), and (-.41) power of particle diameter, depending on the equation used. As far as bed porosity (ϵ) and particle sphericity (ϕ) are concerned, the several correlations show h increasing, decreasing, or unaffected by increasing ϵ and ϕ .

In the experiments from which some of the correlations were derived, only one value of particle diameter was employed. Furthermore, in some of the cases, ϵ and ϕ were not even considered as parameters, but they appear when the equations were manipulated in Appendix A in order to put them, as much as possible, into the same form for comparison.

In attempting to arrive at a compromise correlation, the possible effect of ϵ and ϕ on heat transfer correlation was omitted because of the contradictions among the several correlations. Close scrutiny of the correlations suggested the selection of an h varying with the -0.3 power of particle diameter as a reasonable compromise. Thus, as shown in Table I and Appendix A, the heat transfer correlation used in this analysis is:

TABLE I

N272TI000003
Page 5

HEAT TRANSFER CORRELATIONS

KUNII &
LEVENSPIEL

$$\begin{aligned} Re < 100 \quad Nu &\cong 0.0114 Re^{1.6} & h &\propto d^6; h \downarrow \text{ as } T \uparrow \\ Re > 100 \quad Nu &\cong 2 + 1.6 Re^{0.5} & h &\propto d^{.5}; h \uparrow \text{ as } T \uparrow \end{aligned}$$

No ϵ or ϕ dependence.

KAYS &
LONDON

$$Nu \cong .238 \left(\frac{1}{\phi}\right)^{.31} \frac{(1-\epsilon)^{.31}}{\epsilon} Re^{0.69}$$

$20 < Re < 600$ $h \propto d^{-.31}, h \downarrow \text{ as } \epsilon \uparrow$
 $h \propto \phi^{-.31}, h \uparrow \text{ as } T \uparrow$

LOF &
HAWLEY

$$Nu \cong .276 \left(\frac{\phi}{1-\epsilon}\right) d_{\text{INCH}}^{0.6} Re^{0.7}$$

$25 < Re < 500$ $h \propto d^{+.3}$
 $h \propto \phi$
 $h \uparrow \text{ as } \epsilon \uparrow; h \uparrow \text{ as } T \uparrow$

"ARGENTINE"

$$Nu \cong .131 \left(\frac{\phi}{1-\epsilon}\right) d_{\text{INCH}}^{0.16} Re^{0.92}$$

$25 < Re < 200$ $h \propto d^{+.08}$
 $h \propto \phi$
 $h \uparrow \text{ as } \epsilon \uparrow, h \uparrow \text{ as } T \uparrow$

McADAMS
Pg 295

$$Nu \cong 0.941 Re^{0.59}$$

$350 < Re < 4000$ $h \propto d^{-.41}$
 $h \uparrow \text{ as } T \uparrow$

USED IN ANALYSIS

$$Nu = 0.5 Re^{0.7} \quad h \propto d^{-.3}$$

$h \uparrow \text{ as } T \uparrow$

$$Re = \left(\frac{\dot{W}}{A_{\text{GROSS}}} \frac{d_{\text{PARTICLE}}}{\mu} \right) \quad Nu = \frac{hd_{\text{PARTICLE}}}{k_{\text{AIR}}}$$

d = Particle Diameter



$$Nu = 0.5 Re^{.7} \quad (2a)$$

$$h = 0.5 \frac{k}{d} \left(\frac{\dot{W} d}{A \mu} \right)^{0.7} = 0.5 k \left(\frac{\dot{W}}{A \mu} \right)^{0.7} d^{-0.3} \quad (2b)$$

Figure 1 shows a comparison of the correlations for the case where $d = 1.0"$, $\epsilon = 0.39$, and $\phi = 0.80$.

The correlations discussed are based on having a bed composed entirely of a single pebble size. The correlation does not consider any influence of sphericity, ϕ , (see Appendix B) on the heat transfer coefficient. However, sphericity does affect the total surface area, such that UA_{sur} is affected by the value of ϕ .

FIGURE 1

COMPARISON OF
HEAT TRANSFER
CORRELATIONS

$$d_p = 1.0''$$


$$\epsilon = 0.39$$

$$\phi = 0.8$$

- Kunni & Leven 1
- Kays & London 2
- Lof & Hawley 3
- "Argentine" 4
- Gamson (McAdams) 5

Used in this analysis.

6 - - - -



$$Re_p = \left(\frac{\dot{w}}{A} \frac{d_r}{\mu} \right) \rightarrow$$

III. PRESSURE DROP AND FAN POWER CORRELATIONS

Pressure drop correlations are shown in Appendix C. There are two correlations shown, which turn out to be basically in agreement with one another, though presented in different forms. The correlation employed in this analysis is:

$$\Delta p = 200 \frac{L}{g_c} \frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \frac{\mu V_o}{d^2} + 2.33 \frac{L}{g_c} \frac{(1-\epsilon)}{\epsilon^3 \phi} \frac{\rho V_o^2}{d} \quad (3)$$

where V_o = superficial air velocity.

The first term is referred to as the "laminar" term as it dominates at low velocities (Reynolds number). The second term is referred to as the "turbulent" term as it dominates at high velocities (Reynolds number).

The "laminar" and "turbulent" terms correspond to $f = 100/Re$ and $f = 1.165$, respectively, as shown in Appendix C.

The fan (blower) electrical power is determined by the expression:

$$P_{fan} = \frac{\Delta p \dot{W}}{\rho_{air} (eff)}$$

This fan power is determined in kWe for both the upper and lower limit air temperatures.

IV. ANALYSIS

Based on the heat transfer and pressure drop correlations presented, calculations have been set up to determine heat transfer and air flow parameters of the pebble bed. Of particular interest are the heat transfer parameter, UA_{sur} (Btu/hr⁰F), air pressure drop, Δp (lbF/ft²), and fan power, P_{fan} (kWe).

A time-share computer program has been set up to determine these quantities. In Appendix D, the analysis procedure is shown. The input information includes the pebble bed maximum theoretical energy, the system operating power level, the upper and lower temperature limits, bed diameter, particle diameter, pebble sphericity, bed porosity, and material properties.

Among the calculated parameters are the pebble bed mass, volume and height; air flow rate, velocities, and transit time; total heat transfer surface area; Reynolds and Nusselt numbers; film and overall heat transfer coefficients, h and U ; heat transfer coefficient correction due to conduction into pebble (see Appendix E); system hA_{sur} , UA_{sur} , and NTU; and air flow pressure drop and fan power. Part a of Appendix D shows the equations used to determine these parameters. A time-share program has been set up to carry out these calculations, and a listing is shown in Appendix F.

In Part b of Appendix D, expressions are developed showing the influence of the various input variables (system power, bed energy capacity, bed diameter, particle diameter, system ΔT , sphericity, porosity, fan efficiency, and material properties) on the system parameters hA , Δp , and P_{fan} . These expressions are useful in making a judgment as to what influence on system behavior will result from a proposed change in one or more of the bed characteristics. For a summary, see Sheet 9 of Appendix D.

V. CALCULATIONAL RESULTS

On the basis of the analysis procedure set up, calculations have been made for four cases: (1) ENG = 190 MW days, POW = 286 Mwt; (2) ENG = 150 MW days, POW = 286 Mwt; (3) ENG = 450 MW days, POW = 286 Mwt; (4) ENG = 550 MW days, POW = 250 Mwt. All four cases have $\epsilon = 0.39$, $\phi = 0.80$, $T_{hot} = 1100^{\circ}F$, and $T_{cold} = 600^{\circ}F$ where ENG denotes the system maximum theoretical energy and POW denotes the system operating power.

Of course, there are just a few of the wide variety of possible cases. Plots of fan electric power (kWe) vs bed UA (Btu/hr^oF) are shown in Figures 2a through 2d. The plots shown are an extract from a considerable amount of data calculated. For the reference case (ENG = 190 MW-days, POW = 286 Mwt), the calculated output is shown in Appendix G for all the bed diameter and particle diameter combinations. All the system parameters calculated are shown. Appendix G also serves as an example output for the computer program of Appendix F.

The material properties used for air and rock are shown in Appendix H.





FIGURE 2a
FAN POWER VS. BED UA


ENG(Theo) = 190 MW Days
 POWER = 286 MWt
 $\epsilon = 0.39$ $\phi = 0.80$
 T(hot), T(cold) = 1100°, 600°F


BED VOLUME = 1.237×10^6 ft³
 BED MASS = 62,253 Tons

D(ft)	L(ft)
225	31.1
250	25.2
275	20.8
300	17.5
325	14.9









VI. NOMENCLATURE

A_{GROSS}	Gross Flow Area Through Bed; $A = \frac{\pi D^2}{4}$	ft^2
$A_{\text{NET}}, A_{\text{FREE}}$	Net Flow Area Through Bed; $A_{\text{NET}} = \epsilon A_{\text{GROSS}}$	ft^2
A_{SUR}	Total Surface Area of All Particles in Bed.	ft^2
a	Numerical Constant	
B, b	Numerical Constant	
C_p	Specific Heat; air or rock.	$\text{BTU}/\text{lb}_m \text{ } ^\circ\text{F}$
D	Bed Diameter	feet
d, d_p	Particle Diameter	inch or feet
ENG	Maximum Theoretical Energy Capacity of Bed. $\text{ENG} = M_{\text{BED}} C_p \text{ROCK} (T_{\text{HOT}} - T_{\text{COLD}})$	$\text{BTU},$ MW-day:
eff	Fan Efficiency	
f	Flow Friction Factor (See Appendix C)	

G, G_0	Superficial Mass Velocity $G = \frac{\dot{W}}{A_{GROSS}} = \rho_{air} V_0$	$\frac{lb_m}{hr ft^2}$
g_c	Gravitational Constant, 32.1739×3600^2	$\frac{ft lb_m}{lb_f hr^2}$
h	Air-to-Pebble Heat Transfer Coefficient	$\frac{BTU}{hr ft^2 \circ F}$
hA	Heat Transfer Parameter	$BTU/hr \circ F$
h_v	Volumetric Heat Transfer Coefficient, $h_v = h \times \frac{VOL}{AREA_{SUR}} = \frac{h}{\alpha}$	$\frac{BTU}{hr ft^3 \circ F}$ $\frac{watts}{sq. m^3 \circ F}$
k	Thermal Conductivity; air or rock.	$\frac{BTU}{hr ft \circ F}$
L	Bed Height	ft
M	Mass of Bed	$lb_m, tons$
m	Mass of One Pebble	lb_m
N	Number of Pebbles in Bed	
n	Numerical Constant	


- NTU Heat Transfer Units, $NTU = \frac{JA}{(\dot{w}c_p)_{air}}$
- Nu, Nu_p Nusselt Number Based on Particle Diameter; $Nu = \frac{h d_p}{k_{air}}$
- $P_{(FAN)}$ Fan Power kwe
- $\Delta p, \Sigma \Delta p$ Air Flow Pressure Drop Through Bed lb_f/ft^2
- Δp_{LAM} Component of Air Flow Pressure Drop for $\Delta p \propto W'$ lb_f/ft^2
- Δp_{TURB} Component of Air Flow Pressure Drop for $\Delta p \propto W'^2$ lb_f/ft^2
- POW System Operating Power, $POW = \dot{w}_{air} c_{p,air} (T_{HOT} - T_{COOL})$ MW_t
- Pr Prandtl Number, air $Pr = \frac{\mu c_p}{k}$
- Q Operating Thermal Power $Q = POW = \dot{w}_{air} c_{p,air} (T_{HOT} - T_{COOL})$ BTU/hr
- Re Reynolds Number Based on Particle Diameter and Gross Bed Cross-Sectional Area, $Re = \frac{\dot{w}}{A_{GROSS}} \frac{d_p}{N}$

Re_{KL}	<p>Reynolds Number from Kays & London Correlation;</p> $Re = \frac{\dot{W}}{A_{GRS}} \frac{d_p}{\mu} \left[\frac{z\phi}{3(1-\epsilon)} \right], \text{ See App. A}$	
St	<p>Stanton Number</p> $St = \frac{h}{C_p G}$	
T	Temperature	°F
T_{HOT}, T_{COLD}	Maximum and Minimum System Temperatures	°F
ΔT	<p>Maximum Temperature Difference</p> $\Delta T = (T_{HOT} - T_{COLD})$	°F
U	Overall Heat Transfer Coefficient (includes effect of film resistance and conduction into pebble).	BTU/hr ft ² °F
UA, UA_{SUR}, UA_{BED}	Total Heat Transfer Parameter for Bed.	BTU/hr °F
V, VOL	Bed Volume	ft ³
V_0	<p>Air Superficial Velocity</p> $V_0 = \frac{W_{AIR}}{\rho_{AIR} \text{ Across}}$	ft/sec

V_{NET}, V_{AVG}	Average Air Velocity $V = \frac{W_{AIR}}{\rho_{AIR} A_{NET}}$	ft/sec
\dot{W}	Air Mass Flow Rate	lb _m /hr
Y	Thermal Conductance $Y = \frac{kA}{\Delta x} \text{ or } hA$	BTU/hr °F
Z	$Z = \frac{(M_{CP})_{ROCK}}{(\dot{W}_{CP})_{AIR}}$	hr, sec
$Z1, Z2$	Calculational Parameters in Pressure Drop Expression	
α	Surface Area per Unit Volume $\alpha = \frac{\text{Surface Area}}{\text{Volume}} = \frac{A_{SUR}}{VOL} = \frac{6(1-\epsilon)}{d_p \phi}$	ft ⁻¹
ϵ	Bed Porosity (Void Fraction)	
μ	Air Viscosity	lb _m /hr ft
ρ	Density; Air or Rock	lb _m /ft ³
τ	Air Flow Transit Time, $\tau = \frac{L}{V_{NET}} = \frac{L \rho_{AIR} A_{NET}}{\dot{W}}$	sec
ϕ	Particle Sphericity $\phi = \left(\frac{\text{Surface Area of Sphere}}{\text{Actual Surface Area of Particle of same Volume}} \right)$	See App. B

VII. REFERENCES

1. D. Kunii and O. Levenspiel, Fluidization Engineering, Wiley, 1969, pages 66, 210-212
2. W. M. Kays and A. L. London, Compact Heat Exchangers, National Press, 1955, pages 3, 23, 123
3. G. O. G. Lof and R. W. Hawley, "Unsteady-State Heat Transfer Between Air and Loose Solids," Industrial and Engineering Chemistry, Vol. 40, No. 6, June 1948, pages 1061-1070
4. E. Alanais, L. Saravia, and L. Rovetta, "Measurement of Rock Pile Heat Transfer Coefficients," Solar Energy, Pergamon Press, Vol. 19, 1977, pages 571-572, "Argentine Report"
5. W. H. McAdams, Heat Transmission, 3rd Edition, McGraw-Hill, 1954, pages 295, 450
6. J. H. Perry, Chemical Engineers Handbook, 4th Edition, McGraw-Hill, 1963, pages 5.49-5.53 (Leva Correlation)
7. V. L. Streeter, Handbook of Fluid Mechanics, 1st Edition, McGraw-Hill, 1961, page 17.33 (Ergun Correlation)
8. E. M. Mouradian, Personal notes on the thermal properties of air, based on data from Kreith, Reference 9, page 595
9. F. Kreith, Principles of Heat Transfer, 2nd Edition, International Textbook Company, 1966, pages 594, 595

PREPARED BY: <i>E. m. m.</i>		PAGE NO. <i>21</i> OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. <i>A-1</i>

APPENDIX A


HEAT TRANSFER CORRELATIONS


KUNII & LEVENSPIEL
 (Ref. 1) Pg. 210-212

For $Re > 100$, $Nu = 2 + 1.8 Pr^{1/3} Re^{1/2}$

$Nu \cong 2.0 + 1.6 Re^{0.5}$ for $Pr \cong 0.7$

For $Re < 100$, $Nu \cong 0.01135 Re^{1.60}$
 curve drawn through data below:



PREPARED BY: E. M. M.	 Rockwell International Atomic International Division	PAGE NO. 22 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-2

KAYS & LONDON:
 (Ref. 2) Pg. 123 Fig. 113

Given volume: VOL

Particle diameter: d_p

Volume of one particle: $\frac{\pi}{6} d_p^3$

Surface area, one particle = $\frac{\pi d_p^2}{\phi}$

Number of particles in volume, $N = \frac{VOL(1-\epsilon)}{\frac{\pi}{6} d_p^3}$

Total surface area, $A_{TOT} = NA = \frac{VOL(1-\epsilon)}{\frac{\pi}{6} d_p^3} \frac{\pi d_p^2}{\phi} = \frac{VOL(1-\epsilon) 6}{d_p \phi}$

Volume/Surface Ratio = $\frac{d_p \phi}{6(1-\epsilon)}$

Hydraulic Diameter: $4r_h = \frac{4A_{FACE} L}{A_{SUR}} = \frac{4A_{OR} \epsilon L}{A_{SUR}} = 4\epsilon \frac{VOL}{SUR}$

$$4r_h = \frac{2}{3} \frac{\epsilon}{1-\epsilon} d_p \phi$$

$$G_{KL} = \frac{\dot{W}}{A_{FACE}} = \frac{\dot{W}}{A_{OR} \epsilon} \quad G_{KL} = G\left(\frac{1}{\epsilon}\right)$$


$$Re_{KL} = \frac{4r_h G_{KL}}{\mu} = \frac{2}{3} \frac{\epsilon}{1-\epsilon} d_p \phi \frac{\dot{W}}{A_{OR} \epsilon \mu} = \frac{2}{3} \frac{\phi}{1-\epsilon} \frac{\dot{W}}{A_{OR}} \frac{d_p}{\mu}$$

$$Re = \frac{\dot{W}}{A_{OR}} \frac{d_p}{\mu} \quad \left(Re_{KL} = \frac{2}{3} \frac{\phi}{1-\epsilon} Re \right)$$

$$St = \frac{h}{c_p G_{KL}} = \frac{h \epsilon}{c_p \frac{\dot{W}}{A_{OR}}}$$

$$Pr = \frac{\mu c_p}{k}$$

$$Nu = \frac{h d_e}{k}$$

PREPARED BY:	 Rockwell International Atomic International Division	PAGE NO. 23 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-3

$$St Pr = 0.21 \frac{Re}{KL}^{-.31} \quad 20 < Re < 600$$


$$\frac{h \epsilon}{c_p \frac{\dot{w}}{A_{cr}}} \frac{\mu_{cr}}{k} = 0.21 \left(\frac{2}{3} \frac{\phi}{(1-\epsilon)} \right)^{-.31} Re^{-.31}$$

$$\frac{hd_p}{k} = 0.21 \left(\frac{2}{3} \right)^{0.31} \left[\frac{1}{\epsilon} \left(\frac{1-\epsilon}{\phi} \right)^{0.31} \right] \left(\frac{\dot{w}}{A_{cr}} \frac{d_p}{\mu} \right)^{.69}$$

$$Nu = 0.23813 \left[\frac{1}{\epsilon} \left(\frac{1-\epsilon}{\phi} \right)^{0.31} \right] Re^{0.69}$$

$$20 < Re < 600 \quad \text{KAYS \& LONDON}$$

REV. 8-78

PREPARED BY: E. M. M.	 Rockwell International Atomic International Division	PAGE NO. 24 OF
CHECKED BY:		PROJECT NO.
DATE:		MODEL NO. A-4

LÖF & HAWLEY
(Ref. 3)

$$h_v = 0.79 \left(\frac{G}{d_p} \right)^{0.7}$$

$$h_v = \text{BTU/hr ft}^2 \text{ } \circ\text{F}$$

$$G = \text{lb}_m/\text{hr ft}^2 \text{ of bed cross-section}$$

$$d_p = \text{Particle Equivalent Diameter (feet)}$$

$$h = h_v \left(\frac{1}{\alpha} \right) \text{ where } \alpha = \frac{\text{AREA}}{\text{VOL}} = \frac{6(1-\epsilon)}{d_p \phi}$$

$$0.79 \frac{\text{BTU}}{\text{ft}^2 \text{ hr}^3 \text{ ft}^3}$$

$$\frac{h_{dr}}{k} = \frac{d_r}{k} \frac{1}{\alpha} 0.79 \left(\frac{W}{A_{cr} d} d d \right)^{0.7} \frac{\mu^{0.7}}{d^{1.4}}$$

$\underbrace{\hspace{10em}}_{\text{Re}}$

$$Nu = Re^{0.7} \frac{d^{0.6}}{6(1-\epsilon)} \frac{\phi}{k} (0.79)$$

For air at 100°F → 250°F (T = 175°F)


$$\mu = 0.050607 \text{ lb}_m/\text{ft hr}$$

$$k = 0.0168437 \text{ BTU/hr ft } \circ\text{F} \quad \frac{\mu^{0.7}}{k} = 7.35377$$

$$Nu = Re^{0.7} \left(\frac{d_{\text{INCH}}}{12} \right)^{0.6} \frac{\phi}{6(1-\epsilon)} (7.35377)(0.79)$$

$$Nu \cong 0.276 \frac{\phi}{(1-\epsilon)} \left(\frac{d}{\text{INCH}} \right)^{0.6} Re^{0.7} \text{ LÖF \& HAWLEY}$$

$$25 < Re < 500$$

PREPARED BY: E. M. M.	 Rockwell International Atomics International Division	PAGE NO. 25 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-5

"ARGENTINE"
 ALANIS, SARAVIA & ROVETTA
 (Ref. 4)

$$h_v = a \left(\frac{G}{d} \right)^b$$

$$a = 824 \frac{\text{watt sec}^{0.92}}{\text{meter}^{0.24} \text{ } ^\circ\text{K} \text{ kg}^{0.92}}$$

$$b = 0.92$$

$$h_v = h \frac{\text{VOL}}{\text{AREA}} = h \left(\frac{1}{\alpha} \right)$$

$$\alpha = \frac{\text{AREA}}{\text{VOL}} = \frac{G(1-\epsilon)}{d_p \phi}$$

h_v = Volumetric Coeff.

$$a = 824 \frac{\text{watt sec}^{0.92}}{\text{meter}^{0.24} \text{ } ^\circ\text{K} \text{ kg}^{0.92}}$$

$$1 \text{ watt} = 3.41276 \frac{\text{BTU}}{\text{hr}}$$

$$1 \text{ sec} = \frac{1}{3600} \text{ hr}$$

$$1 \text{ } ^\circ\text{K} = 1.8 \text{ } ^\circ\text{R}$$

$$1 \text{ kg}_m = 2.2046225 \text{ lb}_m$$

$$1 \text{ meter} = \frac{1}{3.2808} \text{ ft}$$

$$a = 824 \frac{\text{watt sec}^{0.92}}{\text{m}^{0.24} \text{ } ^\circ\text{K} \text{ kg}^{0.92}} \cdot 3.41276 \frac{\text{BTU}}{\text{hr w}} \left(\frac{1}{3600} \right)^{0.92} \left(\frac{\text{hr}}{\text{sec}} \right)^{0.92} (3.2808)^{0.24} \left(\frac{\text{m}}{\text{ft}} \right)^{0.24} \frac{\text{ } ^\circ\text{K}}{1.8 \text{ } ^\circ\text{R}} \frac{1}{2.2046225} \left(\frac{\text{kg}}{\text{lb}_m} \right)^{0.92}$$

$$a = 0.3035696 \frac{\text{BTU}}{\text{hr}^{0.08} \text{ ft}^{0.24} \text{ } ^\circ\text{R} \text{ lb}_m^{0.92}}$$

$$T = 18 \text{ } ^\circ\text{C} \rightarrow 67 \text{ } ^\circ\text{C}$$

$$64.4 \text{ } ^\circ\text{F} \rightarrow 152.6 \text{ } ^\circ\text{F}$$

(Test data Range)


$$\bar{T} = 108.5 \text{ } ^\circ\text{F}$$

$$\mu = 0.046665 \frac{\text{lb}_m}{\text{ft hr}}$$

$$\mu^{0.92} = 0.05963103$$

$$k = 0.0155116$$

$$\frac{\mu^{0.92}}{k} = 3.8443 \frac{\text{lb}_m^{0.92} \text{ hr}^{0.08} \text{ ft}^{0.08} \text{ } ^\circ\text{F}}{\text{BTU}}$$

DESIGNED BY: E.M.M.	 Rockwell International Atomic International Division	PAGE NO. 26 OF
CHECKED BY:		RECORD NO.
DATE:		MODEL NO. A-6

$$h_v = a \left(\frac{G}{d_p} \right)^b$$

$$h = h_v \left(\frac{1}{2} \right) = \frac{1}{2} a \left(\frac{G}{d_p} \right)^b$$

$$\frac{h d_p}{k} = \frac{d_p}{k} \frac{a}{2} \left(\frac{G}{d_p} \frac{d_p d_o}{\mu} \right)^b \frac{\mu^b}{d^{2b}}$$

$\underbrace{\hspace{1.5cm}}_{Nu_p} \qquad \underbrace{\hspace{1.5cm}}_{Re_p}$

$$Nu = \frac{d_o}{k} \frac{a d_p \phi}{6(1-\epsilon)} Re^b \frac{\mu^b}{D^{2b}}$$

$$Nu = Re^b \frac{a}{6} \frac{\phi}{1-\epsilon} d^{2(1-b)} \frac{\mu^b}{k}$$


$$b = 0.92 \quad a = .30357 \quad \frac{\mu^{.92}}{k} = 3.8443$$

$$Nu = Re^{.92} \frac{\phi}{1-\epsilon} \frac{d_{INCH}^{0.16}}{12^{0.16}} \frac{.30357}{6} 3.8443$$

$$Nu = 0.1307 \left(\frac{d}{INCH} \right)^{0.16} \left(\frac{\phi}{1-\epsilon} \right) Re^{0.92}$$

"ARGENTINE"

25 < Re < 200

DESIGNED BY: E. M. M.	 Rockwell International Atomics International Division	PAGE NO. 27 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-7

GAMSON
 Mc ADAMS
 (Ref 5) Pg. 295

$$j = \frac{h}{c_p G} \left(\frac{c_p M}{k} \right)^{2/3} = 1.06 \left(\frac{d_p G}{\mu} \right)^{-0.41}$$

$$G = \frac{\dot{W}}{A_{GR}}$$

$$\frac{h d_p}{k} = 1.06 (Re)^{-0.41} c_p G Pr^{-2/3} \frac{d_p}{k} \frac{\mu}{\mu}$$

$$\frac{h d_p}{k} = 1.06 Re^{-0.41} Pr^{-2/3} \frac{G d_p}{\mu} \frac{c_p M}{k}$$


$\underbrace{\hspace{1.5cm}}_{Nu} \qquad \underbrace{\hspace{1.5cm}}_{Re} \qquad \underbrace{\hspace{1.5cm}}_{Pr}$


$$Nu = 1.06 Pr^{1/3} Re^{0.59}$$

For $Pr \geq 0.72$

$$Nu = 0.94 Re^{0.59} \quad \text{GAMSON (McAdams)}$$

$$350 < Re < 4000$$

PREPARED BY: E. M. M.	 Rockwell International Atomic International Division	PAGE NO. 28 of
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-8
SUMMARY OF HEAT TRANSFER CORRELATIONS		
KUNII & LEVENSPIEL	$Re < 100; Nu = 0.01135 Re^{1.6}$ $Re > 100; Nu = 2 + 1.6 Re^{0.5}$ No ϵ or ϕ dependence	$h \propto d^{+0.6}$ $h \propto d^{-0.5}$ $h \downarrow$ as $T \uparrow$ $h \uparrow$ as $T \uparrow$
KAYS & LONDON	$Nu = 0.238 \left(\frac{1}{\phi}\right)^{.31} \frac{(1-\epsilon)^{.31}}{\epsilon} Re^{0.69}$ $20 < Re < 600$	$h \propto d^{-.31}$ $h \propto \phi^{-.31}$ $h \downarrow$ as $\epsilon \uparrow$ $h \uparrow$ as $T \uparrow$
LÖF & HAWLEY	$Nu = 0.276 \frac{\phi}{(1-\epsilon)} \left(\frac{d}{\text{INCH}}\right)^{0.6} Re^{0.7}$ $25 < Re < 500$	$h \propto d^{+.3}$ $h \propto \phi$ $h \uparrow$ as $\epsilon \uparrow$ $h \uparrow$ as $T \uparrow$
"ARGENTINE" Alanis, Saravia, Rovetta	$Nu = 0.131 \frac{\phi}{(1-\epsilon)} \left(\frac{d}{\text{INCH}}\right)^{0.16} Re^{0.92}$ $25 < Re < 200$	$h \propto d^{+.08}$ $h \propto \phi$ $h \uparrow$ as $\epsilon \uparrow$ $h \uparrow$ as $T \uparrow$
GAMSON (McAdams)	$Nu = 0.94 Re^{0.59}$ $350 < Re < 4000$	$h \propto d^{-.41}$ $h \uparrow$ as $T \uparrow$ No ϵ or ϕ dependence.
CORRELATION USED IN ANALYSIS.	$Nu = 0.5 Re^{0.7}$	$h \propto d^{-.3}$ $h \uparrow$ as $T \uparrow$ No ϵ or ϕ dependence.

PREPARED BY: E.M.M.	 Rockwell International Atomic International Division	PAGE NO. 29 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. A-9

CORRELATION USED IN ANALYSIS:

In comparing the several heat transfer correlations, some areas of agreement and disagreement were found.

POROSITY, (VOID FRACTION), ϵ : One correlation shows h decreasing with ϵ , two correlations show h increasing with ϵ , and two correlations show no effect.

THUS, NO CONCLUSIVE INDICATION.

SPHERICITY, ϕ : One correlation shows h decreasing with ϕ , two correlations show h increasing with ϕ , and two correlations show no effect.


THUS, NO CONCLUSIVE INDICATION.

PARTICLE DIAMETER, d_p : Correlations show h varying with the -0.5 to the $+0.6$ power. However, most show $h \propto d^{-0.3}$

To approximate the several heat transfer correlations, the following expression is used:

$$Nu_p = 0.5 Re_p^{0.7}$$

$$\text{where: } \begin{cases} Nu = \frac{h d_p}{k} \\ Re = \frac{\dot{w} d_p}{A_{GR} \mu} \end{cases}$$

PREPARED BY: <u>E. M. M.</u>	 Rockwell International Atomics International Division	PAGE NO. <u>30</u> OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. <u>B-1</u>

APPENDIX B

SPHERICITY = ϕ_s

$$\phi_s = \left(\frac{\text{SURFACE AREA OF SPHERE}}{\text{SURFACE AREA OF PARTICLE}} \right) \text{ Both of Same Volume}$$

$$V = \frac{\pi}{6} d^3 \quad \bar{d} = \left(\frac{6}{\pi} V \right)^{1/3}$$

$$A \left(\begin{smallmatrix} \text{Surface Area} \\ \text{of sphere with} \\ \text{Volume } V \end{smallmatrix} \right) = \pi \bar{d}^2 = (36\pi V^2)^{1/3}$$

$$\phi_s = \frac{(36\pi V^2)^{1/3}}{A_{\text{Actual Surface}}} = \frac{\pi \bar{d}^2}{A_{\text{Act. Surf.}}} \text{ SPHERICITY}$$

CUBE:



$$V = S^3$$

$$A_{\text{Act}} = 6S^2$$

$$\bar{d} = \left(\frac{6}{\pi} V \right)^{1/3} = \left(\frac{6}{\pi} \right)^{1/3} S$$

$$\bar{d} = 1.2407 S$$

$$\phi_s = \frac{\pi \bar{d}^2}{A_{\text{Act}}} = \frac{\pi \left(\frac{6}{\pi} \right)^{2/3} S^2}{6S^2}$$

$$\phi_s = \left(\frac{\pi}{6} \right)^{1/3} = 0.806$$

CUBE

CYLINDER:



Say $f = \frac{L}{D}$
($L = fD$)

$$V = \frac{\pi}{4} D^2 L = \frac{\pi}{4} f D^3$$

$$A_{\text{Act}} = 2 \cdot \frac{\pi}{4} D^2 + \pi D L = D^2 \pi \left(f + \frac{1}{2} \right)$$

$$\bar{d} = \left(\frac{6}{\pi} V \right)^{1/3} = D (1.5 f)^{1/3}$$

$$A_{\text{SURFACE SPHERE}} = \pi \bar{d}^2 = \pi D^2 (2.25 f^2)^{1/3}$$

$$\phi_s = \frac{A_{\text{sur sphere}}}{A_{\text{act}}} = \frac{(2.25 f^2)^{1/3}}{\left(f + \frac{1}{2} \right)}$$

$$f = \frac{L}{D}$$

$$\phi_s$$

$$f \rightarrow 0$$

$$\phi \rightarrow 2.621 f^{2/3}$$

$$0.5$$

$$.8255$$

$$0.75$$

$$.8655$$

$$1.0$$

$$.87358 \text{ (MAX. VALUE)}$$

$$1.25$$

$$.8689$$

$$1.50$$

$$.8585$$


$$2.0$$

$$.832$$

$$f \rightarrow \infty$$

$$\frac{1.3104}{f^{1/3}}$$

RIGHT
CIRCULAR
CYLINDERS

PREPARED BY: <u>E. M. M.</u>	 Rockwell International Atomic International Division	PAGE NO. <u>31</u> OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. <u>C-1</u>


APPENDIX C

PRESSURE DROP & FAN POWER CORRELATIONS


LEVA:
 Perry
 (Ref. 6) Pg. 5.49 - 5.53

$$\Delta p = \frac{2f_m G^2 L (1-\epsilon)^{3-n}}{d_p g_c \rho \phi^{3-n} \epsilon^3}$$

$$N_{Re}' = \frac{d_p G_{cr}}{\mu}$$



Friction factor for beds of solids. [Leva, "Fluidisation," p. 49, McGraw-Hill, New York, 1959.]

PREPARED BY: E. m. m.	 Rockwell International Atomics International Division	PAGE NO. 32 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. C-2

At low Reynolds Number; ($Re < 10$)

$$f_m = \frac{100}{Re} = \frac{100 \mu}{d_r G} \quad n = 1.0$$

$$\Delta p = \frac{2 f_m G^2 L (1-\epsilon)^{3-n}}{d_r g_c \rho \phi^{3-n} \epsilon^3} = 2 \frac{100 \mu}{d_r G} \frac{G^2 L (1-\epsilon)^{3-1}}{d_r g_c \rho \phi^{3-1} \epsilon^3}$$

$$\Delta p = \frac{L}{g_c} (200) \frac{\mu V_o}{d_r^2} \frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \quad \text{At Low } Re.$$

At high Reynolds Number; ($Re > 1000$)


$$\text{Say } f_m \cong 1.165 \quad n = 2.0$$

$$\Delta p = \frac{2 f_m G^2 L (1-\epsilon)^{3-n}}{d_r g_c \rho \phi^{3-n} \epsilon^3} = \frac{2 (1.165) \rho^2 V_o^2 L (1-\epsilon)^1}{d_r g_c \rho \phi \epsilon^3}$$

$$\Delta p = \frac{L}{g_c} (2.33) \frac{\rho V_o^2}{d_r} \frac{(1-\epsilon)}{\epsilon^3 \phi} \quad \text{At High } Re.$$

At intermediate values of Reynolds Number; ($10 < Re < 1000$)

Requires reading f_m and n values from plot on previous page.

PREPARED BY: E. M. M.	 Rockwell International Atomic International Division	PAGE NO. 33 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. C-3

(Ergun)
 KUNNI & LEVENSPIEL
 (Ref. 1) Pg. 66


Streeter
 (Ref. 7) Pg. 17.33

$$\Delta p = \frac{L}{g_c} \left\{ 150 \frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \frac{\mu V_0}{d_p^2} + 1.75 \frac{(1-\epsilon)}{\epsilon^3 \phi} \frac{\rho V_0^2}{d_p} \right\}$$

ERGUN CORRELATION

Kunni & Levenspiel suggest using a pressure drop expression made up of the sum of two terms. At low flow velocity, the first term predominates; at high velocity the second term predominates.

At intermediate flow velocities (i.e., Reynolds Numbers), both term contribute, making it unnecessary to determine a friction factor from a plot.

PREPARED BY:	 Rockwell International Atomic International Division	PAGE NO. 34 of
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. C-4

CORRELATION USED IN ANALYSIS:

The Leva correlation matches the Kunni & Levenspiel^(Ergun) Equation at the Reynolds Number limits (i.e., for $Re < 10$ and $Re > 1000$), except for the numerical value of the constant. The K & L correlation has the calculational advantage of not requiring plot look-ups for f_m and n , as Leva does.

Therefore; the Ergun form for pressure drop is used in the analysis, with the modification that the numerical constants have been increased by a factor of $4/3$, to match the more conservative Leva values.

PRESSURE DROP:

$$\Delta p = \frac{L}{g_c} \left\{ 200 \frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \frac{\mu V_0}{d_p^2} + 2.33 \frac{(1-\epsilon)}{\epsilon^3 \phi} \frac{\rho V_0^2}{d_p} \right\}$$

FOR FAN POWER:

$$P_{\text{FAN}} = \frac{\Delta p \dot{W}}{\rho_{\text{air}} (\text{eff})}$$

APPENDIX D
ANALYSIS PROCEDURE

D-a-1

Part a: Program Logic

INPUT:

Material Properties: Air, Rock.

 Φ = Sphericity of Pebble. ϵ = Bed Porosity (Void Fraction)Temperature Limits, T_{HOT} , T_{COLD}

ENG = SYSTEM MAXIMUM THEORETICAL ENERGY, MW-days

POW = SYSTEM OPERATING POWER, MW_e BED DIAMETER, ft. D_{BED} PARTICLE DIAMETER, inch d

CALCULATE:

$$\Delta T = T_{HOT} - T_{COLD} \quad ^\circ F$$

$$\rho(BED) = \rho(ROCK) \times (1 - \epsilon) \quad \text{lbm/ft}^3$$

$$ENG(BTU) = 24 \times 3.416 \times 10^6 \times ENG(MWdays)$$

$$\text{Mass Bed} = M(Bed) = \frac{ENG}{(C_{p,ROCK} \Delta T)}$$

$$\text{Volume Bed} = Vol(Bed) = \frac{M(Bed)}{\rho(Bed)}$$

D-a-2

$$Q(\text{Heat Rate}) \frac{\text{Btu}}{\text{hr}} = \text{POW}(\text{MW}) \times 3.413 \times 10^6$$

$$\dot{W}(\text{air mass}) \frac{\text{lbm}}{\text{hr}} = Q(\text{air}) / (\bar{C}_p \Delta T)_{\text{air}}$$

$$Z = \frac{(M C_p)_{\text{ROCK BED}}}{(\dot{W} \bar{C}_p)_{\text{AIR}}}$$

$$L(\text{Bed}) = \text{BED HEIGHT} = \left(\frac{4}{\pi}\right) \frac{\text{VOL}(\text{Bed})}{(D_{\text{Bed}})^2} \quad \text{ft}$$

$$A(\text{Gross Cross-Sect}) \text{ft}^2 = \frac{\pi}{4} (D_{\text{Bed}})^2$$

$$\alpha = \frac{\text{Surface Area}}{\text{Unit Volume}} = \frac{6(1-\epsilon)}{d} \quad \text{See App. A Sheet 2}$$

$$\text{Mass}(\text{One Rock}) = m(\text{lbm}) = \frac{\pi}{6} d^3 \rho_{\text{ROCK}} \quad (d = \text{ft})$$

$$N(\text{Number of Rocks}) = \frac{M(\text{Bed})}{m(\text{1 Rock})}$$

$$A(\text{Surface Area of 1 Rock}) \text{ft}^2 = \pi d^2 \left(\frac{1}{4}\right) \quad (d = \text{ft})$$

$$A_{\text{TOT SUR}}(\text{TOTAL SURFACE}) = N(\text{Number of Rocks}) \times A(\text{Surface of One Rock}) \quad \text{ft}^2$$

$$A(\text{Gross Flow}) = \frac{\pi}{4} D_{\text{Bed}}^2$$

$$A(\text{Net Flow}) = \frac{\pi}{4} D_{\text{Bed}}^2 \times \epsilon$$

$$G_0(\text{Superficial Mass Velocity}) = G_0 = \frac{\dot{W}(\text{air})}{A_{\text{GROSS FLOW}}}$$

$$KDX = \frac{(k)}{\text{Rock}} (\Delta x) = 7.7 \times \frac{k_{\text{ROCK}}}{d} \quad \text{See Appendix E}$$

$$V_0(\text{Superficial Velocity}) = \frac{G_0(\text{Gross})}{\rho_{\text{air}}} = \frac{\dot{W}}{A_{\text{GROSS}} \rho_{\text{air}}}$$

$$V(\text{Net Average Velocity}) = \frac{G_0}{\rho_{\text{air}} \times \epsilon} = \frac{\dot{W}}{A_{\text{NET}} \rho_{\text{air}}}$$

$$\text{TRANSIT TIME (Air flow)} = \frac{L(\text{Bed})}{V(\text{Net Avg})} = \frac{L \rho_{\text{air}} A_{\text{NET}}}{\dot{W}}$$

D-a-3

$$Z1 = (\text{Pressure Drop Factor; LAM}) = \frac{1}{g} \cdot 200 \frac{(1-\epsilon)^2}{\epsilon^3}$$

$$Z2 = (\text{Pressure Drop Factor; TURB}) = \frac{1}{g} \cdot 2.33 \frac{(1-\epsilon)}{\epsilon^2}$$

$$\Delta p_{LAM} = Z1 \times \mu \frac{V_o}{\phi^2 d^2}$$

$$\Delta p_{TURB} = Z2 \times \frac{\rho V_o^2}{\phi d}$$

$$\Sigma \Delta p = \Delta p_{LAM} + \Delta p_{TURB}$$

$$Re(\text{Reynolds}) = \frac{dG_o}{\mu}$$

$$Nu(\text{Nusselt}) = 0.5 Re^{0.7}$$

$$h = \frac{Nu \times k_{air}}{d}$$

$$hA = h \times A(\text{TOTAL SURFACE})$$


$$\frac{1}{U} = \frac{1}{h} + \frac{1}{kdx}$$

$$UA = U \times A(\text{TOTAL SURFACE})$$

$$P(\text{FAN POWER, } kw_e) = \frac{\Sigma \Delta p \cdot \dot{W}_{air}}{\rho_{air} (\text{eff})}$$

$$\bar{U}A(\text{Average } U A) = \frac{1}{2} (UA_{T_{HOT}} + UA_{T_{COLD}})$$

$$NTU = \frac{\bar{U}A}{(\dot{W} \bar{c}_p)_{AIR}}$$

DESIGNED BY: E. M. M.	 Rockwell International Atomics International Division	PAGE NO. 38 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. D-b-1

Part b: Influence of Input Variables:

BED hA_{SUR} :

ENG (Theoretical Bed Energy Capacity, BTU or MWdays)

$$ENG = M C_{p, \text{ROCK}} \Delta T$$

$$M (\text{Rock Mass}) = \frac{ENG}{C_{p, \text{ROCK}} \Delta T}$$

$$VOL (\text{Gross Bed Volume}) = \frac{M}{\rho_{BED}} = \frac{M}{\rho_{ROCK} (1-\epsilon)}$$

$$\frac{A_{SUR}}{VOL_{BED}} = \frac{6(1-\epsilon)}{d \phi} = \alpha$$

$$A_{SUR} = \alpha (VOL) = \frac{6(1-\epsilon)}{d \phi} \frac{M}{\rho_{ROCK} (1-\epsilon)} = \frac{6}{d \phi} \frac{ENG}{\rho_{ROCK} C_{p, \text{ROCK}} \Delta T}$$

$$A_{SUR} = \frac{6 ENG}{d \phi (\rho C_p)_{ROCK} \Delta T}$$

POW (Power Rate, MW_t or BTU/hr)

$$POW = \dot{w} C_{p, \text{AIR}} \Delta T \quad \dot{w} = \frac{POW}{C_{p, \text{AIR}} \Delta T}$$


$$A_{GRS} (\text{Gross Bed Cross-Section}) = \frac{\pi}{4} D^2$$

Say: $Nu = a Re^B$

$$\frac{hd}{k} = a \left(\frac{\dot{w}}{A_{GRS}} \right)^B \left(\frac{d}{\mu} \right)^B$$

$$hA_{SUR} = \frac{k}{d} a \left(\frac{POW}{C_{p, \text{AIR}} \Delta T} \right)^B \left(\frac{4}{\pi D^2} \right)^B \left(\frac{d}{\mu} \right)^B \frac{6 ENG}{d \phi (\rho C_p)_{ROCK} \Delta T}$$

$$hA_{SUR} = \left[6a \left(\frac{4}{\pi} \right)^B \right] \left[(POW)^B (ENG) \right] \left(\frac{k_{\text{AIR}}}{\mu_{\text{AIR}}^B C_{p, \text{AIR}}^B \rho C_p}_{ROCK} \right) \left(\frac{1}{D^{2B}} \right) \left(\frac{1}{d^{2-B}} \right) \left(\frac{1}{\phi} \right) \left(\frac{1}{\Delta T^{1+B}} \right)$$

PREPARED BY: E. M. M.	 Rockwell International Atomic International Division	PAGE NO. 39 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. D-b-2

$$\text{FOR: } Nu = 0.5 Re^{0.7} \quad a = 0.5$$

$$B = 0.7$$

$$\left[6a\left(\frac{4}{\pi}\right)^B\right] = (6)(.5)\left(\frac{4}{\pi}\right)^{0.7} = 3.55270$$

$$(\text{POW})^B = (\text{POW})^{.7} = [\text{POW}(\text{MW})]^{0.7} \left[(3.413 \times 10^6)^{0.7} \left(\frac{\text{BTU}}{\text{hr MW}} \right)^{0.7} \right] = 37427.90 (\text{POW})^{.7} \left(\frac{\text{BTU}}{\text{hr MW}} \right)^{.7}$$

$$(\text{ENG}) = [\text{ENG}(\text{MW-day})] \left[3.413 \times 10^6 \frac{\text{BTU}}{\text{hr MW}} \times 24 \frac{\text{hr}}{\text{day}} \right] = 8.1912 \times 10^7 (\text{ENG}) \frac{\text{BTU}}{\text{MW-day}}$$

$$\frac{k_{\text{air}}}{\mu_{\text{air}}^{0.7} c_{p,\text{air}}^{0.7} (\rho c_p)_{\text{ROCK}}} = \left(\frac{^{\circ}\text{F}^{0.7} \text{ft}^{2.7}}{\text{hr}^{0.3} \text{BTU}^{0.7}} \right)$$

$$D^{1.4} = (\text{DIAM: BED})^{1.4} = \text{ft}^{1.4}$$

$$d^{1.3} = (d_{\text{inch}})^{1.3} \left(\frac{\text{ft}}{12 \text{ inch}} \right)^{1.3} = [0.03954252 \left(\frac{\text{ft}}{\text{inch}} \right)^{1.3}] \left(\frac{d}{\text{INCH}} \right)^{1.3}$$


$$\Delta T^{-1.7} = \left(\frac{1}{^{\circ}\text{F}} \right)^{-1.7}$$

$$hA_{\text{SUR}} = (3.55270) (\text{POW})^{0.7} \left(37427.9 \frac{\text{BTU}}{\text{hr MW}} \right)^{.7} [\text{ENG}] \left(8.1912 \times 10^7 \frac{\text{BTU}}{\text{MW-day}} \right) \left(\frac{k_{\text{air}}}{\mu_{\text{air}}^{0.7} c_{p,\text{air}}^{0.7}} \right)$$

$$\left(\frac{1}{\rho c_p} \right)_{\text{ROCK}} \left(\frac{^{\circ}\text{F}^{.7} \text{ft}^{2.7}}{\text{hr}^{0.3} \text{BTU}^{0.7}} \right) \left(\frac{1}{D_{\text{FT}}} \right)^{1.4} \left(\frac{1}{d_{\text{INCH}}} \right)^{1.3} \left(\frac{1}{0.03954252} \right) \left(\frac{\text{inch}}{\text{ft}} \right)^{1.3} \frac{1}{\phi} \left(\frac{1}{\Delta T} \right)^{1.7} \frac{1}{^{\circ}\text{F}^{1.7}}$$

$$hA_{\text{SUR}} = (2.7545 \times 10^{14}) [\text{POW}]^{0.7} [\text{ENG}]^{1.0} \left(\frac{k}{\mu^{0.7} c_p^{0.7}} \right)_{\text{AIR}} \left(\frac{1}{\rho c_p} \right)_{\text{ROCK}} \left(\frac{1}{D} \right)^{1.4} \left(\frac{1}{d} \right)^{1.3} \left(\frac{1}{\phi} \right) \left(\frac{1}{\Delta T} \right)^{1.7}$$

$$\frac{\text{BTU}}{\text{hr } ^{\circ}\text{F}}$$

PREPARED BY: <u>E.M.M.</u>	 Rockwell International Atomic International Division	PAGE NO. <u>40</u> OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. <u>D-b-3</u>

BED Δp and FAN POWER

$$\Delta p = 200 \frac{L}{g_c} \frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \frac{\rho V_0^3}{d_p^2} + 2.33 \frac{L}{g_c} \frac{(1-\epsilon)}{\epsilon^3 \phi} \frac{\rho V_0^2}{d_p}$$

("LAM")
(TURB)

$$P_{\text{FAN POWER}} = \frac{\Delta p \dot{W}}{\rho_{\text{air}} (\text{eff})}$$


$$\dot{W} \frac{\text{lb}_m/\text{hr}}{\text{lb}_m/\text{hr}} = \frac{\text{POW}}{\bar{c}_p \Delta T} = \frac{[\text{POW} - \text{MW}] 3.413 \times 10^6 \frac{\text{BTU}}{\text{hr MW}}}{\bar{c}_p \Delta T \frac{\text{BTU}}{\text{lb}_m \text{ } ^\circ\text{F}} \text{ } ^\circ\text{F}}$$

$$P_{\text{FAN}} \left(\frac{\text{lb}_F \text{ ft}}{\text{hr}} \right) = \frac{\Delta p \frac{\text{lb}_F/\text{ft}^2}{\rho_{\text{air}} \frac{\text{lb}_m}{\text{ft}^3}} \dot{W} \frac{\text{lb}_m/\text{hr}}{(\text{eff})}}$$

$$P_{\text{FAN}} = \frac{\Delta p \frac{\text{lb}_F/\text{ft}^2}{\rho_{\text{air}} \frac{\text{lb}_m}{\text{ft}^3}} (\text{eff}) [\text{POW} (\text{MW})] 3.413 \times 10^6 \frac{\text{BTU}}{\text{hr MW}}}{\bar{c}_p \frac{\text{BTU}}{\text{lb}_m \text{ } ^\circ\text{F}} \Delta T \text{ } ^\circ\text{F}} \frac{\text{BTU}}{778.16 \text{ ft lb}_F} \frac{\text{hr}}{3.413 \times 10^3 \text{ BTU}} \text{ kW}_e$$

$$P_{\text{FAN}} = \frac{\Delta p \frac{\text{lb}_F}{\text{ft}^2} [\text{POW} - \text{MW}]}{\rho_{\text{air}} (\text{eff}) \bar{c}_p \Delta T} (1.2851)$$

kW_e

PREPARED BY: E.M.M.	 Rockwell International Atomic International Division	PAGE NO. 41 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. D-b-4

$$\Delta p_{LAM} = 200 \frac{L}{g_c} \frac{(1-\epsilon)^2}{\epsilon^3} \frac{\mu V_o}{\phi^2 d^2}$$

$$V_o = \frac{\dot{W}}{A_{GRS} \rho_{air}} \quad \dot{W} = \frac{POW}{\bar{C}_p \Delta T} \quad A_{GRS} = \frac{\pi}{4} D^2$$

$$V_o = \frac{4}{\pi} \frac{POW}{\bar{C}_p \Delta T} \frac{1}{\rho_{air} D^2}$$

$$VOL = A_{GRS} L = \frac{M}{\rho_{ROCK} (1-\epsilon)} \quad M = \frac{ENG}{\bar{C}_p \Delta T}$$

$$L = \frac{VOL}{A_{GRS}} = \left(\frac{4}{\pi} \frac{1}{(1-\epsilon)} \frac{1}{(\rho_{ROCK})} \frac{ENG}{\Delta T D^2} \right)$$

$$\Delta p_{LAM} = \frac{L}{g_c} 200 \frac{(1-\epsilon)^2}{\epsilon^3} \frac{\mu V_o}{\phi^2 d^2} = \left[\left(\frac{4}{\pi} \right)^2 (200) \left[\frac{1}{g_c} \right] \left[\frac{(1-\epsilon)^2}{\epsilon^3 \phi^2} \right] \left[(ENG)(POW) \right] \left[\frac{1}{(\Delta T)^2} \right] \left[\frac{1}{(D^4)} \right] \left[\frac{1}{(d^2)} \right] \left[\frac{\mu}{(\rho \bar{C}_p)} \right] \left[\frac{1}{(\rho_{ROCK})} \right]$$

$$(ENG)(POW) = (ENG \text{ MW-day})(POW \text{ MW}) \left[(3.413 \times 10^6)^2 \left(\frac{BTU}{hr MW} \right)^2 \frac{24 \text{ hr}}{\text{day}} \right]$$

$$2.79566 \times 10^{14} \frac{BTU^2}{hr MW^2 \text{ day}}$$

$$\frac{1}{d^2} = \frac{1}{\text{INCH}^2} \frac{144 \text{ in}^2}{\text{ft}^2}$$


$$g_c = \left(32.1739 \frac{\text{ft lb}_F}{\text{lb}_M \text{ sec}^2} \right) \left(3600^2 \frac{\text{sec}^2}{\text{hr}^2} \right) = 4.16974 \times 10^8 \frac{\text{ft lb}_F}{\text{lb}_M \text{ hr}^2}$$

$$\Delta p_{LAM} = (3.1303 \times 10^{10}) \frac{(1-\epsilon)}{\epsilon^3} \frac{1}{\phi^2} \left[\frac{(ENG)(POW)}{\text{MW day}} \right] \left[\frac{1}{(D^4)} \right] \left[\frac{1}{(\Delta T)^2} \right] \left[\frac{1}{(d^2)} \right] \left[\frac{\mu}{(\rho \bar{C}_p)} \right] \left[\frac{1}{(\rho_{ROCK})} \right]$$

$$\frac{\text{lb}_F}{\text{ft}^2}$$

$$P_{FAN, LAM} = (4.0227 \times 10^{10}) \frac{(1-\epsilon)}{\epsilon^3} \frac{1}{\phi^2} \left[(ENG)(POW)^2 \right] \left[\frac{1}{(D^4)} \right] \left[\frac{1}{(\Delta T)^3} \right] \left[\frac{1}{(d^2)} \right] \left[\frac{\mu}{(\rho^2 \bar{C}_p^2)} \right] \left[\frac{1}{(\rho_{ROCK})} \right] \left[\frac{1}{(eff)} \right]$$

$$\text{KW}_e$$

PREPARED BY: E. M. M	 Rockwell International Atomic International Division	PAGE NO. 42 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. D-b-5

$$\Delta P_{TURB} = 2.33 \frac{L}{g_c} \frac{1-\epsilon}{\epsilon^3} \frac{\rho V_0^2}{\phi d}$$

$$V_0 = \frac{4}{\pi} \frac{POW}{\rho_{AIR} \Delta T} \frac{1}{\rho_{ROCK} D^2} \quad L = \frac{4}{\pi(1-\epsilon)} \frac{1}{(\rho_{ROCK})} \frac{ENG}{D^2 \Delta T}$$

$$\Delta P_{TURB} = 2.33 \frac{4}{\pi(1-\epsilon)} \frac{1}{\rho_{ROCK}} \frac{ENG}{D^2 \Delta T} \frac{1}{g_c} \frac{1-\epsilon}{\epsilon^3} \frac{\rho}{\phi d} \left(\frac{4}{\pi}\right)^2 \frac{(POW)^2}{(\rho_{AIR})^2 (\Delta T)^2} \frac{1}{\rho_{AIR}^2 D^4}$$

$$\Delta P_{TURB} = \left[\left(\frac{4}{\pi}\right)^3 (2.33)\right] \left[\frac{1}{g_c}\right] \left[\frac{1}{\epsilon^3} \frac{1}{\phi}\right] \left[\frac{(ENG)(POW)^2}{(\Delta T)^3}\right] \left[\frac{1}{D^6}\right] \left[\frac{1}{d}\right] \left[\frac{1}{\rho_{AIR}^2}\right] \left[\frac{1}{\rho_{ROCK}}\right]$$

$$(ENG)(POW)^2 = [ENG \text{ MW}\cdot\text{day}] [POW \text{ MW}]^2 \left(3.413 \times 10^6 \frac{\text{Btu}}{\text{hr MW}}\right)^3 \left(24 \frac{\text{hr}}{\text{day}}\right)$$

$$9.54156 \times 10^{20}$$

$$\frac{1}{d} = \left(\frac{1}{d}\right) \left(12 \frac{\text{inch}}{\text{ft}}\right)$$

$$g_c = 4.16974 \times 10^8 \frac{\text{ft} \cdot \text{lb}_F}{\text{lb}_M \cdot \text{hr}^2}$$

$$\Delta P_{TURB} = (1.3206 \times 10^{14}) \left[\frac{1}{\epsilon^3} \frac{1}{\phi}\right] \left[\frac{(ENG)(POW)^2}{\text{MW} \cdot \text{day}}\right] \left[\frac{1}{(\Delta T)^3}\right] \left[\frac{1}{D^6}\right] \left[\frac{1}{d}\right] \left[\frac{1}{\rho_{AIR}^2}\right] \left[\frac{1}{\rho_{ROCK}}\right]$$

lb_F/ft²

$$P_{FAN} = (1.6971 \times 10^{14}) \left[\frac{1}{\epsilon^3} \frac{1}{\phi}\right] \left[\frac{(ENG)(POW)^3}{\text{MW} \cdot \text{day}}\right] \left[\frac{1}{(\Delta T)^3}\right] \left[\frac{1}{D^6}\right] \left[\frac{1}{d}\right] \left[\frac{1}{\rho_{AIR}^2}\right] \left[\frac{1}{\rho_{ROCK}}\right] \left[\frac{1}{\text{eff}}\right]$$


KW
TURB

M 15582 REV. 8-76


EFFECT OF BED PARAMETERS ON hA , Δp and P_{FAN} .

	hA_{SUR}	Δp		P_{FAN}		
		LAM	TURB	LAM	TURB	
POROSITY (ϵ)	—	$\Delta p \propto \left(\frac{1-\epsilon}{\epsilon^3}\right)$	OR $\left(\frac{1}{\epsilon^3}\right)$	$P \propto \left(\frac{1-\epsilon}{\epsilon^3}\right)$	OR $\left(\frac{1}{\epsilon^3}\right)$	
SPHERICITY (ϕ)	$hA \propto \frac{1}{\phi}$	$\Delta p \propto \frac{1}{\phi^2}$	OR $\frac{1}{\phi}$	$P \propto \frac{1}{\phi^2}$	OR $\frac{1}{\phi}$	
THEORETICAL MAX ENERGY (ENG) CONTENT	$ENG = (PC_p) \Delta T_{Rock}$	$hA \propto [ENG]$	$\Delta p \propto [ENG]^{1.0}$	OR $[ENG]^{1.0}$	$P \propto [ENG]^{1.0}$	OR $[ENG]^{1.0}$
POWER RATE (POW)	$POW = \dot{w}_{AIR} C_p \Delta T$	$hA \propto [POW]^{0.7}$	$\Delta p \propto [POW]$	OR $[POW]^2$	$P \propto [POW]^2$	OR $[POW]^3$
BED DIAMETER, D	$hA \propto \left(\frac{1}{D}\right)^{1.4}$	$\Delta p \propto \left(\frac{1}{D}\right)^4$	OR $\left(\frac{1}{D}\right)^6$	$P \propto \left(\frac{1}{D}\right)^4$	OR $\left(\frac{1}{D}\right)^6$	
PARTICLE DIAMETER, d	$hA \propto \left(\frac{1}{d}\right)^{1.3}$	$\Delta p \propto \left(\frac{1}{d}\right)^2$	OR $\left(\frac{1}{d}\right)^1$	$P \propto \left(\frac{1}{d}\right)^2$	OR $\left(\frac{1}{d}\right)^1$	
AIR PROPERTIES	$hA \propto \left(\frac{k}{\mu^{1.7} \bar{c}_p^{0.7}}\right)_{air}$	$\Delta p \propto \left(\frac{\mu}{\rho \bar{c}_p}\right)_{air}$	OR $\left(\frac{1}{\rho \bar{c}_p^2}\right)_{air}$	$P \propto \left(\frac{\mu}{\rho^2 \bar{c}_p^2}\right)_{air}$	OR $\left(\frac{1}{\rho^2 \bar{c}_p^3}\right)_{air}$	
ROCK PROPERTIES	$hA \propto \left(\frac{1}{\rho C_p}\right)_{Rock}$	$\Delta p \propto \left(\frac{1}{\rho C_p}\right)_{Rock}$	OR $\left(\frac{1}{\rho C_p}\right)_{Rock}$	$P \propto \left(\frac{1}{\rho C_p}\right)_{Rock}$	OR $\left(\frac{1}{\rho C_p}\right)_{Rock}$	
TEMPERATURE DIFFERENCE (ΔT)	$hA \propto \left(\frac{1}{\Delta T}\right)^{1.7}$	$\Delta p \propto \left(\frac{1}{\Delta T}\right)^2$	OR $\left(\frac{1}{\Delta T}\right)^3$	$P \propto \left(\frac{1}{\Delta T}\right)^3$	OR $\left(\frac{1}{\Delta T}\right)^4$	
FAN EFFICIENCY (eff)	—	—	—	$P \propto \left(\frac{1}{eff}\right)$	OR $\left(\frac{1}{eff}\right)$	

ESG-79-2, Vol II, Book 2
G-44

REVISED BY: C. M. M.	 Rockwell International Atomic International Division	DATE:	REPORT NO.:	PAGE NO.: 43
ORDER NO.:		FORM NO.: D-b-6	OR	

N2/110005

DESIGNED BY: E. M. M.		PAGE NO. 44 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. D-C-1

Part c: Partial Numerical Evaluation

$$ENG = M C_p \Delta T$$

$$M = (VOL) \bar{\rho} = (VOL) \rho (1 - \epsilon)$$

$$VOL = \frac{\pi}{4} D^2 L$$

$$ENG = (VOL) (\rho) (1 - \epsilon) (C_p) \Delta T$$

$$L = \frac{ENG}{\rho(1-\epsilon)(C_p)(\Delta T) \frac{\pi}{4} D^2} = \frac{(ENG - MW \cdot day) 3.413 \times 10^6 \frac{BTU}{hr \cdot MW} 24 \frac{hr}{day}}{(165)(1-.39) \frac{lb_m}{ft^3} (.25 \frac{BTU}{lb_m \cdot ^\circ F}) (500^\circ F) \frac{\pi}{4} D^2 ft^2}$$

$$\boxed{L = \frac{ENG (MW \cdot day)}{D^2} (8289.605)} \left\{ \begin{array}{l} \epsilon = .39 \quad \Delta T = 500 \\ \rho = 165 \quad C_p = .25 \\ \text{Rock} \end{array} \right.$$

$$M = \frac{ENG}{C_p \Delta T} = \frac{(ENG \cdot MW \cdot day) (3.413 \times 10^6 \frac{BTU}{hr \cdot MW} \times 24 \frac{hr}{day})}{(.25 \frac{BTU}{lb_m \cdot ^\circ F}) (500^\circ F) (2000 \frac{lb_m}{TON})}$$

$$\boxed{M = ENG (MW \cdot day) (327.648)}$$


$$VOL = \frac{M}{\rho} = \frac{327.648 \cdot ENG}{165.05}$$

$$\boxed{VOL = ENG (MW \cdot day) (6510.641)}$$

$$POW = \dot{W} C_p \Delta T$$

$$\dot{W} = \frac{POW}{C_p \Delta T} = \frac{(POW - MW) (3.413 \times 10^6 \frac{BTU}{hr \cdot MW})}{(.257057 \frac{BTU}{lb_m \cdot ^\circ F}) (500^\circ F)}$$


$$\boxed{\dot{W}_{air} = POW (MW) (26554.422)} \left\{ \begin{array}{l} \Delta T = 500 \\ \bar{C}_p = .257057 \frac{BTU}{lb_m \cdot ^\circ F} \end{array} \right.$$

PREPARED BY: E.M.M.	 Rockwell International Atomic International Division	PAGE NO. 45 of
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. E-1

APPENDIX E

CONDUCTION THROUGH UPPER LAYER OF ROCK.

Assume Spherical Pebble.



Represents Thermal Resistance of Upper Layer of Rock.

Assume thermal capacitance of pebble is concentrated at "mid-volume" location.

$$V = \frac{\pi}{6} D^3 \quad V_{\frac{1}{2}} = \frac{\pi}{6} \bar{D}^3 = 0.5 V$$

$$\frac{0.5}{1.0} = \left(\frac{\bar{D}}{D}\right)^3$$

$$\bar{D} = (.5)^{\frac{1}{3}} = 0.7937$$

$$\Delta X = \frac{1}{2}(1 - .7937)D = 0.10315 D$$

$$D^* = \sqrt{D \cdot \bar{D}} = D \sqrt{.7937} = 0.8909 D$$

$$\bar{A}_{COND} = \pi D^{*2} = 0.7937 \pi D^2$$

$$Y_{COND} = \frac{kA}{\Delta X} = k \frac{.7937 \pi D^2}{.10315 D} = \frac{\pi D^2 (7.69462) k}{D}$$

$$A_{SUR} = \pi D^2$$

$$Y_{RND} = \frac{7.7 k_{ROCK} A_{SUR}}{D}$$

$$\frac{1}{UA} = \frac{1}{Y_{CONV}} + \frac{1}{Y_{COND}}$$

$$\frac{1}{UA} = \frac{1}{hA} + \frac{D_{PARTICLE}}{7.7 k A_{SUR}}$$

$$"KDX" = \frac{7.7 k_{ROCK}}{D_{PARTICLE}}$$

APPENDIX F

TIME SHARE PROGRAM

ENM003

```

100  F M NIIPADIAN  EXT 2409
110  ENM003
120  E  R440  R388
130  P PESSURE DROP AND HEAT TRANSFER COEFFICIENT
140  IN THERMAL STORAGE ROCK BED.
1500
2100  P PESSURE DROP:  KUNTI & LEUENSPIEL  * 4/3
2200  HEAT TRANS COEFF:  NU = 0.5*RE**.7
1010  DIMENSION TC(2), TP(2), MU(2), K(2), RHO(2), PR(2), PP(2)
1020  DIMENSION DELP(2), DELPL(2), DELPT(2)
1040  DIMENSION UO(2), UOS(2), US(2), RE(2)
1050  DIMENSION NUH(2), NULOR(2), NU(2), H(2), HA(2)
1060  DIMENSION PFN(2), PFHP(2), PFKM(2)
1070  DIMENSION TTRANS(2), UC(2), UR(2), UA(2)
1510  REAL NU, K, MU
1520  REAL RHO, MFK, MRK, LBED
1530  REAL KRK, EDN, NDU, NNDAYS
20000
2003  CPRK = 0.25
2004  RHORK = 165.0
2005  KRK = 1.0
2101  EFF = 0.75
2201  PT = 3.141592653
2203  GO = 32.1739*3600.**2
2301  EFFPCT = 100.*EFF
150000
100100  I=1, HOT AIR,  I=2, COOL AIR.
101100  AREA = SURFACE AREA OF ONE PARTICLE,  FT2
101110  PPRK CONSIDERS INCREASE IN AREA: SURF DUE TO SPHRCTY
101200  ASTAT = TOTAL SURFACE AREA IN BED,  FT2
101220  AGREL = GROSS (SUPERFICIAL) FLOW AREA,  FT2
101230  ACRE = LAND AREA OF BED,  ACRES
101240  ANFL = NET FLOW AREA (GROSS*POROSITY),  FT2
101250  ALPHA = SURFACE AREA PER UNIT VOLUME,  FT2/FT3
103100  CP(I) = AIR SPECIFIC HEAT  BTU/LBM F
103150  CPPP = AVERAGE AIR SPECIFIC HEAT,  BTU/LBM F
103400  CPRK = SPECIFIC HEAT OF ROCK  BTU/LBM F
104100  DTAIR = DELTA TEMP OF SYSTEM,  F
104310  DELPL(I) = PRESSURE DROP, "LAMINAR TERM" PSF
104320  DELPT(I) = PRESSURE DROP, "TURBULENT TERM" PSF
104330  DELPCT) = TOTAL AIR FLOW PRESSURE DROP  PSF
104200  DBED = BED DIAMETER,  FT
104820  DPIN = PARTICLE DIAMETER,  INCH
104840  DP  = PARTICLE DIAMETER,  FEET
105100  E = POROSITY OF ROCK BED
105110  E(REF) = 0.39
105200  ENG = TOTAL ENERGY STORAGE CAPACITY, W/ MARGIN BTU
105300  EFF = FAN (BLOWER) EFFICIENCY
105310  EFFECT = FAN EFFICIENCY, PERCENT
107100  GO = SUPERFICIAL MASS VELOCITY,  LBM/FT2 HR

```

EMM003 CONTINUED

107200 GC = EMPIRICAL CONSTANT FT LBM/LBF HR2
 109100 HCTD = HEAT TRANSFER COEFFICIENT, BTU/HR FT2 F
 109200 HACTD = TOTAL HA FOR BED, BTU/HR F
 111100 KCD = AIR THERMAL CONDUCTIVITY BTU/HR FT F
 111200 KRK = ROCK THERMAL CONDUCTIVITY, BTU/HR FT F
 111400 KCKD = K/DK (EFF): ROCK BTU/HR FT2 F
 112100 LBED = LENGTH (HEIGHT) OF BED, FT
 117100 MUCD = AIR VISCOSITY LBM/FT HR
 112300 MRED = TOTAL MASS OF BED, LBM
 113310 MBEDTN = TOTAL MASS OF BED, TONS
 113400 M1RK = MASS OF ONE ROCK, LBM
 113500 MWDAYS = THEORETICAL MAXIMUM BED ENERGY CAPACITY, MH-DAYS
 114360 NUCD = NUSSELT NO, MINIMUM NU, VALUE TO USE.
 114400 NPK = NUMBER OF ROCKS
 114500 NTU = HT TRANS UNITS: (UA:BAR)/(WATR*CP)
 115100 OS = SPHERICITY
 115110 OS(REF) = 0.80
 116100 PRCD = AIR PRANDTL NUMBER
 116110 PRCD = PR**(1/3)
 116230 PFNCD = FAN (BLOWER) POWER, FT LBF/HR
 116240 PFHPD = FAN (BLOWER) POWER, HP
 116260 PFKWD = FAN (BLOWER) POWER, KW
 116700 PI = 3.141592653
 116700 POPER = STORAGE BED OPERATING POWER RATE, MWT
 117100 QAIR = HEAT RATE, BTU/HR
 118100 RECD = REYNOLDS NUMBER
 118400 RHCD = AIR DENSITY AT 1 ATM LBM/FT3
 118500 RHRK = DENSITY OF SOLID ROCK LBM/FT3
 118550 RHOBED = AVERAGE DENSITY OF BED, LBM/FT3
 120100 TCD = AIR TEMPERATURE, F
 120200 T1,T2 = TEMP HOT, COLD
 120700 TTRANSD = FLOW TRANSIT TIME, SECONDS
 121100 UCD = EFFECTIVE OVERALL HEAT TRANSFER COEFFICIENT
 121200 UACTD = TOTAL UA FOR BED, BTU/HR F
 121300 UABP = UA:AVG BETWEEN HOT & COLD
 122210 UCD = SUPERFICIAL VELOCITY FT/HR
 122220 UCD = SUPERFICIAL VELOCITY FT/SEC
 122230 USCD = AVERAGE ACTUAL VELOCITY FT/SEC
 122400 VOBED = VOLUME OF BED, FT3
 123100 WAIR = AIR FLOW RATE, LBM/HR
 126100 Z1,Z2 = PARAM IN Δ P CALC, LBF HR2/LBM
 126200 ZPER = Z*PERIOD = (MCP:ROCK)/(WATR*CP:ATR) HRS
 127000
 130000
 20080 PRINT.
 20081 PRINT.
 20082 PRINT.
 20083 PRINT.
 20090 PRINT, "POROSITY E, SPHERICITY OS ?"
 20091 READ, E, OS

EMM003 CONTINUED

```

20100 FPRINT, "T:HOT), T(COLD) ="
20101 READ, T(1), T(2)
20200 DO 100 I=1,2
20210 CP(I) = .239 + .90E-05*T(I) + .14E-07*T(I)**2
20220 MU(I) = .02996 + .6336E-04*T(I) - .144E-07*T(I)**2
20230 K(I) = .0133 + .206E-04*T(I) - .2E-06*T(I)**2
20240 RHO(I) = 39.65874/(T(I)+459.69)
20250 PR(I) = MU(I)*CP(I)/K(I)
20260 PR3(I) = PR(I)**(1./3.)
20350 100 CONTINUE
20511 T1 = T(1)
20512 T2 = T(2)
20520 DTAIR = T1-T2
20530 CPBR = .239 + (.9E-05/2.)*(T1+T2)
20531 CPMR = CPBR + (.14E-07/3.)*(T1**2+T1*T2+T2**2)
21510 FPRINT.
21511 PRINT.
21512 PRINT, " - - - - -"
21513 PRINT.
21514 PRINT.
21515 PRINT 201, T(1), T(2)
21516 201 FORMAT (" T:HOT =",F9.1," T:COLD =",F9.1," F")
21518 PRINT 202, DTAIR
21519 202 FORMAT (" DEL TEMP =",F9.1," F")
21600 PRINT.
22110 PRINT, " AIR PROPERTIES:"
22200 PRINT, " HOT COLD"
22210 PRINT 511, T(1), T(2)
22211 511 FORMAT (F13.1, F13.1, " TEMP: AIR, F")
22220 PRINT 512, CP(1), CP(2)
22221 512 FORMAT (F13.6, F13.6, " CP: AIR BTU/LBM F")
22230 PRINT 513, MU(1), MU(2)
22231 513 FORMAT (F13.6, F13.6, " VISCOSITY: AIR LBM/HR FT")
22240 PRINT 514, RHO(1), RHO(2)
22241 514 FORMAT (F13.6, F13.6, " DENSITY: AIR LBM/FT3")
22250 PRINT 515, PR(1), PR(2)
22251 515 FORMAT (F13.6, F13.6, " PRANDTL: AIR")
22260 PRINT 516, PR3(1), PR3(2)
22261 516 FORMAT (F13.6, F13.6, " PR**1/3")
22270 PRINT 517, K(1), K(2)
22271 517 FORMAT (F13.6, F13.6, " CONDUCTIVITY: AIR BTU/HR FT F")
22300 PRINT 518, CPBR
22301 518 FORMAT ("AUS AIR CP =",F9.6, " BTU/LBM F")
22509 PRINT.
22510 PRINT, " ROCK PROPERTIES:"
22530 RHOED = (1.-F)*RHOR
22610 PRINT 521, CPMR
22611 521 FORMAT (F8.4, " CP(ROCK) BTU/LBM F")
22620 PRINT 522, RHOR
22621 522 FORMAT (F8.3, " DENSITY OF SOLID ROCK, LBM/FT3")

```

EMM003 CONTINUED

```

22630 PRINT 523, RHOBED
22631 523 FORMAT (F8.3," MEAN BED DENSITY, LBM/FT3")
22640 PRINT 524, E
22641 524 FORMAT (F8.3," POROSITY")
22650 PRINT 525, OS
22651 525 FORMAT (F8.3," SPHERICITY")
22660 PRINT 526, KRK
22661 526 FORMAT (F8.3," CONDUCTIVITY:ROCK BTU/HR FT F")
25000 25 CONTINUE
25011 PRINT.
25012 PRINT.
25015 PRINT, "-----"
25021 PRINT.
25022 PRINT.
25109 PRINT.
25110 PRINT, "PLANT MW-DAYS,(THEO): OPERATING MWT?"
25111 READ, MWDAYS, POPER
25153 IF (POPER.LE.0.0) GO TO 64
25210 ENG = MWDAYS * 24.0 * 3.413E+06
25211 IF (ENG.LE.0.0) GO TO 64
25220 MBED = ENG/(CPBK*DTAIR)
25225 MBEDTN = MBED/2000.
25230 RHOBED = (1.-F)*RHORK
25240 UOLBED = MBED/RHOBED
25310 QAIR = 3.413E+06*POPER
25320 WAIR = QAIR/(CPBR*DTAIR)
25330 ZPER = (MBED*CPBK)/(WAIR*CPBR)
27060 PRINT 531, MWDAYS
27061 531 FORMAT ("STORAGE FOR",F8.2," MW-DAYS, THEO ")
27080 PRINT 532, POPER
27081 532 FORMAT (F8.2, " MWT BED POWER RATE")
27110 PRINT 541, ENG
27111 541 FORMAT (1PE13.6, " THEO ENERGY STOR CAP, BTU")
27120 PRINT 542, MBED
27121 542 FORMAT (1PE13.6," MASS OF BED, LBM")
27125 PRINT 545, MBEDTN
27126 545 FORMAT (F13.2," MASS OF BED, TONS")
27130 PRINT 543, RHOBED
27131 543 FORMAT (F13.5, " MEAN BED DENSITY, LBM/FT3")
27140 PRINT 544, UOLBED
27141 544 FORMAT (1PE13.6, " BED VOLUME, FT3")
27210 PRINT 551, QAIR
27211 551 FORMAT (1PE13.6," HEAT RATE, BTU/HR")
27220 PRINT 552, WAIR
27221 552 FORMAT (1PE13.6," AIR FLOW RATE, LBM/HR")
27230 PRINT 553, ZPER
27231 553 FORMAT (F13.5," Z*PERIOD = MCP:RK/MCP:AIR HRS")
29500 30 CONTINUE
29980 PRINT.
29981 PRINT.

```


EMM003 CONTINUED

```
29982 PRINT,
29983 PRINT,
29985 PRINT, " = = = = = "
29986 PRINT, " - - - - - "
29989 PRINT,
29990 PRINT,
29991 PRINT,
30109 PRINT,
30110 PRINT, "BED DIAM (FT)?"
30111 READ, DBED
30130 IF (DBED.LE.0.0) GO TO 63
30160 LBED = (4./PI)*(UOLBED/DBED**2)
30210 PRINT 535, DBED, LBED, UOLBED
30211 535 FORMAT ("BED: D=",F7.1," FT  L=",F9.4,"  UOL=",1PE13.6," FT:
30300 ACRE = (PI/4.)*(DBED**2)/43560.
30400 PRINT 536, ACRE
30401 536 FORMAT (F13.5, " ACRES OF LAND AREA")
33000 33 CONTINUE
33109 PRINT,
33110 PRINT, "PARTICLE DIAM, INCH ?"
33111 READ, DPIN
33130 IF (DPIN.LE.0.0) GO TO 62
33150 DP = DPIN/12.
33210 ALPHA = 6.*(1.-E)/DP
33220 M1RK = (PI/6.)*(DP**3)*(RHOROK)
33230 NRK = MBED/M1RK
33240 A1RK = PI*(DP**2)
33241 A1RK = A1RK/OS
33250 ASTOT = NRK*A1RK
33260 AGRFL = (PI/4.)*(DBED**2)
33270 ANTFL = AGRFL*E
33280 GO = WAIR/AGRFL
33510 PRINT 561, DPIN
33511 561 FORMAT ("ROCK SIZE =",F12.6," INCH")
33513 PRINT,
33515 PRINT 570, M1RK, A1RK, OS
33516 570 FORMAT ("ONE ROCK: MS=",F9.7," LBM  A=",F9.7," FT2 FOR OS=",F1
33520 PRINT 562, ALPHA
33521 562 FORMAT (F13.5, " ALPHA = A: SURF/UOL  FT2/FT3")
33530 PRINT 563, NRK
33531 563 FORMAT (1PE13.6, " NUMBER OF ROCKS")
33540 PRINT 564, ASTOT
33541 564 FORMAT (1PE13.6, " TOTAL SURFACE AREA, FT2")
33550 PRINT 565, AGRFL
33551 565 FORMAT (1PE13.6, " SUPERFICIAL FLOW AREA, FT2")
33560 PRINT 566, ANTFL
33561 566 FORMAT (1PE13.6, " NET FLOW AREA, FT2")
33570 PRINT 567, GO
33571 567 FORMAT (F13.5, " W/A SUPERFICIAL,  LBM/HR FT2")
39000C  - - - - -
```

EMM003 CONTINUED

```
39210 KDX = 7.7*KRK/DP
40110 DO 200 I = 1,2
41120 UO(I) = GO/RHO(I)
41130 UOS(I) = UO(I)/3600.
41135 US(I) = UOS(I)/E
41150 TTRANS(I) = LBED/US(I)
43111 Z1 = (LBED/GO)*(200.*(1.-E)**2)/(E**3)
43121 Z2 = (LBED/GO)*(2.33*(1.-E))/(E**3)
43210 DELPL(I) = Z1*MU(I)*UO(I)/((OS*DP)**2)
43220 DELPT(I) = Z2*PHO(I)*(UO(I)**2)/(OS*DP)
43310 DELP(I) = DELPL(I) + DELPT(I)
45140 RE(I) = DP*GO/MU(I)
45151 NU(I) = 0.5*(RE(I)**.7)
45180 H(I) = NU(I)*K(I)/DP
45190 HAC(I) = H(I)*ASTOT
45510 UR(I) = (1./H(I)) + (1./KDX)
45520 U(I) = 1./UR(I)
45530 UAC(I) = U(I)*ASTOT
46110 PFN(I) = DELP(I)*WAIR/(RHO(I)*EFF)
46120 PFHP(I) = PFN(I)/(550.*3600.)
46130 PFKW(I) = PFN(I)/(778.16*3413.)
48999 200 CONTINUE
49110 UABR = (UA(1)+UA(2))/2.
49150 NTU = UABR/(WAIR*CPBR)
50101 PRINT,
50110 PRINT, "          HOT          COLD"
50120 PRINT 511, T(1), T(2)
50140 PRINT 584, UOS(1), UOS(2)
50141 584 FORMAT (F13.6,F13.6," SUPERFICIAL VELOCITY, FT/SEC")
50150 PRINT 585, US(1), US(2)
50151 585 FORMAT (F13.6,F13.6," AVERAGE VELOCITY, FT/SEC")
50160 PRINT 586, TTRANS(1), TTRANS(2)
50161 586 FORMAT (F13.3,F13.3," FLOW TRANSIT TIME, SEC")
50210 PRINT 601, RE(1), RE(2)
50211 601 FORMAT (F13.4,F13.4," REYNOLDS NO.")
50240 PRINT 604, NU(1), NU(2)
50241 604 FORMAT (F13.4,F13.4," NUSSELT, NU = .5*RE**.7")
50250 PRINT 605, H(1), H(2)
50251 605 FORMAT (F13.4,F13.4," H: HT TRANS COEFF, BTU/HR FT2 F")
50260 PRINT 621, KDX, KDX
50261 621 FORMAT (F13.4,F13.4," K/DX EFF OF ROCK, BTU/HR FT2 F")
50270 PRINT 622, U(1), U(2)
50271 622 FORMAT (F13.4,F13.4," U: OVERALL HT TRNS COEFF, BTU/HR FT2 F")
50280 PRINT 623, HAC(1), HAC(2)
50281 623 FORMAT (1PE13.6,1PE13.6," HA:BED BTU/HR F")
50290 PRINT 624, UA(1), UA(2)
50291 624 FORMAT (1PE13.6,1PE13.6," UA:BED BTU/HR F")
50295 PRINT 625, UABR
50296 625 FORMAT (" ",1PE13.6," UA:AUG, BTU/HR F")
50300 PRINT 626, NTU
```

EMM003 CONTINUED

```
50301 626 FORMAT (" ",F13.4," NTU")
50310 PPINT 611, DELPL(1), DELPL(2)
50311 611 FORMAT (F13.5,F13.5," DEL P: LAMIN PSF")
50320 PRINT 612, DELPT(1), DELPT(2)
50321 612 FORMAT (F13.5,F13.5," DEL P: TURBT PSF")
50330 PRINT 613, DELP(1), DELP(2)
50331 613 FORMAT (F13.5,F13.5," TOTAL DELTA PRESS PSF")
50360 PPINT 616, PFKW(1), PFKW(2)
50361 616 FORMAT (F13.3,F13.3," FAN POWER, KW")
50400 PRINT 619, EFFPCT
50401 619 FORMAT (" FAN EFF =",F5.1," %")
59990C -----
60100 61 GO TO 33
60200 62 GO TO 30
60300 63 GO TO 25
60400 64 CONTINUE
99999 END
```

APPENDIX G

CALCULATIONAL
OUTPUT

G-1

POROSITY E, SPHERICITY OS ?
INPUT:20091

? .39, .8

T(HOT), T(COLD) =?
INPUT:20101
? 1100, 600

ENG = 190 MW_{days}

POW = 286 MW_t

$\epsilon = 0.39$

$\phi = 0.80$

T:HOT = 1100.0 T:COLD = 600.0 F
DEL TEMP = 500.0 F

AIR PROPERTIES:

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
0.265840	0.249440	CP: AIR BTU/LBM F
0.092232	0.072792	VISCOSITY: AIR LBM/HR FT
0.025427	0.037425	DENSITY: AIR LBM/FT3
0.731036	0.728037	PRANDTL: AIR
0.900837	0.899603	PR**1/3
0.033540	0.024940	CONDUCTIVITY: AIR BTU/HR FT F

AUG AIR CP = 0.257057 BTU/LBM F

✓ ROCK PROPERTIES:

0.2500	CP(ROCK)	BTU/LBM F
165.000	DENSITY OF SOLID ROCK,	LBM/FT3
100.650	MEAN BED DENSITY,	LBM/FT3
0.390	POROSITY	
0.800	SPHERICITY	
1.000	CONDUCTIVITY: ROCK	BTU/HR FT F

PLANT MW-DAYS,(THEO): OPERATING MNT?

INPUT:25111

? 190, 286

STORAGE FOR 190.00 MW-DAYS, THEO

286.00	MNT BED POWER RATE
1.556328E+10	THEO ENERGY STOR CAP, BTU
1.245062E+08	MASS OF BED, LBM
62253.00	MASS OF BED, TONS
100.65000	MEAN BED DENSITY, LBM/FT3
1.237021E+06	BED VOLUME, FT3
9.761180E+08	HEAT RATE, BTU/HR
7.594574E+06	AIR FLOW RATE, LBM/HR
15.94406	Z*PERIOD = MCP:RK/WCP:AIR HRS

=====

INPUT: 30111
? 225

N272TI000003

A 54

BED: D= 225.0 FT L= 31.1116 UOL= 1.237021E+06 FT3
0.91278 ACRES OF LAND AREA

D = 225'

PARTICLE DIAM, INCH ?
INPUT: 33111
? 1

d = 1.0"

D = 225'

G-2

ROCK SIZE = 1.000000 INCH

ONE ROCK: MS=0.0499964 LBM A=0.0272708 FT2 FOR OS= 0.800
43.92000 ALPHA = A: SURF/UOL FT2/FT3
2.490304E+09 NUMBER OF ROCKS
6.791249E+07 TOTAL SURFACE AREA, FT2
3.976078E+04 SUPERFICIAL FLOW AREA, FT2
1.550670E+04 NET FLOW AREA, FT2
191.00667 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
2.086630	1.417705	SUPERFICIAL VELOCITY, FT/SEC
5.350333	3.635142	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
172.5781	218.6672	REYNOLDS NO.
18.4018	21.7179	NUSSELT, NU = .5*RE**.7
7.4064	6.4997	H: HT TRANS COEFF, BTU/HR FT2 F
92.4000	92.4000	K/OX EFF OF ROCK, BTU/HR FT2 F
6.8567	6.0726	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
5.029837E+08	4.414138E+08	HA: BED BTU/HR F
4.656587E+08	4.124039E+08	UA: BED BTU/HR F
4.390313E+08		UA: AVG, BTU/HR F
	224.8864	NTU
14.59223	7.82464	DEL P: LAMIN PSF
33.47630	26.14170	DEL P: TURBT PSF
53.06853	33.96634	TOTAL DELTA PRESS PSF
7957.441	3460.395	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT: 33111
? .75

ROCK SIZE = 0.750000 INCH

d = 0.75"

ONE ROCK: MS=0.0210922 LBM A=0.0153398 FT2 FOR OS= 0.800
58.55000 ALPHA = A: SURF/UOL FT2/FT3
5.902942E+09 NUMBER OF ROCKS
9.054999E+07 TOTAL SURFACE AREA, FT2
3.976078E+04 SUPERFICIAL FLOW AREA, FT2
1.550670E+04 NET FLOW AREA, FT2
191.00667 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
2.086630	1.417705	SUPERFICIAL VELOCITY, FT/SEC
5.350333	3.635142	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
129.4336	164.0004	REYNOLDS NO.
15.0454	17.7567	NUSSELT, NU = .5*RE**.7
8.0739	7.0856	H: HT TRANS COEFF, BTU/HR FT2 F
123.2000	123.2000	K/OX EFF OF ROCK, BTU/HR FT2 F
7.5774	6.7003	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
7.310958E+08	6.416028E+08	HA: BED BTU/HR F
6.861301E+08	6.067091E+08	UA: BED BTU/HR F
6.464196E+08		UA: AVG, BTU/HR F
	331.1175	NTU
25.94174	13.91047	DEL P: LAMIN PSF
51.30174	34.85560	DEL P: TURBT PSF
77.24348	48.76607	TOTAL DELTA PRESS PSF
11582.390	4968.150	FAN POWER, KW

PARTICLE DIAM, INCH ?
INPUT: 33111
? .5

N2721100003

Pg 55

ROCK SIZE = 0.50000 INCH

d=0.5"

ONE ROCK: MS=0.0062496 LBM A=0.0068177 FT2 FOR DS= 0.800
87.84000 ALPHA = A: SURF/UOL FT2/FT3
1.992243E+10 NUMBER OF ROCKS
1.358250E+08 TOTAL SURFACE AREA, FT2
3.976078E+04 SUPERFICIAL FLOW AREA, FT2
1.550670E+04 NET FLOW AREA, FT2
191.00667 W/A SUPERFICIAL, LBM/HR FT2

D=225'

G-3

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
2.086630	1.417705	SUPERFICIAL VELOCITY, FT/SEC
5.350333	3.635142	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
86.2890	109.3336	REYNOLDS NO.
11.3276	13.3690	NUSSELT, NU = .5*RE**.7
9.1183	8.0021	H: HT TRANS COEFF, BTU/HR FT2 F
184.8000	184.8000	K/DX EFF OF ROCK, BTU/HR FT2 F
8.6895	7.6700	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
1.238491E+09	1.086888E+09	HA: BED BTU/HR F
1.180255E+09	1.041777E+09	UA: BED BTU/HR F
1.111016E+09	UA: AVG, BTU/HR F	
569.0996	NTU	
58.36891	31.29855	DEL P: LAMIN PSF
76.95261	52.28341	DEL P: TURBT PSF
135.32152	83.58195	TOTAL DELTA PRESS PSF
20290.990	8515.094	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INP: 33111
? 1.25

ROCK SIZE = 1.25000 INCH

d=1.25"

ONE ROCK: MS=0.0976492 LBM A=0.0426106 FT2 FOR DS= 0.800
35.13600 ALPHA = A: SURF/UOL FT2/FT3
1.275035E+09 NUMBER OF ROCKS
5.433000E+07 TOTAL SURFACE AREA, FT2
3.976078E+04 SUPERFICIAL FLOW AREA, FT2
1.550670E+04 NET FLOW AREA, FT2
191.00667 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
2.086630	1.417705	SUPERFICIAL VELOCITY, FT/SEC
5.350333	3.635142	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
215.7226	273.3340	REYNOLDS NO.
21.5128	25.3896	NUSSELT, NU = .5*RE**.7
6.9268	6.0789	H: HT TRANS COEFF, BTU/HR FT2 F
73.9200	73.9200	K/DX EFF OF ROCK, BTU/HR FT2 F
6.3333	5.6170	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
3.763318E+08	3.302653E+08	HA: BED BTU/HR F
3.440885E+08	3.051694E+08	UA: BED BTU/HR F
3.246290E+08	UA: AVG, BTU/HR F	
166.2857	NTU	
9.33903	5.00777	DEL P: LAMIN PSF
30.78104	20.91336	DEL P: TURBT PSF
40.12007	25.92113	TOTAL DELTA PRESS PSF
6015.864	2640.772	FAN POWER, KW

FAN EFF = 75.0 %

9 56

BED: D= 250.0 FT L= 25.2004 VOL= 1.237021E+06 FT3
1.12689 ACRES OF LAND AREA

PARTICLE DIAM. INCH ?
INPUT: 33111
? 1

ROCK SIZE = 1.000000 INCH d = 1.0"

G-4

ONE ROCK: MS=0.0499964 LBM A=0.0272708 FT2 FOR DS= 0.800
43.92000 ALPHA = A: SURF/VOL FT2/FT3
2.490304E+09 NUMBER OF ROCKS
6.791249E+07 TOTAL SURFACE AREA, FT2
4.908739E+04 SUPERFICIAL FLOW AREA, FT2
1.914408E+04 NET FLOW AREA, FT2
154.71540 W/A SUPERFICIAL, LBM/HR FT2

D = 250'

HOT	COLD	TEMP: AIR, F
1100.0	600.0	1.148341 SUPERFICIAL VELOCITY, FT/SEC
1.690170	1.148341	2.944465 AVERAGE VELOCITY, FT/SEC
4.333770	2.944465	8.559 FLOW TRANSIT TIME, SEC
5.815	8.559	177.1204 REYNOLDS NO.
139.7893	177.1204	19.7395 NUSSELT, NU = .5*RE**0.7
15.9791	19.7395	5.6084 H: HT TRANS COEFF, BTU/HR FT2 F
6.3906	5.6084	92.4000 K/DX EFF OF ROCK, BTU/HR FT2 F
92.4000	92.4000	5.2874 U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
5.9772	5.2874	4.340037E+08 HA: BED BTU/HR F
4.340037E+08	3.808776E+08	4.059286E+08 UA: BED BTU/HR F
4.059286E+08	3.590825E+08	3.825056E+08 UA: AVG, BTU/HR F
3.825056E+08	195.9320	195.9320 NTU
195.9320	9.57396	5.13374 DEL P: LAMIN PSF
9.57396	5.13374	13.89277 DEL P: TURBT PSF
20.44789	13.89277	19.02652 TOTAL DELTA PRESS PSF
30.02185	19.02652	1938.368 FAN POWER, KW
4501.671	1938.368	

AN EFF = 75.0 %

PARTICLE DIAM. INCH ?
INPUT: 33111
? .75

ROCK SIZE = 0.750000 INCH d = 0.75"

ONE ROCK: MS=0.0210922 LBM A=0.0153398 FT2 FOR DS= 0.800
59.56000 ALPHA = A: SURF/VOL FT2/FT3
5.902942E+09 NUMBER OF ROCKS
9.054999E+07 TOTAL SURFACE AREA, FT2
4.908739E+04 SUPERFICIAL FLOW AREA, FT2
1.914408E+04 NET FLOW AREA, FT2
154.71540 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	TEMP: AIR, F
1100.0	600.0	1.148341 SUPERFICIAL VELOCITY, FT/SEC
1.690170	1.148341	2.944465 AVERAGE VELOCITY, FT/SEC
4.333770	2.944465	8.559 FLOW TRANSIT TIME, SEC
5.815	8.559	132.8403 REYNOLDS NO.
104.8412	132.8403	15.3215 NUSSELT, NU = .5*RE**0.7
12.9820	15.3215	6.1139 H: HT TRANS COEFF, BTU/HR FT2 F
6.9667	6.1139	123.2000 K/DX EFF OF ROCK, BTU/HR FT2 F
123.2000	123.2000	5.8248 U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
6.5938	5.8248	6.308322E+08 HA: BED BTU/HR F
6.308322E+08	5.536124E+08	5.970693E+08 UA: BED BTU/HR F
5.970693E+08	5.274379E+08	5.622536E+08 UA: AVG, BTU/HR F
5.622536E+08	288.0049	288.0049 NTU
288.0049	17.02037	9.12666 DEL P: LAMIN PSF
17.02037	17.02037	18.52370 DEL P: TURBT PSF
27.26385	18.52370	27.65035 TOTAL DELTA PRESS PSF
44.28422	27.65035	

PARTICLE DIAM, INCH ?
INPUT:33111
? .5

N272TI000003

pg. 57

ROCK SIZE = 0.50000 INCH $d = 0.5''$

ONE ROCK: MS=0.0062496 LBM A=0.0068177 FT2 FOR DS= 0.800
87.84000 ALPHA = A: SURF/UOL FT2/FT3
1.992243E+10 NUMBER OF ROCKS
1.358250E+08 TOTAL SURFACE AREA, FT2
4.908739E+04 SUPERFICIAL FLOW AREA, FT2
1.914408E+04 NET FLOW AREA, FT2
154.71540 W/A SUPERFICIAL, LBM/HR FT2

D = 250'

6.5

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.690170	1.148341	SUPERFICIAL VELOCITY, FT/SEC
4.333770	2.944465	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
69.8941	98.5602	REYNOLDS NO.
9.7741	11.5355	NUSSELT, NU = .5*RE**.7
7.3678	6.9047	H: HT TRANS COEFF, BTU/HR FT2 F
184.8000	184.8000	K/OX EFF OF ROCK, BTU/HR FT2 F
7.5465	6.6560	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
1.068642E+09	9.378307E+08	HA: BED BTU/HR F
1.025003E+09	9.040525E+08	UA: BED BTU/HR F
9.645279E+08		UA: AVG, BTU/HR F
494.0632		NTU
38.29584	20.53498	DEL P: LAMIN PSF
40.89577	27.78555	DEL P: TURBT PSF
79.19161	48.32052	TOTAL DELTA PRESS PSF
11874.506	4922.759	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT:33111
? 1.25

ROCK SIZE = 1.25000 INCH $d = 1.25''$

ONE ROCK: MS=0.0976492 LBM A=0.0426106 FT2 FOR DS= 0.800
35.13600 ALPHA = A: SURF/UOL FT2/FT3
1.275035E+09 NUMBER OF ROCKS
5.433000E+07 TOTAL SURFACE AREA, FT2
4.908739E+04 SUPERFICIAL FLOW AREA, FT2
1.914408E+04 NET FLOW AREA, FT2
154.71540 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.690170	1.148341	SUPERFICIAL VELOCITY, FT/SEC
4.333770	2.944465	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
174.7353	221.4005	REYNOLDS NO.
18.5625	21.9076	NUSSELT, NU = .5*RE**.7
5.9768	5.2452	H: HT TRANS COEFF, BTU/HR FT2 F
73.9200	73.9200	K/OX EFF OF ROCK, BTU/HR FT2 F
5.5297	4.8977	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
3.247211E+08	2.849722E+08	HA: BED BTU/HR F
3.004297E+08	2.660909E+08	UA: BED BTU/HR F
2.832603E+08		UA: AVG, BTU/HR F
145.0953		NTU
6.12733	3.28560	DEL P: LAMIN PSF
16.35831	11.11422	DEL P: TURBT PSF
22.48564	14.39981	TOTAL DELTA PRESS PSF
3371.644	1467.013	FAN POWER, KW

FAN EFF = 75.0 %

DEL DATA: 1120
INPUT: 30111
? 275

N272TI000003

Pg. 58

BED: D= 275.0 FT L= 20.8268 VOL= 1.237021E+06 FT3
1.36354 ACRES OF LAND AREA

PARTICLE DIAM, INCH ?
INPUT: 33111
? 1

ROCK SIZE = 1.000000 INCH

d = 1.0"

D = 275'

ONE ROCK: MS=0.0499964 LBM A=0.0272708 FT2 FOR DS= 0.800
43.32000 ALPHA = A: SURF/VOL FT2/FT3
2.490304E+09 NUMBER OF ROCKS
6.791249E+07 TOTAL SURFACE AREA, FT2
5.939574E+04 SUPERFICIAL FLOW AREA, FT2
2.316434E+04 NET FLOW AREA, FT2
127.86397 W/A SUPERFICIAL, LBM/HR FT2

G-6

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.396835	0.949042	SUPERFICIAL VELOCITY, FT/SEC
3.581628	2.433442	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
115.5275	146.3805	REYNOLDS NO.
13.8947	16.3987	NUSSELT, NU = .5*RE**.7
5.5923	4.9078	H: HT TRANS COEFF, BTU/HR FT2 F
92.4000	92.4000	K/DX EFF OF ROCK, BTU/HR FT2 F
5.2732	4.6603	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
3.797902E+08	3.333003E+08	HA: BED BTU/HR F
3.581158E+08	3.164900E+08	UA: BED BTU/HR F
3.373029E+08	UA: AVG, BTU/HR F	
172.7777	NTU	
6.53914	3.50642	DEL P: LAMIN PSF
11.54230	7.842w11	DEL P: TURBT PSF
18.08144	11.34852	TOTAL DELTA PRESS PSF
2711.249	1156.156	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT: 33111
? .75

ROCK SIZE = 0.750000 INCH

d = 0.75"

ONE ROCK: MS=0.0210922 LBM A=0.0153398 FT2 FOR DS= 0.800
58.56000 ALPHA = A: SURF/VOL FT2/FT3
5.902942E+09 NUMBER OF ROCKS
9.054999E+07 TOTAL SURFACE AREA, FT2
5.939574E+04 SUPERFICIAL FLOW AREA, FT2
2.316434E+04 NET FLOW AREA, FT2
127.86397 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.396835	0.949042	SUPERFICIAL VELOCITY, FT/SEC
3.581628	2.433442	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
86.6456	109.7854	REYNOLDS NO.
11.3604	13.4076	NUSSELT, NU = .5*RE**.7
6.0964	5.3502	H: HT TRANS COEFF, BTU/HR FT2 F
123.2000	123.2000	K/DX EFF OF ROCK, BTU/HR FT2 F
5.8090	5.1275	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
5.520318E+08	4.844579E+08	HA: BED BTU/HR F
5.260030E+08	4.642951E+08	UA: BED BTU/HR F
4.951491E+08	UA: AVG, BTU/HR F	
253.6318	NTU	
11.82514	6.23363	DEL P: LAMIN PSF
15.38973	10.45614	DEL P: TURBT PSF
27.01488	16.68977	TOTAL DELTA PRESS PSF
4050.786	1700.307	FAN POWER, KW

6

PARTICLE DIAM, INCH ?
INPUT: 33111
? .50

N272TI000003

P. 59

ROCK SIZE = 0.500000 INCH $d = 0.5''$

ONE ROCK: MS=0.0062496 LBM A=0.0068177 FT2 FOR DS= 0.800
87.84000 ALPHA = A: SURF/VOL FT2/FT3
1.992243E+10 NUMBER OF ROCKS
1.359250E+08 TOTAL SURFACE AREA, FT2
5.939574E+04 SUPERFICIAL FLOW AREA, FT2
2.316434E+04 NET FLOW AREA, FT2
127.86397 W/A SUPERFICIAL, LBM/HR FT2

D = 275'

G-7

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
1.396835	0.949042	SUPERFICIAL VELOCITY, FT/SEC
3.581628	2.433442	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
57.7637	73.1903	REYNOLDS NO.
8.5532	10.0946	NUSSELT, NU = .5*RE**0.7
6.8850	6.0422	H: HT TRANS COEFF, BTU/HR FT2 F
184.8000	184.8000	K/DX EFF OF ROCK, BTU/HR FT2 F
6.6377	5.8509	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
9.351531E+08	8.206816E+08	HA: BED BTU/HR F
9.015640E+08	7.946982E+08	UA: BED BTU/HR F
8.481311E+08	UA: AVG, BTU/HR F	
434.4409	NTU	
26.15658	14.02567	DEL P: LAMIN PSF
23.08460	15.68422	DEL P: TURBT PSF
49.24117	29.70988	TOTAL DELTA PRESS PSF
7383.542	3026.759	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT: 33111
? 1.25

ROCK SIZE = 1.250000 INCH $d = 1.25''$

ONE ROCK: MS=0.0976492 LBM A=0.0426106 FT2 FOR DS= 0.800
35.13600 ALPHA = A: SURF/VOL FT2/FT3
1.275035E+09 NUMBER OF ROCKS
5.433000E+07 TOTAL SURFACE AREA, FT2
5.939574E+04 SUPERFICIAL FLOW AREA, FT2
2.316434E+04 NET FLOW AREA, FT2
127.86397 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
1.396835	0.949042	SUPERFICIAL VELOCITY, FT/SEC
3.581628	2.433442	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
144.4094	182.9756	REYNOLDS NO.
16.2438	19.1710	NUSSELT, NU = .5*RE**0.7
5.2302	4.5900	H: HT TRANS COEFF, BTU/HR FT2 F
73.9200	73.9200	K/DX EFF OF ROCK, BTU/HR FT2 F
4.8846	4.3217	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
2.841585E+08	2.493749E+08	HA: BED BTU/HR F
2.653814E+08	2.347954E+08	UA: BED BTU/HR F
2.500884E+08	UA: AVG, BTU/HR F	
128.1036	NTU	
4.18505	2.24411	DEL P: LAMIN PSF
9.23384	6.27369	DEL P: TURBT PSF
13.41889	8.51779	TOTAL DELTA PRESS PSF
2012.116	867.769	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
 INPUT: 33111
 ? .375

ROCK SIZE = 0.375000 INCH $d = 0.375''$

ONE ROCK: MS=0.0026365 LBM A=0.0038350 FT2 FOR DS= 0.800
 117.12000 ALPHA = A: SURF/VOL FT2/FT3
 4.722353E+10 NUMBER OF ROCKS
 1.811000E+08 TOTAL SURFACE AREA, FT2
 5.939574E+04 SUPERFICIAL FLOW AREA, FT2
 2.316434E+04 NET FLOW AREA, FT2
 127.86397 W/A SUPERFICIAL, LBM/HR FT2

D = 275'

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
1.396835	0.949042	SUPERFICIAL VELOCITY, FT/SEC
3.581628	2.433442	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
43.3228	54.8927	REYNOLDS NO.
6.9931	8.2533	NUSSELT, NU = .5*RE**.7
7.5056	6.5868	H: HT TRANS COEFF, BTU/HR FT2 F
246.4000	246.4000	K/DX EFF OF ROCK, BTU/HR FT2 F
7.2837	6.4153	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
1.359262E+09	1.192875E+09	HA: BED BTU/HR F
1.319081E+09	1.151817E+09	UA: BED BTU/HR F
1.240449E+09	UA: AVG, BTU/HR F	
635.3992	NTU	
46.50058	24.93452	DEL P: LAMIN PSF
30.77946	20.91229	DEL P: TURB PSF
77.28004	45.84680	TOTAL DELTA PRESS PSF
11587.873	4670.743	FAN POWER, KW

FAN EFF = 75.0 %

INPUT:30111
? 300

N2721100003

Pg. 61

BED: D= 300.0 FT L= 17.5003 VOL= 1.237021E+06 FT3
1.62272 ACRES OF LAND AREA

PARTICLE DIAM, INCH ?
INPUT:33111
? 1

ROCK SIZE = 1.00000 INCH d=1.0" D=300'

ONE ROCK: MS=0.0499964 LBM A=0.0272708 FT2 FOR DS= 0.800
43.92000 ALPHA = A: SURF/VOL FT2/FT3
2.490304E+09 NUMBER OF ROCKS
6.791249E+07 TOTAL SURFACE AREA, FT2
7.068583E+04 SUPERFICIAL FLOW AREA, FT2
2.756748E+04 NET FLOW AREA, FT2
107.44125 W/A SUPERFICIAL, LBM/HR FT2

G-9

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.173729	0.797459	SUPERFICIAL VELOCITY, FT/SEC
3.009562	2.044767	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
97.0752	123.0003	REYNOLDS NO.
12.3012	14.5179	NUSSELT, NU = .5*RE**.7
4.9510	4.3449	H: HT TRANS COEFF, BTU/HR FT2 F
92.4000	92.4000	K/DX EFF OF ROCK, BTU/HR FT2 F
4.6992	4.1498	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
3.362325E+08	2.950745E+08	HA:BED BTU/HR F
3.191328E+08	2.818224E+08	UA:BED BTU/HR F
3.004776E+08	UA:AVG, BTU/HR F	
153.9146	NTU	
4.61707	2.47576	DEL P: LAMIN PSF
6.84796	4.65266	DEL P: TURBT PSF
11.46503	7.12843	TOTAL DELTA PRESS PSF
1719.141	726.224	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT:33111
? .75

ROCK SIZE = 0.75000 INCH d=0.75"

ONE ROCK: MS=0.0210922 LBM A=0.0153398 FT2 FOR DS= 0.800
58.56000 ALPHA = A: SURF/VOL FT2/FT3
5.902942E+09 NUMBER OF ROCKS
9.054999E+07 TOTAL SURFACE AREA, FT2
7.068583E+04 SUPERFICIAL FLOW AREA, FT2
2.756748E+04 NET FLOW AREA, FT2
107.44125 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	TEMP: AIR, F
1100.0	600.0	
1.173729	0.797459	SUPERFICIAL VELOCITY, FT/SEC
3.009562	2.044767	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
72.8064	92.2502	REYNOLDS NO.
10.0575	11.8699	NUSSELT, NU = .5*RE**.7
5.3972	4.7366	H: HT TRANS COEFF, BTU/HR FT2 F
123.2000	123.2000	K/DX EFF OF ROCK, BTU/HR FT2 F
5.1707	4.5612	U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
4.887200E+08	4.288961E+08	HA:BED BTU/HR F
4.682083E+08	4.130171E+08	UA:BED BTU/HR F
4.406127E+08	UA:AVG, BTU/HR F	
225.6964	NTU	
8.20813	4.40136	DEL P: LAMIN PSF
9.13061	6.20355	DEL P: TURBT PSF
17.33874	10.60491	TOTAL DELTA PRESS PSF
2599.882	1080.798	FAN POWER, KW

PARTICLE DIAM, INCH ?
INPUT: 33111
? .5

N272TI000003

Py. 62

ROCK SIZE = 0.50000 INCH

d = 0.5"

ONE ROCK: MS=0.0062496 LBM A=0.0068177 FT2 FOR DS= 0.800
87.94000 ALPHA = A: SURF/VOL FT2/FT3
1.992243E+10 NUMBER OF ROCKS
1.358250E+08 TOTAL SURFACE AREA, FT2
7.068583E+04 SUPERFICIAL FLOW AREA, FT2
2.756748E+04 NET FLOW AREA, FT2
107.44125 W/A SUPERFICIAL, LBM/HR FT2

D = 300'

HOT	COLD	TEMP: AIR, F
1100.0	600.0	0.797459 SUPERFICIAL VELOCITY, FT/SEC
1.173729	0.797459	2.044767 AVERAGE VELOCITY, FT/SEC
3.009562	2.044767	8.559 FLOW TRANSIT TIME, SEC
5.815	8.559	61.5001 REYNOLDS NO.
48.5376	61.5001	8.9368 NUSSELT, NU = .5*RE**.7
7.5722	8.9368	5.3492 H: HT TRANS COEFF, BTU/HR FT2 F
6.0954	5.3492	184.8000 K/DX EFF OF ROCK, BTU/HR FT2 F
184.8000	184.8000	5.1987 U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
5.9007	5.1987	8.279016E+08 HA: BED BTU/HR F
8.279016E+08	7.265587E+08	8.014664E+08 UA: BED BTU/HR F
8.014664E+08	7.061193E+08	7.537929E+08 UA: AUG, BTU/HR F
7.537929E+08	UA: AUG, BTU/HR F	386.1177 NTU
386.1177	NTU	18.46829 DEL P: LAMIN PSF
18.46829	9.90306	13.69591 DEL P: TURBT PSF
13.69591	9.30532	32.16420 TOTAL DELTA PRESS PSF
32.16420	19.20838	4822.909 FAN POWER, KW
4822.909	1956.895	

FAN EFF = 75.0 %

G-10

PARTICLE DIAM, INCH ?
INPUT: 33111
? .375

ROCK SIZE = 0.37500 INCH

d = .375"

ONE ROCK: MS=0.0026365 LBM A=0.0038350 FT2 FOR DS= 0.800
117.12000 ALPHA = A: SURF/VOL FT2/FT3
4.722353E+10 NUMBER OF ROCKS
1.811000E+08 TOTAL SURFACE AREA, FT2
7.068583E+04 SUPERFICIAL FLOW AREA, FT2
2.756748E+04 NET FLOW AREA, FT2
107.44125 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	TEMP: AIR, F
1100.0	600.0	0.797459 SUPERFICIAL VELOCITY, FT/SEC
1.173729	0.797459	2.044767 AVERAGE VELOCITY, FT/SEC
3.009562	2.044767	8.559 FLOW TRANSIT TIME, SEC
5.815	8.559	46.1251 REYNOLDS NO.
36.4032	46.1251	7.3068 NUSSELT, NU = .5*RE**.7
6.1911	7.3068	5.8314 H: HT TRANS COEFF, BTU/HR FT2 F
6.6448	5.8314	246.4000 K/DX EFF OF ROCK, BTU/HR FT2 F
246.4000	246.4000	5.6966 U: OVERALL HT TRNS COEFF, BTU/HR FT2 F
6.4703	5.6966	1.203369E+09 HA: BED BTU/HR F
1.203369E+09	1.056066E+09	1.171770E+09 UA: BED BTU/HR F
1.171770E+09	1.031650E+09	1.101710E+09 UA: AUG, BTU/HR F
1.101710E+09	UA: AUG, BTU/HR F	564.3325 NTU
564.3325	NTU	32.83251 DEL P: LAMIN PSF
32.83251	17.60543	18.26121 DEL P: TURBT PSF
18.26121	12.40710	51.09373 TOTAL DELTA PRESS PSF
51.09373	30.01253	7661.326 FAN POWER, KW
7661.326	3057.592	

FAN EFF = 75.0 %

? 325 BED DIAM

N272TI000003

Pg. 63

BED: D= 325.0 FT L= 14.9115 VOL= 1.237021E+06 FT3
1.90445 ACRES OF LAND AREA

PARTICLE DIAM, INCH ?
INPUT: 33111
? 1

D = 325'

ROCK SIZE = 1.000000 INCH d = 1.0"

ONE ROCK: MS=0.0499964 LBM A=0.0272708 FT2 FOR OS= 0.800
43.92000 ALPHA = A: SURF/VOL FT2/FT3
2.490304E+09 NUMBER OF ROCKS
6.791249E+07 TOTAL SURFACE AREA, FT2
8.295768E+04 SUPERFICIAL FLOW AREA, FT2
3.235350E+04 NET FLOW AREA, FT2
91.54757 W/A SUPERFICIAL, LBM/HR FT2

G-11

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
1.000101	0.679492	SUPERFICIAL VELOCITY, FT/SEC
2.564361	1.742287	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
82.7149	104.8050	REYNOLDS NO.
10.9971	12.9789	NUSSELT, NU = .5*RE**0.7
4.4261	3.8843	H: HT TRANS COEFF, BTU/HR FT2 F
92.4000	92.4000	K/DX EFF OF ROCK, BTU/HR FT2 F
4.2238	3.7276	U: OVERALL HT TRANS COEFF, BTU/HR FT2 F
3.005888E+08	2.637939E+08	HA: BED BTU/HR F
2.868483E+08	2.531519E+08	UA: BED BTU/HR F
2.700001E+08		UA: AVG, BTU/HR F
138.3030		NTU
3.35211	1.79747	DEL P: LAMIN PSF
4.23632	2.87825	DEL P: TURBT PSF
7.58843	4.67572	TOTAL DELTA PRESS PSF
1137.858	476.349	FAN POWER, KW

FAN EFF = 75.0 %

PARTICLE DIAM, INCH ?
INPUT: 33111
? .75

ROCK SIZE = 0.750000 INCH d = 0.75"

ONE ROCK: MS=0.0210922 LBM A=0.0153398 FT2 FOR OS= 0.800
58.56000 ALPHA = A: SURF/VOL FT2/FT3
5.902942E+09 NUMBER OF ROCKS
9.054999E+07 TOTAL SURFACE AREA, FT2
8.295768E+04 SUPERFICIAL FLOW AREA, FT2
3.235350E+04 NET FLOW AREA, FT2
91.54757 W/A SUPERFICIAL, LBM/HR FT2

HOT	COLD	
1100.0	600.0	TEMP: AIR, F
1.000101	0.679492	SUPERFICIAL VELOCITY, FT/SEC
2.564361	1.742287	AVERAGE VELOCITY, FT/SEC
5.815	8.559	FLOW TRANSIT TIME, SEC
62.0362	78.6037	REYNOLDS NO.
8.9913	10.6116	NUSSELT, NU = .5*RE**0.7
4.8251	4.2344	H: HT TRANS COEFF, BTU/HR FT2 F
123.2000	123.2000	K/DX EFF OF ROCK, BTU/HR FT2 F
4.6432	4.0937	U: OVERALL HT TRANS COEFF, BTU/HR FT2 F
4.369112E+08	3.834291E+08	HA: BED BTU/HR F
4.204446E+08	3.706884E+08	UA: BED BTU/HR F
3.955665E+08		UA: AVG, BTU/HR F
202.6223		NTU
5.95931	3.19550	DEL P: LAMIN PSF
5.64842	3.83767	DEL P: TURBT PSF
11.60773	7.03317	TOTAL DELTA PRESS PSF
1740.570	716.519	FAN POWER, KW

PARTICLE DIAM, INCH ?
INPUT:33111
? .5

N272T1000003

pg. 64

ROCK SIZE = 0.50000 INCH $d = 0.5''$

ONE ROCK: MS=0.0062496 LBM A=0.0068177 FT2 FOR OS= 0.800
87.84000 ALPHA = A/SURF/UOL FT2/FT3
1.992243E+10 NUMBER OF ROCKS
1.358250E+08 TOTAL SURFACE AREA, FT2
8.295768E+04 SUPERFICIAL FLOW AREA, FT2
3.235350E+04 NET FLOW AREA, FT2
91.54757 W/A SUPERFICIAL, LBM/HR FT2

D = 325'

HOT		COLD		TEMP: AIR, F	
1100.0	600.0	0.679492	1.742287	1100.0	600.0
1.000101	0.679492	1.742287	8.559	1.000101	0.679492
2.564361	1.742287	8.559	52.4025	2.564361	1.742287
5.815	8.559	52.4025	7.9894	5.815	8.559
41.3575	52.4025	7.9894	4.7822	41.3575	52.4025
6.7695	7.9894	4.7822	184.8000	6.7695	7.9894
5.4492	4.7822	184.8000	4.6615	5.4492	4.7822
184.8000	184.8000	4.6615	6.495368E+08	184.8000	184.8000
5.2931	4.6615	6.495368E+08	6.331524E+08	5.2931	4.6615
7.401364E+08	6.495368E+08	6.331524E+08	6.760447E+08	7.401364E+08	6.495368E+08
7.189371E+08	6.331524E+08	6.760447E+08	346.2925	7.189371E+08	6.331524E+08
6.760447E+08	6.760447E+08	346.2925	13.40844	6.760447E+08	6.760447E+08
346.2925	346.2925	13.40844	8.47263	346.2925	346.2925
13.40844	7.18987	8.47263	21.88107	13.40844	7.18987
8.47263	5.75650	21.88107	3280.990	8.47263	5.75650
21.88107	12.94637	3280.990		21.88107	12.94637
3280.990	1318.940			3280.990	1318.940

FAN EFF = 75.0 %

G-12


PARTICLE DIAM, INCH ?
INPUT:33111
? .375

ROCK SIZE = 0.37500 INCH $d = 0.375''$

ONE ROCK: MS=0.0026365 LBM A=0.0038350 FT2 FOR OS= 0.800
117.12000 ALPHA = A/SURF/UOL FT2/FT3
4.722353E+10 NUMBER OF ROCKS
1.811000E+08 TOTAL SURFACE AREA, FT2
8.295768E+04 SUPERFICIAL FLOW AREA, FT2
3.235350E+04 NET FLOW AREA, FT2
91.54757 W/A SUPERFICIAL, LBM/HR FT2

HOT		COLD		TEMP: AIR, F	
1100.0	600.0	0.679492	1.742287	1100.0	600.0
1.000101	0.679492	1.742287	8.559	1.000101	0.679492
2.564361	1.742287	8.559	39.3019	2.564361	1.742287
5.815	8.559	39.3019	6.5322	5.815	8.559
31.0181	39.3019	6.5322	5.2132	31.0181	39.3019
5.5348	6.5322	5.2132	246.4000	5.5348	6.5322
5.9404	5.2132	246.4000	5.1052	5.9404	5.2132
246.4000	246.4000	5.1052	9.441133E+08	246.4000	246.4000
5.8005	5.1052	9.441133E+08	9.245520E+08	5.8005	5.1052
1.075801E+09	9.441133E+08	9.245520E+08	9.875140E+08	1.075801E+09	9.441133E+08
1.050475E+09	9.245520E+08	9.875140E+08	505.8374	1.050475E+09	9.245520E+08
9.875140E+08	9.875140E+08	505.8374	23.83723	9.875140E+08	9.875140E+08
505.8374	505.8374	23.83723	11.29684	505.8374	505.8374
23.83723	12.78198	11.29684	35.13407	23.83723	12.78198
11.29684	7.67534	35.13407	5268.231	11.29684	7.67534
35.13407	20.45732	5268.231		35.13407	20.45732
5268.231	2084.134			5268.231	2084.134

FAN EFF = 75.0 %

PREPARED BY: <u>E. W.</u>	 Rockwell International Atomics International Division	PAGE NO. <u>65</u> OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO. <u>H-1</u>

APPENDIX H
MATERIAL PROPERTIES

AIR: (Ref. 8, 9)

$$C_p \left(\frac{\text{BTU}}{\text{lb}_m \cdot ^\circ\text{F}} \right) = 0.239 + 0.90 \times 10^{-5} T + 0.14 \times 10^{-7} T^2$$

$$\bar{C}_p = \frac{\int_{c_p dT}}{\int dT} = 0.239 + \frac{0.90 \times 10^{-5}}{2} (T_{\text{HOT}} - T_{\text{COLD}}) + \frac{0.14 \times 10^{-7}}{3} (T_{\text{HOT}}^2 + T_{\text{HOT}} T_{\text{COLD}} + T_{\text{COLD}}^2)$$

$$\mu \left(\frac{\text{lb}_m}{\text{hr ft}} \right) = 0.03996 + 0.6336 \times 10^{-4} T - 0.144 \times 10^{-7} T^2$$

$$k \left(\frac{\text{BTU}}{\text{hr ft } ^\circ\text{F}} \right) = 0.0133 + 0.206 \times 10^{-4} T - 0.2 \times 10^{-8} T^2$$

$$\rho \left(\frac{\text{lb}_m}{\text{ft}^3} \right) = 39.65874 / (T + 459.69) \quad (\text{at } 14.696 \text{ psia}).$$

$$Pr = \frac{C_p \mu}{k} \quad T = ^\circ\text{F}$$

ROCK: (Ref. 5) $P_0 = 200$

$$C_p \left(\frac{\text{BTU}}{\text{lb}_m \cdot ^\circ\text{F}} \right) = 0.25$$

$$\rho \left(\frac{\text{lb}_m}{\text{ft}^3} \right) = 165 \quad (\text{No Voids})$$

$$k \left(\frac{\text{BTU}}{\text{hr ft } ^\circ\text{F}} \right) = 1.0$$

APPENDIX H
A COMPARISON OF ALTERNATIVE WAYS OF RECOVERING
THE HYDRAULIC HEAD FROM THE ADVANCED
SOLAR RECEIVER TOWER

CONTENTS

	<u>Page</u>
I. INTRODUCTION.....	1
II. SUMMARY CONCLUSIONS AND RECOMMENDATIONS.....	3
A. Summary of Alternate Schemes.....	3
B. Recommendations.....	3
III. DISCUSSION.....	5
A. General.....	5
B. Alternate Systems.....	5
1. Elevated Hot Tank.....	5
2. Elevated Cold Tank.....	5
3. Parallel Storage Tanks.....	8
4. Reduced Downcomer Diameter.....	8
5. Sodium Turbo Pump Addition.....	8
6. Jet Pump Addition.....	12
7. Addition of Magnetohydrodynamic Generator.....	14
8. Helical Rotor Generator Addition.....	14
IV. CONCLUSIONS.....	19
V. REFERENCES.....	20

FIGURES

<u>Figure</u>		<u>Page</u>
1.	Reference Design.....	2
2.	Two Loops with IHX.....	4
3.	Elevated Hot Storage Tank.....	6
4.	Elevated Cold Storage Tank.....	7
5.	Parallel Storage Tanks.....	9
6.	Reduced Downcomer Diameter.....	10
7.	Addition of Turbo Pump.....	11
8.	Addition of Jet Pumps.....	13
9.	Addition of Magnetohydrodynamic Generator.....	15
10.	Na ac Magnetohydrodynamic Generator.....	16
11.	Helical Rotor Generator Addition.....	17
12.	Helical Rotor Generator.....	18

I. INTRODUCTION

The reference design is shown in Figure 1. In this design, the hot and cold storage tank ullages are at atmospheric pressure. The expansion tank liquid level elevation is 221 m (724 ft) above the average level in the storage tanks. The energy represented by this elevation difference is dissipated in the drag valve during operation. The idealized hydraulic energy converted into heat in the drag valve is approximately 2.2 Mw. This energy is supplied by the Receiver Pump P-1 and represents about 18% of the hotel load or 2.2% of net plant output.

All of this energy is not wasted since about 43% of it is reconverted back into electricity in the plant cycle. What remains to be recovered is 57% of 2.2 Mw or 1.25 Mw.

The purpose of this study is to compare the cost effectiveness of alternate ways of accomplishing this recovery and to make a recommendation for the selection of one of them for the short term and indicate if additional improvement might be possible in the longer term with additional development work.




FIGURE 1
REFERENCE DESIGN

II. SUMMARY CONCLUSIONS AND RECOMMENDATIONS

An earlier trade study (Reference 1) examined the possibility of recovering the head by utilizing a high-pressure loop and a low-pressure loop thermally coupled by a heat exchanger (Figure 2). It was determined that the value of the power savings was less than the cost of the heat exchanger. This system was judged not cost effective. An additional eight other methods were examined. These schemes, their summary evaluation, and recommendations are as follows.

A. SUMMARY OF ALTERNATE SCHEMES

<u>Scheme</u>	<u>Result</u>
1. Elevated Hot Tank	Not cost effective
2. Elevated Cold Tank	Not cost effective
3. Parallel Storage Tanks	Not cost effective
4. Reduced Downcomer Diameter	Net savings $\$0.6 \times 10^6$
5. Sodium Turbo Pump Addition	Net savings $\$0.8 \times 10^6$
6. Jet Pump Addition	Net savings $\$0.85 \times 10^6$
7. Magnetohydrodynamic (MHD) Addition	Net savings $\$1.2 \times 10^6$
8. Helical Rotor Generator Addition	Net savings $\$1.2 \times 10^6$

B. RECOMMENDATIONS

For the near term, Scheme 4 is recommended with Scheme 6 as the "fallback" scheme.

For the long term, Scheme 7 is the recommended approach and Scheme 8 the "fallback" scheme.




FIGURE 2
TWO LOOPS WITH IHX

III. DISCUSSION

A. GENERAL

The rough cost estimates given include factors for capital costs, operating and maintenance costs, and changes in the plant capacity factor.

B. ALTERNATE SYSTEMS

1. Elevated Hot Tank (Figure 3)

By elevating the hot storage tank by 61 m (200 ft), it is possible to eliminate the P-2 pump and the power required to operate it. The cost savings derive from decreasing the auxiliary power requirements and eliminating the cost of the P-2 pump. The estimated savings are $\$0.53 \times 10^6$ due to plant size reduction, $\$0.64 \times 10^6$ due to an improvement in plant capacity factor, and $\$0.5 \times 10^6$ due to eliminating the pump. The total is approximately $\$1.67 \times 10^6$. The additional cost of the tower to support the tank at the 61-m (200-ft) level is estimated (Reference 2) at $\$1.75 \times 10^6$. The added tank support cost is estimated at $\$0.5 \times 10^6$ for a total additional cost of $\$2.25 \times 10^6$. The operational aspects of this arrangement are excellent; however, because of the higher cost, it is considered to be not cost effective.

2. Elevated Cold Tank (Figure 4)

By elevating the cold tank 85 m (280 ft), it is possible to divide the tower head between the two Pumps P-1 and P-2. This arrangement allows the P-1 pump to be changed from a two-stage design to a single-stage design and divides the engineering, QA, and spare parts costs between the two. The savings accruing from the commonality are estimated at approximately $\$0.5 \times 10^6$. From the Case 1 cost estimate for elevating the tank, it is clear that this scheme is not cost effective.




FIGURE 3
ELEVATED HOT STORAGE TANK




FIGURE 4
ELEVATED COLD STORAGE TANK

3. Parallel Storage Tanks (Figure 5)

In this scheme, the storage system is bypassed on direct operation, thus, all of the available tower head is conserved. The energy savings is 1.2 MWe which translates into approximately 1.2×10^6 of capital cost on plant size reduction and approximately 0.5×10^6 (the pump will be running on standby) due to improved capacity factor for a total savings of 1.7×10^6 . To retain the feature of being able to operate from storage while charging to storage simultaneously requires that the P-2 pump develop the same head as the P-1 pump. The additional cost for this change is estimated at 0.5×10^6 (P-1 pump cost less P-2 pump loss, less the pump commonality, savings of 0.5×10^6 , see Scheme 2). An additional cost for control valves to regulate this together with the control system is estimated at 1.0×10^6 . The net savings is about 0.2×10^6 . However, the thermal buffering benefit of the large sodium storage tanks is lost. It is judged that this benefit is worth more than the cost saving, thus, this system is judged not cost effective.

4. Reduced Downcomer Diameter (Figure 6)

In this scheme, the pipe velocity limit is increased to 17 m/sec (56 ft/sec) (this velocity limit is greater than "conventional practice" for sodium flowing in pipes but less than sodium pump velocity practice of 60 m/sec [200 ft/sec] or sodium jet pump successful experience 20 m/sec [65 ft/sec], Reference 3.) The savings are obtained by reducing downcomer pipe diameter. The savings on the installed downcomer pipe is approximately 0.5×10^6 . The drag valve savings is approximately 0.1×10^6 for a total savings of 0.6×10^6 . This approach appears cost effective.

5. Sodium Turbo Pump Addition (Figure 7)

In this scheme, a sodium driver turbine is installed in the downcomer which drives a directly connected pump located in the riser. This pump acts as a booster pump in series with the P-1 pump. The arrangement decreased the peak power requirement by approximately 1.81 MWe, however,




FIGURE 5
PARALLEL STORAGE TANKS




FIGURE 6
REDUCED DOWNCOMER DIAMETER




FIGURE 7
ADDITION OF TURBO PUMP

it is only effective down to about 70% of flow because of the fact that the power of the turbine under throttled operation decreases as the cube of the flow. In addition, full credit cannot be taken for the 1.81 MWe. Approximately 43% of this is recoverable as heat energy which can be reconverted to electricity in the conventional part of the plant. The effective power savings amounts to 0.66 MWe which improves the plant capacity factor, resulting in a reduction in the levelized bus bar cost of 0.446 mils/kWh. This is the equivalent of $\$0.8 \times 10^6$ of capital outlay. The reduction in plant size at peak load is 1.0 MWe. This reduction in auxiliary power capacity is worth approximately $\$1 \times 10^6$. The total installed cost for this equipment is estimated at $\$1.0 \times 10^6$. Thus, the net savings is approximately $\$0.8 \times 10^6$. This system is cost effective if the sodium turbopump component can be installed as a developed item. Maintenance of this unit requires entrance into the sodium system.

6. Jet Pump Addition (Figure 8)

This scheme is similar to Scheme 3 except that the storage capacity is coupled to the loop through the jet pumps which function automatically except at startup when the P-2 pump bypass line is used to "bootstrap" the system into operation. As shown in the figure, Jet Pump 2 is driven by the downcomer head and provides a high inlet pressure for the centrifugal pump. This arrangement functions as a two-stage pump which raises the outlet pressure of the P-2 pump. The higher outlet pressure increment is transferred through the steam generators and supplies the driving head for Jet Pump 1. The output head of Jet Pump 1 adds to the head of the P-1 centrifugal pump. Because of the relatively low efficiency of the jet pump, the expected savings in power will be no more than 0.746 MWe (1000 hp) (Reference 4) but additional benefits accrue since the tower lift can be shared between the two centrifugal pumps as in Scheme 2. This is similar in function to the turbo pumped system but with less hydraulic efficiency. The jet pumps are simpler mechanically. They have no moving parts and, thus, should have a higher reliability. The expected savings are estimated to be $\$0.42 \times 10^6$ due to plant size reduction and $\$0.34 \times 10^6$ due to capacity factor improvement. Pump simplification and commonality savings amount to $\$0.5 \times 10^6$. The cost of the jet pumps is estimated at




FIGURE 8
ADDITION OF JET PUMPS

$\$0.1 \times 10^6$. The net savings is $\$0.85 \times 10^6$. Sodium jet pumps are considered to be existing technology. This system appears to be cost effective.

7. Addition of Magnetohydrodynamic Generator (Figures 9 and 10)

In this scheme, an alternating current liquid metal magnetohydrodynamic (MHD) induction generator replaces the drag valve. This device acts like an electromagnetic brake on the system and converts the tower head to ac power. It would be operated in the constant voltage mode with flow control affected by varying the load on the unit. The electrical conversion efficiency is similar to the Scheme 5 turbo pump except that the unit operates over the entire flow range. The effective electrical savings is 1.0 MWe or 0.67 mills/kWh due to the improvement in capacity factor. This is equivalent to $\$1.2 \times 10^6$ of capital outlay. There is also a reduction in plant size due to reducing the auxiliary power requirements. This unit also replaces the drag valve which is estimated at $\$0.5 \times 10^6$. The total savings is $\$2.7 \times 10^6$. The estimated cost of the unit is $\$1.5 \times 10^6$. The net savings is then $\$1.2 \times 10^6$. This system is cost effective provided that the unit is installed as a developed item. The system has no moving parts and the stator can be designed to be removable for repairs without entering the sodium system (Figure 8).

8. Helical Rotor Generator Addition (Figures 11 and 12)

In this scheme, a helical rotor generator replaces the drag valve. The unit can generate direct current power which is converted to ac power or ac power directly if a variable speed coupling is used. The technology is similar to that of the helical rotor pumps, Reference 6. The economics are similar to those of the MHD unit and appears cost effective provided it is installed as a developed item. The electrical part of this component operates in air and may be removed for maintenance without cutting into the sodium system. It operates at low speed (~5 rps), thus, generating low frequencies which lead to low electrical losses in the flow passage walls. This in turn permits increasing this wall thickness to standard tube dimensions and should enhance reliability.




FIGURE 9
ADDITION OF MAGNETOHYDRODYNAMIC GENERATOR

16




FIGURE 10
Na AC MAGNETOHYDRODYNAMIC GENERATOR





FIGURE 11
HELICAL ROTOR GENERATOR ADDITION

**CUTAWAY VIEW OF HELICAL-ROTOR
ELECTROMAGNETIC GENERATOR
WITH ANNULAR FLOW PASSAGE**



**FIGURE 12
HELICAL ROTOR GENERATOR**

IV. CONCLUSIONS

The scheme that represents the least departure from the reference system that is cost effective is Scheme 4. This scheme should require no R&D and should save at least $\$0.6 \times 10^6$. It would appear to be the best short-term choice. An alternate candidate is the jet pump scheme which also requires no R&D and is cost effective.

For a longer range approach requiring some R&D, the MHD generator appears to be the most cost effective. The helical rotor generator appears as attractive but does involve rotating parts and would be expected to show a lower reliability than the MHD unit.

V. REFERENCES

1. Lorin L. Vant-Hull, Gerry Coleman, Tom Springer, Jerry Friefeld, "Liquid Metal Cooled Solar Central Receiver Feasibility Study and Heliostat Field Analysis," ORO 5178-78-1, UG62, p. 5-11, 1977
2. Stearns-Roger Letter C-20325-13 dated February 17, 1978, A. W. McKensie to Tom Springer, "Central Receiver Tower Study Advanced Central Receiver Power System"
3. D. A. Manner, "Effects of Long Term Exposure on Materials in the Sodium Reactor Experiment," AI-66-53, 1966, p. 33-37
4. IL dated May 11, 1978, J. O. Pfouts to L. E. Glasgow, "Use of Jet Pumps in a Solar Collector System"
5. T. C. Wang and S. J. Dudzinsky, "Theoretical and Experimental Study of a Liquid Metal MHD Induction Generator," AIAA Journal 5, p. 107-112, 1967
6. R. S. Baker, "Theory, Design and Performance of the Helical-Rotor Electromagnetic Pump," NAA-SR-7455-1963

tmf:518

20

APPENDIX I
CENTRAL RECEIVER TOWER STUDY

REPLY	
REPLY DUE	
REMARKS	Encls. to Springer
ANDERSON, S.H.	
ASBOTH	
BALENT	
BARNSHAW	
BATES	
BINDLEY	
BIRNBAUM	
BURMAN, J.C.	
DEGRAM DATA	
DAY	
HAWFORD	
FLOS PRADOS	
STIERMAN	
STAND	
TILFER	
YLFE	
ARTZLER	
EINE	
ILLIG	
CLBROOK	
SCRELLIS	
ACOBSON, J.	
INES, G.	
JIT	
FATL	
WZER	
CLIN	
ANTIN, A.B.	
ECOURT	
DEHMOT	
DONALD, J.S.	
KENZIE, D.E.	
EVERS, G.W.	
DREWIZ	
EDENKAMP	
WIKER, T.	
WIKINS	
FAILEY	
FRICKER	
WIDERS	
THIMM	
ALTER, J.H.	
WELLER	
SENECK	
SPRINGER	
WATZ	
SLASPER	
W. Johnson	
T. Johnson	
W. Johnson	
W. Johnson	
W. Johnson	



RECEIVED

FEB 21 1978

February 17, 1978

Correspondence Dept.

Atomics International Division
 Rockwell International
 8900 DeSota Avenue
 Canoga Park, California 91304

Re: C-20325-13

Attention: Tom Springer
 Project Manager

Subject: Central Receiver Tower Study
 Advanced Central Receiver Power System

Reference: AI Contract N311-0002 FX
 DOE Contract EG-77-C-03-1483

Dear Tom:

Enclosed herewith please find the results of our central receiver tower sensitivity analysis recently completed. The following data is enclosed:

1. Receiver tower model with design criteria used in the analysis, dated February 6, 1978, including the following tables of results:

- Table 1 - Tower and Mat Dimensions
- Table 2 - Dynamic Response (Seismic)
- Table 3 - Tower and Mat Material Quantity

2. Plot of tower cost vs. tower height and receiver weight, dated February 14, 1978.
3. Cost Estimates for the sixteen tower height and receiver weight combinations considered.

Please be advised that the results of this study shows the relative cost of towers vs. tower height for various receiver weights; however we have not attempted to optimize tower cost for any specific tower height/receiver weight combination.

2144A

Atomics International Division
Canoga Park, California 91403
ATTN: Tom Springer

February 17, 1978

Please let us know if you have any questions, or require additional information.

Very truly yours,

STEARNS-ROGER ENGINEERING CO.


A. W. McKenzie
A. W. McKenzie
Project Engineer

AWMc/vr

Enclosure

cc: (w/encl.)
G. C. Coleman - MDAC
W. R. Lang
R. E. Williamson
J. R. Linger/R. J. Colasanti
A. W. McKenzie
R. K. Jones/Job File

JOB NO. C 20325 DATE 2-17-78 BY AWM CHK
CUSTOMER ATOMIC INT'L PROJECT ADVANCED CENTRAL RECEIVER
SUBJECT AFFECT OF RECEIVER WEIGHT ON TOWER DIRECT COST



JOB NO. 20325


DATE 2/6/78

BY RJC

CHK

CUSTOMER ATOMICS INTERNAT'L PROJECT ADVANCED CENTRAL RECEIVER

SUBJECT RECEIVER TOWER



TOWER HEIGHT, METERS	DIMENSIONS, FT.*	RECEIVER WEIGHT, KIPS			
		0	500	1500	3000
100	DTT	20.0	20.0	20.0	20.0
	DTB	53.0	53.0	53.0	53.0
	TTT	0.5833	0.5833	0.8333	1.0
	TTB	0.9167	0.9167	1.25	1.5
	D _{MO}	90.0	90.0	100.0	106.0
	D _{MI}	0.0	0.0	0.0	0.0
	T _M	8.0	8.0	9.0	10.0
200	DTT	40.0	40.0	40.0	40.0
	DTB	106.0	106.0	106.0	106.0
	TTT	0.8333	0.8333	1.0	1.25
	TTB	1.5	1.5	1.875	2.25
	D _{MO}	160.0	160.0	168.0	170.0
	D _{MI}	52.0	52.0	44.0	42.0
	T _M	11.0	11.0	11.0	14.0
300	DTT	60.0	60.0	60.0	60.0
	DTB	159.0	159.0	159.0	159.0
	TTT	1.0	1.0	1.125	1.25
	TTB	2.0	2.0	2.25	2.5
	D _{MO}	220.0	220.0	224.0	230.0
	D _{MI}	98.0	98.0	94.0	88.0
	T _T	15.0	15.0	15.0	15.0
400	DTT	80.0	80.0	80.0	80.0
	DTB	212.0	212.0	212.0	212.0
	TTT	1.25	1.25	1.25	1.25
	TTB	2.5833	2.5833	2.5833	2.5833
	D _{MO}	284.0	284.0	284.0	284.0
	D _{MI}	140.0	140.0	140.0	140.0
	T _M	15.0	15.0	15.0	15.0

*Refer to Figure 1

TABLE 1

ADVANCED CENTRAL RECEIVER - JOB NO. 20325
TOWER AND MAT DIMENSIONS

STEARNS-ROGER
FEBRUARY 6, 1978

TOWER HEIGHT METERS	PARAMETER	RECEIVER WEIGHT, KIPS*			
		0	500	1500	3000
100	Fund. Hor. Freq., Hz	1.25	0.83	0.62	0.50
	Rcv. Hor. Accel., G's	1.35	0.73	0.49	0.39
	Rcv. Hor. Defl., In.	4.61	6.18	7.36	8.75
	Fund. Vert. Freq., Hz	10.49	8.77	7.34	6.23
	Rcv. Vert. Accel., G's	0.86	0.90	0.85	0.81
	Rcv. Vert. Defl., In.	0.07	0.11	0.14	0.19
200	Fund. Hor. Freq., Hz	0.65	0.59	0.53	0.47
	Rcv. Hor. Accel., G's	1.39	1.48	0.96	0.71
	Rcv. Hor. Defl., In.	10.43	12.29	12.71	13.30
	Fund. Vert. Freq., Hz	5.36	5.20	5.00	4.74
	Rcv. Vert. Accel., G's	1.08	1.09	1.10	1.09
	Rcv. Vert. Defl., In.	0.32	0.35	0.38	0.42
300	Fund. Hor. Freq., Hz	0.44	0.43	0.41	0.38
	Rcv. Hor. Accel., G's	1.26	1.89	1.38	1.03
	Rcv. Hor. Defl., In.	16.66	19.26	19.68	20.09
	Fund. Vert. Freq., Hz	3.63	3.59	3.53	3.45
	Rcv. Vert. Accel., G's	1.22	1.21	1.22	1.21
	Rcv. Vert. Defl., In.	0.77	0.79	0.83	0.86
400	Fund. Hor. Freq., Hz	0.34	0.33	0.32	0.31
	Rcv. Hor. Accel., G's	1.21	2.09	1.70	1.26
	Rcv. Hor. Defl., In.	23.41	26.87	27.21	27.61
	Fund. Vert. Freq., Hz	2.74	2.72	2.70	2.66
	Rcv. Vert. Accel., G's	1.10	1.08	1.08	1.08
	Rcv. Vert. Defl., In.	1.12	1.12	1.14	1.16

*Accelerations and deflections for "zero-weight" receiver are referred to top of tower. Accelerations and deflections for 500, 1500 and 3000 kip receivers are referred to receiver centroid, assumed 0.08H above top of tower.

TABLE 2

ADVANCED CENTRAL RECEIVER - JOB NO. 20325
DYNAMIC RESPONSE (SEISMIC)

STEARNS-ROGER
FEBRUARY 6, 1978

TOWER HEIGHT, METERS	QUANTITY	RECEIVER WEIGHT, KIPS			
		0	500	1500	3000
100	Tower Concrete, cu yd	1057.9	1057.9	1452.9	1733.3
	Tower Steel, tons	66.0	75.8	118.4	161.5
	Mat Concrete, cu yd	1885.0	1885.0	2618.0	3268.4
	Mat Steel, tons	103.7	103.7	144.0	179.8
	Soil Excavation, cu yd	2719.033	2719.0	3714.0	4628.0
200	Tower Concrete, cu yd	6772.6	6772.6	8214.8	9930.6
	Tower Steel, tons	529.0	539.2	674.1	839.3
	Mat Concrete, cu yd	7326.2	7326.2	8411.6	11051.0
	Mat Steel, tons	402.9	402.9	462.6	607.8
	Soil Excavation, cu yd	10496.0	10496.0	11443.0	15354.0
300	Tower Concrete, cu yd	19483.0	19483.0	21881.5	24269.1
	Tower Steel, tons	1754.8	1772.7	2017.4	2247.5
	Mat Concrete, cu yd	16927.9	16927.9	18038.0	19703.0
	Mat Steel, tons	931.0	931.0	992.1	1083.7
	Soil Excavation, cu yd	23866.0	23866.0	24976.0	26641.0
400	Tower Concrete, cu yd	44372.8	44372.8	44372.8	44372.8
	Tower Steel, tons	3880.1	3884.4	3887.9	3874.7
	Mat Concrete, cu yd	26640.7	26640.7	26640.7	26640.7
	Mat Steel, tons	1465.2	1465.2	1465.2	1465.2
	Soil Excavation, cu yd	35891.0	35891.0	35891.0	35891.0

- NOTES: 1) Min. Concrete Strength shall be 4000 PSI Compressive Strength at 28 days.
 2) Reinforcing bars shall be new intermediate grade deformed bars which shall conform to ASTM 615 Grade 60.


TABLE 3

ADVANCED CENTRAL RECEIVER - JOB NO. 20325
 TOWER AND MAT MATERIAL QUANTITY

STEARNS-ROGER
 FEBRUARY 6, 1978

Stearns-Roger

JOB NO. 20325 DATE 2/14/78 BY GJP CHK.
 CUSTOMER ATOMICS INT'L PROJECT ADVANCED CENTRAL RECEIVER
 SUBJECT TOWER COST VS TOWER HEIGHT AND RECEIVER WEIGHT



CUSTOMER ATOMICS INTERNATIONAL PROP NO. _____
 LOCATION _____ JOB NO. 20325
 PROJECT ADVANCED CENTRAL RECEIVER DATE 2-6-78
(100 METERS HIGH / NONE KIPS) BY J. G. S. F.
 REV. NO. _____ REV. DATE _____ BY _____

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	SUBCONTRACT	TOTAL
A	EARTHWORK	462	5540	2800	1770	10110
B	CONCRETE	29037	438540	163090		601630
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	29499	444080	165890	1770	611740
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70% OF DIRECT LABOR			310855
	TOTAL FIELD COST					922595
J	ENGINEERING <u>BY OTHERS</u>					
	TOTAL FIELD & ENG COST					
Q	SALES TAX <u>4% OF MAT'L COST</u>					6635
R	PREMIUM PAY <u>NONE</u>					
	ESCALATION <u>CURRENT PRICES AND LABOR RATES</u>					
	CONTINGENCY <u>7 1/2% OF TOTAL FIELD COST PLUS SALES TAX;</u> <u>MINUS SUBCONTRACT</u>					69560
	SUB TOTAL					971770
Y	FEE <u>5% OF SUBTOTAL</u>					47945
	TOTAL					1044720

Stodrus-Roger

ORDER OF MAGNITUDE
ESTIMATE SUMMARY

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (100 METERS HEIGHT / 500 KIPS)	DATE	2-6-78
REV. NO.		REV. DATE	
		BY	J.W.F.

ACT	DESCRIPTION	EXACT QUANTITY	LABOR	MATERIAL	SUBCONTRACT	TOTAL
A	EARTHWORK	1462	5540	2800	1770	10110
B	CONCRETE	29137	440240	167490		607730
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	29579	445780	170290	1770	617840
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70% OF DIRECT LABOR			312045
	TOTAL FIELD COST					929885
J	ENGINEERING BY OTHERS					
	TOTAL FIELD & ENG. COST					
O	SALES TAX 4% OF MAT'L COST					6810
R	PREMIUM PAY NONE					
	ESCALATION CURRENT PRICES AND LABOR RATES					
	CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX					
	MINUS SUBCONTRACT					70120
	SUB TOTAL					1006815
Y	FEE 5% OF SUBTOTAL					50340
	TOTAL					1057155

CUSTOMER ATOMICS INTERNATIONAL PROP NO. _____
 LOCATION _____ JOB NO. 20325
 PROJECT ADVANCED CENTRAL RECEIVER DATE 2-6-78
(100 METERS HEIGHT / 1,500 KIPS) BY J. W. F.
 REV. NO. _____ REV. DATE _____ BY _____

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	SUBCONTRACT	TOTAL
A	EARTHWORK	612	7345	3600	2350	131295
B	CONCRETE	40429	61110	237630		848740
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	41041	168455	241230	2350	862035
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70% OF DIRECT LABOR			432920
	TOTAL FIELD COST					1294955
J	ENGINEERING <u>BY OTHERS</u>					
	TOTAL FIELD & ENG. COST					
O	SALES TAX <u>4% OF MAT'L COST</u>					9650
R	PREMIUM PAY <u>NONE</u>					
	ESCALATION <u>CURRENT PRICES AND LABOR RATES</u>					
	CONTINGENCY <u>7 1/2% OF TOTAL FIELD COST PLUS SALES TAX;</u> <u>MINUS SUBCONTRACT</u>					47670
	SUB TOTAL					1402275
Y	FEF <u>5% OF SUBTOTAL</u>					70115
	TOTAL					1472390

CUSTOMER <i>ATOMICS INTERNATIONAL</i>		PROP NO.					
LOCATION		JOB NO. <i>20325</i>					
PROJECT <i>ADVANCED CENTRAL RECEIVER</i>		DATE <i>2-13-78</i>					
<i>(200 METERS HEIGHT / NONE KIPS)</i>		BY <i>J.W.F.</i>					
REV. NO.	REV. DATE	BY					
ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL	
A	EARTHWORK	11750	21000	10400	6690	38090	
B	CONCRETE	149776	21260290	833050		3093340	
C	BUILDINGS & STRUCTURES						
D	PROCESS EQUIPMENT						
E	PIPING						
F	ELECTRICAL						
G	PAINTING						
L	PLANT ITEMS						
N	INSTRUMENTS & CONTROLS						
P	INSULATION						
DIRECT FIELD COST		151526	2281290	843450	6690	3131430	
H	FIELD EXPENSE						
H	ALL RISK, PR TAX, BOND						
K	CONSTRUCTION SUPPLIES						
M	STARTUP						
S	TEMPORARY FACILITIES						
V	CRAFT BENEFITS						
V	CONSTRUCTION CAMP.						
W	CONSTRUCTION EQUIP.						
INDIRECT FIELD COST			70% OF DIRECT LABOR			1556905	
TOTAL FIELD COST						4728335	
J	ENGINEERING <i>BY OTHERS</i>						
TOTAL FIELD & ENG. COST							
O	SALES TAX <i>4% OF MAT'L COST</i>					33740	
R	PREMIUM PAY <i>NONE</i>						
ESCALATION <i>CURRENT PRICES AND LABOR RATES</i>							
CONTINGENCY <i>7.5% C= TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT</i>						351655	
SUB TOTAL						5118730	
Y	FE <i>5% OF SUBTOTAL</i>					255935	
TOTAL						5374665	

Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J. W. F.
DATE 2-13-78

COUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOTAL
					UNIT	TOTAL	\$/Hr				
	<u>TOWER :</u>										
	<u>HEIGHT: 200 METERS</u>										
	<u>RECV. WT NONE KIPS</u>										
<u>A</u>	<u>SOIL EXCAVATION</u>	<u>10,496</u>	<u>CY</u>	<u>-</u>	<u>.08</u>	<u>840</u>	<u>12⁰⁰</u>	<u>10,080</u>	<u>-</u>	<u>4,090</u>	<u>14,170</u>
<u>A</u>	<u>BACK-FILL (COMPACTED STRU)</u>	<u>2,600</u>	<u>CY</u>	<u>4⁰⁰</u>	<u>.35</u>	<u>910</u>	<u>12⁰⁰</u>	<u>10,920</u>	<u>10,400</u>	<u>2,600</u>	<u>23,920</u>
<u>B</u>	<u>TOWER CONCRETE - $f'_c = 4000$ psi</u>	<u>6,773</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>11</u>	<u>74,503</u>	<u>15⁰⁰</u>	<u>1,117,545</u>	<u>203,190</u>		<u>1,320,735</u>
<u>B</u>	<u>TOWER STEEL - $f_y = GR. 60$</u>	<u>529</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>11</u>	<u>5,819</u>	<u>17⁰⁰</u>	<u>98,925</u>	<u>232,760</u>		<u>331,685</u>
<u>B</u>	<u>MAT CONCRETE - $f'_c = 4000$ psi</u>	<u>7,326</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>9</u>	<u>65,934</u>	<u>15⁰⁰</u>	<u>989,010</u>	<u>219,780</u>		<u>1,208,790</u>
<u>B</u>	<u>MAT STEEL - $f_y = GR. 60$</u>	<u>403</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>8</u>	<u>3,520</u>	<u>17⁰⁰</u>	<u>54,810</u>	<u>177,320</u>		<u>232,130</u>
						<u>119,771</u>		<u>2,000,000</u>	<u>832,050</u>		
	<u>TOTAL</u>					<u>157,526</u>		<u>2,281,290</u>	<u>843,450</u>	<u>6,690</u>	<u>3,131,430</u>

ESTIMATE SUMMARY

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER	DATE	2-13-78
	(200 METERS HEIGHT / 500 KIPS)	BY	J.W.J.
REV. NO.	REV. DATE	BY	

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	11750	211000	10400	6670	34090
B	CONCRETE	149592	2762195	837540		3097735
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		151342	21283195	847940	6670	3137825
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT LABOR			1598235
TOTAL FIELD COST						4736060
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
Q	SALES TAX 4% OF MAT'L COST					33720
R	PREMIUM PAY NONE					
ESCALATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						357245
SUB TOTAL						5127725
Y	ICC 5% OF SUBTOTAL					256260
TOTAL						5383985

ESTIMATE SUMMARY

CUSTOMER <i>ATOMICS INTERNATIONAL</i>		PROP NO.				
LOCATION		JOB NO. <i>20325</i>				
PROJECT <i>ADVANCED CENTRAL RECEIVER</i>		DATE <i>2-13-78</i>				
<i>(200 METERS HEIGHT / 1,500 KIPS)</i>		BY <i>J.W.F.</i>				
REV. NO.	REV. DATE	BY				
ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	<i>1930</i>	<i>23160</i>	<i>11600</i>	<i>7370</i>	<i>42130</i>
B	CONCRETE	<i>177219</i>	<i>2184525</i>	<i>999125</i>		<i>3679650</i>
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		<i>179149</i>	<i>21703680</i>	<i>11010725</i>	<i>7370</i>	<i>37211780</i>
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			<i>70% OF DIRECT LABOR</i>			<i>1892580</i>
TOTAL FIELD COST						<i>5614260</i>
J	ENGINEERING <i>BY OTHERS</i>					
TOTAL FIELD & ENG. COST						
O	SALES TAX <i>4% OF MAT'L COST</i>					<i>40420</i>
R	PREMIUM PAY <i>NONE</i>					
ESCALATION <i>CURRENT PRICES AND LABOR RATES</i>						
CONTINGENCY <i>7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT</i>						<i>418600</i>
SUB TOTAL						<i>6073370</i>
Y	IF <i>5% OF SUBTOTAL</i>					<i>303670</i>
TOTAL						<i>6377060</i>

Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J.W.F.
DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOTAL
					UNIT	TOTAL	\$/MH				
	TOWER :										
	HEIGHT : 200 METERS										
	RECV. WT 1,500 KIPS										
A	SOIL EXCAVATION	11,443	CY	-	.08	915	12 ⁰⁰	10,980	-	4,470	15,450
A	BACK-FILL (COMPACTED STRUCK)	2,900	CY	4 ⁰⁰	.35	1,015	12 ⁰⁰	12,180	11,600	2,900	26,680
						1,930				7,740	4,470
B	TOWER CONCRETE - $f'_c = 4000$ psi	8,215	CY	30 ⁰⁰	11	90,365	15 ⁰⁰	1,355,475	246,450		1,601,925
B	TOWER STEEL - $f_y = GR.60$	674.1	TONS	440 ⁰⁰	11	7,415	17 ⁰⁰	126,055	296,605		422,660
B	MAT CONCRETE - $f'_c = 4000$ psi	8,412	CY	30 ⁰⁰	9	75,735	15 ⁰⁰	1,136,025	252,350		1,388,375
B	MAT STEEL - $f_y = GR.60$	463	TONS	440 ⁰⁰	8	3,704	17 ⁰⁰	62,970	203,720		266,690
						177,214		7,005,000	707,250		7,712,250
TOTAL						179,149		2,703,685	1,010,725	7,370	3,721,780

ESTIMATE SUMMARY

CUSTOMER ATOMICS INTERNATIONAL	PROP NO.
LOCATION	JOB NO. 2032.5
PROJECT ADVANCED CENTRAL RECEIVER (200 METERS HEIGHT / 3,000 KIPS)	DATE 2-13-78
REV. NO.	BY J.W.F.
REV. DATE	BY

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	2558	30700	15200	9790	55690
B	CONCRETE	222796	3370140	1766270		4636410
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		225354	3400140	12811470	9790	4692100
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT LABOR			2380590
TOTAL FIELD COST						7072690
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
O	SALES TAX 4% OF MAT'L COST					51260
R	PREMIUM PAY NONE					
LEGISLATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						527340
SUBTOTAL						7651270
PROFIT 5% OF SUBTOTAL						382565
TOTAL						8033835

Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J. W. F.
DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOT
					UNIT	TOTAL	\$/MH				
	TOWER :										
	HEIGHT : 200 METERS										
	RECV. WT 3,000 KIPS										
A	SOIL EXCAVATION	15,354	CY	-	.08	1,228	12 ⁰⁰	14,740	-	5,990	20,730
A	BACK-FILL (COMPACTED STRUC)	3,800	CY	4 ⁰⁰	.35	1,330	12 ⁰⁰	15,960	15,200	3,800	34,960
						7,558		15,200			22,758
B	TOWER CONCRETE - $f'_c = 4000$ psi	9,931	CY	30 ⁰⁰	11	109,241	15 ⁰⁰	1,638,615	297,930		1,936,545
B	TOWER STEEL - $f_y = GR.60$	839.3	TONS	440 ⁰⁰	11	9,232	17 ⁰⁰	156,950	369,290		526,240
B	MAT CONCRETE - $f'_c = 4000$ psi	11,051	CY	30 ⁰⁰	9	99,459	15 ⁰⁰	1,491,885	331,530		1,823,415
B	MAT STEEL - $f_y = GR.60$	608	TONS	440 ⁰⁰	8	4,864	17 ⁰⁰	82,690	267,520		350,210
						712,740		1,266,270			1,978,980
	TOTAL					225,354		3,400,840	1,281,470	9,790	4,692,100

ESG-79-2, Vol II, Book 2
1-24

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (300 METERS HEIGHT / NONE KIPS)	DATE	2-13-78
REV. NO.		BY	J.W.F.
	REV. DATE	BY	

ACT	DESCRIPTION	CRAFT UNITS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	31974	47690	23600	15210	86500
B	CONCRETE	414656	6276355	2274170		8531025
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		418630	6324545	2297170	15210	8637525
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT LABOR			4427180
TOTAL FIELD COST						13064705
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
O	SALES TAX 4% OF MAT'L COST					91910
R	PREMIUM PAY NONE					
ESCALATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7.5% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						985605
SUB TOTAL						14142220
Y	FLC 5% OF SUBTOTAL					707110
TOTAL						14849330

Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J. W. F.
DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANIOURS			LABOR	MATERIAL	OTHER	TOT
					UNIT	TOTAL	\$/HH				
	<u>TOWER :</u>										
	<u>HEIGHT: 300 METERS</u>										
	<u>RECV. WT NONE KIPS</u>										
<u>A</u>	<u>SOIL EXCAVATION</u>	<u>23,866</u>	<u>CY</u>	<u>-</u>	<u>.08</u>	<u>1,909</u>	<u>12⁰⁰</u>	<u>22,910</u>	<u>-</u>	<u>9,310</u>	<u>32,220</u>
<u>A</u>	<u>BACK-FILL (COMPACTED STRUCK)</u>	<u>5,900</u>	<u>CY</u>	<u>4⁰⁰</u>	<u>.35</u>	<u>2,065</u>	<u>12⁰⁰</u>	<u>24,780</u>	<u>23,600</u>	<u>5,900</u>	<u>54,280</u>
<u>B</u>	<u>TOWER CONCRETE - $f'_c = 4000$ PSI</u>	<u>19,483</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>12</u>	<u>233,796</u>	<u>15⁰⁰</u>	<u>3,506,940</u>	<u>584,490</u>		<u>4,091,430</u>
<u>B</u>	<u>TOWER STEEL - $f_y = GR. 60$</u>	<u>1,755</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>12</u>	<u>21,060</u>	<u>17⁰⁰</u>	<u>358,020</u>	<u>772,200</u>		<u>1,130,220</u>
<u>B</u>	<u>MAT CONCRETE - $f'_c = 4000$ PSI</u>	<u>16,928</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>9</u>	<u>152,352</u>	<u>15⁰⁰</u>	<u>2,285,280</u>	<u>507,840</u>		<u>2,793,120</u>
<u>B</u>	<u>MAT STEEL - $f_y = GR. 60$</u>	<u>931</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>8</u>	<u>7,448</u>	<u>17⁰⁰</u>	<u>126,615</u>	<u>409,640</u>		<u>536,255</u>
						<u>47,651</u>		<u>6,115,555</u>	<u>2,274,170</u>		<u>8,389,725</u>
	<u>TOTAL</u>					<u>47,630</u>		<u>6,324,515</u>	<u>2,277,710</u>	<u>5,210</u>	<u>8,607,435</u>

ESG-79-2, Vol II, Book 2
1-26

CUSTOMER ATOMICS INTERNATIONAL

PROP NO.

LOCATION

JOB NO. 20325

PROJECT ADVANCED CENTRAL RECEIVER

DATE 2-13-78

(300 METERS HEIGHT / 500 KIPS)

BY J.W.F.

REV. NO.

REV. DATE

BY

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	3774	47690	23600	15210	86500
B	CONCRETE	414872	624525	2282090		8562615
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		418846	6328215	2305690	15210	8649115
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
T	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT LABOR			44291750
TOTAL FIELD COST						13078865
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
Q	SALESTAX 4% OF MAT'L COST					92230
R	PREMIUM PAY NONE					
ESCALATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						986190
SUB TOTAL						14157185
FEE 5% OF SUBTOTAL						707859
TOTAL						14865044

Stearns-Roger

INCORPORATED

CLIENT ATOMICS INTERNATIONAL
 ORDER NO. 20325 LOCATION _____

SHEET NO. 1
 BY J.W.F.
 DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOT
					UNIT	TOTAL	\$/NH				
	TOWER :										
	HEIGHT : 300 METERS										
	RECV. WT 500 KIPS										
A	SOIL EXCAVATION	23,866	CY	-	.08	1,909	12 ⁰⁰	22,910	-	9,310	32,2
A	BACK-FILL (COMPACTED STRUC)	5,900	CY	4 ⁰⁰	.35	2,065	12 ⁰⁰	24,780	23,600	5,900	54,
B	TOWER CONCRETE - $f'_c = 4000$ psi	19,483	CY	30 ⁰⁰	12	233,716	15 ⁰⁰	3,506,940	584,490		4,091
B	TOWER STEEL - $f_y = GR.60$	1,773	TONS	440 ⁰⁰	12	21,276	17 ⁰⁰	361,690	780,120		1,141
B	MAT CONCRETE - $f'_c = 4000$ psi	16,928	CY	30 ⁰⁰	9	152,352	15 ⁰⁰	2,285,280	507,840		2,792
B	MAT STEEL - $f_y = GR.60$	931	TONS	440 ⁰⁰	8	7,448	17 ⁰⁰	126,615	409,640		536
						418,846		6,328,215	2,305,690	15,210	8,644
	TOTAL										

ESG-79-2, Vol II, Book 2
 1-28

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (300 METERS HEIGHT / 1,500 KIPS)	DATE	2-13-78
REV. NO.		REV. DATE	
		BY	J.W.F.

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	41168	50015	241800	15945	70760
B	CONCRETE	457073	6920385	2521825		9442210
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		461241	6970400	2546625	15945	9532970
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT LABOR			4879280
TOTAL FIELD COST						14412250
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
D	SALES TAX 4% OF MAT'L COST					101865
R	PREMIUM PAY NONE					
ESCALATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						1087365
SUB TOTAL						15601460
Y	FE 5% OF SUBTOTAL					780075
TOTAL						16381535

Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL
 ORDER NO. 20325 LOCATION _____

SHEET NO. 1
 BY J. W. F.
 DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS						
					UNIT	TOTAL	\$/MH	LABOR	MATERIAL	OTHER	TOT.
	<u>TOWER :</u>										
	<u>HEIGHT : 300 METERS</u>										
	<u>RECV. WT 1,500 KIPS</u>										
<u>A</u>	<u>SOIL EXCAVATION</u>	<u>24,976</u>	<u>CY</u>	<u>-</u>	<u>.08</u>	<u>1,998</u>	<u>12⁰⁰</u>	<u>23,975</u>	<u>-</u>	<u>9,745</u>	<u>33,720</u>
<u>A</u>	<u>BACK-FILL (COMPACTED STRUC)</u>	<u>6,200</u>	<u>CY</u>	<u>4⁰⁰</u>	<u>.35</u>	<u>2,170</u>	<u>12⁰⁰</u>	<u>26,040</u>	<u>24,800</u>	<u>6,200</u>	<u>57,040</u>
<u>B</u>	<u>TOWER CONCRETE - $f'_c = 4000$ psi</u>	<u>21,882</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>12</u>	<u>262,584</u>	<u>15⁰⁰</u>	<u>3,938,760</u>	<u>656,460</u>		<u>4,595,220</u>
<u>B</u>	<u>TOWER STEEL - $f_y = GR.60$</u>	<u>2,017.5</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>12</u>	<u>24,210</u>	<u>17⁰⁰</u>	<u>411,570</u>	<u>887,700</u>		<u>1,299,270</u>
<u>B</u>	<u>MAT CONCRETE - $f'_c = 4000$ psi</u>	<u>18,038</u>	<u>CY</u>	<u>30⁰⁰</u>	<u>9</u>	<u>162,342</u>	<u>15⁰⁰</u>	<u>2,435,130</u>	<u>541,140</u>		<u>2,976,270</u>
<u>B</u>	<u>MAT STEEL - $f_y = GR.60$</u>	<u>992.1</u>	<u>TONS</u>	<u>440⁰⁰</u>	<u>8</u>	<u>7,937</u>	<u>17⁰⁰</u>	<u>134,925</u>	<u>436,525</u>		<u>571,450</u>
						<u>457,072</u>		<u>6,113,355</u>	<u>2,521,825</u>		
	<u>TOTAL</u>					<u>461,241</u>		<u>6,970,400</u>	<u>2,546,625</u>	<u>15,945</u>	<u>9,532,970</u>

ESG-79-2, Vol II, Book 2
I-30

CUSTOMER	<i>ATOMICS INTERNATIONAL</i>	PROP NO.	
LOCATION		JOB NO.	<i>20325</i>
PROJECT	<i>ADVANCED CENTRAL RECEIVER</i> <i>(300 METERS HEIGHT / 3,000 KIIPS)</i>	DATE	<i>2-13-78</i>
EV. NO.	REV. DATE	BY	<i>J.W.F.</i>

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	<i>4441</i>	<i>53290</i>	<i>26400</i>	<i>16975</i>	<i>96685</i>
B	CONCRETE	<i>504203</i>	<i>7634340</i>	<i>2705240</i>		<i>10419580</i>
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	<i>508644</i>	<i>7627630</i>	<i>2811640</i>	<i>16975</i>	<i>10516265</i>
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
J	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		<i>70% OF DIRECT LABOR</i>			<i>5381340</i>
	TOTAL FIELD COST					<i>15897605</i>
J	ENGINEERING <i>BY OTHERS</i>					
	TOTAL FIELD & ENG. COST					
O	SALES TAX <i>4% OF MAT'L COST</i>					<i>112465</i>
R	PREMIUM PAY <i>NONE</i>					
	ESCALATION <i>CURRENT PRICES AND LABOR RATES</i>					
	CONTINGENCY <i>7% OF TOTAL FIELD COST PLUS SALES TAX</i> <i>MINUS SUBCONTRACT</i>					<i>1199400</i>
	SUB TOTAL					<i>17209550</i>
Y	FEE <i>5% OF SUBTOTAL</i>					<i>860400</i>
	TOTAL					<i>18070030</i>

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (400 METERS HEIGHT / NONE KIPS)	DATE	2-13-78
REV. NO.	REV. DATE	BY	J. W. F.

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	61021	72250	36000	23000	131250
B	CONCRETE	874898	1324030	448220		1772250
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		600919	1313220	451220	23000	1785450
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP					
INDIRECT FIELD COST			70% OF DIRECT LABOR			931859
TOTAL FIELD COST						2717209
J	ENGINEERING BY OTHERS					
TOTAL FIELD & ENG. COST						
D	SALES TAX 4% OF MAT'L COST					180730
R	PREMIUM PAY NONE					
ESCALATION CURRENT PRICES AND LABOR RATES						
CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT						2049738
SUB TOTAL						29402560
Y	IFC 5% OF SUBTOTAL					14701280
TOTAL						30872690

Steans-Roger
INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J. W. F.
DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TO
					UNIT	TOTAL	\$/HH				
	TOWER :										
	HEIGHT: 400 METERS										
	RECV. WT NONE KIPS										
A	SOIL EXCAVATION	35,891	CY	-	.08	2,871	12 ⁰⁰	34,450	-	14,000	48
A	BACK-FILL (COMPACTED STRUC)	9,000	CY	4 ⁰⁰	.35	3,150	12 ⁰⁰	37,800	36,000	9,000	82
						1,521		18,252	36,000	13,111	131
B	TOWER CONCRETE - $f'_c = 4000$ psi	44,373	CY	30 ⁰⁰	13	576,849	15 ⁰⁰	8,652,735	1,331,190		9,000
B	TOWER STEEL - $f_y = GR. 60$	3,880	TONS	440 ⁰⁰	12	46,560	17 ⁰⁰	791,520	1,707,200		2,400
B	MAT CONCRETE - $f'_c = 4000$ psi	26,641	CY	30 ⁰⁰	9	239,769	15 ⁰⁰	3,596,535	799,230		4,300
B	MAT STEEL - $f_y = GR. 60$	1,465	TONS	440 ⁰⁰	8	11,720	17 ⁰⁰	199,240	644,600		84
						274,810		4,622,220	4,422,220		772
	TOTAL					880,919		13,312,200	4,518,220	23,000	17,800

ESG-79-2, Vol II, Book 2
I-34

CUSTOMER: ATOMICS INTERNATIONAL PROP. NO. _____
 LOCATION _____ JOB NO. 2032.5
 PROJECT ADVANCED CENTRAL RECEIVER DATE 2-13-78
(400 METERS HEIGHT / 500 KIPS) BY J.W.F.
 REV. NO. _____ REV. DATE _____ BY _____

ACT	DESCRIPTION	UNIT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	61021	72250	36000	23000	131250
B	CONCRETE	874950	1324100	448440		1772540
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
DIRECT FIELD COST		8809791	13313300	4520420	23000	17668720
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP					
W	CONSTRUCTION EQUIP.					
INDIRECT FIELD COST			70% OF DIRECT	LABOR		939310
TOTAL FIELD COST						27185030
J	ENGINEERING <u>BY OTHERS</u>					
TOTAL FIELD & ENG. COST						
O	SALES TAX <u>4% OF MAT'L COST</u>					180915
R	PREMIUM PAY <u>NONE</u>					
ESCALATION <u>CURRENT PRICES AND LABOR RATES</u>						
CONTINGENCY <u>7 1/2% OF TOTAL FIELD COST PLUS SALES TAX</u> <u>MINUS SUBCONTRACT</u>						2050715
SUB TOTAL						27416560
Y	FEE <u>5% OF SUBTOTAL</u>					1470830
TOTAL						30887390

Steals-Roger
INCORPORATED

CLIENT ATOMICS INTERNATIONAL
ORDER NO. 20325 LOCATION _____

SHEET NO. 1
BY J.W.F.
DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS						
					UNIT	TOTAL	\$/HH	LABOR	MATERIAL	OTHER	TOTAL
	TOWER :										
	HEIGHT: 400 METERS										
	RECV. WT 500 KIPS										
A	SOIL EXCAVATION	35,891	CY	-	.08	2,871	12 ⁰⁰	34,450	-	14,000	48,450
A	BACK-FILL (COMPACTED STRUCK)	9,000	CY	4 ⁰⁰	.35	3,150	12 ⁰⁰	37,800	36,000	9,000	82,800
						6,021		71,150	36,000	25,000	132,150
B	TOWER CONCRETE - $f'_c = 4000$ psi	44,373	CY	30 ⁰⁰	13	576,849	15 ⁰⁰	8,652,735	1,331,190		9,983,925
B	TOWER STEEL - $f_y = GR.60$	3,825	TONS	440 ⁰⁰	12	46,620	17 ⁰⁰	792,540	1,709,400		2,501,940
B	MAT CONCRETE - $f'_c = 4000$ psi	26,641	CY	30 ⁰⁰	9	239,769	15 ⁰⁰	3,596,535	799,230		4,395,765
B	MAT STEEL - $f_y = GR.60$	1,465	TONS	440 ⁰⁰	8	11,720	17 ⁰⁰	199,240	644,600		843,840
						574,950		1,110,000	4,400,000		6,084,950
	TOTAL					880,979		13,313,300	4,520,420	23,000	17,856,720

Stearns-Roger

ORDER OF MAGNITUDE
ESTIMATE SUMMARY

CUSTOMER		ATOMICS INTERNATIONAL				PROP NO.			
LOCATION						JOB NO.		20325	
PROJECT		ADVANCED CENTRAL RECEIVER (400 METERS HEIGHT / 1,500 KIPS)				DATE		2-13-78	
REV. NO.		REV. DATE				BY		J.W.F.	
ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL			
A	EARTHWORK	61021	72250	36000	23000	131250			
B	CONCRETE	874974	13241660	4485740		17727400			
C	BUILDINGS & STRUCTURES								
D	PROCESS EQUIPMENT								
E	PIPING								
F	ELECTRICAL								
G	PAINTING								
L	PLANT ITEMS								
N	INSTRUMENTS & CONTROLS								
P	INSULATION								
DIRECT FIELD COST		8811015	13313910	41521740	231000	17858650			
H	FIELD EXPENSE								
H	ALL RISK, PR TAX, BOND								
K	CONSTRUCTION SUPPLIES								
M	STARTUP								
S	TEMPORARY FACILITIES								
V	CRAFT BENEFITS								
V	CONSTRUCTION CAMP.								
W	CONSTRUCTION EQUIP								
INDIRECT FIELD COST			70% OF DIRECT LABOR			9319740			
TOTAL FIELD COST						27178390			
J	ENGINEERING	BY OTHERS							
TOTAL FIELD & ENG. COST									
Q	SALES TAX	4% OF MAT'L COST					180870		
R	PREMIUM PAY	NONE							
ESCALATION CURRENT PRICES AND LABOR RATES									
CONTINGENCY		7 1/2% OF TOTAL FIELD COST PLUS SALES TAX							
		MINUS SUBCONTRACT							
SUB TOTAL						291407480			
Y	FE	5% OF SUBTOTAL					1470475		
TOTAL						30871755			

Stearns-Roger

INCORPORATED

CLIENT ATOMICS INTERNATIONAL
 ORDER NO. 20325 LOCATION _____

SHEET NO. 1
 BY J.W.F.
 DATE 2-13-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOTAL
					UNIT	TOTAL	\$/MH				
	TOWER :										
	HEIGHT: 400 METERS										
	RECV. WT 1,500 KIPS										
A	SOIL EXCAVATION	35,891	CY	-	.08	2,871	12 ⁰⁰	34,450	-	14,000	48,450
A	BACK-FILL (COMPACTED STRUCK)	9,000	CY	4 ⁰⁰	.35	3,150	12 ⁰⁰	37,800	36,000	9,000	82,800
						6,001	7	84,000	23,000	107,000	
B	TOWER CONCRETE - $f'_c = 4000$ psl	44,373	CY	30 ⁰⁰	13	576,849	15 ⁰⁰	8,652,735	1,331,190		9,983,925
B	TOWER STEEL - $f_y = GR.60$	3,888	TONS	440 ⁰⁰	12	46,656	17 ⁰⁰	793,150	1,710,720		2,503,870
B	MAT CONCRETE - $f'_c = 4000$ psc	26,641	CY	30 ⁰⁰	9	239,769	15 ⁰⁰	3,596,535	799,230		4,395,765
B	MAT STEEL - $f_y = GR.60$	1,465	TONS	440 ⁰⁰	8	11,720	17 ⁰⁰	199,240	644,600		843,840
						14,914	11	4,455,740			17,200
	TOTAL					281,015		13,313,910	4,521,740	23,000	17,858,650

ESG-79-2, VOL II, BOOK 2
I-38

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (400 METERS HEIGHT / 3,000 KIPS)	DATE	2-13-78
REV. NO.		REV. DATE	
		BY	J.W.F.

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK	61021	72250	36000	23000	131250
B	CONCRETE	874838	13237010	4486020		17719030
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	8801859	131311260	4516020	23000	17850280
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
V	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70% OF DIRECT LABOR			9317880
	TOTAL FIELD COST					27168160
J	ENGINEERING BY OTHERS					
	TOTAL FIELD & ENG. COST					
O	SALES TAX 4% OF MAT'L COST					180640
R	PREMIUM PAY NONE					
	ESCALATION CURRENT PRICES AND LABOR RATES					
	CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX					2049435
	MINUS SUBCONTRACT					
	SUB TOTAL					29396285
Y	TTL 5% OF SUBTOTAL					1469810
	TOTAL					30866095

Stearns-Roger

INCORPORATED

CLIENT ATOMICS INTERNATIONAL

ORDER NO. 20325 LOCATION _____

SHEET NO. 1

BY J. W. F.

DATE 2-13-78

COUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	NAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOTAL
					UNIT	TOTAL	\$/MH				
	TOWER :										
	HEIGHT: 400 METERS										
	RECV. WT 3,000 KIPS										
A	SOIL EXCAVATION	35,891	CY	-	.08	2,871	12 ⁰⁰	34,450	-	14,000	48,450
A	BACK-FILL (COMPACTED STRUCK)	9,000	CY	4 ⁰⁰	.35	3,150	12 ⁰⁰	37,800	36,000	9,000	82,800
						6,021		1,250	36,000	23,000	15,250
B	TOWER CONCRETE - $f'_c = 4000$ psl	44,373	CY	30 ⁰⁰	13	576,849	15 ⁰⁰	8,652,735	1,331,190		9,983,925
E	TOWER STEEL - $f_y = GR.60$	3,875	TONS	440 ⁰⁰	12	46,500	17 ⁰⁰	790,500	1,705,000		2,495,500
B	MAT CONCRETE - $f'_c = 4000$ psc	26,641	CY	30 ⁰⁰	9	239,769	15 ⁰⁰	3,596,535	799,230		4,395,765
B	MAT STEEL - $f_y = GR.60$	1,465	TONS	440 ⁰⁰	8	11,720	17 ⁰⁰	199,240	644,600		843,840
						874,831		1,250,000	4,400,020		17,111,111
	TOTAL					880,857		13,311,260	4,516,020	23,000	17,850,280

ESG-79-2, Vol II, Book 2
I-40

APPENDIX J
A COMPARISON OF MECHANICAL AND ELECTROMAGNETIC SODIUM PUMPS

AT Letter 78AT-2995

ESG-79-2, Vol II, Book 2

J-1



Atomics International Division
8900 De Soto Avenue
Canoga Park, California 91304
(213) 341-1000

Rockwell
International

LTR. NO.

78AT-2864

ANDERSON, S. H.

ASHWORTH

ASQUITH

BALENT

BARTO

BAUMEISTER

BOTTS

BRIGHTMAN

BRINDLEY

BUERGIN

CARTER, E. H.

COCHRAN, J. C.

COCKERAM

CRAWFORD

DE LOS PRADOS

DETERMAN

DI POL

FEILER

GYLFE

HARRIS WASH.

HARTZLER

HILLIG

HOLBROOK

IACOBELLIS

JACOBSON, J.

JANIS

JETTER

JOHLER

JONES, R. O.

JULIAN, M.

KEATEN

KITTINGER

KOLIN

KUSTUDIA

MARTIN, A. S.

MCCOURT

MCDERMOTT, R. J.

MCDONALD, J. S.

MEYERS, G. W.

MURPHY, J. E.

OLDENKAMP

PARKINS

PARRY

PAULSON

REINECKER

REMLEY

ROBERTS, W. J.

ROHLFS

SANDERS

SCHIRM, R. C.

TINGER

TOMER

WALTER, J. H.

WEISNER

WHEELER

WIESENECK

WILLIAMS, R. O.

KLAUS, P.

KATZ, B.

Johann, S. C.

Thompson, W.

FRANCO, H.

GLASCO, W.

SKRIBNER, V. B.

March 22, 1978

In reply refer to 78AT-2995

Technical Manager
Contract EG-77-C-03-1483
Solar Projects Division, 8132
Sandia Laboratories
Livermore, California 94550

Attention: Mr. Ed Cull

Reference: TWX 24 dated February 14, 1978, E. T. Cull to T. H. Springer,
"Comments and Action Items from the First Quarterly Review
for the Atomics International Advanced Control Receiver
Program, at Atomics International, Canoga Park, on
February 9, 1978"

Gentlemen:

Subject: Response to Action Item 4.2 of the Referenced TWX -
"A Comparison of Mechanical and Electromagnetic
Sodium Pumps"

Action Item 4.4

"AI will furnish a comparison of mechanical and electromagnetic sodium
pumps by March 10, 1978."

Response

The enclosed document briefly describes typical large-scale electro-
magnetic and mechanical pumps, describes their characteristics, notes
the advantages and disadvantages of each, and assesses their appli-
cability to the Advanced Central Receiver Power System main sodium
loops. The conclusions reached in this study are:

1. The electromagnetic pump head-flow characteristics are not
suited to the requirements of the receiver system sodium
loop (P-1 pump).
2. The electromagnetic pump does meet the requirements of the
steam generator sodium loop (P-2 pump).

NEI

CLASSIFICATION LTR/ENC

UNCLASSIFIED

CLASSIFIED

LTR. APPROVALS

78AT-2995
March 22, 1978
Page 2

3. The mechanical pump will meet all system requirements.
4. The calculated cost penalty to the use of electromagnetic pumps is $\$4.1 \times 10^6$ for the P-1 pump and $\$0.59 \times 10^6$ for the P-2 pump.

Very truly yours,



T. H. Springer
Project Manager
Solar Electric Systems
Atomics International Division

nth:3/3-4

Enclosure

cc w/enclosure: Mark Schanfein, DOE
G. C. Coleman, MDAC
W. Lang, S-R
S. Chalmers, SRP
G. Kaplan, DOE/OSE

CONTENTS

	Page
I. Summary and Conclusions	1
II. Objective and Purpose	1
III. Description and Principles of Operation	1
A. Electromagnetic Pumps	
1. Flat Linear Induction Pump - FLIP	3
2. Annular Linear Induction Pump - ALIP	6
3. Annular Duct - HIP	8
4. Performance Characteristics	9
5. Advantages of EM Pumps.	9
6. Disadvantages of EM Pumps	9
IV. Mechanical Pumps Description and Principles of Operation	14
A. Advantages of Mechanical Pumps	14
B. Disadvantages of Mechanical Pumps	16
V. Application of EM vs Mechanical Pumps	16
A. Advance Central Receiver System	16
VI. Reliability Comparison	16
VII. Maintenance Comparison	18
VIII. Economic Comparison	18
IX. References	19

FIGURES

1. Advanced Central Receiver P&I Diagram	2
2. Secondary FLIP Pump	4
3. Principles of Operation - Linear Induction Pump	5
4. ALIP Conceptual Configuration "Straight-Thru" Flow	7
5. ALIP Conceptual Configuration Design (With "Center-Return" Flow)	10
6. Flat Linear Induction Pump (FLIP) Pressure-Flow Characteristics at Rated Voltage	11

FIGURES

	Page
7. Annular Linear Induction Pump (ALIP) "Straight Thru" Flow - Pressure-Flow Characteristics	12
8. Annular Linear Induction Pump (ALIP) With "Center Return Flow," Pressure Flow Characteristics	13
9. Typical Centrifugal Pump for Sodium Systems	15
10. Receiver Pump Head Flow Requirement	17

I. SUMMARY AND CONCLUSIONS

The performance characteristics and economics of electromagnetic pumps and mechanical centrifugal pumps were compared for application to the Advanced Central Receiver Power System main sodium loops. The larger size electromagnetic pumps appear to have a rising head flow characteristic which makes them less suitable than mechanical pumps for high lift variable flow applications. In all aspects, except efficiency, the electromagnetic pumps and the mechanical pumps are equally suited for application to the steam generator sodium system.

The lower pumping efficiency of the electromagnetic pumps imposes a cost penalty of $\$4.1 \times 10^6$ for the P-1 pump and $\$0.59 \times 10^6$ for the P-2 pump.

It is concluded that centrifugal pumps should be used in the conceptual design of the Advanced Central Receiver Power System main sodium loops.

II. OBJECTIVE AND PURPOSE

The objective of this study is to assess the operational benefits and cost differences between electromagnetic and mechanical pumps, as they apply to the Advanced Central Receiver System, in order to permit a selection between the two types. The pump type with the best cost benefit ratio will be selected for the receiver pump P-1 and the steam generator pump P-2 (see Figure 1).

III. DESCRIPTION AND PRINCIPLES OF OPERATION

A. ELECTROMAGNETIC PUMPS^(1,2)

The pumping action of all electromagnetic pumps is due to body forces on the sodium, or other electrically conductive fluid, being pumped. An electric current in a magnetic field has a force exerted in it. If the current is flowing in a conducting material, the force is effectively exerted on the conductor. The total pressure developed is the integral of the flux density times the current density throughout the pump duct.

SODIUM ADVANCED CENTRAL RECEIVER

R-1 SODIUM COOLED RECEIVER 429 MW (1.5×10^9 BTU/hr)	P-1 RECEIVER PUMP 305 m (1,000 ft) TDH 1.3 m ³ /sec (20×10^3 gpm) 4.7 Mw (6,300 hp)	T-1 LOW TEMPERATURE SODIUM TANK 288°C (550°F) 8,700 m ³ (2.3×10^6 gal)	T-2 HIGH TEMPERATURE SODIUM TANK 590°C (1,100°F) 9,500 m ³ (2.5×10^6 gal) 3 hrs FULL POWER	P-2 STEAM GENERATOR PUMP 61 m (200 ft) TDH 1.0 m ³ /sec (15×10^3 gpm) 0.7 Mw (900 H.P.)	X-1 EVAPORATOR 341°C (646°F) 15 MN/m ² (2,200 psia) 156 MW
--	--	--	---	--	--

X-2
SUPERHEATER
540°C (1,000°F)
12.9 MN/m² (1,865 psig)
79.7 MW

X-3
REHEATER
540°C (1,000°F)
3.2 MN/m² (463 psig)
37 MW





Figure 1. Advanced Central Receiver P&I Diagram

 **Rockwell International**
Atomics International Division

Enclosure to
AI Letter 78AT-2995

EM pumps can be made in an extremely wide variety of shapes limited only by the designer's ability to bring electric current into a magnetic field. In addition to direct acting pumps, impellerless centrifugal force can also be used to generate pressure in a conducting fluid which is being rotated by electromagnetic body forces.


For small, low-cost, laboratory or test loop pumps, it is convenient to generate current outside the pump and pass it through the sodium by conducting it through the walls of the duct. This can be done by attaching bus bars to the duct, but since large currents at very low voltage are desired, the resistances must be kept extremely low. These types of pumps are conduction pumps. High currents present problems in large conduction pumps [$\sim 500,000$ amperes at $6.3 \text{ m}^3/\text{s}$ (10,000 gpm)], so high-capacity units are usually of the type where current is induced in the fluid directly by the action of a time-varying magnetic field.

Within the group of pumps called induction pumps, the duct may have different shapes. The two shapes which have been developed and employed most often are flat and annular.

The basic principle of operation of a linear induction electromagnetic pump is the same as that of a polyphase, squirrel cage induction motor. In an induction motor, a moving magnetic field is produced by a distributed polyphase winding, wound on the inner periphery of a cylindrical magnetic structure (stator). The rotating field induces a voltage in conductors imbedded in the outer periphery of a second cylindrical magnetic structure (rotor). Interaction between the magnetic field and the currents resulting from the induced voltages produces a force on the magnetic structure of the rotor. Since the configuration is cylindrical, these forces produce a torque on the rotor.

1. Flat Linear Induction Pump - FLIP

In a flat linear induction electromagnetic pump (FLIP), shown in Figure 2, the stator structure is similar to that of a motor except that the windings are distributed in a flat rather than a cylindrical magnetic structure. Therefore, the motion of the field is linear (in a straight line) rather than circular



ESG-79-2, Vol II, Book 2
 J-9

Enclosure to AI Letter 78AT-2995




Figure 3. Principles of Operation - Linear Induction Pump

(revolving) as in a motor. The rotor is replaced by a layer of conducting fluid confined in a metal envelope of rectangular cross-section (pump duct). Voltages are induced in the fluid, and interaction of the resulting current with the field produces a force on the fluid. The integrated effect of this force along the length of the duct is the pressure developed by the pump. These principles are illustrated in Figure 3.

In FLIP design practice, two stator structures are used. These are placed on opposite sides of the layer of conducting fluid and connected so that the fields produced are additive. Note (Figure 3) that the induced currents flow across the duct perpendicular to the direction of the linear motion of the magnetic field. To complete their paths, the currents must flow for a short distance (one pole length, maximum) parallel to the direction of magnetic field motion. Some gain in efficiency is afforded by providing a low resistance path, such as a copper bar for these edge currents, but its attachment is a difficult design problem in practice, under the action of thermal shocks, and this feature is often omitted.

2. Annular Linear Induction Pump — ALIP

The required orthogonal relation of flux and current can be preserved in round and annular shapes. Flow in the annulus can be axial, helical, or tangential.

Figure 3 shows an arrow in the "direction of linear motion of magnetic field." If one imagines this arrow as an axis and rolls the flat duct into a thin, cylindrical annulus surrounding the axis, the result is the annular linear induction pump (ALIP) duct (Figure 4). The induced currents have circular paths in the sodium annulus and the currents flow in planes perpendicular to the axis. Current flow parallel to the axis is not present as it is in the FLIP.

Axial flow is used in the ALIP or annular linear induction pump. This pump was the subject of a patent filed in Germany in 1936 by Albert Einstein and Leo Szilard. The magnetic iron is laminated radially. This is convenient in the stator outside the annulus, where radial spaces between groups of punchings provide convenient channels for gas cooling the electric coils, but it complicates




Figure 4. ALIP Conceptual Configuration
("Straight-Thru"Flow)
(Ref. GE Report GEAP-13965)

the magnetic lamination structure inside the annulus. The electric coils of the ALIP are of uniform size, spirally wound, and shaped like a slice of canned pineapple. The currents induced in the sodium flow in circles concentric with the pump axis.

The larger the capacity, the more attractive the ALIP pump. As the diameter of the annulus increases, more space is available for coils and punchings inside the annulus. In small ALIP pumps, there is space for only the outer coils. This is analogous to a FLIP pump with a stator winding on only one side of the duct. The output of a given pump is less with one stator than two due to the greater magnetic leakage flux. Also, the slots in two stators can be smaller than would be required in the same capacity pump designed for a single stator, thereby reducing magnetic reluctance and leakage and producing improved power factor.

3. Annular Duct -- HIP

Spiral flow through the annulus is used in the HIP or helical induction pump. The stator winding is of the same construction as for three-phase induction motors. The stator induces currents which flow in the sodium parallel to the pump axis. At the ends of the stator, the currents must flow circumferentially one pole width to their return path under the adjacent magnetic pole.

The interaction of the induced currents with the magnetic field causes the sodium to rotate tangentially the same as an induction motor rotor rotates. No net pumping action is produced so a spiral vane (or vanes) is provided in the annulus. The vanes cause the sodium to literally screw itself along the annulus at a rate determined by the rotational speed of the sodium and the pitch or helix angle of the spiral vane(s). Appropriate choice of helix angle allows a wide variation in the ratio of pressure to flow in the same annulus excited by the same stator. However, the HIP is usually applied where ratios of developed pressure-to-flow are much higher than required in LMFBR main heat transport systems.

Once the sodium has passed through the annulus in either HIP or ALIP pumps, it may take one of three paths. First, it may be ducted to the exit pipe directly by either a tapered axially oriented conical section as illustrated in

Figure 4, or collected in a toroidal section and fed to a tangential pipe nozzle. Or, if desired, the sodium can be returned to the entrance end of the pump through a central pipe coincident with the axis of the pump (see Figure 5). The pipe runs through a hole provided in the core magnetic laminations on the inside of the sodium annulus. This is possible because the flux return path stays near the outer circumference and the center is not needed for the magnetic circuit. In induction motors, this space is occupied by the shaft.

In the HIP, a third possibility is to return the sodium to the inlet end of the pump through a second annulus, adjacent to the first, with helical vanes at a negative angle with respect to the first pass. This is an appropriate design for very high ratios of pressure to flow, and is not possible in the ALIP.

4. Performance Characteristics

Typical pump curves for the FLIP and the SLIP "straight thru" and "center return flow" pumps are given in Figures 6, 7, and 8. It is to be noted that these pumps exhibit a raising head-flow characteristic up to nearly 100% design flow.

5. Advantages of EM Pumps

The principal advantages of the EM pumps are: (1) they have no moving parts and should, following the development period, exhibit a high reliability and a long life; (2) they do not require a penetration of the pressure boundary and do not require rotating seals or a cover gas; and (3) they have good control characteristics from 0 to 100% at full flow in systems with a predominant dynamic head-flow characteristic.

6. Disadvantages of EM Pumps

The principal disadvantages of EM pumps are: (1) a relatively low pump efficiency; and (2) the requirement that the pump throat section must be kept warm during shutdown, to keep from freezing the sodium in it, and simultaneously the stator must be kept cool to protect the winding insulation; (3) a drained pump risks burn-out of the pump throat section if the power is inadvertently turned on; and (4) EM pumps tend to have a raising head flow characteristic when the flow is somewhat less than the design point.




Figure 5. ALIP Conceptual Configuration Design
(With "Center-Return" Flow)




Figure 6. Flat Linear Induction Pump Pressure Flow Characteristic at Rated Voltage (Ref. G.E. Report GEAP - 13965)




Figure 7. Annular Linear Induction Pump With "Straight Thru" Flow - Preliminary ALIP Designs




Figure 8. Annular Linear Induction Pump With "Canter Return Flow" -- Preliminary ALIP Design

IV. MECHANICAL PUMPS DESCRIPTION AND PRINCIPLES OF OPERATION

Large sodium systems nearly always use centrifugal pumps for the main pumps and EM pumps for auxiliary services where pumping efficiency is not important. A typical pump for application to sodium systems is shown in Figure 9. The basic centrifugal pump theory, key components, and manufacturing techniques are similar to water pumps. One distinct difference is the requirement to provide a cover gas over the free surface of the sodium which is passive with respect to sodium and the materials of construction. (The cover gas is usually either argon or helium.) To conserve the cover gas and to preclude air from the pump ullage, a rotating shaft seal is required. The hydrostatic radial bearing that is used in these pumps is similar to those used successfully on water cooled nuclear reactor main circulation pumps. About one-half of the sodium that flows through the bearing flows into the pump barrel; the other part flows back to the backside of the impeller. Sodium pumps are normally designed to permit the rotating parts to be removed from the pump casing without cutting into the system which is the reason for the separate center barrel, fixed into the system, and the removable inner barrel which supports the rotating parts and the radial bearing. This removal feature necessitates a slip seal (labyrinth case seal, shown in Figure 9) between the high pressure plenum and upper part of the barrel which is at low pressure. Some sodium flows through this seal and adds to the sodium flowing from the bearing. This tends to fill the pump upper barrel. Pressuring the gas space over the sodium forces the sodium through the overflow connection back to the sodium supply tank.

A. ADVANTAGES OF MECHANICAL PUMPS

The principal advantages of the mechanical pumps are: (1) they have the highest pumping efficiency of any known alternative; (2) the technology is very well developed; (3) there are many proven design options which permit the pump characteristics to be closely fitted to system characteristics; and (4) the control characteristics of these pumps can be well matched to the system requirement.




Figure 9. Typical Centrifugal Pump for Sodium Systems

Enclosure to
AI Letter 78AT-2995

B. DISADVANTAGES OF MECHANICAL PUMPS

For sodium systems, the disadvantages of mechanical pumps are: (1) they are subject to the usual problems of rotating equipment, rubbing, shaft binding and vibration; (2) they require a controlled free surface; and (3) they require an inert cover gas and a shaft seal where the shaft penetrates the pressure boundary.

V. APPLICATION OF EM vs MECHANICAL PUMPS

A. ADVANCE CENTRAL RECEIVER SYSTEM

The receiver pump (P-1) must provide a high static lift (92% of the total head) plus the normal dynamic head loss. This requirement is illustrated in Figure 10, which shows the system curves together with typical curves for EM and mechanical pumps. As can be seen from the curves for the EM pumps, the raising head flow characteristic tends to make the flow unstable as the trim valves close. (See Section III, Paragraph A-4 and Figures 6, 7, and 8.) For the mechanical pump, which has a falling head flow characteristic, the system is self regulating and the flow is stable.

For systems with a high static lift characteristic, variable speed pumps are not recommended for flow control because of the flat intercept between the pump curve and the system curve, the good flow control characteristics of the EM pump cannot be exploited for the P-1 pump application. See Paragraph III A-5

For the mechanical pump, the high head requirement can be achieved by using a two stage centrifugal pump.

The requirements on the Steam Generator Pump (P-2) are more conventional. Since 80% of the head is dynamic head, and flow control is required of this pump, the EM pump is more attractive in this application than it is for the receiver pump application.

VI. RELIABILITY COMPARISON

In Reference 3, p 30, if one uses the GEAP estimate for the mechanical pump and the current estimate for EM pump, p 31, then the mechanical pump appears to





Figure 10. Receiver Pump Head Flow Requirement

be more reliable. If one takes the "Scientific Associates, Inc." estimate vs the GEAP estimate, then the EM pump is the more reliable. Taken either way, the relative reliability is within a factor of two which is not significant for this state of the design. The conclusion is that within our ability to estimate this quantity, the reliability factor is equal for both pumps.

VII. MAINTENANCE COMPARISON

No significant advantage has been found in terms of failure rates or repair times which would favor either pump.

VIII. ECONOMIC COMPARISON

Usually the five aspects of pump costs which are considered in pump economics are: (1) capital cost of the pump; (2) capital cost of the plant to provide the additional capacity to power the pump; (3) cost of the power used by the pump; (4) cost of plant downtime caused by pump failures; and (5) pump maintenance costs.

1. CAPITAL COST OF THE PUMPS

Reference (2), p 77, claims that the mechanical pump cost is approximately one-half to two thirds the cost of the EM pump. Reference (3), p 33H, claims a 23% advantage for the EM pump in the $4.1 \text{ m}^3/\text{s}$ (67,5000 gpm) size. My assessment of the data given on p 33G, scaling down the cost of the $2.12 \text{ m}^3/\text{s}$ (33,700 gpm) CRBRP pump to $0.91 \text{ m}^3/\text{s}$ (14,500 gpm), gives about the same price for the EM and mechanical pumps (using a 0.6 scaling law). I conclude that, within our ability to estimate, the cost of the EM pump approximates the cost of the mechanical pump, if both pumps are made of the same materials. This is the same conclusion reached in Reference 4. Since we plan to make the P-1 pump out of mild steel, we expect to save at least the difference in the cost of the materials. Thus for the receiver pump the mechanical pump cost should be lower.

For the steam generator pump, P-2, both pumps must be made of stainless steel and the two pumps should cost about the same.

2. CAPITAL COST OF THE PLANT TO PROVIDE THE ADDITIONAL
CAPACITY TO POWER THE PUMPS

Since pumps return energy to the system, this factor was considered in the analysis.

From Reference 1, p 2-14, the pump drive (M.G. set equipment) efficiency is given as 0.91. Page 3-13 (ibid) gives a 45% pump efficiency at the best efficiency point (B.E.P.), thus the overall efficiency is 40%. This requires 7.75 MW of electrical power be delivered to the pump. 2.1 MWe is recovered from the fluid energy input. From Reference 5, p 3, the mechanical pump efficiency is 82%, the motor efficiency is 95%. Thus, the overall efficiency is 78%. This requires 3.9 MW of electrical energy to the pump. The recovery is 1.47 MWe. The net difference is 2.95 MW electrical. This is 2.6% of the plant gross capacity.

The increase in plant size to accommodate this extra power, scaled to the 0.8 power, gives an increase of capital investment of $\$2.42 \times 10^6$ for the P-1 pump and $\$0.346 \times 10^6$ for the P-2 pump. The associated present worth of these two amounts is $\$4.1 \times 10^6$ for the P-1 pump and $\$0.59 \times 10^6$ for the P-2 pump.

3. COST OF THE POWER USED BY THE PUMP

Since there is no fuel charge in a solar energy system, the consumption of electricity difference cost was considered to be insignificant.

4. COST OF PLANT DOWNTIME

The Difference in the cost of plant down-time caused by the different pumps was considered to be negligible.

5. PUMP MAINTENANCE COSTS

The maintenance cost of the two pump types was determined to be approximately equal.

IX. REFERENCES



1. Collins, G. D. "Development of Large Electromagnetic Pumps for Main Heat Transport Systems of LMFBR's," GEAP-13965, June 1973
2. Brunings, J. E. and Larson, E. M. "PLBR Main Circulating Pump Type and Location Selection," AI Document N222TSR310001, March 29, 1976
3. General Electric Co., "Large EM Pump Program Review," January 23, 1976, ERDA-RDD Headquarters, Germantown, Maryland
4. Morabito, J. J., to Thorne, R. D., "Large EM Pump Development," 189 No. SG012; Report on Meeting of January 23, 1976 at ERDA, Germantown, Maryland
5. Pfouts, J. O. to Frangos, A. Z., Internal Atomics International Letter, "Preliminary Size and Cost Related Information for Pumps for a Solar System," dated January 16, 1978

APPENDIX K
PIPE ROUTING STUDY OF SODIUM DOWNCOMER

AI Technical Information

Document N272T1000001

APPENDIX **K**

 Rockwell International <small>Aluminum International Division</small>		SUPPORTING DOCUMENT		NUMBER N272T1000001	REV LTR/CHG NO. SEE SUMMARY OF CHG.
PROGRAM TITLE Conceptual Design of Advanced Central Receiver Power Systems				DOCUMENT TYPE Technical Information	
DOCUMENT TITLE Pipe Routing Study of Sodium Downcomer				KEY NOUNS Piping, Pipe Supports, Snubbers, Expansion Devices	
PREPARED BY/DATE W. J. Hughes/1-26-78				GO NO. 09272	S/A NO. 12000
DEPT 731				PAGE 1 OF TOTAL PAGES 24	
MAIL ADDR LB14				REL. DATE 2-3-78	
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____				SECURITY CLASSIFICATION	
APPROVALS C. A. Norelius 				(CHECK ONE BOX ONLY)	
				UNCL <input type="checkbox"/>	(CHECK ONE BOX ONLY)
				DOE <input type="checkbox"/>	RESTRICTED DATA <input type="checkbox"/>
				DOD <input type="checkbox"/>	DEFENSE INFO. <input type="checkbox"/>
				CONF. <input type="checkbox"/>	
				SECRET <input type="checkbox"/>	
				AUTHORIZED CLASSIFIER	DATE
DISTRIBUTION			ABSTRACT		
*	NAME	MAIL ADDR	Four piping configurations were developed and studied to determine the simplest routing for a 20-in. sodium downcomer line from the receiver at 900 ft above grade to the hot storage tank at grade.		
*	L. Glasgow	LB39			
*	R. Jetter	LB14			
*	T. Johnson	LA19			
*	B. Katz	LA19			
*	C. Norelius	LB14			
731-V.3/jdj					
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY					

CONTENTS

	<u>Page</u>
STATEMENT OF REPORT.....	4
INDEX OF TYPES.....	5
SUMMARY.....	6
MAINTENANCE.....	7
ENGINEERING.....	8
CONCLUSION.....	9
TYPE I.....	10
Reference Design.....	10
Support Diagram.....	11
Sample Calculations.....	12
TYPE II.....	13
Reference Design.....	13
Support Diagram.....	14
Sample Calculations.....	15, 16, 17
TYPE III.....	18
Reference Design.....	18
Support Diagram.....	19
Sample Calculations.....	20

CONTENTS
(continued)

	<u>Page</u>
TYPE IV.....	22
Reference Design.....	22
Expansion Joint.....	23
Support Diagram.....	24

STATEMENT OF REPORT

Given:

A single run of 20-in. A452, TP304H pipe with a fixed anchor at 900 ft above grade and the other end at grade. The operating temperature is 1100⁰F. The piping will be conventionally supported from an existing structure that will impose no unusual loadings on the pipe. There is no wind loadings on the pipe.

Find:

The simplest routing for the piping.

Data:

Allowable Stress $S_A = 21,600$ psi
 Free End Expansion = 155.56 in. (9 ft - 7-1/2 in.)

INDEX OF TYPES

Type I:

Multiple U shape with equal tangents (Sketch 1).

Type II:

90° turn (Sketch 2).

Type III:

Single tangent with multiple U bends at grade (Sketch 3).

Type IV:

Straight through with expansion device (Sketch 4).

SUMMARY

All four types are suitable for the intended purposes.

Type IV is the simplest routing for the piping, but it requires the use of a high-price expansion device.

Type II is a simple pipe routing. It requires about 15 compliance supports. These could be counterweight hangers. The cost will depend on a detailed study of a reference hanger design.

Type III is a little more complicated than Type II but it has the advantage of occupying less floor space and using fewer snubbers. It could also be rerouted to fit the contour of a 150 ft diameter building.

Type I is the most complicated pipe routing. It uses the more common pipe fittings and supports; therefore, it would be the easiest to set its construction cost. It could be used as a basis for evaluating the other types.

MAINTENANCE.

All the piping will require access maintenance the full height of the tower with platforms at frequent intervals (30 ft). The rigging supports used for construction should be left in place for major maintenance.

The frequency of maintenance will vary. Type I should require only the visual inspection for leakage and hanger engagement.

Types II and III will require additional checks to insure movement of compliance supports.

Type IV will require instrumentation to indicate movement.

ENGINEERING

Type IV will require testing and qualifying of the bellows component. If a detailed stress analysis of the bellows is required, this cost could be an open end item.

Types II and III will require design evaluation of the compliance supports. The space, structure, and mechanical devices required for free movement of the pipe and pipe supports will have to be developed.

Type I will not require any special engineering studies.

CONCLUSION

There are more types and variations of piping arrangements than the four discussed in this report. But within the limitations of these four I would recommend the multiple U shape with equal tangents (Type I). It is the highest in piping material costs, but this would be more than offset by lower engineering and maintenance costs. It is the highest in normal operating costs, but it would also be the most reliable.

The 90° turn (Type II) and the single tangent with multiple U bends at grade (Type III) are roughly equivalent. The only reason I do not recommend either of them ahead of the Type I is because of some doubt as to the reliability of the counterweight supports.

The straight through with expansion device (Type IV) would encounter the usual resistance and analysis costs associated with all bellows.

TYPE I

Type I is the most conventional configuration from a pipe routing standpoint. It is similar in design to the high-temperature steam piping used in petro-chem and large process plants. The principal difference is the steam piping is usually in a horizontal plane. The Advanced Central Receiver (ACR) downcomer is principally in a vertical plane. This does not effect the thermal loadings, the anchor locations, or the restraint locations, but it does effect the weight supports. The steam piping lateral restraints are the weight support elements. The ACR downcomer weight can be carried by the anchors and rod supports at points of zero vertical movement (see Sketch 1).


The distance between anchors and the U shape can be optimised to give the best support arrangement. The configuration can be altered to follow the tower support structure. Rod supports and anchors require minimum maintenance.

Reference Design


Distance between anchors = 90 ft

Offset of U bend = 25 ft

This configuration had a maximum stress of 19,353 psi and required only rod hangers and anchors for weight support.

PREPARED BY:	 Atomics International Division Rockwell International	PAGE NO. 11 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO.

TYPE I - SUPPORT DIAGRAM



RIGID GUIDED
OUT OF PLANE


SKETCH 1

M 100.0.2 REV A.75

Type I

(Ref. Grinnell - Piping Design and Engineering)

U Shape with equal tangents

Maximum Bending Stress, $S_B = k_b c \frac{D}{L}$ Assume $S_B = 20,000$ psi

$$D = 20''$$

$$c = 2036$$

$$\frac{L}{k_b} = \frac{c D}{S_B} = \frac{2036 (20)}{20,000} = 2.036$$

$$\text{If } L = 90': \quad K_b = \frac{90}{2.036} = 44.2$$

$$\left. \begin{array}{l} L/a = 2, 3, 4, 5, 6 \\ L/h = 4.4, 3.5, 3.1, 2.9, 2.7 \\ a = 45, 30, 22.5, 18, 15 \\ h = 20.5, 25.7, 29, 31, 33 \end{array} \right\} *$$

TYPE II

This configuration uses less pipe than Type I. There is no penalty in pipe weight even if we assume most of the weight is supported from the top. The problem here is the large pipe movement (approximately 10 ft) at the bend. This will require compliant restraints and supports. This excludes spring hangers and sway braces in the vicinity of the bend. The design of roller restraints and counterweight supports present no special problem. The analysis and maintenance of compliant devices would require special consideration.

Pipe rolls are, in general, used in tunnels and enclosed areas. In a controlled environment, they should present no special problems. In an outdoor environment they have been known to freeze up.


The large pipe movements will require an exclusion area. This area will have to be sealed off or monitored to prevent interferences.

Reference Design


Long leg = 900 ft; Short leg = 250 ft

Maximum stress 21,945 psi for an unguided arrangement.

A partially guided arrangement would require a longer "short leg" but should result in an overall cost reduction.

PREPARED BY:	 Atomics International Division Rockwell International	PAGE NO. 14 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO.

TYPE II - SUPPORT DIAGRAM




SKETCH 2

M 152-9-7 REV 8-73

Type II

(Ref. Grinnell - Piping Design and Engineering)

90° turn

Maximum Bending Stress $S_B = k_b C \frac{D}{L}$ Assume $S_B = 20,000$ PSI $D = 20''$ $C = 2036$ $L = 900'$

$$k_b = \frac{S_B L}{C D} = \frac{20,000 (900)}{2036 (20)} = 442$$

$$\frac{L}{h} = 4.568$$

$$h = \frac{900}{4.568} = 197$$

Use $h = 250'$

$$4.6 - 456$$

$$\frac{4.4}{.2} = \frac{406}{50}$$

$$.2 - 50$$


$$\frac{42}{50} \times .2 = 1.68$$

Type II

N272T100001

Page 16

90° Turn, Guided



Maximum Bending Stress $S_B = k_b c \frac{D}{L} \left(\frac{L'}{L} \right)$

Assume $S_B = 20,000$ PSI, $D = 20''$, $c = 2036$, $L' = 900$

$$k_b = \frac{S_B L}{c D} \left(\frac{L}{L'} \right) = .491 \left(\frac{L^2}{900} \right) = .000546 L^2$$

L	k_b	L/h	h
450	110	2.1	214
225	27	< 1	

$$S_B = 36(2036) \frac{20}{250} \left(\frac{900}{250} \right) = 21,109$$

Minimum $L = h = 250'$

Type IISUPPORT WEIGHT

① PRESSURE OF 900' COLUMN
OF SODIUM

$$\text{DENSITY AT } 212^{\circ}\text{F} = 57.9 \text{ \#/FT}^3$$

$$\text{DENSITY AT } 482^{\circ}\text{F} = 55.7 \text{ \#/FT}^3$$

$$\text{USE DENSITY OF } 62.4 \text{ \#/FT}^3$$

$$150' = 64.97 \text{ PSI}$$

$$900' = 389.82 \text{ Say } 400 \text{ psi}$$

USE 20" x 0.500" PIPE


$$\text{WEIGHT} = 170.93 \text{ \#/FT, SAY } 200 \text{ \#/FT}$$

$$\text{TOTAL WEIGHT} = 1150 \times 200 = 230,000 \text{ \#}$$

$$\text{SUPPORT STRESS} = \frac{230,000}{30.6} = 7516 \text{ PSI}$$

$$\text{ALLOWABLE AT } 1100^{\circ}\text{F} = 7400 \text{ PSI}$$

THIS IS OK IF WE ASSUME 20%
OF THE WEIGHT IS CARRIED BY LOWER
LEG SUPPORTS.




TYPE III


This configuration is similar to Type II except that it does not require compliant restraints on the tangent but it does require an extra 50 ft of pipe in the U bend and two extra elbows. The comments on restraints and supports for Type II apply to Type III.

Reference Design

A 150 ft offset by 50 ft U shape, guided at 150 ft above grade.

PREPARED BY:	 Atomics International Division Rockwell International	PAGE NO. 19 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO.

TYPE III - SUPPORT DIAGRAM



SKETCH 3

(Ref. Drinnell - Piping Design and Engineering)

U shape with single tangent

Maximum Bending Stress (S_B)


$$S_B = k_b c \frac{D}{L} \left(\frac{L'}{L} \right)$$

$$k_b = \frac{S_B L^2}{c D L'} = \frac{20,000 L^2}{2036(20) 900}$$

$$k_b = 0.000546 L^2$$

L	k_b	L/a	L/h	a	h
250	34	1.5	2.0	166	125
"	"	2	1.9	125	132
"	"	3	1.7	83	147
"	"	4	1.8	63	138
200	22	4	1.3	50	154


150	12	4	1	50	150
-----	----	---	---	----	-----



Type IIIV shape - equal legs

$$K_b = 0.000546 L^2$$

<u>L</u>	<u>K_b</u>	<u>4h</u>	<u>h</u>
100	5.46	0.65	153
50	1.37	0.3	166



TYPE IV

There are two types of expansion devices in general use, a slip joint and a bellows joint. This application would probably use a combination of the two - a slip joint for alignment and side loading and a bellows for pressure loading.

The 10-ft pipe movement presents a special problem. The simplest solution would be to break up this movement into, say, ten one-ft movements. Then, a commercial expansion device could probably be found that would suit this requirement.

Reference Design

Nine units equally spaced.

Axial-movement type expansion joints are quite similar in detail to their counterpart in packed joints, with the substitution of a bellows seal for the packing. When constructed with machined parts, this type of design is obviously expensive and can be justified only for special cases where installed location and general system arrangement make it difficult to achieve effective guiding by other means, or where a large amount of axial movement must be provided and guiding of the bellows assembly against lateral buckling is necessary. With an internal arrangement it is also possible to secure maximum confinement of the bellows against abrupt release of contents, and sometimes an auxiliary packed joint is provided to further minimize this hazard particularly for toxic content services. Sometimes joints of this type are fabricated to reasonably close forming tolerances, without machining; however, without lubrication, binding is much more likely to occur.

TYPE IV







FIG. 7.11 Axial movement type expansion joints.

PREPARED BY:	 Atomics International Division Rockwell International	PAGE NO. 24 OF
CHECKED BY:		REPORT NO.
DATE:		MODEL NO.

TYPE IV - SUPPORT DIAGRAM




SKETCH 4

APPENDIX L
SODIUM-COOLED ADVANCED CENTRAL RECEIVER
SYSTEM SIMULATION MODEL

AI Technical Information

Document N272TI00000

 SUPPORTING DOCUMENT		NUMBER N272T1000006	REV LTR/CHG NO. SEE SUMMARY OF CHG																						
PROGRAM TITLE Conceptual Design of Advanced Central Receiver Power System		DOCUMENT TYPE Technical Information																							
DOCUMENT TITLE Sodium-Cooled Advanced Central Receiver System Simulation Model		KEY NOUNS Advanced Central Receiver Simulation Model																							
PREPARED BY/DATE W. W. Willcox 8/23/78		ORIGINAL ISSUE DATE August 25, 1978																							
DEPT 714		GO NO. 09272	S/A NO. 18000																						
MAIL ADDR LA19		PAGE 1 OF 136 TOTAL PAGES 136 REL. DATE																							
IR&D PROGRAM? YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> IF YES, ENTER TPA NO. _____		SECURITY CLASSIFICATION																							
APPROVALS B. Katz 8/30/78 T. Springer 8/24/78 T.L. Johnson 8/29/78		(CHECK ONE BOX ONLY) UNCL <input type="checkbox"/> CONF. <input type="checkbox"/> SECRET <input type="checkbox"/>	(CHECK ONE BOX ONLY) DOE <input type="checkbox"/> DOD <input type="checkbox"/> RESTRICTED DATA <input type="checkbox"/> DEFENSE INFO. <input type="checkbox"/>																						
DISTRIBUTION		ABSTRACT																							
<table border="1"> <thead> <tr> <th>* NAME</th> <th>MAIL ADDR</th> </tr> </thead> <tbody> <tr><td>E. Ash</td><td>LA24</td></tr> <tr><td>A. Frangos</td><td>LA19</td></tr> <tr><td>L. Glasgow</td><td>LB39</td></tr> <tr><td>* T. Johnson</td><td>LA19</td></tr> <tr><td>B. Katz</td><td>LA19</td></tr> <tr><td>R. Oidenkamp</td><td>LA42</td></tr> <tr><td>* T. Springer (2)</td><td>LA18</td></tr> <tr><td>W. Thompson</td><td>LA19</td></tr> <tr><td>H. Wieseneck</td><td>LA21</td></tr> <tr><td>* W. Willcox</td><td>LA19</td></tr> </tbody> </table>		* NAME	MAIL ADDR	E. Ash	LA24	A. Frangos	LA19	L. Glasgow	LB39	* T. Johnson	LA19	B. Katz	LA19	R. Oidenkamp	LA42	* T. Springer (2)	LA18	W. Thompson	LA19	H. Wieseneck	LA21	* W. Willcox	LA19	<p>A mathematical model describing the dynamic behavior of the sodium-cooled advanced central receiver power system has been written and used to verify the receiver control methodology and simulate the receiver system under various transients of interest. The control methodology of individual panel control has been verified for controlled situations with receiver mixed outlet temperatures varying less than 8°F over the range of controlled transients examined. However, active heliostat steer-off is required during transients in which the receiver pump trips.</p>	
* NAME	MAIL ADDR																								
E. Ash	LA24																								
A. Frangos	LA19																								
L. Glasgow	LB39																								
* T. Johnson	LA19																								
B. Katz	LA19																								
R. Oidenkamp	LA42																								
* T. Springer (2)	LA18																								
W. Thompson	LA19																								
H. Wieseneck	LA21																								
* W. Willcox	LA19																								
714-F.57/bes																									
* COMPLETE DOCUMENT NO ASTERISK, TITLE PAGE/SUMMARY OF CHANGE PAGE ONLY																									

FORM 734-C REV. 11-77



CONTENTS

	<u>Page</u>
I. INTRODUCTION.....	3
A. ADVANCED CENTRAL RECEIVER SYSTEM DESCRIPTION.....	3
B. MODEL SCOPE.....	3
II. MODEL DESCRIPTION.....	6
A. CSMP.....	6
B. MODEL FEATURES, GENERAL DESCRIPTION AND ASSUMPTIONS.....	7
C. SPECIFIC EQUATIONS.....	10
III. RESULTS.....	28
A. RESPONSE TO 10% STEP CHANGE IN INCIDENT FLUX.....	28
B. RESPONSE TO CLOUD COVER TRANSIENT.....	30
C. RESPONSE TO 25% STEP (STEEP RAMP CHANGES)....	31
D. RESPONSE TO LOSS OF RECEIVER PUMP POWER.....	31
E. RESPONSE TO ACCIDENTAL DRAG VALVE FUNCTION... 33	33
F. RESPONSE TO EMERGENCY SHUTDOWN.....	33
IV. CONCLUSIONS AND RECOMMENDATIONS.....	35
V. REFERENCES.....	36

APPENDICES

- A. MODEL LISTING
- B. RESPONSE TO 10% STEP CHANGE
- C. RESPONSE TO CLOUD COVER TRANSIENT
- D. RESPONSE TO 25% STEP CHANGES
- E. RESPONSE TO LOSS OF RECEIVER PUMP POWER
- F. RESPONSE TO ACCIDENTAL DRAG VALVE FUNCTION
- G. RESPONSE TO EMERGENCY SHUTDOWN RAMP



I. INTRODUCTION

A. ADVANCED CENTRAL RECEIVER SYSTEM DESCRIPTION

A simplified flow and control diagram of the baseline conceptual configuration of a 100-MWe Sodium-Cooled Advanced Central Receiver Power System is shown in Figure 1. In this system, liquid sodium is circulated from a cold tank (T-1) through 24 panels located on the surface of a right circular cylinder receiver, located on top of a tower, to a hot tank (T-2) by a centrifugal pump (P-1). Sodium is heated in the receiver by solar insolation reflected by a large number of heliostats which surround the receiver tower. From the hot tank, sodium is circulated by a second pump (P-2) through a superheater (X-2) and reheater (X-3), configured for parallel sodium flow, to an evaporator (X-1) and finally back to the cold tank. Under conditions of full solar insolation, the flow through the steam generators (evaporator, superheater, reheater) is about 2/3 of the receiver flow. Thus, 1/3 of the receiver flow accumulates in the hot tank during the day for use at night. Steam, generated by sensible heat released by the sodium in the steam generators, is used to drive a conventional three-stage steam turbine in conjunction with a conventional Rankine cycle. A more detailed description of the sodium-cooled advanced central receiver system is contained in Reference 1.

B. MODEL SCOPE

For purposes of developing a meaningful representation of the Sodium-Cooled Advanced Central Receiver Power System, only the normally active sodium components physically located in the flow stream between the cold and hot tanks, including the cold and hot tanks, are included in the model. The steam generator and Rankine cycle equipment have been previously simulated in various LMFBR programs⁽²⁾, and their response to a large number of transients is well known. More importantly, the large mass

ADVANCED CENTRAL RECEIVER
(100 MWe)

P-1
RECEIVER PUMP

TDH-220 (722)
F - 1.3 (20)
J - 3.35 (4.5)
D/H 1.9/3.5 (6.4/11.3)

T-1 & T-2
STORAGE TANKS

D - 305 (100)
H - 13.6 (45)
Q - 9.4 (2.5)

P-2
ST. GEN. PUMP

TDH-76 (250)
F - 1.0 (15)
J - .53 (.706)
D/L-1.2/2.7(4/9)

X-1
EVAPORATOR

T-341(646)
P-17 (2400)
J-155

X-2
SUPERHEATER

538 (1000)
15 (2200)
76

X-3
REHEATER

538 (1000)
6.9 (1000)
37




Figure 1. Simplified Flow and Control Diagram

Rockwell International
Energy Systems Group



capacity of the hot and cold tanks effectively isolates the receiver and its associated components from the steam generation equipment. Consequently, it is cost effective to consider the receiver and its equipment separately since the outlet temperature variation of the hot tank and cold tank are insignificant.

The components comprising the model include: the cold tank, receiver pump, riser check valve, riser piping, panel control valves, 24 receiver panels and associated manifolding, panel flow controllers, receiver outlet surge tank, surge tank level controller, downcomer piping, drag valve and hot tank. Pipes and valves used for filling or draining receiver equipment have been omitted from the model but can be inserted if required.



II. MODEL DESCRIPTION

A. CSMP

The Advanced Central Receiver (ACR) Sodium-Cooled Solar Electric Power Plant was modeled using International Business Machine's Continuous System Modeling Program (CSMP).⁽³⁾ CSMP solves coupled sets of first order differential equations. If a system of differential equations is expressed in terms of time, then CSMP will simulate the response of the systems to various perturbations in boundary and initial conditions, much like an analog computer.

A variety of integration routines are available to the CSMP user ranging from rectangular to fourth order Runge-Kutter methods. Naturally, for simple models, the more stable, sophisticated methods require more computer time per solution and are, consequently, more expensive. This common dilemma requires that the user trade off model accuracy against simulation cost. The size of the ACR model, in terms of finite element nodes, required that the integration method be among the least sophisticated so that reasonably low computer costs result.

The CSMP format requires that the model be expressed in three parts. Boundary and initial conditions are input directly or calculated in the first section called "INITIAL." The coupled differential equations and intermediate calculations are contained in a section entitled "DYNAMIC." Solution monitoring, time step changes and output instructions are located in the "TERMINAL" section. Subroutines, called MACRO's in CSMP, are physically located prior to the INITIAL section and can be called from either the INITIAL or DYNAMIC sections as required. CSMP also has a table look-up capability with several interpolation options. A full description of CSMP is well beyond the scope of this report. The interested reader is referred to Reference 3 for more detailed CSMP information. It is hoped that the foregoing discussion will allow a reasonable understanding of CSMP such that the code listing in Appendix A will be understandable.



B. MODEL FEATURES, GENERAL DESCRIPTION AND ASSUMPTIONS

For purposes of thermal analyses, certain large components of the ACR system, contained within the previously described scope, are divided into finite elements, and each element represented by a node. A nodal diagram is shown in Figure 2. The components which are so divided include the receiver, the receiver riser piping, and the receiver downcomer piping. The hot and cold storage tanks, the receiver outlet tank, the receiver pump, and suction pipe and the drag valve and its discharge pipe are all treated as single nodes for purposes of thermal analyses.

The receiver riser pipe is divided into 10 equal axial sodium nodes which are considered to be ideally insulated. Each axial node's response is determined by first order dynamics and is subject to input only from the upstream sodium node.

The receiver downcomer is similarly divided into five axial sodium nodes. The characteristic time constants of the riser and downcomer nodes are variable as the hydraulic conditions of the system change.

The receiver section of the model is more complicated. In the riser and downcomer, flow is considered possible only in one direction. The receiver panels, each of which is modeled, can experience flow reversals if the receiver is isolated from the pump and hot tank. Thus, each receiver panel model subsection has reverse flow thermal as well as hydraulic capabilities built in. Each panel is considered to be thermally independent (i.e., ideally insulated back side) along its length, but is hydraulically coupled at each end. Thus, panel thermal interaction is due totally to hydraulically coupled perturbations.

Each panel is divided into three axial sections, each section consisting of a tubing or wall node and sodium node. The differential equation describing each node's temperature is derived from an energy balance taken around each node. Thermal losses from the wall nodes




Figure 2. Advanced Central Receiver
Transient Model Schematic



include reflection, reradiation to ground and sky, and convection to air. The film coefficient of the convection loss term can be circumferentially and time varied to simulate the receiver boundary conditions due to wind variation, if required. The incident receiver flux can also be circumferentially, axially, or time varied so simulate heliostat field design variations, cloud cover passage, or the effect of various aim point strategies. Panel wall node physical properties are assumed constant, but sodium properties and film coefficients are allowed to vary with temperature.

Each receiver panel is assumed to empty into the receiver outlet tank, and the tank is a small enough volume that it is assumed to mix ideally. Ideal mixing is also assumed for the hot and cold tanks.

Temperature rises of the sodium due to inefficiencies in the receiver pump and pressure drop in the drag valve are considered and included in the model. Changes in these rises are assumed to occur instantaneously.

For purposes of hydraulic simulation, three flow sections are considered. The first section runs from the cold tank surface to the point where the sodium flow splits to each panel. The second section runs from where the receiver panels diverge to where they converge. The third section includes the sodium from the receiver outlet tank surface to the hot tank surface.

For each section, the derivative of flow is determined from a force balance around that section. This method can accommodate reverse flow without methodology modification. One force balance is required for each panel as well as the receiver downstream and upstream sections. At the interface of the receiver and its upstream section (i.e., the receiver inlet manifold), no free surface and, therefore, no arbitrary pressure exists. Therefore, the continuity equation must be utilized to obtain pressure. Pressure drops are neglected in the receiver inlet and outlet manifolds.



For purposes of panel flow and receiver outlet tank level control, Proportional plus Integral (reset) plus Derivative control schemes are built in. Any combination of the above can be selected. The problem of integral wind-up, wherein the demanded valve position is greater than open or less than closed is resolved in the model through the use of appropriate logic. Valve pressure drop is calculated by means of standard equations developed by Kern.⁽⁴⁾

C. SPECIFIC EQUATIONS

1. Thermal (Section 3.3)

All temperatures are derived by integrating the time derivative of the temperature developed from a first law or energy balance equation for each node generally given by

$$\left\{ \begin{array}{l} \text{Accumulation of} \\ \text{energy within} \\ \text{the system} \end{array} \right\} = \left\{ \begin{array}{l} \text{Transfer of energy} \\ \text{into the system through} \\ \text{system boundary} \end{array} \right\} - \left\{ \begin{array}{l} \text{Transfer of energy} \\ \text{out of the system} \\ \text{through system boundary} \end{array} \right\} + \left\{ \begin{array}{l} \text{Energy generation} \\ \text{within the system} \end{array} \right\} - \left\{ \begin{array}{l} \text{Energy consumption} \\ \text{within the system} \end{array} \right\}^{(5)} \quad (1)$$

Since there is no significant internal generation or consumption in any of the nodes, the last two terms zero out. For a given node the term on the left side of the equation becomes

$$\text{Accumulation} = dMTc_p/dt \quad (2)$$

where M = mass of node*
T = temperature of node
Cp = heat capacity of node
t = time

In all cases, the Cp of the node is assumed constant for at least each time step, thus Equation 2 becomes

$$\text{Accumulation} = C_p dMT/dt \quad (3)$$

*Units are defined in the variable index in Appendix A



In most cases, the volume of the node is fixed and the density assumed to be constant over the time interval of interest. Hence, Equation 2 becomes

$$\text{Accumulation} = MCpdT/dt \quad (4)$$

The exception to this is the tanks, which are either draining and filling and, therefore, subject to changing volume and mass, in which case Equation 2 become

$$\text{Accumulation} = Cp(TdM/dt + MdT/dt) \quad (5)$$

The right hand terms of Equation 1 including energy transfer to and from the system depend upon the node at hand and will be considered on an individual basis below

a. Receiver Tube Nodes (Section 3.3.1.1)*

Solar energy absorbed by the nodes is given by

$$Q_a = Q_i \alpha - Q_r - Q_c \quad (6)$$

where

- Q_a = Incident power absorbed
- Q_i = Incident power
- α = Tube Absorbtivity (constant)
- Q_r = Reradiated power
- Q_c = Convection power losses

Q_i is determined by

$$Q_a = P_p \times P_f \quad (7)$$

*Refers to numbering system of Code in Appendix A



where

$$\begin{aligned}
 P_p &= \text{Circumferential varying panel power} \\
 P_p &= R_p \times N_{pp} \quad (8) \\
 R_p &= \text{Total receiver power} \\
 N_{pp} &= \text{Panel power fraction} \\
 P_f &= \text{Axial position power fraction}
 \end{aligned}$$

$$Q_r = (\alpha \sigma A_{rr} [(T_g^4 - T_s^4) + (T_s^4 - T_g^4)]) / s \quad (9)$$

where

$$\begin{aligned}
 \sigma &= \text{Stephan/Boltzman Constant} \\
 A_{rr} &= \text{Node reradiation area} \\
 T_g &= \text{Ground temperature} \\
 T_s &= \text{Sky temperature}
 \end{aligned}$$

Note that a view factor of 1/2 was used for sky and ground, respectively.

$$A_c = \text{HFA} \times A_{rr} (T - T_A) \quad (10)$$

where

$$\begin{aligned}
 \text{HFA} &= \text{Receiver outside surface film coefficient} \\
 T_A &= \text{Ambient Air Temperature}
 \end{aligned}$$

Energy transferred from the tube nodes to the sodium is given by

$$\text{Energy transferred} = \text{HARN} (T - T_N) \quad (11)$$

where

$$\begin{aligned}
 \text{HARN} &= \text{Sodium film coefficient (variable) x tube sodium} \\
 &\quad \text{side area (calculated from the Seban-Shimiyaki} \\
 &\quad \text{correlation in a macro)} \\
 T_N &= \text{Sodium temperature}
 \end{aligned}$$



Combining Equations 4, 6, and 11 yields the equation for the derivative of tube wall temperature

$$dT_W/dt = (Q_a - HANR (T_W - T_N))/(MCp) \quad (12)$$

where

T_W = Temperature of the tubing wall

b. Receiver Sodium Node Temperature (Section 3.3.1.2)

The energy transferred to a receiver sodium node is equal to the energy transferred from the adjacent receiver tubing node and is described by Equation 11.

Energy is transferred from the sodium node by sensible heat gain of the sodium leaving the node.

$$\text{Energy transferred from system} = |\dot{m}| Cp (T_{NI} - T_{NO}) \quad (13)$$

where

$|\dot{m}|$ = Absolute value of flow of sodium through node

Cp = Sodium heat capacity

T_{NI} = Sodium node inlet temperature

T_{NO} = T_N = Sodium node outlet temperature

If the flow direction in any panel reverses, the physical inlet to the node changes. To accommodate this, the inlet temperature of each sodium node is selected by an input switch function depending on the flow direction. Each sodium node is assumed to mix ideally, resulting in a uniform node temperature equal to the outlet temperature. Utilization of the absolute value of flow keeps the sense of direction of energy flow correct since the inlet-outlet temperature difference provides the driving potential and energy direction sign.



Combining Equations 4, 11, and 13 yields the expression for the derivative of a receiver sodium node.

$$dT_N/dt = (HANR (T_W - T_N) + |\dot{M}| Cp (T_{NI} - T_N)) / (V_N \rho_N Cp) \quad (14)$$

where

- V_N = Volume of the sodium node
- ρ_N = Sodium density
- Cp = Sodium heat capacity
- T_N = Sodium temperature

c. Riser Piping (Section 3.3.2.2)

The equation describing the derivative of the outlet temperature of each riser piping node is:

$$dT_{NR}/dt = |\dot{M}| / M (T_{NRI} - T_{NR}) \quad (15)$$

where

- T_{NR} = Riser node sodium outlet temperature
- T_{NRI} = Riser node sodium inlet temperature

This is the classical equation describing a first order lag-type dynamic situation; however, the time constant is allowed to vary with the flow. This provides a more accurate picture of the riser dynamics.

d. Receiver Pump (Section 3.3.2.3)

The temperature rise due to viscous heating is assumed to be a quasi-steady-state phenomenon. The equation describing the outlet temperature is:

$$T_{RP\theta} = T_{RPI} - H_{RP}/\rho C_p (1 - 1/\eta) \quad (16)$$

where

- $T_{RP\theta}$ = Receiver pump outlet temperature
- T_{RPI} = Receiver pump inlet temperature
- η = Receiver pump hydraulic efficiency

The receiver pump efficiency is assumed to be .75 of the normalized pump sodium flow.

e. Cold Tank to Receiver Pump (Section 3.3.2.4)

The cold tank-to-receiver pump piping temperature dynamics are similar to the riser dynamics. The equation describing the dynamics is similar to Equation 15.

f. Cold Tank

Since the level of the cold tank is variable, the changing mass of the cold tank must be accounted for as noted in Equation 5. The equation for the cold tank outlet temperature derivative is:

$$dT_{CT}/dt = (\dot{M}_i T_i - \dot{M}_o T_{CT} - dM/dt T_{CT})/M C_p \quad (17)$$

where

- T_{CT} = Cold tank temperature
- \dot{M}_i = Cold tank sodium inlet flow
- T_i = Cold tank sodium inlet temperature
- \dot{M}_o = Cold tank sodium outlet flow

dM/dt is determined from the continuity equation.

g. Downcomer Piping (Section 3.3.2.6)

The downcomer piping node temperature equations are the same as the riser equation. See Equation 15.

h. Pressure Reducing Device (Section 3.3.2.7)

The viscous heating of sodium due to pressure drop across the drag valve is assumed to be quasi-steady-state process similar to the rise across the receiver pump. However, in this case all of the pressure drop is converted to heat by the equation

$$T_{DVO} = T_{DVI} + P_{DV} \times 144 / (778 \rho C_p) \quad (18)$$

where

$$\begin{aligned} T_{DVO} &= \text{Drag valve outlet temperature} \\ T_{DVI} &= \text{Drag valve inlet temperature} \\ P_{DV} &= \text{Drag valve pressure drop} \end{aligned}$$

i. Pressure Reducing Device to Hot Tank (Section 3.2.1.8)

The hot tank inlet temperature piping equation is similar to the riser piping temperature equation. See Equation 15.

j. Hot Tank (Section 3.2.1.9)

The hot tank temperature derivative equation is similar to the cold tank equation. See Equation 17.

k. Sodium Film Coefficients and Properties (Section 3.1)

The sodium film coefficients for all sodium convective heat transfer in the receiver is determined by the Seban-Shimazaki correlation:



$$\text{Nu} = 5.0 + 0.025(\text{RePr})^{.8} \quad (19)$$

where

Nu = Nusselt Number

$$\text{Nu} = \frac{\text{H} \times \text{D}}{\text{K}}$$

H = Film coefficient

D = Tube diameter

K = Sodium thermal conductivity

Re = Reynolds Number

Pr = Prandtl Number

This correlation includes thermal conductivity and is useful at low flows. Sodium properties are determined from correlations supplied by Reference 6. The correlation for heat capacity is:

$$\text{Cp} = 0.364 - 0.792 \times 10^{-4}\text{T} + 0.341 \times 10^{-7}\text{T}^2 \quad (20)$$

The correlation for thermal conductivity is:

$$\text{K} = 54.306 - 0.01878\text{T} + 2.09 \times 10^{-6}\text{T}^2 \quad (21)$$

The correlation for viscosity is:

$$\text{Log}_{10} \mu = 1.0203 + 397.17/\text{T} - 0.4925 \text{log}_{10}\text{T} \quad (22)$$

All of the above correlations are handled as macros which are called as required from the DYNAMIC sections. These macros are physically located in Section 1.0.



2. Hydraulics (Section 3.2)

The flow in a given flow channel is determined by integrating flow acceleration as determined by a force balance between two points in the flow path. The general equation is:

$$\Sigma F = Ma \quad (23)$$

where

- ΣF = Summation of the forces exerted on the fluid
- M = Mass of Sodium between Points 1 and 2
- a = Acceleration of fluid between Points 1 and 2
which is given by

$$a = dV/dt \quad (24)$$

Instantaneous velocity is given by:

$$V = \dot{M}/\rho A \quad (25)$$

noting that the mass of the fluid accelerated is given by:

$$M = \rho AL \quad (26)$$

where

- V = fluid velocity
- A = Flow area
- L = Flow path length

and combining Equations 23, 25, and 26 yields

$$\rho AL d(\dot{M}/\rho A)/dt = \Sigma F \quad (27)$$



ρ and A are assumed constant and Equation 27 becomes

$$L \dot{m}/dt = \Sigma F \quad (28)$$

dividing by gA to convert to force per unit flow area and lbf to lbm yields the expression for flow acceleration

$$d\dot{M}/dt = (gA/L) \Sigma F \quad (29)$$

where

g = acceleration due to gravity

it is often numerically convenient to express the flow referenced to steady-state as a fraction

$$\dot{M}_f / \dot{M}_0 = \dot{M} \quad (30)$$

where

\dot{M}_f = Fraction of reference flow
 \dot{M}_0 = Reference flow

Substituting Equation 30 into 29 and dividing through by \dot{M} yields the form of Equation 29 used in the model.

$$d\dot{M}_f/dt = (gA/L\dot{M}_0) \Sigma F \quad (31)$$

g , A, L and \dot{M}_0 are all easily calculated constants or initial conditions and are lumped into a term called the flow inertia.

$$I_f = \dot{M}_0 L / gA$$

where

I_f = Flow inertia.

a. Receiver Panel and Riser Flow (Section 3.2.1.1.1)

For any receiver panel, the inlet pressure is the same as any other panel since all panels start from a common point and manifold losses are assumed to be negligible. The same is true for the receiver outlet pressure. The equation for the i th panel is:

$$d\dot{M}_i/dt = (\text{PIR} - \text{POR} - \text{FH}_i - \text{DPCV}_i - \text{SH}_i)/I_{f_i} \quad (32)$$

where

PIR = Common panel inlet pressure
 POR = Common panel outlet pressure
 FH_i = Panel i friction head
 DPCV_i = Panel i control valve head
 SH_i = Panel i static head
 \dot{M}_i = Panel i flow

POR is determined from the static head in the receiver outlet tank.

Each panel friction head is approximated by

$$\text{FH}_i = \text{KF}_i |\dot{M}_i| \times \dot{M}_i \quad (33)$$

where

KF_i = steady-state flow friction drop. The absolute value function causes the sign of the friction drop to automatically change during panel flow reversal.

The expression for control valve head is given by:

$$\text{DPCV}_i = \frac{\rho}{\rho_w} q |h| / \text{CVC}^2 \quad (34)$$

where

ρ/ρ_w = Specific gravity of sodium



Q = Sodium volumetric flow
CVC = Control valve flow coefficient
(See control model description)

The equation for panel static head is:

$$SH_i = (E_o - E_i) \bar{\rho} / 144 \quad (35)$$

where

E_o = Panel outlet elevation
 E_i = Panel inlet elevation
 $\bar{\rho}$ = Average panel density

The riser flow equation is written in a manner similar to the panel flow equations. However, only one equation is required. The equation is:

$$\frac{dM_f}{dt} = (POCT - PIR + (E_i - E_o) \bar{\rho} / 144 - \dot{M}_f |M_f| KFH_R + H_{RP}) / I_R \quad (36)$$

where

POCT = Ullage pressure of cold tank
 E_i = Cold tank level elevation
 E_o = Receiver inlet elevation
 KFH_R = Steady-state riser friction drop
 H_{RP} = Receiver pump head
 I_R = Riser inertia

b. Receiver Outlet Tank and Cold Tank (Sections 3.2.1.1.2 and 3)

In these sections the time varying inventories and levels are determined by a simple integration of the continuity equation

$$dm/dt = \sum \dot{M}_i - \sum \dot{M}_o \quad (37)$$



c. Receiver Pump (Section 3.2.1.1.4)

The receiver pump speed is determined by integrating the equation

$$dN/dt = K_{RP}(\tau_m - \tau_p) \quad (38)$$

where

- N = Receiver pump speed (normalized)
- K_{RP} = 1/receiver pump inertia
- τ_m = Receiver pump motor output torque (normalized)
- τ_p = Receiver pump torque required (normalized)

The expression for required receiver pump torque was determined by fitting the speed-torque-flow curves for a typical sodium pump. The expression is

$$\tau_p = C_1 N^2 + C_2 \dot{M}_f N + D_3 \dot{M}_f^2 \quad (39)$$

where

C_1 , C_2 , and C_3 are the coefficients required to fit the speed-torque-flow curve. Similarly, the expression for receiver pump head is

$$H_{RP} = C_1 N^2 + C_2 N \dot{M}_f + C_3 \dot{M}_f^2 \quad (40)$$

where

C_1 , C_2 , and C_3 are the coefficients required to fit the speed-flow-head curve characteristics of the modeled receiver pump. Receiver pump head is limited to 120% of the design head.

d. Riser Pressure (Section 3.2.1.1.5)

Determining the riser outlet/receiver inlet pressure is critical to the solution of Equations 32 and 36. This pressure is determined from the derivative of the continuity equation:

$$\dot{M}_R = \sum_{i=1}^{24} \dot{M}_i \quad (41)$$

where

$$\begin{aligned} \dot{M}_R &= \text{Riser flow} \\ \dot{M}_i &= \text{Panel } i \text{ flow} \end{aligned}$$

taking the derivative of Equation 41 yields

$$d\dot{M}_R/dt = d(\sum_{i=1}^{24} \dot{M}_i)/dt = \sum_{i=1}^{24} d\dot{M}_i/dt \quad (42)$$

The left side of Equation 42, when expanded is similar to Equation 36. When expanded, the right side of Equation 42 is similar to Equation 32. The differences are due to Equations 32 and 36 being expressed as normalized flow. When Equations 32 and 36 are multiplied through by the reference flow and substituted into Equation 42, the result is:

$$\begin{aligned} &(\text{POCT} + (E_1 - E_0)\bar{P}/144 - \dot{M}_f |\dot{M}_f| \text{KFH}_R + H_{RP})/\text{LOGAR} = \\ &\sum_{i=1}^{24} (\text{PIR} - \text{POR} - \text{FH}_i - \text{DPCV}_i - \text{SH}_i)/\text{PLOGA} \end{aligned} \quad (43)$$

where

$$\text{LOGAR} = I_R \dot{M}_{ro} \quad (44)$$

and

$$\text{PLOGA} = I_f \dot{M}_{i0} \quad (45)$$



Solving Equation 43 for the receiver inlet pressure yields:

$$\begin{aligned} \text{PIR} = & \left((24 \times \text{POR} + \sum_{i=1}^{24} \text{SH}_i + \text{FH}_i + \text{DPCV}_i) / \text{PLOGA} + \right. \\ & \left. (\text{POCT} + (\text{E}_i - \text{E}_0) \bar{\rho} / 144 - \dot{M}_f / \dot{M}_f | \text{KFH}_R + \text{H}_{\text{RP}}) / \text{LOGAR} / \right. \\ & \left. (24 / \text{PLOGA} + 1 / \text{LOGAR}) \right) \end{aligned} \quad (46)$$

which is the form used in the model. Equation 46 is not used at very low or zero riser flow due to numerical methods considerations. At low flow, Equation 46 is simplified to:

$$\text{PIR} = \left(\sum_{i=1}^{24} \text{FH}_i + \text{SH}_i + \text{DPCV}_i \right) / 24 + \text{POR} \quad (47)$$

e. Downcomer Flow (Section 3.2.1.1.6)

The force balance used to describe the downcomer flow is taken between the receiver outlet tank surface and the hot tank surface. The expression is

$$\dot{dM}_{\text{FDC}} / dt = (\text{POROT} - \text{POHT} - \text{FH}_{\text{DC}} - \text{DP}_{\text{DV}} - \text{SH}_{\text{DC}}) / I_{\text{DC}} \quad (48)$$

where

- \dot{M}_{FDC} = Downcomer fractional flow
- POROT = Receiver outlet tank ullage pressure
- POHT = Hot tank ullage pressure
- FH_{DC} = Downcomer friction head
- DP_{DV} = Drag valve head
- SH_{DC} = Downcomer static head

The equations describing the friction, static and drag valve heads are the same as those used in the panel friction, static, and control valve heads.



f. Hot Tank (Section 3.2.1.1.7)

See "Receiver Outlet Tank and Cold Tank."

3. Plant Protection and Control System (Section 3.4)

The plant protection and control model consists of receiver panel controllers and a drag valve controller. Each controller model has the capability of simulating any combination of all three control nodes (proportion, integral, or derivative).

a. Receiver Panel Controllers

The valve position demanded by a given controller is fundamentally expressed as a function of receiver outlet panel temperature error is:

$$VPOX_i = \int_0^t EIR_i \times KC_i \mathcal{I}_i dt + K_C \mathcal{D}_i dT_i/dt + K_C ET_i \quad (49)$$

where

- $VPOX_i$ = Valve position demanded by controller for Panel i
- EIR_i = integral error of Panel i
 - = ET for $0 < VPOX_i < 1$
 - = 0 for $1 < VPOX_i < 0$
 - (prevents integral windup)
- KC_i = Proportional constant for Panel i controller
- \mathcal{I}_i = Integral time (1/reset rate) Panel i controller
- \mathcal{D}_i = Derivative time, Panel i controller
- T_i = Panel i outlet temperature
- ET_i = Panel i outlet temperature error.

In addition to Equation 49, the outlet temperature of each panel is processed by first order dynamics to simulate thermocouple signal lag. Also, the demanded valve position is also processed by first order dynamics to simulate the valve actuator. The flow coefficient for each valve is determined from the equation:



$$CVC = .025 \frac{(3.67 \times VP_i)}{CV} \quad (50)$$

where

VP_i = Actual valve position, Panel i
 CV = Design valve flow coefficient, Panel i

Note the equal percentage valves are used and Equation 50 is a curve fit from Reference 7 describing flow coefficient as a function of valve position. The values of KC_i , T_i and T_{Di} were determined from the methodology outlined in Reference 8 and are considered optimum.

b. Pressure Reducing Device Controller (Section 3.4.2)

The equations describing the drag valve controller response are similar to those describing the panel valve controllers. The only difference is that the error is provided by the level of the receiver outlet tank. Again, the constants K_c , T_c , T_D were determined by the methodology of Reference 8.

4. Boundary and Initial Conditions (Section 2)

This section inputs known constants and calculates boundary and initial conditions. Initial conditions used in integrals in the dynamic section are calculated using equations similar to the various differential equations but with the derivatives set to zero. For example, a typical receiver tubing node temperature is:

$$T_W = Q_a / HARN + T_N \quad (51)$$

In this example, the associated sodium node temperature, T_N , must be known. This requires an iterative solution in this case. Guesses of sodium node temperatures are input and the true values are determined by converging on the correct value of Q_a . In most cases, iterative



processes are not required to determine boundary and initial conditions since the required inputs have been previously determined. The numbering system of the initial section is keyed to that of the dynamic section. Hence, the boundary and initial conditions required by Section 3.3.2.6 are contained in Section 2.3.2.6. A listing of the model followed by a variable and function index, defining all variable and function names and units, is located in Appendix A.



III. RESULTS

The transients examined using the ACR model included: A 10% step change in incident flux, a cloud cover transient, 25% step-ramp changes in incident flux, loss of receiver pump power, accidental drag valve function, and an emergency shutdown incident flux ramp. The Cathode Ray Tube (CRT) output for each transient is presented in Appendix B-G, respectively. The response of the model to each of these perturbations will be discussed individually. For each of the transients examined, except for cloud cover, the following parameters were graphed as functions of time: incident power, absorbed power, riser flow, receiver outlet tank temperature, cold tank temperature, pump inlet and outlet temperature, receiver inlet temperature; south, east-west and north panel incident power, valve position, flow, outlet temperature, and mid-plane tube temperature, drag valve inlet temperature, drag valve outlet temperature, hot tank inlet and outlet temperatures, drag valve position, downcomer flow, receiver outlet tank level and error, normalized pump speed and head, receiver inlet and outlet pressures, and hot and cold tank levels. The CRT's for each run are presented in the previously indicated order with a legend at the top of each defining variable names and units.

Due to computer perversity, the CRT output for the cloud cover transient was not generated. The graph presented for this run is a hand-drawn plot of digital information obtained from the printed output. The significant response parameters for all runs are summarized in Table I.

A. RESPONSE TO 10% STEP CHANGE IN INCIDENT FLUX

The purpose of this run was to test the response of the panel control system. A 10% step change in control system input is a standard perturbation used to test the response of the control system. It is important to note that with the ACR system such a transient would never occur due to limitation on heliostat steer-off rates. The transient was



TABLE I - TRANSIENT PARAMETER SUMMARY

<u>Transient</u>	<u>10% Step</u>	<u>Cloud Cover</u>	<u>25% Step</u>	<u>Pump** Trip</u>	<u>Drag Valve Failure</u>	<u>Emergency Shut-Down</u>
Receiver Outlet Variation (°F)	6	5	6	7400	NA	8
Panel Outlet Variation (°F)	12	NA	25	7500	NA	12
Tube Ramp* (°F)	8	NA	20	7160	NA	5
Max. Receiver Inlet Pressure (psia)	100	NA	150	70	70	170
Receiver Outlet Tank Level Variation ft	.4	NA	2.5	.2	5	1
Minimum Receiver Inlet Pressure (psia)	70	70	70	33	70	70

*All controlled tube ramps lasted less than 100°F
**Uncontrolled transient

hgw: 5/1

FORM 719-P REV. 7-78



initiated at 5 seconds, and a total of 100 seconds of system response was examined. The Cathode Ray Tube (CRT) graphs of the system response are shown in Appendix B. The overall system response, shown on the first sheet, indicates a receiver outlet tank temperature variation of less than 6°F. Representative panel responses (Sheets 3-5) show overall panel outlet temperature variations of less than 8, 10, and 12°F, respectively. Ring down of all controlled panel temperatures occurs in less than 3 cycles. This indicates that the panel response is satisfactory and the control settings for gain, derivative time, and reset rate are optimum. The maximum wall temperature variation is approximately 20°F in 3 seconds. However, it should be noted that actual step changes in flux are impossible and that these ramps represent the worst case situation. Most realistic runs show wall ramps of lower magnitude. The remaining system variations in temperature were of an insignificant magnitude. The response of the receiver outlet tank indicated sluggish drag valve function. This was corrected by increasing the drag valve controller integral reset rate. Due to the closing of the panel valves, the receiver inlet pressure increased from 70 to 100 psia.

B. RESPONSE TO CLOUD COVER TRANSIENT

The purpose of this run is to verify adequate system response to a typical cloud cover. The cloud was approximated by a 1%/sec ramp to zero incident power initiated at 5 seconds. The inverse ramp of 1%/sec to 100% power was started at 105 seconds. Total run duration was 250 seconds. The overall response of the system was smooth, with the absorbed power going negative at low incident power due to reradiation and reflection losses. The riser flow follows the ramp and overshoots on return to 100% power due to control valve travel limitations. The maximum variation in receiver outlet tank temperature was 5°F, indicating an acceptable control response.



C. RESPONSE TO 25% STEP (STEEP RAMP CHANGES)

The purpose of this run was to demonstrate the ability of the system to follow incident power changes of the type that might be imposed by electrical load variations. The ramp rate was 25% power in 15 seconds or 1-2/3%/second. A total of four changes were applied, two negative, followed by two positive. Each change was followed by 50 seconds of no change to allow the system to recover. The first change was initiated at 5 seconds. Total run time was 265 seconds. The CRT's are shown in Appendix D. The overall response of the system was satisfactory, with slight overshoots in riser flow and a maximum receiver outlet temperature variation of 6°F.

The pump outlet temperature increases approximately 7°F at 50% incident power due to increased head and decreased flow. The maximum panel outlet temperature variation was less than 25°F and occurred in the north panel due to the panel valve opening completely during the last positive ramp. This indicates panel interaction can cause nonlinearities in certain circumstances. However, the magnitude of the overshoot is acceptable. Wall temperature variations were severe in this transient, with the maximum variation occurring in the south panel. However, the ramps are not carried more than 100°F, so they are acceptable. All other system temperature variations were insignificant. The drag valve followed the changes and limited receiver outlet tank level error to ±2.5 ft. The maximum receiver inlet pressure achieved was 150 psia.

D. RESPONSE TO LOSS OF RECEIVER PUMP POWER

The purpose of this simulation was to explore the possibility of allowing passive heliostat defocusing during emergency conditions. The



pump motor was tripped at 5 seconds, and the flux allowed to follow a decay curve, supplied by the heliostat subcontractor, representative of a solar image drift-off due to heliostat power failure.

It was assumed that during this transient the drag valve would fail closed and the panel valves fail open. With the receiver isolated by a check valve soon after pump trip, natural circulation induced reverse flow in the cooler panels. The gradual power decay of the image drift-off is shown in the first sheet of Appendix E. Due to the large static head of the riser, riser flow decays to zero within 5 seconds of pump trip. Due to recirculation, the receiver outlet tank temperature rises to about 1500°F during the run duration of 100 seconds. The pump outlet temperature experiences a 30°F spike during pump trip. The receiver inlet manifold sodium boils 80 seconds after pump trip.

The model does not include latent heat transfer. Hence, it is invalid past boiling temperatures. However, the model is adequate for purposes of showing the response of the system up to boiling.

The response of the south panel shows a rapid flow decay and flow reversal at 4 seconds from pump trip. The sodium in this panel does not boil. The east-west panel flow also reverses, although not to the same magnitude as the south panel. The sodium in this panel also does not boil. The north panel flow does not reverse, but the sodium boils 15 seconds after pump trip. The tubing temperature plots rise rapidly to 1600°F and are meaningless past this point. The remaining system temperature variations are insignificant. The minimum receiver inlet pressure is 33 psia.

Clearly, passive defocusing is inadequate to prevent boiling in the receiver, an undesirable condition. As will be shown later, active defocusing is adequate. Another possibility is to provide an



inventory of cold sodium to prevent boiling. Preliminary calculations indicate that 5,000 gallons of sodium heated from 550 to 1500°F would suppress all receiver boiling. It should be noted receiver control is effectively lost when the pump does not supply adequate receiver inlet pressure.

E. RESPONSE TO ACCIDENTAL DRAG VALVE FUNCTION

The purpose of these runs was to determine the time available to take action following a drag valve failure. Two cases were considered: drag valve failed open and closed. Each failure was initiated at 5 seconds.

1. Drag Valve Fails Open

Over the run duration of 100 seconds, the temperature and flow variations were insignificant, and after 100 seconds about 1 foot of sodium remained in the receiver outlet tank. Even if no action were taken, the tank would merely drain. This would only present a problem if the pump failed subsequent to tank draining. The mild response of this transient is due to the nearly open steady-state valve position.

2. Drag Valve Fails Closed

The run duration was 30 seconds. Again, the temperature and flow variations were insignificant. However, the receiver outlet tank filled in 25 seconds. Clearly, active steer-off and pump trip measures must be initiated within 20 seconds of drag valve closure if receiver flow stoppage is to be avoided.

F. RESPONSE TO EMERGENCY SHUTDOWN

This transient was initiated at 5 seconds and included a 15 second ramp from 100 to 0% incident power (6-2/3%/sec). The run duration was 20 seconds. Pump trip was initiated at 20% riser flow.



The maximum temperature variation of the receiver outlet tank was 8°F, maximum panel outlet temperature variation was 30°F with the worst ramp, 12°F/sec carried for less than 20°F. Tube temperature ramps of 5°F/sec were experienced for less than 50°F. This response is acceptable. All other temperature variations were insignificant. Receiver outlet tank level variation was 1 foot. Maximum receiver inlet pressure was 170 psia.



IV. CONCLUSIONS AND RECOMMENDATIONS

Over the range of transients examined, the controlled receiver outlet tank temperature varied less than 8°F. The maximum panel sodium temperature variation was 30°F, less than 6% of the total panel rise. The maximum real life tube temperature ramp experienced in a controlled transient was less than 15°F/second. In no controlled case were these ramps carried for more than 50°F.

It was found that passive heliostat defocusing is inadequate in an emergency situation. Emergency power must be available for active heliostat steer-off. As an alternative, a cold sodium supply could be used to cool the receiver during a pump failure.

The control methodology of individually controlled panels is adequate for purposes of receiver control over the range of transients studied.



V. REFERENCES

1. Final Report - Conceptual Design of Advanced Central Receiver Power System - Sodium Cooled Receiver Concept - Volume II
2. N322TI123001, "PLBR Pool Plant Transient Analysis Model," W. W. Willcox, November 9, 1977, Energy Systems Group, Rockwell International, Canoga Park, California
3. SH19-7001-s, "Continuous System Modeling Program III (CSMP III) Program Reference Manual," IBM Program Number 5734- XS9, September 9, 1972
4. Kern, Robert, "Control Valves in Process Plants," Chemical Engineering, April 14, 1975
5. Himmelblan, David M., "Basic Principles and Calculations in Chemical Engineering," Third Edition, 1974, Prentice Hall, New Jersey
6. TDT 12083 (WHAN-D-3), "Standard FFTF Values for the Physical and Thermophysical Properties of Sodium," W. H. Yunker, Westinghouse Electric Corporation, Richland, Washington
7. Masoneilan Handbook for Control Valve Sizing, 5th Edition, Masoneilan, 1975
8. Cohen, G. H. and Coon, G. A., "Theoretical Consideration of Retarded Control," Transactions of the ASME, July 1953 American Society of Mechanical Engineers, New York



APPENDIX A

ADVANCED CENTRAL RECEIVER SIMULATION MODEL
COMPUTER CODE LISTING AND VARIABLE INDEX

FORM 719-P REV. 7-78

\$\$\$CONTINUOUS SYSTEM MODELING PROGRAM III VIM3 TRANSLATOR OUTPUT\$\$\$

TITLE	ADVANCED CENTRAL RECEIVER, SODIUM COOLED SOLAR/ELECTRIC	00000010
TITLE	POWER PLANT SIMULATION MODEL	00000020
TITLE	RUN 04-07 CLOUD COVER SIMULATION, 200 SECONDS	00000030
		00000040
*	CURRENT VERSION DATE JULY 13, 1978, DSN ACRPTM7.DAT	00000050
		00000060
		00000070
FIXED	KEEP, I, J, II, JJ, K, M, N, KK, L, LL, MM, NN, IJ, JI, JK, KJ, IK, KI, KL	00000080
		00000090
		00000100
*1,0	MACRO STATEMENTS	00000110
		00000120
*1.3.3.1	SEBAN-SHIMAZAKI EQUATION FOR SODIUM FILM COEFF.	00000130
MACRO	CP, HA=LKEQ(MDOT, T, AFLOW, D, A)	00000140
	TR=T+460.	00000150
	MULOG=1.0203+397.17/TR-0.4925*ALOG(0(TR)	00000160
	MU=10.**MULOG/3600.	00000170
	RED=MDOT*D/AFLOW/MU	00000180
	KNA=(54.306-0.01878*T+2.0914E-06*T**2)/3600.	00000190
	CP=0.34574-0.79226E-04*T+0.34086E-07*T**2	00000200
	PR=CP*MU/KNA	00000210
	NUN=5.0+0.025*(RED*PR)**.8	00000220
	H=NUN*KNA/D	00000230
	HA=H*A	00000240
ENDMACRO		00000250
		00000260
		00000270
MACRO	RHON=RHONA(TNA)	00000280
	RHON=59.566-7.9504E-03*TNA-.2872E-06*TNA**2+.06035E-09*TNA**3	00000290
ENDMACRO		00000300
		00000310
MACRO	CPSOD=CPNA(TSOD)	00000320
	CPSOD=0.34574-0.79226E-04*TSOD+0.34086E-07*TSOD**2	00000330
ENDMACRO		00000340
		00000350
		00000360
		00000370
*2,0	CONSTANTS RUN PARAMETERS AND INITIAL CONDITIONS	00000380
		00000390
*2.0.1	ARRAY DIMENSIONS	00000400
		00000410

ESG-79-2, Vol II, Book 2
L-39

38
N27100006

STORAGE	WNRR(24),HFA(24),NPP(24),HANR1(24),HANR2(24),HANR3(24),	...00000420
	QI1(24),QI2(24),QI3(24),PP(24),TNR10G(24),TNR20G(24)	...00000430
	TNR30G(24),SH(24)	...00000440
	QA1(24),QA2(24),QA3(24),CPMEAN(24),NOA1(24),NOA2(24)	...00000450
	QA3(24),WNRA(24),CP1(24),CP2(24),CP3(24),RHO1(24),RHO2(24),	...00000460
	RHO3(24),IR(24),NOA3(24),CV(24),VPOX(24)	...00000470
	KC(24),TAU(24)	...00000480
	TAUD(24),KFH(24),KFHC(24),FH(24),OPCV(24)	...00000490
		00000500
*2,1	INPUT AND BOUNDARY CONDITIONS	00000510
		00000520
INITIAL		00000530
		00000540
PROCEDURE	WNRR,TNR10,TNR20,TNR30,TRW10,TRW20,TRW30=INITC(TNR10G,	...00000550
	TNR30G,NPP,RPI,PF1,PF2,PF3,AREEF,MHBTUS,AFLO,DRTUBE,HART,	...00000560
	HFA,ALPHA,ASRA,TG,TS,TA,AR,TNR20G,TNR10)	00000570
DO 10	KK=1,24	00000580
	TNR10(KK)=TNR10G(KK)	00000590
	TNR20(KK)=TNR20G(KK)	00000600
	TNR30(KK)=TNR30G(KK)	00000610
	CPMEAN(KK)=.30296	00000620
	PP(KK)=NPP(KK)*RPI	00000630
	QI1(KK)=PP(KK)*PF1*MHBTUS	00000640
	QI2(KK)=PP(KK)*PF2*MHBTUS	00000650
	QI3(KK)=PP(KK)*PF3*MHBTUS	00000660
	QA1(KK)=QI1(KK)*AREEF	00000670
	QA2(KK)=QI2(KK)*AREEF	00000680
	QA3(KK)=QI3(KK)*AREEF	00000690
10	QA1(KK)=QA1(KK)+QA2(KK)+QA3(KK)	00000700
15	DO 20 LL=1,24	00000710
	WNRR(LL)=QA1(LL)/CPMEAN(LL)/550.	00000720
	CP1I,HANR1I=LKEQ(WNRR(LL),TNR10(LL),AFLO,DRTUBE,HART)	00000730
	TNR10(LL)=QA1(LL)/WNRR(LL)/CP1I+TNR10	00000740
	TRW10(LL)=QA1(LL)/HANR1I+TNR10(LL)	00000750
	CP2I,HANR2I=LKEQ(WNRR(LL),TNR20(LL),AFLO,DRTUBE,HART)	00000760
	TNR20(LL)=QA2(LL)/WNRR(LL)/CP2I+TNR10(LL)	00000770
	TRW20(LL)=QA2(LL)/HANR2I+TNR20(LL)	00000780
	CP3I,HANR3I=LKEQ(WNRR(LL),TNR30(LL),AFLO,DRTUBE,HART)	00000790
	TNR30(LL)=QA3(LL)/WNRR(LL)/CP3I+TNR20(LL)	00000800
	TRW30(LL)=QA3(LL)/HANR3I+TNR30(LL)	00000810
	CPMEAN(LL)=(CP1I+CP2I+CP3I)/3.	00000820
	OCR1=HFA(LL)*AR*(TRW10(LL)-TA)	00000830

```

OCR2=HFA(LL)*AR*(TRW20(LL)-TA) 00000840
OCR3=HFA(LL)*AR*(TRW30(LL)-TA) 00000850
TRW14=(TRW10(LL)+460.)*.4 00000860
TRW24=(TRW20(LL)+460.)*.4 00000870
TRW34=(TRW30(LL)+460.)*.4 00000880
QRG1=ASRA*(TRW14-TG) 00000890
QRG2=ASRA*(TRW24-TG) 00000900
QRG3=ASRA*(TRW34-TG) 00000910
QRS1=ASRA*(TRW14-TS) 00000920
QRS2=ASRA*(TRW24-TS) 00000930
QRS3=ASRA*(TRW34-TS) 00000940
QR1=(QRS1+QRG1)/2. 00000950
QR2=(QRS2+QRG2)/2. 00000960
QR3=(QRS3+QRG3)/2. 00000970
NQA1(LL)=QI1(LL)*ALPHA-QR1-QCR1 00000980
NQA2(LL)=QI2(LL)*ALPHA-QR2-QCR2 00000990
20 NQA3(LL)=QI3(LL)*ALPHA-QR3-QCR3 00001000
ERRFLG=0.0 00001010
DO 30 MM=1,24 00001020
ERROR1=ABS((NQA1(MM)-QA1(MM))/QA1(MM)) 00001030
ERROR2=ABS((NQA2(MM)-QA2(MM))/QA2(MM)) 00001040
ERROR3=ABS((NQA3(MM)-QA3(MM))/QA3(MM)) 00001050
IF (ERROR1.GT..001) ERRFLG=1.0 00001060
IF (ERROR2.GT..001) ERRFLG=1.0 00001070
IF (ERROR3.GT..001) ERRFLG=1.0 00001080
QA1(MM)=NQA1(MM) 00001090
QA2(MM)=NQA2(MM) 00001100
QA3(MM)=NQA3(MM) 00001110
30 QAI(MM)=QA1(MM)+QA2(MM)+QA3(MM) 00001120
IF (ERRFLG.GT.0.0) GO TO 15 00001130
WRITE(6,40) 00001140
40 FORMAT(54H1PANEL TNR10 TNR20 TNR30 TRW10 TRW20 TRW30/)00001150
WRITE(6,41)(MM,TNR10(MM),TNR20(MM),TNR30(MM),TRW10(MM), 00001160
TRW20(MM),TRW30(MM),MM=1,24) .. 00001170
41 FORMAT(I3,5X,6F8.2) 00001180
WRITE(6,42) 00001190
42 FORMAT(31H1PANEL QA1 QA2 QA3/) 00001200
WRITE(6,43)(MM,QA1(MM),QA2(MM),QA3(MM),MM=1,24) 00001210
43 FORMAT(I3,5X,3F9.2) 00001220
ENDPROCEDURE 00001230
PORI=POROT+SLROT*RHODCO/SINSFT 00001240
PIRI=PUCT+(LNACTO-LRI)*RHORPO/SINSFT-KFHPR+HRPO 00001250

```

ESG-79-2, Vol II, Book 2
L-41

40
N2721000006

LNACT0=MNACT0/RHOCT0/CACT	00001260
RHORP0=RHONA((TNCT0+TNRI0)/2,)	00001270
RHOCT0=RHONA(TNCT0)	00001280
	00001290
PROCEDURE KFHC, IR, VPI =HYDINT(KFH, WNRR, PLOGA, TNR10, TNR20, TNR30	00001300
PIRI, PORI, RH, SINSFT, LBSGPM, TNRI0, CV)	00001310
DO 50 NN=1, 24	00001320
KFHC(NN)=WNRR(NN)**2*KFH(NN)	00001330
IR(NN)=PLOGA*WNRR(NN)	00001340
RHO1I=RHONA(TNR10(NN))	00001350
RHO2I=RHONA(TNR20(NN))	00001360
RHO3I=RHONA(TNR30(NN))	00001370
SHI=RH*(RHO1I+RHO2I+RHO3I)/3./SINSFT	00001380
DPCVI=PIRI-PORI-KFHC(NN)-SHI	00001390
RHONRI=RHONA(TNRI0)	00001400
SGNRI=RHONRI/62.4	00001410
QI=WNRR(NN)*LBSGPM/SGNRI	00001420
ISRSG=SQRT(SGNRI)	00001430
CVCI=QI*ISRSG/SQRT(DPCVI)	00001440
50 VPI(NN)=1.00086+.272681*ALOG(CVCI/CV(NN))	00001450
WRITE(6, 1001)	00001460
1001 FORMAT(36H1PANEL WNRR KFHC IR VPI/)	00001470
WRITE(6, 1010)(NN, WNRR(NN), KFHC(NN), IR(NN), VPI(NN), NN=1, 24)	00001480
1010 FORMAT(I3, 5X, 4F8.2)	00001490
ENDPROCEDURE	00001500
	00001510
PROCEDURE WN0=WN0INT(ZERO, WNRR)	00001520
WN0=ZERO	00001530
DO 1020 JI=1, 24	00001540
1020 WN0=WN0+WNRR(JI)	00001550
ENDPROCEDURE	00001560
	00001570
	00001580
KFHRP=KFHRPR*WN0**2	00001590
RHOHT0=RHONA(TNHT0)	00001600
LNAHT0=MNAHT0/RHOHT0/CAHT	00001610
LROT0=MNR0T0/RHODC0/CAROT	00001620
RHODC0=RHONA(TNR00)	00001630
SHDCI=(LROT0+EBR0T-LNAHT0)*RHODC0/SINSFT	00001640
KFHDC=KFHDCR*WN0**2	00001650
DPDVI=SHDCI-KFHDC	00001660
SGDV=RHODC0/62.4	00001670

	QIDC=WNO*LSGPM/SGDV	00001680
	SRSGDV=SQRT(SGDV)	00001690
	CVCDV=QIDC*SRSGDV/SQRT(DPDVI)	00001700
	VPDVI=1.00086+.272681*ALOG(CVCDV/CVDV)	00001710
	WCTIR=2./3.*WNO	00001720
		00001730
*2,1,3,3.1	SODIUM FILM COEFFICIENTS	00001740
		00001750
CONST	AFLO=.2535 ,DRTUBE=.0542 ,HART=327.45	00001760
		00001770
*2,2,1,1.1	RECEIVER PANEL FLOW	00001840
		00001850
CONST	ZERO=0.0 ,LSGPM=7.1928 ,RH=55.48 ,SINSFT=144. ,...	00001860
	ONE=1.0, AREEF=.9	00001870
		00001880
*	LSGPM=CONVERSION LBM/SEC TO GAL/MIN	00001890
*	RH=RECEIVER PANEL HEIGHT (FT)	00001900
*	SINSFT=CONVERSION FACTOR SQ IN TO SQ FT	00001910
*	PIR=PRESSURE AT RECEIVER INLET (PSIA)	00001920
		00001930
TABLE	KFH(1)=9.68E-04,KFH(2)=9.50E-04,KFH(3)=9.13E-04 ,...	00001940
	KFH(4)=8.96E-04,KFH(5)=8.71E-04,KFH(6)=8.39E-04 ,...	00001950
	KFH(7)=8.02E-04,KFH(8)=8.11E-04,KFH(9)=8.03E-04 ,...	00001960
	KFH(10)=7.92E-04,KFH(11)=7.85E-04,KFH(12)=7.81E-04 ,...	00001970
	KFH(13)=7.85E-04,KFH(14)=7.92E-04,KFH(15)=8.03E-04 ,...	00001980
	KFH(16)=8.11E-04,KFH(17)=8.20E-04,KFH(18)=8.39E-04 ,...	00001990
	KFH(19)=8.71E-04,KFH(20)=8.96E-04,KFH(21)=9.13E-04 ,...	00002000
	KFH(22)=9.50E-04,KFH(23)=9.68E-04,KFH(24)=9.68E-04	00002010
		00002020
TABLE	CV(1-2)=2*76.,CV(3-5)=3*133.,CV(6)=224.,CV(7-9)=3*415. ,...	00002030
	CV(10-14)=5*640.,CV(15-17)=3*415.,CV(18)=224. ,...	00002040
	CV(19-21)=3*133.,CV(22-24)=3*76.	00002050
TABLE	WNR0(1-24)=24*1.0	00002060
		00002070
*2,2,1,1.2	RECEIVER OUTLET TANK	00002120
		00002130
INCON	MNROT0=40158.4	00002140
		00002150
	WDNR=WNO	00002160
		00002170
		00002180
CONST	CAROT=176.71	00002190

*2.2.1.1.3	COLD TANK	00002200
		00002210
INCON	MNACT0=8.4E06	00002220
		00002230
CONST	MCTI=1.0, CACT=7854.	00002240
		00002250
		00002260
*2.2.1.1.4	RECEIVER PUMP	00002270
		00002280
CONST	ST0=.0260, RT0=.0216	00002290
CONST	TA1=.58889, TA2=.63333, TA3=-.22222	00002300
CONST	HA1=1.22694, HA2=.05925, HA3=-.28619	00002310
CONST	KRP=.1956, TPT=1000.	00002320
INCON	NRP0=1.0	00002330
		00002340
	POCT=POROT	00002350
		00002360
		00002370
		00002380
*2.2.1.1.5	RISER PRESSURE	00002390
		00002400
CONST	LRI=663.0, LRRP=1100., G0=32.2, RRPCA=359.4, ...	00002410
	LRPSP=100.0, RPSPCA=875.7, KFMRPR=3.159E-06, ...	00002420
	HRP0=315.29, POROT=15.7	00002430
		00002440
	$IWN=WNO * LRRP / G0 / RRPCA + WNO * LRPSP / G0 / RPSPCA$	00002450
	$IWNRPS=WNO * LRPSP / G0 / RPSPCA$	00002460
	LOGAR=IWN/WNO	00002470
		00002480
*2.2.1.1.6	DOWNCOMER FLOW	00002490
		00002500
	POHT=PQRQT	00002510
		00002520
	$IDC=WDNR * LRDCP / G0 / RDCCA + WDNR * LRDVDP / G0 / DVDPCA$	00002530
		00002540
CONST	LRDCP=1100., LRDVDP=100.0, RDCCA=260.9, DVDPCA=260.9, ...	00002550
	KFHDCR=7.005E-06, CVDV=1445., EWR0T=718.5	00002560
		00002570
INCON	WDN0=1.0	00002580
*2.2.1.1.7	HOT TANK	00002590
		00002600
INCON	MNAHT0=8.4E06	00002610

N272T1000006
43

ESG-79-2, Vol II, Book 2
L-44

CONST	WHTD=1.0, CAHT=7854.0	00002620
	WHTOR=WCTIR	00002630
		00002640
		00002650
*2.3.1.1	RECEIVER TUBE NODE TEMPERATURES	00002660
		00002670
		00002680
FUNCTION	RPOWER=(0.,433.09),(5.,433.09),(15.,422.06),(25.,406.32),...	00002690
	(35.,384.27),(45.,352.77),(55.,314.97),(65.,267.33),...	00002691
	(75.,223.63),(85.,182.68),(95.,144.89),(105.,113.39),...	00002692
	(115.,81.9),(125.,59.84),(135.,42.52),(145.,28.35),...	00002693
	(155.,18.9),(165.,11.02),(175.,6.3),(185.,0.)	00002694
		00002695
		00002700
		00002710
CONST	ALPHA=0.95, ASRA=5.42E-11, TG=7.31E10, TS=7.31E10, ...	00002720
	TA=60., AR=120.17, MCPTH=78.87, PF1=.1964, ...	00002730
	PLOGA=.1584, MWTUS=948.06, RPI=433.09	00002740
		00002750
TABLE	HFA(1-24)=24*5.56E-04	00002760
		00002770
TABLE	NPP(1)=.0176, NPP(2)=.0187, NPP(3)=.02, NPP(4)=.0245, ...	00002780
	NPP(5)=.0313, NPP(6)=.0398, NPP(7)=.0493, NPP(8)=.0551, ...	00002790
	NPP(9)=.0614, NPP(10)=.0661, NPP(11)=.0705, NPP(12)=.0738, ...	00002800
	NPP(13)=.0705, NPP(14)=.0661, NPP(15)=.0614, NPP(16)=.0551, ...	00002810
	NPP(17)=.0493, NPP(18)=.0398, NPP(19)=.0313, NPP(20)=.0245, ...	00002820
	NPP(21)=.02, NPP(22)=.0187, NPP(23)=.0176, NPP(24)=.0176	00002830
CONST	PF2=.6072	00002840
		00002850
CONST	PF3=.1964	00002860
		00002870
TABLE	TNR10G(1-24)=24*658.0	00003040
TABLE	TNR20G(1-24)=24*992.	00003050
TABLE	TNR30G(1-24)=24*1100.	00003060
		00003070
*2.3.1.2	RECEIVER SODIUM NODE TEMPERATURES	00003080
		00003090
CONST	NVOL=4.434, NVOLIH=277.5	00003100
		00003110
		00003140
*2.3.2.1	RECEIVER OUTLET TANK TEMPERATURES	00003150
		00003160

INCON	TNRO=1101.9		00003170
			00003180
*2.3.2.2	RISER PIPING		00003190
			00003200
CONST	TAURN=8.42		00003210
			00003220
TABLE	TNRP0(1-9)=9*550.0		00003230
			00003240
INCON	TNRI0=550.		00003250
			00003260
*2.3.2.4	COLD TANK TO RECEIVER PUMP		00003310
			00003320
CONST	TAURPS=15.5		00003330
			00003340
INCON	TNCT0=549.0		00003350
			00003360
*2.3.2.5	COLD TANK		00003370
			00003380
CONST	WCTI=1.0, TNCTI=549.0		00003390
			00003400
*2.3.2.6	DOWNCOMER PIPING		00003410
			00003420
CONST	TAUDC=11.21		00003430
			00003440
TABLE	TNDC0(1-4)=4*1101.9		00003450
			00003460
*2.3.2.8	PRESSURE REDUCING DEVICE TO HOT TANK		00003470
			00003480
CONST	TAUDHT=3.94		00003490
			00003500
INCON	TNHTI0=1104.5		00003510
			00003520
*2.3.2.9	HOT TANK		00003530
			00003540
INCON	TNHT0=1104.5		00003550
			00003560
CONST	WHT0=1.0		00003570
			00003580
CONST	STR=1101.85 ,TAUTC=0.6 ,TAUVLV=0.3		00003590
			00003600
			00003610
			00003620

ESG-79-2, Vol II, Book 2
L-46

NP27100006
45

TABLE	KC(1)=.0142,KC(2)=.0132,KC(3)=.015,KC(4)=.013,KC(5)=.01	...	00003630
	KC(6)=.01,KC(7)=.011,KC(8)=.0102,KC(9)=.011,KC(10)=.013	...	00003640
	KC(11)=.014,KC(12)=.0151,KC(13)=.014,KC(14)=.013	...	00003650
	KC(15)=.011,KC(16)=.0102,KC(17)=.011,KC(18)=.01	...	00003660
	KC(19)=.01,KC(20)=.013,KC(21)=.015,KC(22)=.0132	...	00003670
	KC(23-24)=2*.0142		00003680
TABLE	TAU(1)=6.07,TAU(2)=5.802,TAU(3)=5.49,TAU(4)=4.84,TAU(5)=4.27	...	00003700
	TAU(6)=3.86,TAU(7)=3.62,TAU(8)=3.53,TAU(9)=3.47,TAU(10)=3.43	...	00003710
	TAU(11)=3.4,TAU(12)=3.39,TAU(13)=3.4,TAU(14)=3.43	...	00003720
	TAU(15)=3.47,TAU(16)=3.53,TAU(17)=3.62,TAU(18)=3.86	...	00003730
	TAU(19)=4.27,TAU(20)=4.84,TAU(21)=5.49,TAU(22)=5.8	...	00003740
	TAU(23-24)=2*6.07		00003750
			00003760
TABLE	TAUD(1)=.912,TAUD(2)=.873,TAUD(3)=.826,TAUD(4)=.728	...	00003770
	TAUD(5)=.645,TAUD(6)=.585,TAUD(7)=.55,TAUD(8)=.538	...	00003780
	TAUD(9)=.53,TAUD(10)=.524,TAUD(11)=.521,TAUD(12)=.52	...	00003790
	TAUD(13)=.521,TAUD(14)=.524,TAUD(15)=.530,TAUD(16)=.538	...	00003800
	TAUD(17)=.55,TAUD(18)=.585,TAUD(19)=.621,TAUD(20)=.728	...	00003810
	TAUD(21)=.826,TAUD(22)=.873,TAUD(23-24)=2*.912		00003820
			00003830
*2.4.2	PRESSURE REDUCING DEVICE CONTROLLER		00003920
			00003930
CONST	TAUDV=3.0, TAUDV1=69.93, KCDV=0.045, TAUDVD=11.1	...	00003940
	SLROT=4.50		00003950
			00003960
			00003970
*3.0	DYNAMIC SEGMENT		00003980
			00003990
DYNAMIC SEGMENT			00004000
			00004010
			00004020
*3.1	INPUT AND BOUNDARY CONDITIONS		00004030
			00004040
*3.1.3.3.1	SODIUM FILM COEFFICIENTS		00004050
			00004060
PROCEDURE	CP1,HANR1,RHO1,CP2,HANR2,RHO2,CP3,HANR3,RHO3,WNRA=HANR(WNR,...	...	00004070
	TNR1,TNR2,TNR3,AFLO,DRTUBE,HART,WNRR)		00004080
	DO 500 II=1,24		00004090
	WNRA(II)=ABS(WNR(II))*WNRR(II)		00004100
	X1,Y1=LKEQ(WNRA(II),TNR1(II),AFLO,DRTUBE,HART)		00004110
	CP1(II)=X1		00004120

HANR1(II)=Y1	00004130
Z1=RHONA(TNR1(II))	00004140
RHO1(II)=Z1	00004150
X2,Y2=LKEQ(WNRA(II),TNR2(II),AFLO,ORTUBE,HART)	00004160
CP2(II)=X2	00004170
HANR2(II)=Y2	00004180
Z2=RHONA(TNR2(II))	00004190
RHO2(II)=Z2	00004200
X3,Y3=LKEQ(WNRA(II),TNR3(II),AFLO,ORTUBE,HART)	00004210
CP3(II)=X3	00004220
HANR3(II)=Y3	00004230
Z3=RHONA(TNR3(II))	00004240
500 RHO3(II)=Z3	00004250
ENDPROCEDURE	00004260
CPH=CPNA(TNRI)	00004270
RP=AFGEN(RPOWER,TIME)	00004280
	00004290
*3.1.3.3.2.1 RECEIVER OUTLET TANK	00004300
	00004310
CPROT=CPNA(TNRO)	00004320
RHOROT=RHONA(TNRO)	00004330
MCPROT=MNAROT*CPROT	00004340
	00004350
*3.1.2.5 COLO TANK	00004360
	00004370
MCPCT=MNACT*CPCT	00004380
CPCT=CPNA(TNCT)	00004390
RHOCT=RHONA(TNCT)	00004400
	00004410
	00004420
*3.1.2.7 PRESSURE REDUCING DEVICE	00004430
	00004440
RHONDV=RHONA(TNOVI)	00004450
CPNDV=CPNA(TNOVI)	00004460
	00004470
*3.1.2.9 HOT TANK	00004480
	00004490
MCPHT=MNAHT*CPHT	00004500
CPHT=CPNA(TNHT)	00004510
RHOHT=RHONA(TNHT)	00004520
	00004530
	00004540

ESG-79-2, Vol II, Book 2
L-48

N2721000006
47

*3.2	HYDRAULICS	00004550
		00004560
*3.2.1	RECEIVER SYSTEM	00004570
		00004580
*3.2.1.1	RECEIVER SIDE SODIUM COMPONENTS	00004590
		00004600
*3.2.1.1.1	RECEIVER PANEL FLOW	00004610
		00004620
	WNR=INTGRL(WNR0,DWNR,24)	00004630
	SNARII=RHONA(TNRI)	00004640
	SNARI=SNARII/62.4	00004650
		00004660
	PROCEDURE DWNR=DW(PIR,POR,FH,DPCV,SH,IR)	00004670
	DO 2000 JJ=1,24	00004680
	2000 DWNR(JJ)=(PIR-POR-FH(JJ)-DPCV(JJ)-SH(JJ))/IR(JJ)	00004690
	ENDPROCEDURE	00004700
		00004709
	PROCEDURE SH,TSH=STATIC(EBROT,LRI,RHO1,RHO2,RHO3,SINSFT,WNR,ZERO)	00004710
	TSH=ZERO	00004711
	DO 1201 LL=1,24	00004712
	SH(LL)=(EBROT-LRI)*(RHO1(LL)+RHO2(LL)+RHO3(LL))/3./SINSFT	00004713
	1201 TSH=TSH+SH(LL)	00004714
	ENDPROCEDURE	00004715
		00004716
		00004730
	PROCEDURE FH,DPCV,TFHR,TFHCV=HEAD(ZERO,KFHC,WNR,WNRR,LBSGPM,SNARI,VP,CV)	00004740
	TFHR=ZERO	00004750
	TFHCV=ZERO	00004760
	DO 2050 LL=1,24	00004770
	FH(LL)=KFHC(LL)*WNR(LL)*ABS(WNR(LL))	00004780
	Q=WNR(LL)*WNRR(LL)*LBSGPM/SNARI	00004790
	CVC=,025465*EXP(3.667293*VP(LL))*CV(LL)	00004800
	DPCV(LL)=SNARI*Q*ABS(Q)/CVC**2	00004810
	TFHR=TFHR+FH(LL)	00004820
	2050 TFHCV=TFHCV+DPCV(LL)	00004830
	ENDPROCEDURE	00004840
		00004850
		00004860
	PROCEDURE WN=TEST(ZERO,WNI)	00004870
	IF (WNI.LT,ZERO)CALL DEBUG(1,0,0)	00004871
	WN=LIMIT(ZERO,2,0,WNI)	00004872
	ENDPROCEDURE	00004873

	WNI=INTGRL(WDNO,DWN)	00004880
	DWN=(POCT-PIR+(LNACT-LRI)*(RHOCT+SNARII)/2./SINSFT-WN*WNA* KFHRP+HRP*HRP0)/LOGAR/WNO	00004890
		00004900
		00004920
		00004930
*3.2.1.1.2	RECEIVER OUTLET TANK	00004940
		00004950
	DMNROT=WNIRT-WDN*WDNR	00004960
	PROCEDURE WNIRT=FLOROT(WNRR,WNR,ZERO)	00004961
	WNIRT=ZERO	00004962
	DO 2100 KL=1,24	00004963
	2100 WNIRT=WNIRT+WNRR(KL)*WNR(KL)	00004964
	ENDPROCEDURE	00004965
	MNAROT=INTGRL(MNROT0,DMNROT)	00004970
	LROT=MNAROT/RHOROT/CAROT	00004980
	POR=POROT+LROT*RHOROT/SINSFT	00004990
		00005000
		00005010
*3.2.1.1.3	COLD TANK	00005020
	DMNACT=WCTI*WCTIR-WN*WNO	00005030
	MNACT=INTGRL(MNACT0,DMNACT)	00005040
	LNACT=MNACT/RHOCT/CACT	00005050
		00005060
*3.2.1.1.4	RECEIVER PUMP	00005070
		00005080
	RPIP=POCT+LNACT*RHOCT/SINSFT	00005090
	NRPX=NRP	00005100
	SSRP=INSW(NRPX,0.0,1.0)	00005110
	TILL=INSW(NRP,STQ,RTQ)	00005120
	TIMRP=TA1*NRP**2+TA2*WN*NRP+TA3*WN*WNA	00005130
	TIMRPX=(1.0-RTQ)*TIMRP+TILL	00005140
	DNRP=KRP*(TIMRP-TIMRPX)+SSRP	00005150
	NRP=INTGRL(NRP0,DNRP)	00005160
	HRP=LIMIT(0.,1.2,HA1*NRP**2+HA2*WN*NRP+HA3*WN*WNA)	00005170
	RPOP=RPIP+HRP*HRP0	00005180
*3.2.1.1.5	RISER PRESSURE	00005190
		00005200
	PIRFLO=((24.*POR+TSH+TFHR+TFHCV)/PLOGA+(POCT+(LNACT-LRI)* (RHOCT+SNARII)/2./SINSFT-WN*WNA*KFHRP+HRP*HRP0)/LOGAR)/...	00005210
	(24./PLOGA+1./LOGAR)	00005220
	PIRSO=(TSH+TFHR+TFHCV)/24.+POR	00005235
	PIR=INSW(WN-.0001,PIRSO,PIRFLO)	00005236

ESG-79-2, Vol II, Book 2
L-50

N2721000006

*3.2.1.1.6	DOWNCOMER FLOW	00005240
		00005250
	DWDN=(POROT-POHT-FHDC-OPDV+SHDC)/IDC	00005260
	WDNA=ABS(WDN)	00005270
	WDN=INTGRL(WDN0,DWDN)	00005280
	FHDC=KFHDC*WDN*WDNA	00005290
	OPDV=QDC*ABS(QDC)/CYCDV**2*SNDV	00005300
	SNDV=RHONDV/62.4	00005310
	QDC=WDN*WDNR*LBSGPM/SNDV	00005320
	CYCDV=.025465*EXP(3.667293*VPDV)*CVDV	00005330
	SHDC=(LROT+EBROT-LNAHT)*RHOROT+RHONDV)/2./SINSFT	00005340
		00005350
		00005360
*3.2.1.1.7	HOT TANK	00005370
	DMNAHT=WDN*WDNR-WHTO*WHTOR	00005380
	MNAHT=INTGRL(MNAHT0,DMNAHT)	00005390
	LNAHT=MNAHT/RHOHT/CAHT	00005400
		00005410
*3.2.1.2	STEAM GENERATOR SODIUM COMPONENTS	00005420
		00005430
		00005440
*3.2.2	BALANCE OF PLANT	00005450
		00005460
*3.2.2.1	WATER SYSTEM COMPONENTS	00005470
		00005480
		00005490
		00005500
*3.3	HEAT TRANSFER	00005510
		00005520
*3.3.1	RECEIVER	00005530
		00005540
*3.3.1.1	RECEIVER TUBE NODE TEMPERATURES	00005550
		00005560
	TRW1=INTGRL(TRW10,DTRW1,24)	00005570
	TRW2=INTGRL(TRW20,DTRW2,24)	00005580
	TRW3=INTGRL(TRW30,DTRW3,24)	00005590
		00005600
		00005610
PROCEDURE	QI1,QA1,DTRW1,PP =DTR1(NPP,TRW1,TNR1,ALPHA,ASRA,TG,TS, ..	00005620
	TA,AR,HFA,MCPTW,PF1,HANR1,MWBUS,RP)	00005630
	DO 100 I=1,24	00005640
	PP(I)=NPP(I)*RP	00005650

ESG-79-2, Vol II, Book 2
L-51

N4721100006
5

```

QI1(I)=PF1*PP(I)*MWBTUS                                00005660
QCR1=HFA(I)*AR*(TRW1(I)-TA)                             00005670
TRW14=(TRW1(I)+460.)*4                                  00005680
QRG1=ASRA*(TRW14-TG)                                    00005690
QRS1=ASRA*(TRW14-TS)                                    00005700
QR1=(QRS1+QRG1)/2.                                      00005710
QA1(I)= QI1(I)*ALPHA-QR1-QCR1                           00005720
100 DTRW1(I)=(QA1(I)-HANR1(I)*(TRW1(I)-TNR1(I)))/MCPTH  00005730
ENDPROCEDURE                                             00005740
                                                           00005750
PROCEDURE QI2,QA2,DTRW2 = DTR2(TRW2,TNR2, ALPHA,ASKA,TG,TS, ... 00005760
      TA,AR,HFA,MCPTH,PF2,PP,HANR2,MWBTUS)              00005770
DO 101 J=1,24                                           00005780
QI2(J)=PF2*PP(J)*MWBTUS                                 00005790
QCR2=HFA(J)*AR*(TRW2(J)-TA)                             00005800
TRW24=(TRW2(J)+460.)*4                                  00005810
QRG2=ASRA*(TRW24-TG)                                    00005820
QRS2=ASRA*(TRW24-TS)                                    00005830
QR2=(QRS2+QRG2)/2.                                      00005840
QA2(J)= QI2(J)*ALPHA-QR2-QCR2                           00005850
101 DTRW2(J)=(QA2(J)-HANR2(J)*(TRW2(J)-TNR2(J)))/MCPTH  00005860
ENDPROCEDURE                                             00005870
                                                           00005880
PROCEDURE QI3,QA3,DTRW3 = DTR3(TRW3,TNR3,ALPHA,ASKA,TG,TS,TA,AR, ... 00005890
      HFA,MCPTH,PF3,PP,HANR3,MWBTUS)                   00005900
DO 102 K=1,24                                           00005910
QI3(K)=PF3*PP(K)*MWBTUS                                 00005920
QCR3=HFA(K)*AR*(TRW3(K)-TA)                             00005930
TRW34=(TRW3(K)+460.)*4                                  00005940
QRG3=ASRA*(TRW34-TG)                                    00005950
QRS3=ASRA*(TRW34-TS)                                    00005960
QR3=(QRS3+QRG3)/2.                                      00005970
QA3(K)=QI3(K)*ALPHA-QR3-QCR3                             00005980
102 DTRW3(K)=(QA3(K)-HANR3(K)*(TRW3(K)-TNR3(K)))/MCPTH  00005990
ENDPROCEDURE                                             00006000
PROCEDURE QI,QA=QIASUM(QI1,QI2,QI3,QA1,QA2,QA3,MWBTUS)  00006010
      QI=0.0                                              00006020
      QA=0.0                                              00006030
DO 200 N=1,24                                           00006040
QI=QI+(QI1(N)+QI2(N)+QI3(N))/MWBTUS                    00006050
200 QA=QA+(QA1(N)+QA2(N)+QA3(N))/MWBTUS                 00006060
ENDPROCEDURE                                             00006070

```

ESG-79-2, Vol 11, Book 2
 L-52

N271100006
 5/

		00006080
*3.3.1.2	RECEIVER SODIUM NODE TEMPERATURE	00006090
		00006100
	TNR1=INTGRL(TNR10,DTNR1,24)	00006110
	TNR2=INTGRL(TNR20,DTNR2,24)	00006120
	TNR3=INTGRL(TNR30,DTNR3,24)	00006130
		00006140
		00006150
	PROCEDURE DTNR1=BKFLOW(ZERO,WNR,WNRR,TNR1,TNR1,WN,WNO,TNRPO, ...	00006151
	NVOLIH,SNARII,CPIH)	00006152
	MTNSER=ZERO	00006153
	DO 1200 KK=1,24	00006154
	1200 MTNSER=MTNSER+WNR(KK)*WNRR(KK)*INSW(WNR(KK),TNR1(KK),TNR1)	00006155
	DTNR1=(WN*WNO*TNRPO-MTNSER)/(NVOLIH*SNARII+CPIH)	00006156
	ENDPROCEDURE	00006157
		00006158
		00006160
	PROCEDURE DTNR1,DTNR2,DTNR3=DTN(HANR1,HANR2,HANR3,TRW1,TRW2,TRW3, ...	00006170
	TNR1,TNR2,TNR3,WNR,CP1,CP2,CP3,TNR1,NVOL,RHO1,RHO2,RHO3, ...	00006180
	TNRQ,WNRA)	00006185
	DO 1000 L=1,24	00006190
	TNR1I=INSW(WNR(L),TNR2(L),TNR1)	00006195
	DTNR1(L)=(HANR1(L)*(TRW1(L)-TNR1(L))+WNRA(L)*CP1(L)*(TNR1I-...	00006200
	TNR1(L))/(NVOL*RHO1(L)*CP1(L))	00006210
	TNR2I=INSW(WNR(L),TNR3(L),TNR1(L))	00006215
	DTNR2(L)=(HANR2(L)*(TRW2(L)-TNR2(L))+WNRA(L)*CP2(L)*(TNR2I-...	00006220
	TNR2(L))/(NVOL*RHO2(L)*CP2(L))	00006230
	TNR3I=INSW(WNR(L),TNRQ,TNR2(L))	00006235
	1000 DTNR3(L)=(HANR3(L)*(TRW3(L)-TNR3(L))+WNRA(L)*CP3(L)*(TNR3I-...	00006240
	TNR3(L))/(NVOL*RHO3(L)*CP3(L))	00006250
	ENDPROCEDURE	00006260
		00006270
	PROCEDURE MTINSM=MDT(WNR,WNRR,TNR3,TNRQ)	00006280
	MTINSM=0.0	00006290
	DO 1500 IJ=1,24	00006300
	1500 MTINSM=MTINSM+INSW(WNR(IJ),TNRQ*WNR(IJ)*WNRR(IJ),TNR3(IJ)* ...	00006310
	WNR(IJ)*WNRR(IJ))	00006311
	ENDPROCEDURE	00006320
		00006330
		00006340
		00006350
*3.3.2	INTERCONNECTING LINES, TANKS AND PUMPS	00006360

*3.3.2.1	RECEIVER OUTLET TANK	00006370
		00006380
	DTNRO=(MTINSM-WDN*TNRO*WDNR-DMNROT*TNRO)/MNAROT	00006390
	TNRO=INTGRL(TNROO,DTNRO)	00006400
		00006410
		00006420
*3.3.2.2	RISER PIPING	00006430
		00006440
	KLNR=WNA/TAURN	00006450
		00006460
	TNRP=INTGRL(TNRP0,DTNRP,9)	00006470
	TNRPO=INTGRL(TNRIO,DTNRII)	00006480
	TNRI=INTGRL(TNRIO,DTNRI)	00006485
		00006490
	PROCEDURE DTNRP,DTNRII=RISER(TNRP,KLNR,TNRPUO,TNRI)	00006500
	DTNRP(1)=KLNR*(TNRPUO-TNRP(1))	00006510
	DO 300 IK=2,9	00006520
	300 DTNRP(IK)=KLNR*(TNRP(IK-1)-TNRP(IK))	00006530
	DTNRII =KLNR*(TNRP(9)-TNRPO)	00006540
	ENDPROCEDURE	00006550
		00006560
*3.3.2.3	RECEIVER PUMP	00006570
		00006580
	TNRPUO=INSH(WN=.01,TNRPUI,TNRPUI=HRP*HRPO*SINSFT/778./...)	00006590
	RHOCT/CPCT*(1.-1./(ETARP+.01)))	00006591
	ETARP=.75*WN	00006592
		00006600
*3.3.2.4	COLD TANK TO RECEIVER PUMP	00006610
		00006620
	KLRPS=WNA/TAURPS	00006630
	TNRPUI=INTGRL(TNCTO,KLKPS*(TNCT-TNRPUI))	00006640
		00006650
*3.3.2.5	COLD TANK	00006660
		00006670
	TNCT=INTGRL(TNCTO,(WCTI*TNCTI*WCTIR-WN*WNO*TNCT-DMNACT*TNCT)/...)	00006680
	MCPCT)	00006681
		00006690
*3.3.2.6	DOWNCOMER PIPING	00006700
		00006710
	KLDC=WNA/TAUDC	00006720
		00006730
	TNDC=INTGRL(TNDCO,DTNDC,4)	00006740

ESG-79-2, Vol II, Book 2
L-54

N2721000006
53

	TNDVI=INTGRL(TNROO,DTNDVI)	00006750
		00006760
	PROCEDURE DTNDC,DTNDVI=DWNCOM(KLDC,TNRO,TNDC)	00006770
	DTNDC(1)=KLDC*(TNRO-TNDC(1))	00006780
	DO 400 KI=2,4	00006790
	400 DTNDC(KI)=KLDC*(TNDC(KI-1)-TNDC(KI))	00006800
	DTNDVI=KLDC*(TNDC(4)-TNDVI)	00006810
	ENDPROCEDURE	00006820
*3.3.2.7	PRESSURE REDUCING DEVICE	00006830
		00006840
		00006850
	TNDVO=TNDVI+DPDV*SINSFT/RHONDV/778.16/CPNDV	00006860
		00006870
*3.3.2.8	PRESSURE REDUCING DEVICE TO HOT TANK	00006880
		00006890
	KLDVHT=WDNA/TAUDHT	00006900
		00006910
	TNHTI=INTGRL(TNHTIO,KLDVHT*(TNDVO-TNHTI))	00006920
		00006930
*3.3.2.9	HOT TANK	00006940
		00006950
	DTNHT=(WDN*WDNR*TNHTI-WHTO*WHTOR*TNHT-DMNAHT*TNHT)/MCPHT	00006960
	TNHT=INTGRL(TNHTO,DTNHT)	00006970
		00006980
		00006990
		00007000
*3.3.3	EVAPORATOR	00007010
		00007020
		00007030
		00007040
*3.3.4	SUPERHEATER	00007050
		00007060
		00007070
		00007080
*3.3.5	REHEATER	00007090
		00007100
		00007110
		00007120
*3.3.6	HIGH PRESSURE TURBINE	00007130
		00007140
		00007150
		00007160

ESG-79-2, Vol II, Book 2
L-55

N272T1000006
54

*3,3,7	LOW PRESSURE TURBINE	00007170
		00007180
		00007190
		00007200
*3,3,8	FEED WATER HEATERS	00007210
		00007220
		00007230
		00007240
*3,3,9	CONDENSER	00007250
		00007260
		00007270
		00007280
*3,4	PLANT PROTECTION AND CONTROL SYSTEM	00007290
		00007300
*3,4,1	RECEIVER PANEL CONTROLLERS	00007310
		00007320
	PROCEDURE ETI=INTCON(ES,VPOX,ZERO,ONE,TAU,KC,STR,DTNR3)	00007330
	DO 2500 JK=1,24	00007340
	ET=ES(JK)-STR	00007350
	EIR=NAND(ET,(VPOX(JK)-ONE)*NAND(-ET,(ZERO-VPOX(JK))))*ET	00007360
	2500 ETI(JK)=EIR*KC(JK)/TAU(JK)	00007370
	ENDPROCEDURE	00007380
		00007390
		00007400
	IRX=INTGRL(VPI,ETI,24)	00007410
		00007420
	PROCEDURE VPX,VPOX=RCONT(IRX,ZERO,ONE,TAUD,KC,ES,STR,VP,TAUVLV,VPI,...	00007430
	DTNR3,NRP)	00007440
	DO 3000 M=1,24	00007450
	IRA=LIMIT(ZERO,ONE,IRX(M))	00007460
	ET=ES(M)-STR	00007470
	DR=TAUD(M)*DTNR3(M)	00007480
	VPOX(M)=INSW(NRP,ONE,IRA+KC(M)*(DR+ET))	00007490
	3000 VPX(M)=(LIMIT(ZERO,ONE,VPOX(M))-VP(M))/TAUVLV	00007500
	ENDPROCEDURE	00007510
		00007520
	PROCEDURE TNR3X=DLAY(TNR3,ES,TAUTC)	00007530
	DO 4000 KJ=1,24	00007540
	4000 TNR3X(KJ)=(TNR3(KJ)-ES(KJ))/TAUTC	00007550
	ENDPROCEDURE	00007560
		00007570
	ES=INTGRL(TNR30,TNR3X,24)	00007580

	VP=INTGRL(VPI,VPX,24)	00007590
		00007600
*3.4.2	PRESSURE REDUCING DEVICE CONTROLLER	00007610
		00007620
	ELROT=LROT-SLROT	00007630
	EROTL=DEADSP(-0.25,0.25,ELROT)	00007640
	LVL SW=INSH(ABS(EROTL)-.001,ZERO,ONE)	00007650
	DVE=EROTL	00007660
	DVEIX=NAND(DVE,(VPDVOX-ONE)*NAND(-DVE,(ZERO-VPDVOX)))*DVE	00007670
	DVEI=DVEIX*KCDV/TAUDVI	00007680
	IRDVX=INTGRL(VPDVI,DVEI)	00007690
	IRDV=LIMIT(ZERO,ONE,IRDVX)	00007700
	DLROT=(HN*WNO-WDN*WNR)/RHOROT/CAROT	00007710
	DRDVC=TAUDVD*DLROT*LVL SW	00007720
	VPDVOX=INSH(TPT-TIME,ZERO,IRDV+KCDV*(DVE+DRDVC))	00007730
	VPDVX=(LIMIT(ZERO,ONE,VPDVOX)-VPDV)/TAUDV	00007740
	VPDV=INTGRL(VPDVI,VPDVX)	00007750
		00007760
*3.4.3	RECEIVER PUMP	00007761
		00007762
	TMRP=INSH(TPT-TIME,ZERO,ONE)	00007763
		00007764
		00007765
		00007790
*4.0	CONTROL STATEMENTS	00007800
		00007810
	TIMER DELT=0.03, FINTIM=.10, PRDEL=1.0, OUTDEL=1.0	00007820
	METHOD TRAPZ	00007830
	FINISH LROT=ZERO,LROT=10.0,TNRD=1700.	00007840
		00007845
		00007850
*5.0	OUTPUT STATEMENTS	00007860
		00007870
*5.1	DEBUG INSTRUCTIONS	00007880
		00007890
	Y=DEBUG(1,0.0)	00007900
		00007910
		00007920
*5.2	PRINT OUT INSTRUCTIONS	00007930
		00007940
PRINT	TNCT,TNRPUI,TNRPUD,TNRI,QI,QA,WN,TNRD,PP(1),VP(1),WNR(1)	00007950
		00007960

ESG-79-2, Vol II, Book 2
L-57

52
N2221000006

TNR3(1),PP(6),VP(6),WNR(6),TNR3(6),PP(12),VP(12),WNR(12)	,...	00007970
TNR3(12),TNDVI,TNDVO,INHII,INH1,VPDV,WON,LROI,EROIL,NRP,HRP	,...	00007980
PIR,POR,LNACT,LNAHT,TRW2(1),TRW2(6),TRW2(12)		00007990
		00008000
		00008010
*5,3	PLOT INSTRUCTIONS	00008020
		00008030
PAGE XY PLOT		00008040
		00008050
LABEL RUN 04-07 CLOUD COVER TRANSIENT, 7-13-78, 200 SECONDS		00008060
		00008070
OUTPUT TIME	,TNCT ,TNRPUI ,TNRPUO ,TNRI	00008080
		00008090
LABEL	TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)	00008100
LABEL	TNRPUI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)	00008110
LABEL	TNRPUO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)	00008120
LABEL	TNRI - TEMPERATURE OF SODIUM, RECEIVER INLET (F)	00008130
		00008140
OUTPUT TIME	,QI ,QA ,WN ,TNRO	00008150
		00008160
LABEL	QI - TOTAL INCIDENT SOLAR POWER (MWT)	00008170
LABEL	QA - TOTAL ABSORBED SOLAR POWER (MWT)	00008180
LABEL	WN - TOTAL RECEIVER FLOW (LB/SEC)	00008190
LABEL	TNRO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)	00008200
		00008210
OUTPUT TIME	,PP(1) ,VP(1) ,WNR(1) ,TNR3(1)	00008220
		00008230
LABEL	PP(1) - SOUTH PANEL INCIDENT POWER (MWT)	00008240
LABEL	VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)	00008250
LABEL	WNR(1) - SOUTH PANEL FLOW (NORMALIZED TO 36.17 LBM/SEC)	00008260
LABEL	TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)	00008270
		00008280
OUTPUT TIME	,PP(6) ,VP(6) ,WNR(6) ,TNR3(6)	00008290
		00008300
LABEL	PP(6) - WEST PANEL INCIDENT POWER (MWT)	00008310
LABEL	VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)	00008320
LABEL	WNR(6) - WEST PANEL FLOW (NORMALIZED 88.15 LBM/SEC)	00008330
LABEL	TNR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)	00008340
		00008350
OUTPUT TIME	,PP(12) ,VP(12) ,WNR(12) ,TNR3(12)	00008360
		00008370
LABEL	PP(12) - NORTH PANEL INCIDENT POWER (MWT)	00008380

ESG-79-2, Vol II, Book 2
L-58

N272100006
57

LABEL	VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)	00008390
LABEL	MNR(12) - NORTH PANEL FLOW (NORMALIZED TO 167.69 LBM/SEC)	00008400
LABEL	TNR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)	00008410
OUTPUT TIME	,TRW2(1) ,TRW2(6) ,TRW2(12)	00008420
LABEL	TRW2(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)	00008430
LABEL	TRW2(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)	00008440
LABEL	TRW2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)	00008450
OUTPUT TIME	,TNDVI ,TNDVO ,TNHTI ,TNHT	00008460
LABEL	TNDVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET, F	00008470
LABEL	TNDVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET F	00008480
LABEL	TNHTI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)	00008490
LABEL	TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)	00008500
OUTPUT TIME	,VPDV ,NDN ,LROT ,EROTL	00008510
LABEL	VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)	00008520
LABEL	NDN - DOWNCOMER FLOW (NORMALIZED TO 2220.1 LBM/SEC)	00008530
LABEL	LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)	00008540
LABEL	EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR	00008550
OUTPUT TIME	,NRP ,HRP ,PIR ,PQR	00008560
LABEL	NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)	00008570
LABEL	HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)	00008580
LABEL	PIR - PRESSURE AT RECEIVER INLET (PSIA)	00008590
LABEL	PQR - PRESSURE AT RECEIVER OUTLET (PSIA)	00008600
OUTPUT TIME	,LNACT ,LNAHT	00008610
LABEL	LNACT - LEVEL OF SODIUM IN COLD TANK (FT)	00008620
LABEL	LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)	00008630
		00008640
		00008650
		00008660
		00008670
		00008680
		00008690
		00008700
		00008710
		00008720
		00008730
		00008740
		00008750
		00008760
*	VARIABLE AND FUNCTION INDEX	00008769
*		00008770
*	A=HEAT TRANSFER AREA/NODE (SQ-FT)	00008771
		00008780

ESG-79-2, Vol II, Book 2
L-59

N27211000006
52

*	ABS=ABSOLUTE VALUE FUNCTION	00008790
*	AFGEN=CSMP ARBITRARY FUNCTION GENERATOR	00008800
*	AFLO=SODIUM FLOW AREA/PANEL (SQ FT)	00008810
*	AFLOW=SODIUM FLOW AREA (SQ-FT)	00008820
*	ALPHA=RECEIVER SURFACE ABSORPTIVITY(EMISSIVITY)	00008830
*	AR=PROJECTED RECEIVER NODAL SURFACE AREA (SQ FT)	00008840
*	AREEF=INITIAL RECEIVER EFFICIENCY GUESS	00008850
*	ASRA=RECEIVER SURFACE ALPHA*SIGMA*AREA (BTU/SEC-R**4)	00008860
		00008870
*	BKFLOW=RECEIVER INLET HEADER TEMPERATURE SIMULATION ROUTINE	00008880
		00008890
*	CACT=COLD TANK CROSS-SECTIONAL AREA (SQ-FT)	00008900
*	CAHT=HOT TANK CROSS-SECTIONAL AREA (SQ-FT)	00008910
*	CAROT=CROSS-SECTIONAL AREA OF THE RECEIVER OUTLET TANK (SQ-FT)	00008920
*	CP=SODIUM HEAT CAPACITY (BTU/LBM-F)(FUNCTION OUTPUT)	00008930
*	CPCT=SODIUM HEAT CAPACITY, COLD TANK (BTU/LBM-F)	00008940
*	CPHT=HOT TANK SODIUM HEAT CAPACITY (BTU/LBM-F)	00008950
*	CPIN=RECEIVER INLET HEADER HEAT CAPACITY (BTU/LBM-F)	00008960
*	CPMEAN(I)=PANEL I, SODIUM MEAN HEAT CAPACITY (BTU/LBM-F)	00008970
*	CPNA=SODIUM HEAT CAPACITY ROUTINE NAME	00008980
*	CPNDV=DRAG VALVE SODIUM HEAT CAPACITY (BTU/LBM-F)	00008990
*	CPROT=HEAT CAPACITY RECEIVER OUTLET TANK (BTU/LBM-F)	00009000
*	CPSOD=SODIUM HEAT CAPACITY (BTU/LBM-F)	00009010
*	CP1I=INITIAL SODIUM HEAT CAPACITY, LOWER NODES (BTU/LBM-F)	00009020
*	CP2I=INITIAL SODIUM HEAT CAPACITY, MIDDLE NODES (BTU/LBM-F)	00009030
*	CP3I=INITIAL SODIUM HEAT CAPACITY, UPPER NODES (BTU/LBM-F)	00009040
*	CP1(I)=LOWER NODE, PANEL I SODIUM HEAT CAPACITY (BTU/LBM-F)	00009050
*	CP2(I)=MIDDLE NODE, PANEL I SODIUM HEAT CAPACITY (BTU/LBM-F)	00009060
*	CP3(I)=UPPER NODE, PANEL I SODIUM HEAT CAPACITY (BTU/LBM-F)	00009070
*	CVC=CONTROL VALVE FLOW COEFFICIENT (GPM/PSI)	00009080
*	CVCDV=INITIAL DRAG VALVE FLOW COEFFICIENT (GPM/PSI)	00009090
*	CVCI=INITIAL CONTROL VALVE FLOW COEFFICIENT (GPM/PSI)	00009100
*	CVOV=DRAG VALVE FULL OPEN FLOW COEFFICIENT (GPM/PSI)	00009110
*	CV(I)=PANEL I CONTROL VALVE FLOW COEFFICIENT (GPM/PSI)(OPEN)	00009120
		00009130
*	D=FLOW PASSAGE DIAMETER (FT)	00009140
*	DEADSP=CSMP DEADBAND FUNCTION	00009150
*	DEBUG=CSMP DEBUG FUNCTION	00009160
*	DELT=CSMP TIME STEP (SEC)	00009170
*	DLAY=THERMOCOUPLE DYNAMIC SIMULATION ROUTINE	00009180
*	DLROT=RECEIVER OUTLET TANK LEVEL DERIVATIVE (FT/SEC)	00009190
*	DMHACT=COLD TANK SODIUM NET INFLOW (LBM/SEC)	00009200

N2721000006

57

*	DMNAHT=HOT TANK SODIUM NET INFLOW (LBM/SEC)	00009210
*	DMNRQT=RECEIVER OUTLET TANK SODIUM MASS DERIVATIVE (LBM/SEC)	00009220
*	DNRP=RECEIVER PUMP SPEED ACCELERATION (NORMALIZED)	00009230
*	OPCVI=INITIAL CONTROL VALVE PRESSURE DROP (PSI)	00009240
*	DPCV(I)=PANEL I CONTROL VALVE PRESSURE DROP (PSI)	00009250
*	DPDVI=INITIAL DRAG VALVE PRESSURE DROP (PSI)	00009270
*	DPDVOX=UNLIMITED RECEIVER OUTLET TANK CONTROLLER RESPONSE	00009280
*	DPDV=DRAG VALVE PRESSURE DROP (PSI)	00009290
*	DR=CONTROLLER DERIVATIVE RESPONSE	00009300
*	DRDVC=DERIVATIVE RESPONSE RECEIVER OUTLET TANK LEVEL CONTROLLER	00009310
*	DRTUBE=RECEIVER TUBE INSIDE DIAMETER (FT)	00009320
*	DTN=SODIUM TEMPERATURE DERIVATIVE FUNCTION	00009330
*	DTNOC(I)=DOWNCOMER NODE I TEMPERATURE DERIVATIVE (F/SEC)	00009340
*	DTNDVI=DRAG VALVE INLET TEMPERATURE DERIVATIVE (F/SEC)	00009350
*	DTNHT=HOT TANK SODIUM TEMPERATURE DERIVATIVE (F/SEC)	00009360
*	DTNRI=RECEIVER INLET TEMPERATURE DERIVATIVE (F/SEC)	00009370
*	DTNRII=RISER OUTLET TEMPERATURE DERIVATIVE (F/SEC)	00009380
*	DTNR0=RECEIVER OUTLET TANK TEMPERATURE DERIVATIVE (F/SEC)	00009390
*	DTNRP(I)=RISER NODE I TEMPERATURE DERIVATIVE (F/SEC)	00009400
*	DTNRI(I)=RECEIVER PANEL I, NODE 1, SODIUM TEMPERATURE DERIV.	00009410
*	DTNR2(I)=RECEIVER PANEL I, NODE 2, SODIUM TEMP. DERIVATIVE	00009420
*	DTNR3(I)=RECEIVER PANEL I, NODE 3, SODIUM TEMP. DERIVATIVE	00009430
*	DRT1=NODE 1 RECEIVER TUBE TEMPERATURE DERIVATIVE ROUTINE NAME	00009440
*	DRT2=NODE 2 RECEIVER TUBE TEMPERATURE DERIVATIVE ROUTINE	00009450
*	DRT3=NODE 3 RECEIVER TUBE TEMPERATURE DERIVATIVE ROUTINE	00009460
*	DTRW1(I)=PANEL I, NODE 1 WALL TEMPERATURE DERIVATIVE (F/SEC)	00009470
*	DTRW2(I)=PANEL I, NODE 2 WALL TEMPERATURE DERIVATIVE (F/SEC)	00009480
*	DTRW3(I)=PANEL I, NODE 3 WALL TEMPERATURE DERIVATIVE (F/SEC)	00009490
*	DVDPCA=DRAG VALVE DISCHARGE PIPE CROSS-SECTIONAL AREA (SQ-IN)	00009500
*	OVE=SEE EROTL	00009510
*	OVEI=PROCESSED INTEGRAL CONTROL RESPONSE	00009520
*	OVEIX=LEVEL CONTROLLER INTEGRAL ERROR (FT)	00009530
*	DW=RECEIVER PANEL FLOW ACCELERATION ROUTINE NAME	00009540
*	DMON=NORMALIZED DOWNCOMER FLOW ACCELERATION (1/SEC-SEC)	00009550
*	DWN=RISER FLOW ACCELERATION (NORMALIZED) (1/SEC-SEC)	00009560
*	DWNCOM=DOWNCOMER SODIUM TEMPERATURE DERIVATIVE ROUTINE	00009570
*	DWNR(I)=FLOW DERIVATIVE, PANEL I, NORMALIZED (1/SEC-SEC)	00009580
*		00009590
*	EBROT=ELEVATION OF BASE OF RECEIVER OUTLET TANK (FT)	00009600
*	EIR=PROCESSED PANEL ERROR (F)	00009610
*	ELROT=RECEIVER OUTLET TANK LEVEL ERROR (FT)	00009620
*	EROTL=ERROR SIGNAL TO RECEIVER OUTLET TANK LEVEL CONTROLLER	00009630

*	ERRFLG=INITIAL CONDITION ERROR FLAG	00009640
*	ERROR1=LOWER NODES ABSORBED POWER ERROR	00009650
*	ERROR2=MIDDLE NODES ABSORBED POWER ERROR	00009660
*	ERROR3=UPPER NODES ABSORBED POWER ERROR	00009670
*	ES(I)=THERMOCOUPLE OUTPUT TEMPERATURE PANEL I (F)	00009680
*	ET= PANEL OUTLET SODIUM TEMPERATURE ERROR(F)	00009690
*	ETARP=RECEIVER PUMP EFFICIENCY	00009700
*	ETI(I)=PROCESSED INTEGRAL ERROR	00009710
		00009720
*	FHDC=DOWNCOMER FRICTION HEAD (PSI)	00009730
*	FH(I)=PANEL I FRICTION DROP (TIME VARYING)(PSI)	00009740
*	FINTIM=RUN FINISH TIME (SEC)	00009750
*	FLOROT=RECEIVER OUTLET TANK NET INFLOW ROUTINE NAME	00009760
		00009770
*	GO=ACCELERATION DUE TO GRAVITY (32.2 FT/SEC-SEC)	00009780
		00009790
*	H=SODIUM FILM COEFFICIENT (BTU/SQFT-SEC-F)	00009800
*	HA=SODIUM FILM COEFF.-AREA PRODUCT (BTU/SEC-F)(FUNCTION OUTPUT)	00009810
*	HART=TOTAL TUBE INSIDE HEAT TRANSFER AREA/NODE (SQ FT)	00009820
*	HANR=SODIUM FILM COEFF.-AREA PRODUCT (BTU/SEC-F)	00009830
*	HANR1I=INITIAL FILM COEF.-AREA PRODUCT, LOWER NODES (BTU/SEC-F)	00009840
*	HANR2I=INITIAL FILM COEF.-AREA PRODUCT, MID. NODES (BTU/SEC-F)	00009850
*	HANR3I=INITIAL FILM COEF.-AREA PRODUCT, UPPER NODES (BTU/SEC-F)	00009860
*	HANR1(I)=LOWER AXIAL NODE FILM COEFF.-AREA PRODUCT (BTU/SEC-F)	00009870
*	HANR2(I)=MIDDLE AXIAL NODE FILM COEFF.-AREA PRODUCT (BTU/SEC-F)	00009880
*	HANR3(I)=UPPER AXIAL NODE FILM COEFF.-AREA PRODUCT (BTU/SEC-F)	00009890
*	HA1=RECEIVER PUMP DEVELOPED HEAD COEFFICIENT 1	00009900
*	HA2=RECEIVER PUMP DEVELOPED HEAD COEFFICIENT 2	00009910
*	HA3=RECEIVER PUMP DEVELOPED HEAD COEFFICIENT 3	00009920
*	HFA(I)=LOCAL RECEIVER-AIR FILM COEFFICIENT(BTU/SQFT-DEGF-SEC)	00009930
*	HRP=NORMALIZED RECEIVER PUMP HEAD	00009940
*	HRP0=INITIAL RECEIVER PUMP HEAD (PSI)	00009950
*	HYDINT=RECEIVER HYDRAULIC INITIAL CONDITION ROUTINE NAME	00009960
		00009970
		00009980
*	IDC=DOWNCOMER INERTIA (PSI-SEC)	00009990
*	INITC=INITIAL TEMPERATURE CALCULATION ROUTINE NAME	00010000
*	INSW=CSMP INPUT SWITCH FUNCTION NAME	00010010
*	INTCON=RECEIVER PANEL CONTROLLER INTEGRATOR ROUTINE	00010020
*	INTGRL=CSMP INTEGRATION ROUTINE CALL-UP	00010030
*	IRA=ACTUAL INTEGRAL CONTROLLER RESPONSE	00010040
*	IRDV=ACTUAL RECEIVER OUTLET TANK LEVEL CONTROLLER INTEGRAL RES.	00010050
*	IRDVX=RECEIVER OUTLET TANK LEVEL CONTROLLER INTEGRAL RESPONSE	00010050

*	IRX(I)=PANEL I, INTEGRAL CONTROL RESPONSE	00010060
*	ISRSQ=SQUARE ROOT RECEIVER INLET SPECIFIC GRAVITY	00010070
*	IR(I)=PANEL I FLOW INERTIA (PSI-SEC)	00010080
*	IWN=RISER PIPING INERTIA (PSI-SEC)	00010090
*	IWNRPS=RECEIVER PUMP SUCTION PIPEING INERTIA (PSI-SEC)	00010100
		00010110
*	KCDV=DRAG VALVE CONTROLLER GAIN	00010120
*	KC(I)=PANEL I CONTROLLER GAIN	00010130
*	KFHDC=STEADY-STATE DOWNCOMER FRICTION HEAD (PSI)	00010150
*	KFHDCR=DOWNCOMER FRICTION HEAD PER UNIT FLOW SQUARED	00010160
*	KFHRP=INITIAL RISER FRICTION DROP (PSI)	00010170
*	KFHRPR=RISER FRICTION HEAD PER UNIT FLOW SQUARED (PSI/SQ=LBM/S)	00010180
*	KFHC(I)=PANEL I STEADY-STATE FRICTION DROP (PSI)	00010190
*	KFH(I)=PANEL I STEADY-STATE FRICTION DROP/UNIT FLOW SQUARED	00010200
*	KLDC=DOWNCOMER VARIABLE TRANSPORT TERM (1/SEC)	00010210
*	KLDVHT=DRAG VALVE DISCHARGE PIPE TRANSPORT TERM (1/SEC)	00010220
*	KLNR=RISER PIPING NODE VARIABLE TRANSPORT TERM (1/SEC)	00010230
*	KLRPS=RECEIVER PUMP SUCTION VARIABLE TRANSPORT TERM (1/SEC)	00010240
*	KNA=SODIUM THERMAL CONDUCTIVITY (BTU/FT-SEC-F)	00010250
*	KRP=RECEIVER PUMP NORMALIZED INERTIA (1/SEC)	00010260
		00010270
*	LBSGPM=CONVERSION LBM/SEC TO GAL/MIN	00010280
*	LIMIT=CSMP LIMITER FUNCTION	00010290
*	LKEQ=SODIUM FILM COEFFICIENT ROUTINE NAME	00010300
*	LNACT=COLD TANK SODIUM LEVEL (FT)	00010310
*	LNACT0=INITIAL COLD TANK SODIUM LEVEL (FT)	00010320
*	LNAHT=HOT TANK SODIUM LEVEL (FT)	00010330
*	LNAHT0=INITIAL HOT TANK SODIUM LEVEL (FT)	00010340
*	LOGAR=RISER INERTIA/RISER REFERENCE FLOW (PSI-SEC-SEC/LBM)	00010350
*	LRDCP=DOWNCOMER PIPE LENGTH (FT)	00010360
*	LRDVOP=DRAG VALVE DISCHARGE PIPE LENGTH (FT)	00010370
*	LRI=RECEIVER INLET ELEVATION (FT)	00010380
*	LR0T=RECEIVER OUTLET TANK LEVEL (FT)	00010390
*	LR0T0= INITIAL RECEIVER OUTLET TANK SODIUM LEVEL (FT)	00010400
*	LRPSP=RECEIVER PUMP SUCTION PIPE LENGTH (FT)	00010410
*	LRRP=RISER PIPING LENGTH (FT)	00010420
		00010440
*	MCPCT=MASS CAPACITY, COLD TANK (BTU/F)	00010450
*	MCPHT=HOT TANK SODIUM MASS-CAPACITY (BTU/F)	00010460
*	MCPROT=MASS-CAPACITY PRODUCT RECEIVER OUTLET TANK (BTU/F)	00010470
*	MCPTW=MASS-HEAT CAPACITY PRODUCT/TUBE NODE (BTU/DEG F)	00010480
*	MDUT=SODIUM MASS FLOWRATE (LBM/SEC)	00010490

*	MDT=MASS-TEMPERATURE PRODUCT-SUMMATION RECEIVER OUTLET TANK	00010500
*	MNACT=COLD TANK SODIUM MASS (LBM)	00010510
*	MNACT0=INITIAL COLD TANK SODIUM MASS (LBM)	00010520
*	MNAHT=HOT TANK SODIUM MASS (LBM)	00010530
*	MNAHT0=INITIAL HOT TANK SODIUM MASS (LBM)	00010540
*	MNARDT=RECEIVER OUTLET TANK SODIUM MASS (LBM)	00010550
*	MNROT0=INITIAL MASS OF SODIUM IN THE RECEIVER OUTLET TANK (LBM)	00010560
*	MTINSM=MASS-TEMPERATURE PRODUCT-SUMMATION RECEIVER OUTLET TANK	00010570
*	MTNSER=MASS-TEMPERATURE PRODUCT SUMMATION RECEIVER INLET PLENUM	00010580
*	MU=SODIUM ABSOLUTE VISCOSITY (LBM/FT-SEC)	00010590
*	MULOG=BASE 10 LOG OF VISCOSITY	00010600
*	MWBTUS=CONVERSION FACTOR MWT TO BTU/SEC	00010610
		00010620
*	NPP(I)=PANEL I NORMALIZED INCIDENT POWER	00010630
*	NQA1(I)=LOWER NODE, PANEL I, ABSORBED POWER (BTU/SEC) UPDATE	00010640
*	NQA2(I)=MIDDLE NODE, PANEL I, ABSORBED POWER (BTU/SEC) UPDATE	00010650
*	NQA3(I)=UPPER NODE, PANEL I, ABSORBED POWER (BTU/SEC) UPDATE	00010660
*	NRP=NORMALIZED RECEIVER PUMP SPEED	00010670
*	NRPX=INTERMEDIATE RECEIVER PUMP SPEED, NORMALIZED	00010680
*	NRP0=INITIAL NORMALIZED RECEIVER PUMP SPEED	00010690
*	NUN=NUSSELT NUMBER	00010700
*	NVOL=SODIUM VOLUME/RECEIVER NODE (CUFT)	00010710
*	NVOLIH=SODIUM VOLUME, RECEIVER INLET HEADER (CUFT)	00010720
		00010730
*	ONE=ONE	00010740
*	OUTDEL=OUTPUT INTERVAL (PLOT)	00010750
		00010760
*	PF1=FRACTION OF PANEL POWER INCIDENT ON AXIAL TUBE NODE 1	00010770
*	PF2=FRACTION OF PANEL POWER INCIDENT ON AXIAL TUBE NODE 2	00010780
*	PF3=FRACTION OF PANEL POWER INCIDENT ON AXIAL TUBE NODE 3	00010790
*	PIR=RECEIVER TOTAL INLET PRESSURE (PSIA)	00010800
*	PIRFLO=RECEIVER INLET TOTAL PRESSURE-RISER FLOW (PSIA)	00010810
*	PIRI=STEADY-STATE RECEIVER INLET TOTAL PRESSURE (PSIA)	00010820
*	PIRSO=RECEIVER INLET PRESSURE-RISER SHUT-OFF (PSIA)	00010830
*	PLOGA=PANEL LENGTH/GRAVITY ACCELERATION-FLOW AREA	00010840
*	POCT=ULLAGE PRESSURE OF THE COLD TANK (PSIA)	00010850
*	POHT=HOT TANK ULLAGE PRESSURE (PSIA)	00010860
*	POR=TOTAL RECEIVER OUTLET PRESSURE (PSIA)	00010870
*	PORI=STEADY-STATE RECEIVER OUTLET TOTAL PRESSURE (PSIA)	00010880
*	POROT=RECEIVER OUTLET TANK ULLAGE PRESSURE (PSIA)	00010890
*	PP(I)=PANEL I INCIDENT POWER, (MWT)	00010900
*	PR=PRANDTL NUMBER	00010910

ESG-79-2, Vol II, Book 2
L-64

NP27TI000006
43

*	PRDEL=OUTPUT INTERVAL (PRINT)	00010920
		00010930
*	Q= PANEL FLOW OF SODIUM (GPM H2O)	00010940
*	QA= TOTAL RECEIVER TUBING ABSORBED POWER (MWT)	00010950
*	QAI(I)= PANEL I, TOTAL ABSORBED POWER (BTU/SEC)	00010960
*	QA1(I)= LOWER NODE, PANEL I, ABSORBED POWER (BTU/SEC)	00010970
*	QA2(I)= MIDDLE NODE, PANEL I, ABSORBED POWER (BTU/SEC)	00010980
*	QA3(I)= UPPER NODE, PANEL I, ABSORBED POWER (BTU/SEC)	00010990
*	QCR1= NODE 1 CONVECTIVE HEAT LOSS (BTU/SEC)	00011000
*	QCR2= NODE 2 CONVECTIVE HEAT LOSS (BTU/SEC)	00011010
*	QCR3= NODE 3 CONVECTIVE HEAT LOSS (BTU/SEC)	00011020
*	QDC= DOWNCOMER FLOW (GPM)	00011030
*	QI= TOTAL RECEIVER INCIDENT POWER (MWT)	00011040
*	QIASUM= TOTAL RECEIVER POWER ROUTINE	00011050
*	QIDC= INITIAL DOWNCOMER FLOW (GPM)	00011060
*	QI1(I)= LOWER AXIAL NODE, PANEL I, INCIDENT POWER (BTU/SEC)	00011070
*	QI2(I)= MIDDLE AXIAL NODE, PANEL I, INCIDENT POWER (BTU/SEC)	00011080
*	QI3(I)= UPPER AXIAL NODE, PANEL I, INCIDENT POWER (BTU/SEC)	00011090
*	QRG1= NODE 1 RADIATIVE LOSS TO GROUND (BTU/SEC)	00011100
*	QRG2= NODE 2 RADIATIVE LOSS TO GROUND (BTU/SEC)	00011110
*	QRG3= NODE 3 RADIATIVE LOSS TO GROUND (BTU/SEC)	00011120
*	QRS1= NODE 1 RADIATIVE LOSS TO SKY (BTU/SEC)	00011130
*	QRS2= NODE 2 RADIATIVE LOSS TO SKY (BTU/SEC)	00011140
*	QRS3= NODE 3 RADIATIVE LOSS TO SKY (BTU/SEC)	00011150
*	QR1= NODE 1 TOTAL RADIATIVE LOSS (BTU/SEC)	00011160
*	QR2= NODE 2 TOTAL RADIATIVE LOSS (BTU/SEC)	00011170
*	QR3= NODE 3 TOTAL RADIATIVE LOSS (BTU/SEC)	00011180
		00011190
*	RCONT= RECEIVER PANEL CONTROLLER ROUTINE	00011200
*	RDCCA= DOWNCOMER CROSS-SECTIONAL AREA (SQ-IN)	00011210
*	RED= REYNOLDS NUMBER	00011220
*	RH= RECEIVER PANEL HEIGHT (FT)	00011230
*	RHOCT= COLD TANK SODIUM DENSITY (LBM/CU-FT)	00011240
*	RHOCT0= INITIAL COLD TANK SODIUM DENSITY (LBM/CU-FT)	00011250
*	RHODC0= INITIAL DOWNCOMER SODIUM DENSITY (LBM/CU-FT)	00011260
*	RHOHT= HOT TANK SODIUM DENSITY (LBM/CU-FT)	00011270
*	RHOHT0= INITIAL HOT TANK SODIUM DENSITY (LBM/CU-FT)	00011280
*	RHON= SODIUM DENSITY (LBM/CU-FT)	00011290
*	RHONA= SODIUM DENSITY ROUTINE NAME	00011300
*	RHONDV= DRAG VALVE SODIUM DENSITY (LBM/CU-FT)	00011310
*	RHONRI= RECEIVER INLET SODIUM DENSITY (LBM/CU-FT)	00011320
*	RHOROT= SODIUM DENSITY RECEIVER OUTLET TANK (LBM-CUFT)	00011330

*	RHORPO=INITIAL RISER PIPE SODIUM DENSITY (LBM/CU-FT)	00011340
*	RHO1I=INITIAL SODIUM LOWER NODE DENSITY (LBM/CU-FT)	00011350
*	RHO2I=INITIAL SODIUM MIDDLE NODE DENSITY (LBM/CU-FT)	00011360
*	RHO3I=INITIAL SODIUM UPPER NODE DENSITY (LBM/CU-FT)	00011370
*	RHO1(I)=LOWER NODE, PANEL I SODIUM DENSITY (LBM/CU-FT)	00011380
*	RHO2(I)=MIDDLE NODE, PANEL I SODIUM DENSITY (LBM/CU-FT)	00011390
*	RHO3(I)=UPPER NODE, PANEL I SODIUM DENSITY (LBM/CU-FT)	00011400
*	RISER=RISER PIPE TEMPERATURE DERIVATIVE ROUTINE	00011410
*	RP=TOTAL INCIDENT RECEIVER POWER (MWT)	00011420
*	RPI=INITIAL INCIDENT RECEIVER POWER (MWT)	00011430
*	RPIP=RECEIVER PUMP INLET PRESSURE (PSIA)	00011440
*	RPOP=RECEIVER PUMP OUTLET PRESSURE (PSIA)	00011450
*	RPOWER=INCIDENT RECEIVER POWER FUNCTION NAME	00011460
*	RSPCA=RECEIVER PUMP SUCTION PIPE CROSS-SECTIONAL AREA (SQ-IN)	00011470
*	RRPCA=RISER PIPING CROSS-SECTIONAL AREA (SQ-IN)	00011480
*	RTQ=RECEIVER PUMP AND MOTOR NORMALIZED RUNNING TORQUE	00011490
		00011500
*	SGDV=DRAG VALVE SODIUM SPECIFIC GRAVITY	00011510
*	SGNRI=RECEIVER INLET SPECIFIC GRAVITY	00011520
*	SHDC=DOWNCOMER STATIC HEAD (PSI)	00011530
*	SHDCI=INITIAL DOWNCOMER STATIC HEAD (PSI)	00011540
*	SHI=INITIAL RECEIVER STATIC HEAD (PSI)	00011550
*	SH(I)=PANEL I STATIC HEAD (PSI)	00011560
*	SINSFT=CONVERSION FACTOR SQUARE INCHES TO SQUARE FOOT	00011570
*	SLROT=RECEIVER OUTLET TANK SET LEVEL (FT)	00011580
*	SNARI=RECEIVER INLET SODIUM SPECIFIC GRAVITY	00011590
*	SNARI=RECEIVER INLET SODIUM DENSITY (LBM/CU-FT)	00011600
*	SNDV=DRAG VALVE SODIUM SPECIFIC GRAVITY	00011610
*	SRSGDV=SQUARE ROOT OF THE DRAG VALVE SODIUM SPECIFIC GRAVITY	00011620
*	SSRP=RECEIVER PUMP SPEED SWITCH	00011630
*	STATIC=RECEIVER PANEL STATIC HEAD ROUTINE NAME	00011640
*	STQ=NORMALIZED STATIC TORQUE OF THE RECEIVER PUMP AND MOTOR	00011650
*	STR=RECEIVER OUTLET SET POINT (F)	00011660
		00011670
*	T=SODIUM TEMPERATURE (F)	00011680
*	TA=AMBIENT AIR TEMPERATURE (DEGREES F)	00011690
*	TAUDC=DOWNCOMER FLOW TIME CONSTANT (SEC)	00011700
*	TAUDHT=DRAG VALVE DISCHARGE PIPE TIME CONSTANT (SEC)	00011710
*	TAUDV=DRAG VALVE TIME CONSTANT (SEC)	00011715
*	TAUDVD=DRAG VALVE CONTROLLER DERIVATIVE TIME (SEC)	00011720
*	TAUDVI=DRAG VALVE CONTROLLER INTEGRAL TIME (SEC)	00011730
*	TAUD(I)=DERIVATIVE TIME, PANEL I CONTROLLER (SEC)	00011740

*	TAU(I)=INTEGRAL TIME, PANEL I CONTROLLER (SEC)(1/RESET)	00011750
*	TAURN=RISER PIPING NODE TIME CONSTANT (MASS/MASS-FLOW, SEC)	00011760
*	TAURPS=RECEIVER PUMP SUCTION PIPE TIME CONSTANT (SEC)	00011770
*	TAUTC= PANEL THERMOCOUPLE TIME CONSTANT (SEC)	00011780
*	TAUVLY=PANEL VALVE ACTUATORS TIME CONSTANT (SEC)	00011790
*	TA1=RECEIVER PUMP REQUIRED TORQUE COEFFICIENT 1	00011800
*	TA2=RECEIVER PUMP REQUIRED TORQUE COEFFICIENT 2	00011810
*	TA3=RECEIVER PUMP REQUIRED TORQUE COEFFICIENT 3	00011820
*	TEST=CHECK VALVE SIMULATION FUNCTION	00011830
*	TFHCV=SUM OF PANEL CONTROL VALVE DROPS (PSI)	00011840
*	TFHR=SUM OF PANEL FRICTION HEAD (PSI)	00011850
*	TG=EFFECTIVE GROUND TEMPERATURE (R**4)	00011860
*	TILL=RECEIVER PUMP INPUT TORQUE FRACTION	00011870
*	TIME=TIME	00011880
*	TIMRP=RECEIVER PUMP REQUIRED TORQUE (NORMALIZED)	00011890
*	TIMRPX=RECEIVER PUMP REQUIRED NORMALIZED TORQUE	00011900
*	TMRP=RECEIVER PUMP MOTOR NORMALIZED TORQUE	00011910
*	TNA=SODIUM TEMPERATURE (F)	00011920
*	TNCT=COLD TANK SODIUM TEMPERATURE (F)	00011930
*	TNCTI=COLD TANK SODIUM INLET TEMPERATURE (F)	00011940
*	TNCTO=INITIAL COLD TANK SODIUM TEMPERATURE (F)	00011950
*	TNDCO(I)=INITIAL DOWNCOMER NODE I TEMPERATURE (F)	00011960
*	TNDC(I)=DOWNCOMER NODE I TEMPERATURE (F)	00011970
*	TNDVI=DRAG VALVE SODIUM INLET TEMPERATURE (F)	00011980
*	TNDVO=DRAG VALVE SODIUM OUTLET TEMPERATURE (F)	00011990
*	TNHT=HOT TANK SODIUM TEMPERATURE (F)	00012000
*	TNHTI=HOT TANK SODIUM INLET TEMPERATURE (F)	00012010
*	TNHTO=INITIAL HOT TANK SODIUM INLET TEMPERATURE (F)	00012020
*	TNHTO=INITIAL HOT TANK SODIUM TEMPERATURE (F)	00012030
*	TNRI=RECEIVER INLET MANIFOLD TEMPERATURE (F)	00012040
*	TNRIO=INITIAL RECEIVER INLET TEMPERATURE (F)	00012050
*	TNRQ=RECEIVER OUTLET TANK TEMPERATURE (F)	00012060
*	TNRQO=INITIAL RECEIVER OUTLET TANK TEMPERATURE (F)	00012070
*	TNRPO=RISER PIPING OUTLET TEMPERATURE (F)	00012080
*	TNRPUI=RECEIVER PUMP SODIUM INLET TEMPERATURE (F)	00012090
*	TNRPUD=RECEIVER PUMP OUTLET TEMPERATURE (F)	00012100
*	TNRPO(I)=RISER PIPING NODE INITIAL TEMPERATURE (F)	00012110
*	TNRP(I)=RISER PIPING NODE I SODIUM TEMPERATURE (F)	00012120
*	TNR1I=NODE 1 SODIUM INLET TEMPERATURE (F)	00012130
*	TNR2I=NODE 2 SODIUM INLET TEMPERATURE (F)	00012140
*	TNR3I=NODE 3 SODIUM INLET TEMPERATURE (F)	00012150
*	TNR1(I)=RECEIVER PANEL I, NODE 1, SODIUM TEMPERATURE (F)	00012160

*	TNR2(I)=RECEIVER PANEL 1, NODE 2, SODIUM TEMPERATURE (F)	00012170
*	TNR3(I)=RECEIVER PANEL 1, NODE 3, SODIUM TEMPERATURE (F)	00012180
*	TNR10G(I)=LOWER NODE, PANEL 1, INITIAL SODIUM TEMP. GUESS (F)	00012190
*	TNR20G(I)=MIDDLE NODE, PANEL 1, INITIAL SODIUM TEMP. GUESS (F)	00012200
*	TNR30G(I)=UPPER NODE, PANEL 1, INITIAL SODIUM TEMP. GUESS (F)	00012210
*	TNR10(I)=PANEL 1, AXIAL NODE 1 INITIAL SODIUM TEMPERATURE (F)	00012220
*	TNR20(I)=PANEL 1, AXIAL NODE 2 INITIAL SODIUM TEMPERATURE (F)	00012230
*	TNR30(I)=PANEL 1, AXIAL NODE 3 INITIAL SODIUM TEMPERATURE (F)	00012240
*	TPT=TIME OF THE RECEIVER PUMP TRIP (SEC)	00012250
*	TR=SODIUM TEMPERATURE (R)	00012260
*	TRAPZ=INTEGRATION METHOD (TRAPAZOIDAL)	00012270
*	TRW14=NODE 1 TUBE TEMPERATURE RAISED TO FOURTH POWER (R)	00012280
*	TRW24=NODE 2 TUBE TEMPERATURE RAISED TO FOURTH POWER (R)	00012290
*	TRW34=NODE 3 TUBE TEMPERATURE RAISED TO FOURTH POWER (R)	00012300
*	TRW1(I)=PANEL 1, NODE 1 WALL TEMPERATURE (F)	00012310
*	TRW2(I)=PANEL 1, NODE 2 WALL TEMPERATURE (F)	00012320
*	TRW3(I)=PANEL 1, NODE 3 WALL TEMPERATURE (F)	00012330
*	TRW10(I)=PANEL 1, AXIAL NODE 1 INITIAL WALL TEMPERATURE (F)	00012340
*	TRW20(I)=PANEL 1, AXIAL NODE 2 INITIAL WALL TEMPERATURE (F)	00012350
*	TRW30(I)=PANEL 1, AXIAL NODE 3 INITIAL WALL TEMPERATURE (F)	00012360
*	TS=EFFECTIVE SKY TEMPERATURE (R**4)	00012370
*	TSM=SUM OF PANEL STATIC HEADS (PSI)	00012380
*	TSOD=SODIUM TEMPERATURE (F)	00012390
		00012400
*	VPDV=DRAG VALVE POSITION (FRACTION OPEN)	00012410
*	VPOVI=INITIAL DRAG VALVE POSITION (PERCENT OPEN)	00012420
*	VPOVX=DRAG VALVE INTERMEDIATE POSITION DEMAND (FRACTION OPEN)	00012430
*	VPI(I)=INITIAL VALVE POSITION, PANEL I (PERCENT OF FULL OPEN)	00012440
*	VPOX(I)=PANEL I CONTROLLER VALVE POSITION DEMAND (PERCENT OPEN)	00012450
*	VPX(I)=CONTROLLER I VALVE POSITION SIGNAL (FRACTION OPEN)	00012460
*	VP(I)=PANEL I VALVE POSITION (FRACTION OPEN)	00012470
		00012480
*	NCTI=NORMALIZED COLD TANK SODIUM INLET FLOW (LBM/SEC)	00012490
*	NCTIR=REFERENCE COLD TANK INLET SODIUM FLOW (LBM/SEC)	00012500
*	NDN=NORMALIZED DOWNCOMER FLOW	00012510
*	NDNA=ABSOLUTE VALUE OF NORMALIZED DOWNCOMER FLOW	00012520
*	NDNR=DOWNCOMER REFERENCE FLOW (LBM/SEC)	00012530
*	NDNQ=INITIAL DOWNCOMER NORMALIZED FLOW	00012540
*	NHTO=NORMALIZED HOT TANK SODIUM OUT LET FLOW	00012550
*	NHTOR=HOT TANK OUTLET REFERENCE FLOW (LBM/SEC)	00012560
*	NHTO=INITIAL HOT TANK NORMALIZED SODIUM INLET FLOW	00012570
*	NN=RISER NORMALIZED SODIUM FLOW	00012580

*	WNA=ABSOLUTE VALUE OF RISER FLOW (LBM/SEC)	00012590
*	WNI=NORMALIZED RISER SODIUM FLOW	00012600
*	WNIRT=NET FLOW INTO RECEIVER OUTLET TANK (LBM/SEC)	00012610
*	WNRA(I)=ABSOLUTE VALUE OF PANEL I FLOW (LBM/SEC)	00012630
*	WNRR(I)=PANEL I REFERENCE SODIUM FLOW (LBM/SEC)	00012640
*	WNRO(I)=PANEL I INITIAL NORMALIZED SODIUM FLOW	00012670
*	WNR(I)=PANEL I NORMALIZED SODIUM FLOW	00012675
*	WNO=INITIAL RISER FLOW (LB/SEC)	00012680
*	WNOINT=INITIAL RISER FLOW ROUTINE NAME	00012690
		00012700
*	X1,2 AND3=RECEIVER AXIALNODE HEAT CAPACITY (BTU/LBM-F)	00012710
		00012720
*	Y1,2 AND3=REC. AXIAL NODE FILM-COEFF.-AREA PRODUCT (BTU/F-SEC)	00012730
		00012740
*	ZERO=ZERO	00012750
*	Z1,2 AND3=REC. AXIAL NODE SODIUM DENSITY (LBM/CUFT)	00012760
*		00012770
*6.0	END CONTINUE STATEMENTS	00012780
		00012790
END		00012800
STOP		00012810

OUTPUT VARIABLE SEQUENCE

WNRR	TRW10	TRW20	TRW30	TNR10	TNR20	TNR30	POCT	RHOCT0	LNACT0
ZZ1030	RHORP0	WNO	KFHRP	PIRI	RHDC0	PORI	KFHC	IR	VPI
SGDV	QIDC	SRSQDV	LROT0	RHOHT0	LNAHT0	SHDCI	KFHDC	DPDVI	CVCDV
VPOVI	IWNRP	IWN	LOGAR	POHT	WDNR	IDC	WCTIR	WHTOR	WN
CPI	RHO1	RHO2	RHO3	SH	TSH	SNARI	SNARI	FH	TFHR
TFHCV	RHOROT	LROT	POR	PIRSO	RHOCT	LNACT	WNA	HRP	PIRFLO
PIR	DPCV	DWR	WNR	DWN	WNI	WNIRT	DMNROT	MNAROT	DMNACT
MNACT	TMRP	TMRP	TILL	TIMRPX	NRPX	SSRP	DNRP	NRP	WDNA
FHDC	RHONDV	SNDV	QDC	CVCDV	DPDV	RHOHT	LNAHT	SHDC	DWDN
WDN	DMNAHT	MNAHT	HANR1	RP	QI1	DTRW1	TRW1	PP	HANR2
QI2	DTRW2	TRW2	HANR3	QI3	DTRW3	TRW3	CP2	CP3	WNRA
DTNR1	TNR1	DTNR2	TNR2	DTNR3	TNR3	MTNSM	DTNR0	TNR0	KLNR
CPCT	ETARP	TNRPU0	DTNRP	TNRP	DTNR1	TNRPO	CPIH	DTNR1	TNR1
KLRPS	ZZ1085	TNRPU1	MCPCT	ZZ1087	TNCT	KLOC	DTNDC	TNOC	DTNDVI
TNDVI	KLDVHT	CPNDV	TNDV0	ZZ1091	TNHTI	CPHT	MCPHT	DTNHT	TNHT
VPX	VPOX	ETI	IRX	TNR3X	ES	VP	ELROT	EROTL	DVE
IRDV	DLROT	LVLSW	DRDVC	VPDV0X	DVEIX	DVEI	IRDVX	VPDVX	VPDV
CPR0T	MCPROT	RP1P	RPUP	QA1	QA2	QA3	QI	QA	Y

\$\$\$ TRANSLATION TABLE CONTENTS \$\$\$	CURRENT	MAXIMUM
MACRO AND STATEMENT OUTPUTS	190	1200
STATEMENT INPUT WORK AREA	645	3800
INTEGRATORS+MEMORY BLOCK OUTPUTS	28 + 0	300
PARAMETERS+FUNCTION GENERATORS	83 + 1	400
STORAGE VARIABLES+INTEGRATOR ARRAYS	39 + 12/2	50
HISTORY AND MEMORY BLOCK NAMES	21	50
MACRO DEFINITIONS AND NESTED MACROS	9	126
MACRO STATEMENT STORAGE	25	200
LITERAL CONSTANT STORAGE	0	100
SORT SECTIONS	2	20
MAXIMUM STATEMENTS IN SECTION	249	987

\$\$\$END OF TRANSLATOR OUTPUT\$\$\$

ESG-79-2, Vol II, Book 2
L-70

69
N272100006







APPENDIX B

MODEL RESPONSE TO 10% STEP CHANGE IN INCIDENT FLUX





RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC., PID
Q1 - TOTAL INCIDENT SOLAR POWER (MW)
QA - TOTAL ABSORBED SOLAR POWER (MW)
IN - TOTAL RECEIVER FLOW (LB/SEC)
TNR0 - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)

*071756301
050978 0002







RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC., PID
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNRPI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNRPUO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNRIL - TEMPERATURE OF SODIUM, RECEIVER INLET (F)

*071758301
050978 0001







*071758301
050978 0003

RUN 04-04 100 SEC, 10% STEP FLUX DECREASE AT 5 SEC., PID
PP(1) - SOUTH PANEL INCIDENT POWER (MW)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
INR(1) - SOUTH PANEL FLOW (NORMALIZED TO 36.17 LBW/SEC)
INR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)







RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC., PID
PP(6) - WEST PANEL INCIDENT POWER (MW)
VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)
WR(6) - WEST PANEL FLOW (NORMALIZED 89.15 LBM/SEC)
TNR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)

*071758301
050978 0004






RUN 04-04 100 SEC. 10% STEP FLUX DECREASE AT 5 SEC., PID
PP(12) - NORTH PANEL INCIDENT POWER (MW)
VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
NFR(12) - NORTH PANEL FLOW (NORMALIZED TO 187.69 LBM/SEC)
TNR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (°F)

*071758301
050978 0005







RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC. PID
TR42(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TR42(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TR42(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)

*071758301
050978 0006







RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC. PID
TNVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
TNVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
TNHI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)

*071758301
050978 0007







*071758301
050978 0008

RUN 04-04 100 SEC. 100 STEP FLUX DECREASE AT 5 SEC. PID
VPOV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
MON - DOWNCOMER FLOW (NORMALIZED TO 2220 LBM/SEC)
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR





071758301
050978 0009

RUN 04-04 100 SEC. 10% STEP FLUX DECREASE AT 5 SEC., PID
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
RHP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)



RUN 04-04 100 SEC, 100 STEP FLUX DECREASE AT 5 SEC., PID
LNACT - LEVEL OF SODIUM IN COLD TANK (FT)
LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)

*071758301
050978 0010










APPENDIX C

MODEL RESPONSE TO CLOUD COVER TRANSIENT COVERING
1%/SEC OF THE TOTAL FIELD

RUN 04-07 CLONIX AUGUST 9, 1978
 OI - TOTAL INCIDENT SOLAR FLOW (MMH)
 OA - TOTAL ABSORBED SOLAR POWER (MMH)
 IN - TOTAL RECEIVER FLOW (LBS/SEC)
 TAND - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)









APPENDIX D

MODEL RESPONSE TO 25% STEP (STEEP RAMP)
CHANGES IN INCIDENT FLUX





FORM 719-P REV. 7-78

RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
QI - TOTAL INCIDENT SOLAR POWER (MW)
QA - TOTAL ABSORBED SOLAR POWER (MW)
WN - TOTAL RECEIVER FLOW (LB/SEC)
TARO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)

*071758301
081078 0002







RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNRPUJ - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNRPUO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNRJ - TEMPERATURE OF SODIUM, RECEIVER INLET (F)







RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
PP(1) - SOUTH PANEL INCIDENT POWER (MW)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
WNR(1) - SOUTH PANEL FLOW (NORMALIZED TO 35.17 LBW/SEC)
TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)

*071758301
081078 0003







*071758301
081078 0004

RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
PP(6) - WEST PANEL INCIDENT POWER (MW)
VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)
WR(6) - WEST PANEL FLOW NORMALIZED 88.15 LB/SEC
TR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)






RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
PP(12) - NORTH PANEL INCIDENT POWER (MW)
VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
WR(12) - NORTH PANEL FLOW (NORMALIZED TO 157.69 LBM/SEC)
TNR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)

*071758301
081078 0005







1071798301
081078 0006

RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
TR#2(11) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TR#2(16) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TR#2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)







RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
 TNDVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
 TNDVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
 TNDTI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
 TNDT - TEMPERATURE OF SODIUM, HOT TANK (F)

*071758301
 081078 0007







*071758301
091078 0008

RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
LDN - DOWNFLOW FLOW (NORMALIZED TO 3220.1 LBM/SEC)
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR





RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)

071758301
081078 0009



RUN 04-07 25 PERCENT STEP CHANGES, AUGUST 9, 1978
LNACT - LEVEL OF SODIUM IN COLD TANK (FT)
LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)

071759301
081078 0010









APPENDIX E

MODEL RESPONSE TO LOSS OF RECEIVER PUMP POWER
(DRAG VALVE CLOSES WITH LOSS OF PUMP)

FORM 719-P REV. 7-78





071759301
071378 0002

RUN 04-039 PUMP TRIP, DEFUEL, RUNDOWN INC. 7-13-78
QI - TOTAL INCIDENT SOLAR POWER (MW)
QA - TOTAL ABSORBED SOLAR POWER (MW)
IN - TOTAL RECEIVER FLOW (LB/SEC)
TNRO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)




*071758301
071378 0001

RUN 04-038 PUMP TRIP, DEFOCUS, RUNDOWN INC. 7-13-78
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNRPI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNRPO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNR1 - TEMPERATURE OF SODIUM, RECEIVER INLET (F)







*071758301
071378 0003

RUN 04-03B PUMP TRIP, DEFOCUS, RUNDOWN INC., 7-13-78
PP(1) - SOUTH PANEL INCIDENT POWER (MW)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
WNR(1) - SOUTH PANEL FLOW (NORMALIZED TO 35.17 LB/SEC)
TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)



RUN 04-038 PUMP TRIP, DEFOCUS, RUNDOWN (NC, 7-13-78)
PP(12) - NORTH PANEL INCIDENT POWER (MW)
VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
NR(12) - NORTH PANEL FLOW (NORMALIZED TO 167.69 LB/SEC)
TR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)




071759301
071378 0005



99





RUN 04-038 PUMP TRIP, DEFOCUS, RUNDOWN INC, 7-13-78
TR#2(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TR#2(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TR#2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)

*071758301
071378 0006







RUN 04-038 PUMP TRIP, DEFOCUS, RANDON INC., 7-13-78
TNOVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
TNOVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
TNHTI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)

*071758301
071378 0007







*071758301
071378 0008

RUN 04-038 PUMP TRIP, DEFOCUS, RUNDOWN INC, 7-13-78
VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
WON - DOWNCOMER FLOW (NORMALIZED TO 2200.1 LBM/SEC)
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR





*071758301
071378 0009

RUN 04-038 PUMP TRIP, DEFOCUS, RUNDON INC., 7-13-78
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)



RUN 04-038 PUMP TRIP, DEFOCUS, RUNDOWN (INC. 7-13-78)
LNACT - LEVEL OF SODIUM IN COLD TANK (FT)
LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)

*071758301
071378 0010









APPENDIX F

MODEL RESPONSE TO
ACCIDENTAL DRAG VALVE OPENING AND CLOSING

FORM 719-P REV. 7-78





RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
Q1 - TOTAL INCIDENT SOLAR POWER (MW)
QA - TOTAL ABSORBED SOLAR POWER (MW)
WN - TOTAL RECEIVER FLOW (LB/SEC)
TNRO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)

*071758301
070678 0002




*071758301
070678 0001

RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNRPI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNRPO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNRI - TEMPERATURE OF SODIUM, RECEIVER INLET (F)




RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
PP(1) - SOUTH PANEL INCIDENT POWER (MMT)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
NVR(1) - SOUTH PANEL FLOW (NORMALIZED TO 35.17 LBM/SEC)
TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)

4071758301
070878 0003







RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
PP(6) - WEST PANEL INCIDENT POWER (MW)
VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)
NR(6) - WEST PANEL FLOW (NORMALIZED 88.15 LBW/SEC)
TR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)

*071758301
070678 0004






*071798301
070678 0005

RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
PP(12) - NORTH PANEL INCIDENT POWER (MW)
VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
WNR(12) - NORTH PANEL FLOW (NORMALIZED TO 187.69 LBM/SEC)
TNR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)







RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
TR#2(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TR#2(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TR#2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)

*071758301
070678 0006







071758301
070678 0007

RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
TNVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
TNVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
TNHI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)







*071758301
070678 0008

RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
MDN - DOWNCOMER FLOW (NORMALIZED TO 2220.1 LBM/SEC)
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR



*071758301
070678 0009



RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)



118





RUN 04-04 DRAG VALVE FAILS OPEN, NO DEFOCUS, 7-03-78
LNACT - LEVEL OF SODIUM IN COLD TANK (FT)
LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)

*071758301
070878 0010







RUN 04-05 DRAO VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
 QI - TOTAL INCIDENT SOLAR POWER (MWT)
 QA - TOTAL ABSORBED SOLAR POWER (MWT)
 WN - TOTAL RECEIVER FLOW (LB/SEC)
 TNRO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)

*071758301
 070678 0002







RUN 04-05 DRAG VALVE FAILS CLOSED. NO DEFOCUS. 7-03-78
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNRPI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNRPUO - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNR1 - TEMPERATURE OF SODIUM, RECEIVER INLET (F)

*071758301
070678 0001







RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
PP(1) - SOUTH PANEL INCIDENT POWER (MW)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
NR(1) - SOUTH PANEL FLOW (NORMALIZED TO 36.17 LBM/SEC)
TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)

*071758301
070678 0003







RUN 04-038 PUMP TRIP, DEFOCUS, RANDOAN INC. 7-13-78
PP(6) - WEST PANEL INCIDENT POWER (MW)
VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)
NR(6) - WEST PANEL FLOW (NORMALIZED 89.15 LBW/SEC)
TNR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)

*071758301
071378 0004







*071758301
070678 0004

RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
 PP(6) - WEST PANEL INCIDENT POWER (MW)
 VP(6) - WEST PANEL VALVE POSITION (FRACTION OPEN)
 WNR(6) - WEST PANEL FLOW (NORMALIZED 88.15 LBM/SEC)
 TNR3(6) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)






RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
 PP(12) - NORTH PANEL INCIDENT POWER (MW)
 VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
 NR(12) - NORTH PANEL FLOW (NORMALIZED TO 167.69 LBW/SEC)
 TRN3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)

*071758301
 070678 0005







*071758301
070578 0006

RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-79
TRW2(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TRW2(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TRW2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)







RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
TNOVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
TNOVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
TNHTI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)

*071758301
070678 0007







071758301
070678 0008

RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
WON - DOWNCOMER FLOW (NORMALIZED TO 2220.1 LBM/SEC)
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR





RUN 04-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)

*071758301
070578 0009



RUN 84-05 DRAG VALVE FAILS CLOSED, NO DEFOCUS, 7-03-78
LNACT - LEVEL OF SODIUM IN COLD TANK (FT)
LNAHT - LEVEL OF SODIUM IN COLD TANK (FT)

*071758301
070678 0010









APPENDIX G

MODEL RESPONSE TO EMERGENCY SHUTDOWN
15-SECOND INCIDENT POWER DECAY RAMP





*071756301
080978 0002

RUN ON-10 EMERGENCY SHUTDOWN 08-09-78
QI - TOTAL INCIDENT SOLAR POWER (MW)
QA - TOTAL ABSORBED SOLAR POWER (MW)
IN - TOTAL RECEIVER FLOW (LB/SEC)
TNO - TEMPERATURE OF SODIUM RECEIVER OUTLET TANK (F)




*071758301
080978 0001

RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
TNCT - TEMPERATURE OF SODIUM IN COLD TANK (F)
TNPUI - TEMPERATURE OF SODIUM, RECEIVER PUMP INLET (F)
TNPUD - TEMPERATURE OF SODIUM, RECEIVER PUMP OUTLET (F)
TNRI - TEMPERATURE OF SODIUM, RECEIVER INLET (F)




*071759301
080978 0003

RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
PP(1) - SOUTH PANEL INCIDENT POWER (MW)
VP(1) - SOUTH PANEL VALVE POSITION (FRACTION OPEN)
WNR(1) - SOUTH PANEL FLOW (NORMALIZED TO 36.17 LBW/SEC)
TNR3(1) - TEMPERATURE OF SODIUM, SOUTH PANEL OUTLET (F)




*071758301
080978 0004

RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
PP(S) - WEST PANEL INCIDENT POWER (MW)
VP(S) - WEST PANEL VALVE POSITION (FRACTION OPEN)
WNR(S) - WEST PANEL FLOW (NORMALIZED TO 15 LB/SEC)
TNR3(S) - TEMPERATURE OF SODIUM, WEST PANEL OUTLET (F)




*071758301
080978 0005


RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
PP(12) - NORTH PANEL INCIDENT POWER (MW)
VP(12) - NORTH PANEL VALVE POSITION (FRACTION OPEN)
WR(12) - NORTH PANEL FLOW (NORMALIZED TO 167.69 LB/SEC)
TR3(12) - TEMPERATURE OF SODIUM, NORTH PANEL OUTLET (F)




PP(12) VS TIME



VP(12) VS TIME






WR(12) VS TIME



TR3(12) VS TIME





*071758301
080978 0006

RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
TR-2(1) - MEAN WALL TEMPERATURE, MIDPLANE SOUTH PANEL (F)
TR-2(6) - MEAN WALL TEMPERATURE, MIDPLANE WEST PANEL (F)
TR-2(12) - MEAN WALL TEMPERATURE, MIDPLANE NORTH PANEL (F)




RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
 TNVI - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE INLET
 TNVO - TEMPERATURE OF SODIUM, PRESSURE REDUCING DEVICE OUTLET
 TNHI - TEMPERATURE OF SODIUM, HOT TANK INLET (F)
 TNHT - TEMPERATURE OF SODIUM, HOT TANK (F)

*071758301
 080978 0007




RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
VPDV - PRESSURE REDUCING DEVICE VALVE POSITION (FRACTION OPEN)
WON - DOWNCOMER FLOW (NORMALIZED TO 2220.) LPM/SEC
LROT - RECEIVER OUTLET TANK SODIUM LEVEL (FT)
EROTL - RECEIVER OUTLET TANK SODIUM LEVEL ERROR


*071758301
080978 0008




VPDV VS TIME



WON VS TIME







LROT VS TIME



EROTL VS TIME

RUN 04-10 EMERGENCY SHUTDOWN 08-09-78
NRP - RECEIVER PUMP SPEED (NORMALIZED TO 700 RPM)
HRP - RECEIVER PUMP HEAD (NORMALIZED TO 824 FT)
PIR - PRESSURE AT RECEIVER INLET (PSIA)
POR - PRESSURE AT RECEIVER OUTLET (PSIA)

*071756301
080978 0009



RUN 04-10 EMERGENCY SHUTDOWN, 08-09-78
LNACT - LEVEL OF SODIUM IN COLD TANK (FT.)
LNAMT - LEVEL OF SODIUM IN COLD TANK (FT.)

*071756301
080978 0010

