

8452

SAN-1483-1/5


**CONCEPTUAL DESIGN OF ADVANCED CENTRAL RECEIVER POWER  
SYSTEMS SODIUM-COOLED RECEIVER CONCEPT. FINAL REPORT**

**Volume 4, Commercial and Pilot Plant Cost Data**

**March 1979**

**Work Performed Under Contract No. EG-77-C-03-1483**

**Rockwell International  
Energy Systems Group  
Canoga Park, California**



**U.S. Department of Energy**



**Solar Energy**

22.0013 VOL 4

## NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

This report has been reproduced directly from the best available copy.

Available from the National Technical Information Service, U. S. Department of Commerce, Springfield, Virginia 22161.

Price: Paper Copy \$9.00  
Microfiche \$3.00

**CONCEPTUAL DESIGN  
OF  
ADVANCED CENTRAL RECEIVER POWER SYSTEMS  
SODIUM-COOLED RECEIVER CONCEPT  
FINAL REPORT**

**VOLUME IV  
COMMERCIAL AND PILOT PLANT COST DATA**

**MARCH 1979**

**PREPARED FOR THE  
U.S. DEPARTMENT OF ENERGY  
AS PART OF  
CONTRACT NO. EG-77-C-03-1483**



Rockwell International  
Energy Systems Group



**Salt River Project**  
WATER POWER



## CONTENTS

	Page
Preface . . . . .	7
I. Introduction . . . . .	9
II. 100-MWe Commercial Plant Cost . . . . .	10
A. 100-MWe Baseline Concept . . . . .	10
1. Collector Cost Analysis . . . . .	10
2. Receiver Subsystem . . . . .	23
3. Thermal Storage Subsystem . . . . .	24
4. Master Control Cost Analysis . . . . .	24
B. Alternative Concept With Air-Rock Storage . . . . .	30
III. 281-MWe Commercial Plant Cost . . . . .	35
A. 281-MWe Plant Description . . . . .	35
IV. Pilot Plant Cost . . . . .	43
V. Solar Thermal Electric Annual Energy Calculated and BUCKS Input Data . . . . .	50
A. Comments . . . . .	53
1. STEAEC . . . . .	53
2. BUCKS . . . . .	53
B. Input Data . . . . .	53
1. STEAEC . . . . .	53
2. BUCKS . . . . .	57
Appendices	
A. Cost Substantiation Data for the 100-MWe Commercial Plant — All Sodium Storage . . . . .	A-1
B. Cost Substantiation Data for the 100-MWe Commercial Plant — Air-Rocks Storage . . . . .	B-1
C. Cost Substantiation Data for the 281-MWe Commercial Plant . . .	C-1
D. Cost Substantiation Data for the Pilot Plant . . . . .	D-1

## TABLES

	Page
1. 100-MWe Baseline Concept With All-Sodium Storage . . . . .	11
2. Advanced Central Receiver System — 100-MWe Commercial Plant Summary Data . . . . .	16
3. 100-MWe Plant With Air-Rock Storage . . . . .	31
4. 281-MWe Commercial Plant With All-Sodium Storage . . . . .	36
5. Advanced Central Receiver System — 281-MWe Commercial Plant Summary Data . . . . .	41
6. 10-MWe Pilot Plant . . . . .	44
7. Advanced Central Receiver System Summary Data — Pilot Plant . . . .	48
8. Field Efficiency Matrix, F, Provided by MDAC . . . . .	54
9. Scaling Factors Used With Sample Data . . . . .	54
10. Field Efficiency Matrix, F, With "Adjusted" Dot Values . . . . .	54
11. Sample Problem STEAEC Inputs . . . . .	55
12. Salient Items for ACR STEAEC Inputs . . . . .	56
13. Plant Characteristics — Derated Operation Capability . . . . .	57
14. Revised All-Sodium Baseline STEAEC Inputs With "Adjusted" Field Efficiencies and "No Derated" Operation . . . . .	58
15. STEAEC Output → BUCKS Input . . . . .	59
16. BUCKS Input . . . . .	60
17. Base Solar-Related Cost Estimates . . . . .	61
18. Base Nonsolar-Related Cost Estimates . . . . .	62
19. Advanced Central Receiver — BUCKS Output . . . . .	63

## FIGURES

	Page
1. 100-MWe Baseline Concept With All-Sodium Storage . . . . .	15
2. Prototype Heliostat Baseline . . . . .	20
3. Master Control Unit . . . . .	26
4. Pilot and First Plants — Master Control Subsystem — Block Diagram . . . . .	28
5. Nth Plants — Master Control Subsystem — Block Diagram . . . . .	29
6. Advanced Central Receiver — Combined Air-Rock and All-Sodium Storage . . . . .	34
7. 281-MWe Commercial Plant With All-Sodium Storage . . . . .	40
8. 10-MWe Pilot Plant With All-Sodium Storage . . . . .	47
9. Solar Thermal Electric Power Plant Analysis Models . . . . .	50
10. Solar Thermal Electric Annual Energy Calculator . . . . .	51
11. BUCKS . . . . .	52

## PREFACE

This report is submitted by the Energy Systems Group to the Department of Energy under Contract EG-77-C-03-1483 as final documentation. This Conceptual Design Report summarizes the analyses, design, planning, and cost efforts performed between October 1, 1977 and September 1, 1978. The report is submitted in four volumes, as follows:

- Volume I     Executive Summary
- Volume II    Book 1, Commercial Plant Conceptual Design  
              Book 2, Appendices
- Volume III   Development Plan and Pilot Plant Description
- Volume IV    Commercial and Pilot Plant Cost Data

The principal contractors supporting the Rockwell International Energy Systems Group, in this conceptual design effort, together with the main areas of responsibility, included McDonnell Douglas Aircraft Corporation as responsible for the Collector and Master Control Subsystem; Stearns-Roger Services, Inc. as responsible for Electric Power Generating Subsystem, Tower Design and Civil Engineering; and Salt River Project as the Utility Consultant. The University of Houston supported McDonnell Douglas in the Collector Field Studies. Personnel contributing to this design program and to the final report included:

### Rockwell International, Energy Systems Group

- T. H. Springer, Project Manager
- T. L. Johnson, Project Engineer
- W. B. Thomson, Lead Engineer, Receiver
- L. E. Glasgow, Lead Engineer, Receiver Subsystem
- A. Z. Frangos, Lead Engineer, Thermal Storage

### McDonnell Douglas Aircraft Corporation

- G. C. Coleman, Project Manager
- J. E. Raetz, Lead Engineer, Collector Subsystem

D. W. Pearson, Lead Engineer, Master Control Subsystem  
J. H. Nourse, Lead Engineer, Cost Analysis

University of Houston

L. L. Vant-Hull, Associate Director, Solar Energy Laboratory

Stearns-Roger Services, Inc.

W. R. Lang, Project Manager  
A. W. McKenzie, Principal Author

Salt River Project

S. M. Chalmers, Director, Engineering Services  
R. F. Durning, Staff Consultant, Engineering Services  
D. R. Squire, Supervisor, Power Plant Engineering  
R. M. Hayslip, Manager, Corporate Planning



## 1. INTRODUCTION

This volume of the Advanced Central Receiver Final Report presents the cost data using the Cost Breakdown Structure identified in the Preliminary Specification. Cost summaries are presented in the following sections for the 100-MWe and 281-MWe Commercial Plant and a 10-MWe Pilot Plant. Cost substantiation data for this volume are presented in the Appendices.

Other cost summary data include Nth Plant data for the 100-MWe and 281-MWe Commercial Plants, and a summary for the alternative concept Air-Rock Storage System.

The main description of the plant costing technique occurs as part of Section II for the 100-MWe Baseline Concept.

## II. 100-MWE COMMERCIAL PLANT COST

The cost summaries for the 100-MWe Commercial Plant are presented in this section for the baseline plant with an all-sodium storage system and for the alternative air-rock storage system. While the major cost estimating effort was for the first commercial plant, cost projections for the Nth Plant are also presented. A description of the cost methodology is given here also.

### A. 100-MWe BASELINE CONCEPT

Table 1 presents a cost summary for the 100-MWe Baseline Concept. A brief description of the costing methodology is included here for each of the major subsystems. The plant configuration is shown schematically in Figure 1 with plant parameters given in Table 2.

#### 1. Collector Cost Analysis

##### a. Costing Results

Summarized costing results relating to the Collector Equipment subsystem are shown for Pilot, First, and Nth Commercial power plants that employ liquid sodium as a coolant in the receiver. These costs are based on data developed in association with the Prototype Heliostat study. Appendices A, B, C, and D provide further breakdown of these costs. Nonrecurring costs for Commercial Plants are shown as nil because those costs that are not already paid for in prior development are allocated over all production and included in the overhead. Visibility is buried in the Pilot and First Commercial costs but has been listed separately for Nth Commercial because of the likelihood of compensating "break-throughs" to occur that would tend to support the eventual realization of the projection before visibility is applied. The Operations and Maintenance (O&M) costs include the costs of ongoing spares and repair parts as well as field maintenance.

TABLE 1  
100-MWe BASELINE CONCEPT WITH ALL-SODIUM STORAGE  
(Sheet 1 of 4)

		Solar Plant Capital Investment Cost (\$000)						123,693
		First Commercial			Nth Plant			
4000	Solar Plant Cost			152,614				
4100	Site, Structures and Miscellaneous Equipment		5,381			5,271		
4110	Site		1,500			1,500		
	4111 Land							
	4112 Yard Work							
4120	Buildings		2,200			2,100		
	4121 Turbine Building	1,386			1,386			
	4122 Administration Buildings	180			180			
	4123 Warehouse and Maintenance Buildings	300			300			
	4124 Control Building	216			216			
	4125 Other	118			18			
4130	Miscellaneous Equipment		1,681			1,671		
	4131 Transportation and Lifting Equipment	721			711			
	4132 Communication Equipment	110			110			
	4133 Other	850			850			
4200	Turbine Plant Equipment			19,424			19,424	
	4210 Turbine Generators and Accessories		10,856			10,856		
	4220 Heat Rejection System		4,215			4,215		
	4230 Condensing Systems		320			320		
	4240 Feed-Heating or Recuperator System		1,655			1,655		
	4250 Working Fluid Circulation, Treatment, and Auxiliary Inventory Containment Equipment		2,378			2,378		
Subtotal				24,805			24,695	

TABLE 1  
 100-MWe BASELINE CONCEPT WITH ALL-SODIUM STORAGE  
 (Sheet 2 of 4)

	Solar Plant Capital Investment Cost (\$000)							
	First Commercial				Nth Plant			
4300 Electric Plant Equipment			4,834				4,301	
4310 Switchgear		860				860		
4320 Station Service Equipment		1,502				1,502		
4330 Protective Equipment		253				253		
4340 Power Wiring, Electrical Structures and Wiring Containers		938				938		
4350 Master Control Equipment		1,281				748		
4351 Hardware	697				487			
4352 Hardware Design & Engineering	332				185			
4353 Software Design, Development, and Test	252				76			
4400 Collector Equipment			60,596				45,820	
4410 Reflective Unit		16,956				12,460		
4420 Drive Unit		24,177				18,420		
4421 Azimuth or Horizontal Drive								
4422 Elevation or Vertical Drive								
4423 Motors								
4424 Position Indicators or Encoders								
4425 Power Distribution and Emergency Supply								
4430 Control and Instrumentation		2,621				1,720		
4431 Sensor or Calibration Equipment								
4432 Field Control Electronics								
4433 Control Signal Distribution Equipment								
4440 Foundation and Site		10,918				8,590		
4450 Heliostat Support and Protection		2,525				1,910		
4451 Heliostat Support Structure								
4452 Heliostat Protective Enclosure								
4453 Lightning Protection								
4460 Field Assembly and Check Out		3,399				2,720		
4470 Design and Engineering								
Subtotal			65,430				50,121	


TABLE 1  
100-MWe BASELINE CONCEPT WITH ALL-SODIUM STORAGE  
(Sheet 3 of 4)

	Solar Plant Capital Investment Cost (\$000)					
	First Commercial			Nth Plant		
4500 Receiver Equipment			23,305			19,852
4510 Receiver Unit		8,551		7,451		
4511 Absorber Unit	4,022			3,258		
4512 Support Structure	236			236		
4513 Receiver Circulation Equipment	1,526			1,190		
4514 Instrumentation and Control	1,452			1,452		
4515 Transportation, Field Erection, and Installation	1,315			1,315		
4520 Riser, Downcomer, and Horizontal Piping		4,942			4,942	
4530 Working Media Cost		183			183	
4540 Tower		3,166			3,166	
4550 Foundation						
4560 Steam Generator or Working Media Heat Transfer Equipment		5,144			4,110	
4570 Design and Engineering		1,319			0	
4600 Thermal Storage Equipment			12,086			11,400
4610 Media Containment Equipment		4,356			4,072	
4620 Media Circulation Equipment		724			688	
4630 Working Fluid Circulation Equipment		0			0	
4640 Discharging Heat Exchangers		0			0	
4650 Charging Heat Exchangers		0			0	
4660 Foundation		300			300	
4670 Design and Engineering		306			0	
4680 Media		6,400			6,400	
4800 Distributables and Indirect Costs			26,988			17,565
4810 Temporary Facilities, Equipment, etc.		1,200			1,000	
4820 Spare Parts		601			503	
4830 Architectural Engineering Services		1,482			1,450	
4840 Construction Management		3,394			3,113	
4850 Plant Startup and Checkout		1,000			500	
4860 Contingency		19,311			11,499	
Subtotal			62,379			48,877

**TABLE 1**  
**100-MWe BASELINE CONCEPT WITH ALL-SODIUM STORAGE**  
**(Sheet 4 of 4)**

Summary Category 4800 Calculations
4810 - Temporary Facilities - See Breakdown Sheet in Appendix
4820 - Spare Parts 1/2% of 4200 through 4600
4830 - A&E Services 5% of 4100 through 4300
4840 - Construction Management 5% of 4100 through 4300; 4400, 50, and 60; 4514, 15, 20, 40, 50, and 60; 4610 through 4660
4850 - Startup and Checkout - 20 Man-Years at \$50K/yr
4860 - Contingency - 10% of 4100 through 4400 29% of 4500 and 4600
4860 - Contingency on Nth Plant - 10% of 4100 through 4400 12.9% of 4500 and 4600

Items	O&M Costs (\$000/yr)					
	First Commercial			Nth Plant		
OM100 Operations Supervision			693			301
OM200 Maintenance Materials			581			253
OM210 Spare Parts		581			253	
OM211 Turbine and Electric Plant	320			139		
OM212 Collector Equipment	195			85		
OM213 Receiver Equipment				29		
OM214 Thermal Storage Equipment	66					
OM220 Material for Repair						
OM230 Other						
OM300 Maintenance Labor			1,112			810
OM310 Scheduled Maintenance	1,112			810		
OM320 Corrective Maintenance						
Total			2,386			1,364



42400-1096C

Figure 1. 100-MWe Baseline Concept With All-Sodium-Storage

TABLE 2  
 ADVANCED CENTRAL RECEIVER SYSTEM — 100-MWe  
 COMMERCIAL PLANT SUMMARY DATA  
 (Sheet 1 of 2)

Net Electrical Power (MWe)	100
Parasitic Power (MWe)	
Daytime	12
Nighttime	6
Insolation (W/m <sup>2</sup> )	950
Maximum Solar Power Absorbed (MWt)	390
Nominal Solar Power Absorbed for Direct Operating (MWt)	260
Plant Net Efficiency (%)	22.9
Collector Field Configuration	Single 360°, North Biased
Solar Multiple, Equinox Noon	1.5
Number of Heliostats	14,100
Heliostat Shape and Size [m (ft)]	Square, 7.38 x 7.42 (24.2 x 24.3)
Number of Towers/Receivers	1
Land Area (acre)	780
Receiver Mid-Point Elevation [m (ft)]	174 (571)
Receiver Configuration	External Cylinder
Number of Receiver Panels	24
Receiver Height and Diameter [m (ft)]	16.1 x 16.1 (52.8 x 52.8)
Receiver Maximum Heat Flux (MW/m <sup>2</sup> )	1.53
Sodium Temperatures [°C (°F)]	288/593 (550/1100)
Receiver Sodium Flow Rate [kg/hr (lb/hr)]	3.66 x 10 <sup>6</sup> (8.07 x 10 <sup>6</sup> )
Steam Generator Sodium Flow Rate (Direct Operation) [kg/hr (lb/hr)]	2.34 x 10 <sup>6</sup> (5.29 x 10 <sup>6</sup> )



TABLE 2  
 ADVANCED CENTRAL RECEIVER SYSTEM — 100-MWe  
 COMMERCIAL PLANT SUMMARY DATA  
 (Sheet 2 of 2)

Thermal Storage Capacity (MWth)	805
Total Sodium Inventory kg (lb)	$7.6 \times 10^6$ ( $16.8 \times 10^6$ )
Steam Generator and Reheater Type	Modular Steam Generator
Steam Conditions [ $\text{MN/m}^2$ , °C (psia, °F)]	
Initial	12.51, 538 (1815, 1000)
Reheated	2.72, 538 (394, 1000)
Steam Flow Rate [kg/hr (lb/hr)]	
Daytime	$3.32 \times 10^5$ ( $7.32 \times 10^5$ )
Nighttime	$3.15 \times 10^5$ ( $6.95 \times 10^5$ )
TSS Sodium Flow Rate [kg/hr (lb/hr)]	$2.31 \times 10^6$ ( $5.09 \times 10^6$ )
Feedwater Temperature [°C (°F)]	234 (453)
Turbine Back Pressure [ $\text{MN/m}^2$ (in. Hg)]	0.007 (2.0)
Heat Rejection [MW (Btu/hr)]	
Daytime	158 ( $540 \times 10^6$ )
Nighttime	150 ( $511 \times 10^6$ )

Cost Element	1978 DOLLARS IN MILLIONS			
	Pilot	1st Commercial	Nth Commercial	
			100 MWe	300 MWe
Nonrecurring	\$ 4.70	—	—	—
Transport and Lift Equipment	\$ 0.24	\$ 0.54	\$ 0.53	\$ 1.53
Collectors	\$10.55	\$60.60	\$45.82	\$131.82
Visibility	—	—	\$ 5.63	\$ 16.20
Total Collect	\$10.55	\$60.60	\$51.45	\$149.55
Initial Spares	\$ 0.01	\$ 0.04	\$ 0.02	\$ 0.06
1st Year O&M	\$ 0.09	\$ 0.80	\$ 0.77	\$ 2.22
Follow-on O&M	\$ 0.06	\$ 0.46	\$ 0.45	\$ 1.29

b. Basic Scenarios

The prototype heliostat projections are based on a specific set of cost driving ground rules and assumptions, design characteristics, and production scenarios. Although covered in previous sections of this report, a summary of the major drivers is useful in understanding costing results.

c. Major Costing Ground Rules


The costs that are presented assume the following major financial ground rules:

- 1) First half of 1978 dollars — no escalation.
- 2) Eight percent fee applied to each CBS line item.
- 3) Interest during construction (IDC) not costed.
- 4) No state sales tax applied due to uncertainty of state and potential tax rulings.
- 5) Special collector production profit center assumed for commercial costing.

- 6) Minimal manufacturing support practice for commercial production. No analysis except as purchased from the outside.
- 7) Overhead and fringe benefits applied as a factor on direct labor only.
- 8) Nth Commercial cost projected as that typical of the tenth year of operation of production facilities at 25,000 units produced per year. First Commercial cost reflects first year production in same facilities.
- 9) Commercial vendor quotes and production facility manning baseline at 25,000 heliostats per year. Pilot Plant material quoted basis at 1700 units.
- 10) Assumed utility operations hourly labor rate (\$15) – actual not known.
- 11) Commercial grade (non-mil standard) electronic components.
- 12) Scrap and rework, machine downtime, labor efficiency, operations refix factors, and first year failure rate factors applicable.
- 13) Cost reduction curves applied where specific cost difference from the 25,000 per year or 1700 unit baseline are not identified.

d. Technical Characteristics

Figure 2 summarizes the technical characteristics of the selected design. Key top level cost drivers include the enlarged reflector area ( $49 \text{ m}^2$ ) that has been divided into two main panels for ease of transport and installation; inverted stowage which is accomplished with a second screw jack and other additional hardware; the harmonic azimuth drive; and the factory-integrated drive-pedestal-electronics assembly which may be checked and calibrated in the factory. Other important drivers include the deep pile foundation which features a 1.22 m above grade tapered pipe interface extension; the use of a weldment versus a casting for the drive housing; and the stringer-semi-radial beam mirror backing structure configuration. Except for inversion, these design characteristics generally have allowed a simplified production scenario as well as purchased part and material economics.



9272-10

Figure 2. Prototype Heliostat Baseline

e. Baseline Scenarios

Main features of the baseline commercial production-installation scenario are listed below.

- 1) 25,000 units per year
- 2) 62,500 ft<sup>2</sup> production facility (no site assembly plant)

Central, unnamed location – outside Los Angeles  
Integrated mirror line and harmonic drive fabrication  
Automated assembly-transfer  
NC machining

- 3) Low skill labor – <300 factory direct
- 4) Private fleet transportation
- 5) Four basic installations – mechanized using special equipment

Foundation  
Pedestal-drive-electronic unit  
L&R reflector  
Power-control distribution

- 6) One shift per operation (240 days)

The Pilot Plant heliostat is assumed to be produced at Huntington Beach. As indicated, the Commercial baseline has been oriented to the 25,000 units per year production rate. The main changes associated with First Commercial production include reduced lapsed times, some increase in manning requirements reflecting startup problems of scheduling, line flows, equipment and tooling breakdowns, and material availability. Also, material costs are expected to be higher according to historical pattern.

The operations and maintenance scenario calls for the use of conventional handling equipment, mobile test vans, and special mirror washing equipment. In most cases, defective assemblies or components are first removed and replaced

with a spare or a previously repaired part and then the defective item is repaired or scrapped. The main exceptions occur where certain structural damage may be repaired in-place. The preponderance of maintenance actions involve repairs rather than scrapping defective hardware.

f. Costing Approach

The costing approach has been to develop a data base associated with the 25,000 units per year production rate and then perturb the data base to reflect special circumstances associated with the Pilot and First Commercial plant. The 25,000 unit data base has been developed as resource loads for labor where operator and support positions required for each item of production equipment or responsibilities are counted and classified by skill in order to accumulate staffing by CBS. Vendor quotes on ongoing 25,000 units per year requirements and at 1700 units were obtained for important cost items and catalogs consulted for common items. Like item costs were employed where certain electronic components have been projected as being available off the shelf at future dates. Appropriate factors have been applied to the data base along with burdened labor rates to arrive at total costs.

Changes to the 25,000 per year data base were accomplished specifically where design or production differences were identified and generally through appropriate changes in factors, labor rates, and overhead rates and through cost reduction curve logic. Costs not specifically addressed were altered along a cost reduction curve. Each basic cost entry has been "pegged" to a specific point on a cost reduction curve. For First Commercial, the cost is adjusted in accordance with cost reduction logic to a new estimate for the new production scenario.

Operations and maintenance costs are based on both resource loading and direct estimates of hours, unit investment cost for replaced or spared parts, and on quotes or prior study information on operations materials such as washing solution. Spares and repair parts are the product of annual failures (based on failure rates tables), hardware unit costs estimated for investment, and repair or replacement factors. Corrective maintenance is the product of crew size and

lapsed time or a direct hour estimate for bench labor, annual failures, repair factors for bench labor, and burdened labor rates. Scheduled maintenance is based on direct estimates or crew size and burdened labor rates, material quotes, and estimated frequencies. Results were factored to consider efficiency, added first year failures or problems, and refix where the first attempt at repair is not successful and must be redone.

For Commercial plants, applied labor and burden rates vary between factory, field, and operations. Factory rates are based on low side national average labor costs and MDAC burden and G&A experience at volume production facilities. MDAC Huntington Beach rates were used for Pilot Plant. Installation rates are based on Riverside, California, trade labor and fringe rates adjusted to allocate distributable cost. Both the factory and field rates include an 8% fee. The O&M labor rate has been estimated at \$15/h and does not include fee since the utility presumably would not charge itself a fee.

## 2. Receiver Subsystem

Material cost value was arrived at by vendor quotations and supplier catalogs based on commercial grade. Labor hours were developed by past experience and estimating manuals, a productivity factor was included due to height and location. The labor dollars per hours were based on fabrication and installation to be in the southern California area.

The piping systems are fabricated according to ASME B31.1, Heat Exchangers and Tanks, Section VIII Codes and Standards.

All exterior piping and equipment requiring insulation shall be weather proofed; the remainder shall be painted.

The estimate is based on 1978 dollars and excludes interest during construction, cost of land, and state and local taxes.

Cost reduction for the Nth Plant was the result of components which could be manufactured utilizing a learning curve.

Each receiver panel is fabricated with 100 tubes, 3/4-in. OD by 0.049 wall, Type 304 stainless steel, welded into 6-in. Type 304 stainless steel standard pipe. All material is commercial with standards per ASME Section VIII Code. All tube-to-tube and tube-to-header welds are made by using automatic weld process commercially available. All active tubes are coated with Pyromark, a heat collecting material. Costs include welding jig and weld development. All tube butt welds are radiographed. No installation costs are included.

### 3. Thermal Storage Subsystem

The hot sodium storage tank is a standard API type vessel 100-ft in diameter and 45-ft shell height with cone roof and column supports, all constructed with Type 304 stainless steel. The shell walls vary from 1/4-in. thickness at the top course to 1-in. thickness at the bottom course. The bottom is 1/4-in. plate and the roof is 3/16-in. thick. The vessel is of all-welded construction.

The cold sodium storage tank is a standard API type vessel 100-ft in diameter and 41-ft shell height with cone roof and column supports, all constructed of SA.516-70 and SA36 carbon steel. The shell walls vary in thickness of 1/4-in. top course to 11/16-in. bottom course. The bottom is 1/4-in. plate and the roof is 3/16-in. thick. The vessel is of all-welded construction.

A ring is provided around the base of each tank to provide a lateral seismic tie between the concrete base and the tank, with slotted attachments for thermal growth. A drip basin is also included around the base of the tanks.

The pump, piping, and valves are priced in the same manner as that used for the receiver subsystem.

### 4. Master Control Cost Analysis

#### a. Costing Results

Summarized costing results relating to the Master Control Equipment subsystem are shown here for the Pilot Plant and for the First and Nth Commercial



power plants that employ liquid sodium as a coolant in the receiver. Appendices A, B, C, and D provide a further breakdown of these costs. The nonrecurring

Cost Element	1978 DOLLARS IN MILLIONS			
	Pilot	1st Commercial	Nth Commercial	
			100 MWe	300 MWe
Nonrecurring	\$1.25	\$0.58	\$0.26	\$0.26
Investment	0.73	0.58	0.41	0.41
Visibility	0.14	0.12	0.08	0.08
Total	\$2.12	\$1.28	\$0.75	\$0.75
1st Year O&M	\$0.05	\$0.05	\$0.05	\$0.05
Followon O&M	\$0.05	\$0.05	\$0.05	\$0.05

costs for Hardware Design and Engineering (4352) and Software Design, Development and Test (4353) cover unique effort associated with the sodium control concept. The investment cost represents the cost of production-procurement, installation and checkout of the Master Control Unit (MCU) and includes an 8% fee. The visibility applies to the investment only and indicates a protected cost. However, it is just as likely that the lower projection will occur. The operations and maintenance indicate the costs of the various service contracts for the equipment procured for the MCU. It is important to note that the costs for the specialized subsystem controllers are not covered by the Master Control Subsystem Cost.

b. Basic Scenario

The Pilot Plant provides for the first "all-up" sodium system solar plant control. Both the Pilot Plant and the First Commercial require special data acquisition hardware that disappears in the Nth scenarios.

The First Commercial installation is assumed to be equivalent to the third in line following prior development, including the Pilot Plant. However, the




Figure 3. Master Control Unit

prior development relates more to the smaller Pilot Plant and water-steam systems. The Nth unit is costed as the 14th unit. For any given installation, the console is assembled and checked out, probably through simulation at the laboratory in Huntington Beach. After testing, the console is disassembled into major components and packaged and shipped to the installation site where it is reassembled and checked out for system operation. It is assumed that each installation is identical.

Although the commercial costs for the MCU are given in 1978 dollars, technological advances are taken into account, especially for the processor and the disc. The MCU will provide monitor and control of all system and subsystem parameters necessary to ensure safe and proper operation of the plant. The control practices are proven and off-the-shelf substantiating simple interface between the master control and each subsystem.

Those parameters that are pertinent to the evaluation of plant performance, safety and operation are displaced and/or recorded. The master control is designed to operate the plant essentially automatically with the override capability of the operator. Should the operator desire, the subsystem control can be accomplished through manual operation through single console control with easily read displays.

In general, the master control provides coordinated control and integration of the subsystems for single operator, single console control. Figures 3, 4, and 5 provide further insight on the technical characteristics of the costed hardware.

#### c. Costing Approach

Costs were developed based on specific identification of hardware requirements and the manpower on lapsed time necessary to perform the necessary assembly, testing and installation and other tasks. The preponderance of the material requirement is in the form of purchased parts, so that it was possible to obtain these costs along with the monthly maintenance contract costs from supplier catalogs. Hours have been developed as an extension of the manning and lapsed




Figure 4. Pilot and First Plants – Master Control Subsystem – Block Diagram




Figure 5. Nth Plants - Master Control Subsystem - Block Diagram

9272-12

times. Factors have been added to the costs to cover the 8% fee, rework, direct support of the engineering time, and efficiency. Labor has been costed on a 90% cost reduction curve, but material items, with the exception of processors, have been costed the same for all plants. The processors have been costed in accordance with the expected state-of-the-art for the time frames involved. Overhead is included as a factor on the applied labor rate. All labor is assumed part of the engineering burden centers. Transportation has been costed as a factor of the hardware cost.

#### B. ALTERNATIVE CONCEPT WITH AIR-ROCK STORAGE

The cost summary for the 100-MWe Commercial Plant with the air-rock storage system is presented in Table 3. Backup cost data are presented in Appendix B. A flow schematic of the receiver and storage subsystem are shown in Figure 6.

The cost data of Table 3 are the same as those of Table 1 except for CBS 4600, Thermal Storage, and for CBS 4520 for the additional piping. CBS 4800 also changes since this item is proportional to the other subsystem costs.

TABLE 3  
100-MWe PLANT WITH AIR ROCK STORAGE  
(Sheet 1 of 3)

		Solar Plant Capital Investment Cost (\$000)						
		First Commercial Air-Rocks			Nth Plant Air-Rocks			
4000	Solar Plant Cost			153,083				124,982
4100	Site, Structures and Miscellaneous Equipment		5,381			5,381		
4110	Site	1,500				1,500		
4111	Land							
4112	Yard Work							
4120	Buildings	2,200				2,200		
4121	Turbine Building	1,386				1,386		
4122	Administration Buildings	180				180		
4123	Warehouse-Maintenance Buildings	300				300		
4124	Control Building	216				216		
4125	Other	118				118		
4130	Miscellaneous Equipment	1,681				1,681		
4131	Transportation and Lifting Equipment	721				721		
4132	Communication Equipment	110				110		
4133	Other	850				850		
4200	Turbine Plant Equipment		19,424				19,424	
4210	Turbine Generators and Accessories	10,856				10,856		
4220	Heat Rejection System	4,215				4,215		
4230	Condensing Systems	320				320		
4240	Feed-Heating or Recuperator System	1,655				1,655		
4250	Working Fluid Circulation, Treatment, and Auxiliary Inventory Containment Equipment	2,378				2,378		
Subtotal			24,805				24,805	


**TABLE 3**  
**100-MWe PLANT WITH AIR ROCK STORAGE**  
**(Sheet 2 of 3)**

	Solar Plant Capital Investment Cost (\$000)					
	First Commercial Air-Rocks			Nth Plant Air Rocks		
4300 Electric Plant Equipment			4,834			4,301
4310 Switchgear		860			860	
4320 Station Service Equipment		1,502			1,502	
4330 Protective Equipment		253			253	
4340 Power Wiring, Electrical Structures, and Wiring Containers		938			938	
4350 Master Control Equipment		1,281			748	
4351 Hardware	697			487		
4352 Hardware Design and Engineering	332			185		
4353 Software Design, Development, and Test	252			76		
4400 Collector Equipment			60,596			45,820
4410 Reflective Unit		16,956			12,460	
4420 Drive Unit		24,177			18,420	
4421 Azimuth or Horizontal Drive						
4422 Elevation or Vertical Drive						
4423 Motors						
4424 Position Indicators or Encoders						
4425 Power Distribution and Emergency Supply						
4430 Control and Instrumentation		2,621			1,720	
4431 Sensor or Calibration Equipment						
4432 Field Control Electronics						
4433 Control Signal Distribution Equipment						
4440 Foundation and Site		10,918			8,590	
4450 Heliostat Support and Protection		2,525			1,910	
4451 Heliostat Support Structure						
4452 Heliostat Protective Enclosure						
4453 Lightning Protection						
4460 Field Assembly and Checkout		3,399			2,720	
4470 Design and Engineering						
Subtotal			65,430			50,121



TABLE 3  
100-MWe PLANT WITH AIR ROCK STORAGE  
(Sheet 3 of 3)

		Solar Plant Capital Investment Cost (\$000)					
		First Commercial Air-Rocks			Nth Plant Air Rocks		
4500	Receiver Equipment			24,588			21,397
4510	Receiver Unit		9,388			8,586	
	4511 Absorber Unit	4,022			3,220		
	4512 Support Structure	236			236		
	4513 Receiver Circulation Equipment	1,526			1,526		
	4514 Instrumentation and Control	2,289			2,289		
	4515 Transportation, Field Erection, and Installation	1,315			1,315		
4520	Riser, Downcomer, and Horizontal Piping		5,362			5,362	
4530	Working Media Cost		183			183	
4540	Tower		3,156			3,156	
4550	Foundation						
4560	Steam Generator or Working Media Heat Transfer Equipment		5,144			4,110	
4570	Design and Engineering		1,355			0	
4600	Thermal Storage Equipment			11,021			9,978
4610	Media Containment Equipment		538			538	
4620	Media Circulation Equipment and Buffer Storage		1,900			1,900	
4630	Working Fluid Circulation Equipment		1,391			1,250	
4640	Discharging Heat Exchangers		6,051			5,450	
4650	Charging Heat Exchangers						
4660	Foundation		240			240	
4670	Design and Engineering		300				
4680	Media		601			600	
4800	Distributables and Indirect Costs			27,239			18,681
4810	Temporary Facilities, Equipment, etc.		1,200			1,200	
4820	Spare Parts		600			505	
4830	Architectural Engineering Services		1,482			1,455	
4840	Construction Management		3,693			3,449	
4850	Plant Startup and Checkout		1,000			500	
4860	Contingency		19,264			11,572	
Subtotal				62,848			50,056



78-N27-62-20A

Figure 6. Advanced Central Receiver — Combined Air-Rock and All-Sodium Storage

### III. 281-MWe COMMERCIAL PLANT COST

The 281-MWe Commercial Plant cost summary is presented in Table 4. The cost data is for the Nth Plant. Backup cost data are presented in Appendix C.

#### A. 281-MWe PLANT DESCRIPTION

The 281-MWe plant flow schematic is shown in Figure 7. The concept is identical with that for the 100-MWe plant with two exceptions. Two evaporator units are used in parallel, and an additional feedwater heater is inserted on the suction side of the feedwater pump, giving a total of seven heaters. Table 5 provides a summary of basic 281-MWe plant data. The design data sheets of Appendix D, Vol II provide a list of system and component performance and design data.

TABLE 4  
281-MWe COMMERCIAL PLANT WITH ALL-SODIUM STORAGE  
(Sheet 1 of 4)

		Solar Plant Capital Investment Cost (\$000)		
		Nth Plant		
4000	Solar Plant Cost			306,034
4100	Site, Structures and Miscellaneous Equipment		11,239	
4110	Site	2,829		
4111	Land			
4112	Yard Work			
4120	Buildings	7,950		
4121	Turbine Building	5,500		
4122	Administration Buildings			
4123	Warehouse-Maintenance Buildings	1,600		
4124	Control Building			
4125	Other	850		
4130	Miscellaneous Equipment		460	
4131	Transportation and Lifting Equipment	350		
4132	Communication Equipment	110		
4133	Other			
4200	Turbine Plant Equipment		38,759	
4210	Turbine Generators and Accessories	21,560		
4220	Heat Rejection System	9,875		
4230	Condensing Systems	577		
4240	Feed-Heating or Recuperation System	3,203		
4250	Working Fluid Circulation, Treatment, and Auxiliary Inventory Containment Equipment	3,544		
Subtotal			49,998	

TABLE 4  
281-MWe COMMERCIAL PLANT WITH ALL-SODIUM STORAGE  
(Sheet 2 of 4)

		Solar Plant Capital Investment Cost (\$000)		
		Nth Plant		
4300	Electric Plant Equipment			6,865
4310	Switchgear		1,502	
4320	Station Service Equipment		2,163	
4330	Protective Equipment		300	
4340	Power Wiring, Electrical Structures, and Wiring Containers		2,231	
4350	Master Control Equipment		669	
	4350 Hardware	408		
	4352 Hardware Design and Engineering	185		
	4353 Software Design, Development and Test	76		
4400	Collector Equipment			131,820
4410	Reflective Unit		35,830	
4420	Drive Unit		53,030	
	4421 Azimuth or Horizontal Drive			
	4422 Elevation or Vertical Drive			
	4423 Motors			
	4424 Position Indicators or Encoders			
	4425 Power Distribution and Emergency Supply			
4430	Control and Instrumentation		4,890	
	4431 Sensor or Calibration Equipment			
	4432 Field Control Electronics			
	4433 Control Signal Distribution Equipment			
4440	Foundation and Site		24,720	
4450	Heliostat Support and Protection		5,550	
	4451 Heliostat Support Structure			
	4452 Heliostat Protective Enclosure			
	4453 Lightning Protection			
4460	Field Assembly and Check Out		7,800	
4470	Design and Engineering			
Subtotal				138,685

TABLE 4  
281-MWe COMMERCIAL PLANT WITH ALL-SODIUM STORAGE  
(Sheet 3 of 4)

		Solar Plant Capital Investment Cost (\$000)	
		Nth Plant	
4500	Receiver Equipment		42,077
4510	Receiver Unit	16,425	
4511	Absorber Unit	6,288	
4512	Support Structure	455	
4513	Receiver Circulation Equipment	4,342	
4514	Instrumentation and Control	2,802	
4515	Transportation, Field Erection, and Instal- lation	2,538	
4520	Riser, Downcomer, and Horizontal Piping	9,538	
4530	Working Media Cost	520	
4540	Tower	7,652	
4550	Foundation		
4560	Steam Generator or Working Media Heat Transfer Equipment	7,942	
4570	Design and Engineering		
4600	Thermal Storage Equipment		30,490
4610	Media Containment Equipment	8,025	
4620	Media Circulation Equipment	1,886	
4630	Working Fluid Circulation Equipment	0	
4640	Discharging Heat Exchangers	0	
4650	Charging Heat Exchangers	0	
4660	Foundation	579	
4670	Design and Engineering		
4680	Media	20,000	
4800	Distributables and Indirect Costs		44,784
4810	Temporary Facilities, Equipment, etc.	2,143	
4820	Spare Parts	1,250	
4830	Architectural Engineering Services	2,843	
4840	Construction Management	6,795	
4850	Plant Startup and Checkout	2,000	
4860	Contingency	29,753	
Subtotal			117,351

TABLE 4  
281-MWe COMMERCIAL PLANT WITH ALL-SODIUM STORAGE  
(Sheet 4 of 4)

	O&M Costs (\$1,000/year)					
	First Commercial			Nth Plant		
OM100 Operations Supervision			843			376
OM200 Maintenance Materials			1,078			469
OM210 Spare Parts		1,078			469	
OM211 Turbine and Electric Plant	593			258		
OM212 Collector Equipment	363			158		
OM213 Receiver Equipment	122			54		
OM214 Thermal Storage Equipment						
OM220 Material for Repair						
OM230 Other						
OM300 Maintenance Labor			2,539			1,800
OM310 Scheduled Maintenance	2,539			1,800		
OM320 Corrective Maintenance						
<b>Total</b>			<b>4,460</b>			<b>2,645</b>




Figure 7. 281-MWe Commercial Plant With All Sodium Storage



TABLE 5  
 ADVANCED CENTRAL RECEIVER SYSTEM --  
 281-MWe COMMERCIAL PLANT  
 SUMMARY DATA  
 (Sheet 1 of 2)

Net Electrical Power (MWe)	281
Parasitic Power (MWe)	
Daytime	31
Nighttime	16
Insolation ( $W/m^2$ )	950
Maximum Solar Power Absorbed (MWt)	1084
Nominal Solar Power Absorbed for Direct Operating (MWt)	723
Plant Net Efficiency (%)	25
Collector Field Configuration	Single $360^\circ$ , North Biased
Solar Multiple, Equinox Noon	1.5
Number of Heliostats	40,591
Heliostat Shape and Size [m (ft)]	Square, 7.38 x 7.42 (24.2 x 24.3)
Number of Towers/Receivers	1
Land Area (acre)	2220
Receiver Mid-Point Elevation [m (ft)]	268 (879)
Receiver Configuration	External Cylinder
Number of Receiver Panels	24
Receiver Height and Diameter [m (ft)]	22.8 x 22.8 (74.8 x 74.8)
Receiver Maximum Heat Flux ( $MW/m^2$ )	1.94
Sodium Temperatures [ $^\circ C$ ( $^\circ F$ )]	288/593 (550/1100)
Receiver Sodium Flow Rate [kg/hr (lb/hr)]	$10.2 \times 10^6$ ( $22.6 \times 10^6$ )
Steam Generator Sodium Flow Rate (Direct Operation) [kg/hr (lb/hr)]	$6.82 \times 10^6$ ( $15.0 \times 10^6$ )

TABLE 5  
 ADVANCED CENTRAL RECEIVER SYSTEM —  
 281-MWe COMMERCIAL PLANT  
 SUMMARY DATA  
 (Sheet 2 of 2)

---

Thermal Storage Capacity (MWth)	2350*
Total Sodium Inventory [kg (lb)]	23 x 10 <sup>6</sup> (50.4 x 10 <sup>6</sup> )
Steam Generator and Reheater Type	Modular Steam Generator
Steam Conditions [MN/m <sup>2</sup> , °C (psia, °F)]	
Initial	16.6, 538 (2400, 1000)
Reheated	538 (1000)
Steam Flow Rate [kg/hr (lb/hr)]	
Daytime	9.3 x 10 <sup>5</sup> (20.5 x 10 <sup>5</sup> )
Nighttime	8.80 x 10 <sup>5</sup> (19.5 x 10 <sup>5</sup> )
TSS Sodium Flow Rate [kg/hr (lb/hr)]	6.82 x 10 <sup>6</sup> (15.0 x 10 <sup>6</sup> )
Feedwater Temperature [°C (°F)]	242 (468)
Turbine Back Pressure [MN/m <sup>2</sup> (in. Hg)]	0.007 (2.0)
Heat Rejection [MW (Btu/hr)]	
Daytime	442 (1500 x 10 <sup>6</sup> )
Nighttime	420 (1430x 10 <sup>6</sup> )

---

\*Includes 180 MWt for startup/shutdown

#### IV. PILOT PLANT COST

Pilot Plant cost summary data are presented in Table 6. The cost backup data are given in Appendix D.

The Pilot Plant is designed to produce 10-MW net electrical power and to provide a test of the full-scale 100-MWe size receiver panels.

The receiver consists of three full-size receiver panels arranged as a cylindrical segment to give ~38 MW thermal power. The plant schematic is shown in Figure 8, with performance parameters as given in Table 7.

The Solar Multiplier (SM) is estimated to be 1.2 in order to supply a 1-h storage capability. The 1 h of storage capability was selected to provide demonstration of the buffering capability of the all-sodium storage system and yet demonstrate significant nighttime operation from storage without the cost of a longer duration storage capacity.

The receiver outlet temperature will be 1100<sup>0</sup>F, the same as for the 100-MWe plant, in order to demonstrate sodium system capability and operation at this temperature condition. Since reheat turbines are not available in the small 10-MWe size, reheat capability will not be provided. The steam generator will be a once-through unit of the MSG design. A once-through unit will be of sufficient size to represent the commercial-scale units. Steam outlet temperatures up to 1000<sup>0</sup>F will be provided for demonstration purposes, though the turbine may be limited to lower temperatures. An attemporator will be used to reduce steam temperatures. The steam generator unit is expected to be nearly identical to the ESG MSG in physical size and design.

TABLE 6  
10-MWe PILOT PLANT  
(Sheet 1 of 3)


		Solar Plant Capital Investment Cost (\$000)		
4000	Solar Plant Cost			39,306
4100	Site, Structures and Miscellaneous Equipment		1,427	
4110	Site		300	
4111	Land			
4112	Yard Work			
4120	Buildings		560	
4121	Turbine Building	300		
4122	Administration Buildings	20		
4123	Warehouse-Maintenance Buildings	50		
4124	Control Building	100		
4125	Other	90		
4130	Miscellaneous Equipment		567	
4131	Transportation and Lifting Equipment	296		
4132	Communication Equipment	11		
4133	Other	260		
4200	Turbine Plant Equipment		4,880	
4210	Turbine Generators and Accessories			
4220	Heat Rejection System			
4230	Condensing Systems			
4240	Feed-Heating or Recuperator System			
4250	Working Fluid Circulation, Treatment, and Auxiliary Inventory Containment Equipment			
Subtotal			6,307	

**TABLE 6**  
**10-MWe PILOT PLANT**  
**(Sheet 2 of 3)**

		Solar Plant Capital Investment Cost (\$000)	
4300	Electric Plant Equipment		3,154
4310	Switchgear	}	1,040
4320	Station Service Equipment		
4330	Protective Equipment		
4340	Power Wiring, Electrical Structures, and Wiring Containers		
4350	Master Control Equipment		2,114
4351	Hardware	868	
4352	Hardware Design and Engineering	790	
4353	Software Design, Development, and Test	456	
4400	Collector Equipment		7,090
4410	Reflective Unit	2,630	
4420	Drive Unit	4,460	
4421	Azimuth or Horizontal Drive		
4422	Elevation or Vertical Drive		
4423	Motors		
4424	Position Indicators or Encoders		
4425	Power Distribution and Emergency Supply		
4430	Control and Instrumentation		990
4431	Sensor or Calibration Equipment		
4432	Field Control Elect Electronics		
4433	Control Signal Distribution Equipment		
4440	Foundation and Site		960
4450	Heliostat Support and Protection		390
4451	Heliostat Support Structure		
4452	Heliostat Protective Enclosure		
4453	Lightning Protection		
4460	Field Assembly and Check Out		550
4470	Design and Engineering		570
Subtotal			13,704

TABLE 6  
10-MWe PILOT PLANT  
(Sheet 3 of 3)

		Solar Plant Capital Investment Cost (\$000)	
4500	Receiver Equipment		8,063
	4510 Receiver Unit	1,523	
	4511 Absorber Unit	345	
	4512 Support Structure	246	
	4513 Receiver Circulation Equipment	80	
	4514 Instrumentation and Control	798	
	4515 Transportation, Field Erection, and Installation	54	
	4520 Riser, Downcomer, and Hori- zontal Piping	2,426	
	4530 Working Media Cost	28	
	4540 Tower	} 1,049	
	4550 Foundation		
	4560 Steam Generator or Working Media Heat Transfer Equipment	900	
	4570 Design and Engineering	2,137	
4600	Thermal Storage Equipment		1,471
	4610 Media Containment Equipment	478	
	4620 Media Circulation Equipment	20	
	4630 Working Fluid Circulation Equipment	0	
	4640 Discharging Heat Exchangers	0	
	4650 Charging Heat Exchangers	0	
	4660 Foundation	14	
	4670 Design and Engineering	711	
	4680 Media	248	
4800	Distributables and Indirect Costs		9,761
	4810 Temporary Facilities, Equip- ment, etc.	2,594	
	4820 Spare Parts	47	
	4830 Architectural Engineering Services	473	
	4840 Construction Management	1,287	
	4850 Plant Startup and Checkout	500	
	4860 Contingency	4,860	
Subtotal			19,295



42400-1096G

Figure 8. 10-MWe Pilot Plant With All-Sodium Storage

TABLE 7  
 ADVANCED CENTRAL RECEIVER  
 SYSTEM SUMMARY DATA —  
 PILOT PLANT  
 (Sheet 1 of 2)

Net Electrical Power (MWe)	10
Parasitic Power (MWe)	
Daytime	1.2
Nighttime	0.6
Isolation ( $W/m^2$ )	950
Maximum Solar Power Absorbed (MWt)	36.2
Nominal Solar Power Absorbed for Direct Operating (MWt)	30.2
Plant Net Efficiency (%)	
Collector Field Configuration	North
Solar Multiple, Equinox Noon	1.2
Number of Heliostats	1065 (Inverted)
Heliostat Shape and Size [m (ft)]	Square, 6.4 x 6.4 (24.2 x 24.3)
Number of Towers and Receivers	1
Receiver Mid-Point Elevation [m (ft)]	104 (341)
Receiver Configuration	External Cylinder
Number of Receiver Panels	3
Receiver Height and Diameter [m (ft)]	16.1 x 6.3 (52.8 x 20.7)
Receiver Maximum Heat Flux ( $MW/m^2$ )	1.53
Sodium Temperatures [ $^{\circ}C$ ( $^{\circ}F$ )]	288/593 (550/1100)
Receiver Sodium Flow Rate [kg/h (lb/h)]	$0.337 \times 10^6$ ( $0.741 \times 10^6$ )
Steam Generator Sodium Flow Rate (Direct Operation) [kg/h (lb/h)]	$0.281 \times 10^6$ ( $0.018 \times 10^6$ )



TABLE 7  
 ADVANCED CENTRAL RECEIVER  
 SYSTEM SUMMARY DATA -  
 PILOT PLANT  
 (Sheet 2 of 2)

Thermal Storage Capacity (MWth)	30.2
Total Sodium Inventory [kg (lb)]	$0.352 \times 10^6$ ( $0.775 \times 10^6$ )
Steam Generator and Reheater Type	Modular Steam Generator
Steam Conditions [ $\text{MN/m}^2$ , $^{\circ}\text{C}$ (psia, $^{\circ}\text{F}$ )]	
Initial	10.10, 538 (1465, 1000)
Steam Flow Rate [kg/h (lb/h)]	
Daytime	$0.42 \times 10^5$ ( $0.929 \times 10^5$ )
Nighttime	$0.405 \times 10^5$ ( $0.893 \times 10^5$ )
TSS Sodium Flow Rate [kg/h (lb/h)]	$0.281 \times 10^6$ ( $0.618 \times 10^6$ )
Feedwater Temperature [ $^{\circ}\text{C}$ ( $^{\circ}\text{F}$ )]	234 (453)
Turbine Back Pressure [ $\text{MN/m}^2$ (in. Hg)]	0.007 (2.0)
Heat Rejection [MW (Btu/h)]	
Daytime	22 ( $75 \times 10^6$ )
Nighttime	21.2 ( $72 \times 10^6$ )

## V. SOLAR THERMAL ELECTRIC ANNUAL ENERGY CALCULATED AND BUCKS INPUT DATA

The Solar Thermal Electric Annual Energy Calculator (STEAEC) is a quasi-steady state computer model which estimates the annual performance of a solar thermal electric power plant. BUCKS is a computer model developed for economic analysis of solar electric power plants. The model calculates the levelized busbar energy costs which is the constant revenue per unit output required over the lifetime of the plant to compensate for its fixed and variable costs, pay interest to stockholders, and provide return to shareholders.

Both STEAEC and BUCKS were developed at Sandia Laboratories for use as part of the Central Receiver Solar Thermal Electric Program. MIRVAL is another program developed at Sandia to provide field efficiencies as a function of sun azimuth and elevation. These three programs are used in conjunction with each other (although they may be used independently) as shown in Figure 9. Figure 10 shows the STEAEC block diagram, and Figure 11 shows the block diagram for BUCKS






Figure 9. Solar Thermal Electric Power Plant Analysis Models



9272-14

Figure 10. Solar Thermal Electric Annual Energy Calculator



9272-15

Figure 11. BUCKS

The block diagrams show the general logic and information input and output for both these programs. More detailed information is contained in the Sandia reports for these programs.

## A. COMMENTS

### 1. STEAEC

#### a. Collector Field Efficiency Data, F

The effects of reflectivity, atmospheric attenuation, blocking, shading, cosine, tower shadow, tracking errors, alignment errors, receiver interception, and heliostat reliability are all included in the function, F. In the STEAEC program, F is represented by a bicubic spline fit to a rectangular array of elevation and azimuth angles ( $\theta_e, \theta_a$ ). The data provided for the ACR collector field are shown in Table 8. The dot (.) entries indicate nonexistent values for any one of several reasons. Since STEAEC uses a bicubic spline fit for these data, Sandia has suggested using F values scaled from the STEAEC sample problem data in lieu of "zeros" to preclude spurious STEAEC output resulting from the bicubic spline fit methodology. The scaling factors are shown in Table 9. The "adjusted" values for use in the STEAEC input data are shown in Table 10.

### 2. BUCKS

BUCKS inputs are taken primarily from the cost breakdown of Section II. Other inputs such as capital cost escalation rates, income tax, and construction time and year of commercial operation are assumed values. ACR plant sizes are those resulting from the baseline design. STEAEC inputs are discussed in the next section.

## B. INPUT DATA

### 1. STEAEC

Table 11 shows the STEAEC sample problem inputs provided by Sandia and are included for reference purposes only. Table 12 shows the data developed for the

TABLE 8  
FIELD EFFICIENCY MATRIX, F, PROVIDED BY MDAC

Elevation	Azimuth						
	0	30	60	75	90	110	130
5	.	.	0.300	0.290	0.288	0.289	.
15	.	.	0.472	0.462	0.463	.	.
25	.	0.592	0.578	0.570	0.561	.	.
45	0.662	0.660	0.657	0.644	0.631	.	.
65	0.672	0.667	0.660	.	.	.	.
89.5	0.678	.	.	.	.	.	.

TABLE 9  
SCALING FACTORS USED WITH SAMPLE DATA

Elevation	Azimuth						
	0	30	60	75	90	110	130
5	.	.	1.240	1.229	1.247	1.279	.
15	.	.	1.035	1.048	1.074	.	.
25	.	1.039	1.068	1.065	1.077	.	.
45	1.064	1.078	1.070	1.075	1.082	.	.
65	1.067	1.044	1.066	.	.	.	.
89.5	1.085	.	.	.	.	.	.

TABLE 10  
FIELD EFFICIENCY MATRIX, F, WITH "ADJUSTED" DOT VALUES

Elevation	Azimuth						
	0	30	60	75	90	110	130
5	0.311	0.310	0.300	0.290	0.288	0.289	0.278
15	0.506	0.491	0.472	0.462	0.463	0.431	0.427
25	0.609	0.592	0.578	0.570	0.561	0.539	0.525
45	0.662	0.660	0.657	0.644	0.631	0.613	0.601
65	0.672	0.667	0.660	0.648	0.643	0.636	0.639
89.5	0.678	0.675	0.676	0.677	0.678	0.679	0.689

TABLE 11  
SAMPLE PROBLEM STEAEC INPUTS

```

STEAEC.BLKDATA.FORT
00030 BLOCK DATA
00040 COMMON /DATA2/ PTWF, PWF, XT, TRI, TA2, TR2A, TR3, PTS,
00050 I PFS, PFT, PTT
00060 COMMON /STRGE/ SUPTS, UPFS, XES, XPFS, ESMAXP
00070 DATA PTWF /0./, PWF /0./
00080 DATA SUPTS /0./, UPFS /0./, XES /0./, XPFS /0./
00090 COMMON /COMCOR/ ELR(6), NY, AZR(7), NY, FR(6,7), COE(16,5,6)
00100 I LCX, LCY
00110 COMMON /COMCOL/ FS, ASB, AOL, TLINL, TLINU, ELIN, WSLIN, RFLCTY
00120 COMMON /COMERW/ NEFMS, WSX(8), WSEI(8)
00130 COMMON /COMRCV/ EPS, XHR, RS, ALPHAR, TCS, RHF, CAXP, DEPTF,
00140 I MODPO, XTD, DTST
00150 COMMON /COMXLR/ NXLR, NCXLR, RXLR(5), CXLR(6), FXLR(10)
00160 COMMON /COMXLP/ NXLP, TKLP(9), YXLP(9)
00170 COMMON /COMTRB/ ALPHA, BETA, TAUR, TAUS, ALPHR, ALPHS, TPFRL,
00180 I TPFSL, AUXPC, TMFR, THFS, SMFC, SHFD, TURBSS, MOPMF
00190 COMMON /COMEPS/ NREPSR, NCEPSR, REPSR(4), CEPSR(6), FEPSR(24)
00200 COMMON /KOMEPS/ NREPS, NCEPS, REPS(4), CEPS(6), FEPS(24)
00210 COMMON /COMSTW/ PTSMAX, PFSMAX, EMAX, EMIS, ES, XLL, A, B,
00220 I ALPHC, ALPHD, ALPHL, C1, C2, C3, D1, D2, D3, LS
00230 COMMON /TSTATU/ ISBR, ISBT, ISUT, ISUS, IOFR, IOFS, IOFRPS,
00240 I GCOR74
00250 DATA AZR /0.,30.,60.,75.,90.,110.,130./, NY /7/
00260 DATA ELR /5.,15.,25.,43.,65.,89.5/, NX /6/
00270 DATA FR /
00280 I .29150385, .56115821, .66819170, .72588351, .73519690, .72920901,
00290 I .29079515, .54432693, .66533133, .71349580, .74503362, .72612763,
00300 I .28273488, .53175144, .63130811, .71661620, .72234359, .72722612,
00310 I .27557995, .51487068, .62427393, .69904697, .71418629, .72779114,
00320 I .26982498, .50277789, .60764914, .68002701, .70804967, .72876434,
00330 I .26387111, .47851924, .59189314, .66554903, .70130568, .73079122,
00340 I .26016708, .47302487, .57601535, .65345907, .70355616, .74037288/
00350 DATA FS /889732./,
00360 I ASR /3.934E-9/,
00370 I AOL /3.934E-7/,
00380 I TLINL /32.0/,
00390 I TLINU /104.0/,
00400 I ELIN /0.0/,
00410 I WSLIN /16.0/,
00420 I RFLCTY /0.857/,
00430 DATA NEFMS /8/,
00440 I WSX /0.0,2.0,4.0,6.0,8.0,10.0,12.0,13.4/,
00450 I WSEI /1.0,0.9997,0.998,0.996,0.994,0.985,0.964,0.942/
00460 DATA EPS /0.93677/,
00470 I XHR /6.695E-2/,
00480 I RS /560.0/,
00490 I ALPHAR /0.5/,
00500 I TCS /0.5/,
00510 I RHF /0.10/,
00520 I CAXP /3.824E-5/,
00530 I DEPTF /0.15/,
00540 I MODPO /2/,
00550 I XTD /0.75/,
00560 I DTST /0.75/
00570 DATA NCXLR /5/, RXLR /0.0,3.0,8.0,10.0,16.0/
00580 DATA NXLR /5/, CXLR /-4.0,32.0,68.0,104.0,140.0/
00590 DATA FXLR /
00600 I 2.446E-2,2.393E-2,2.339E-2,2.286E-2,2.232E-2,

```

```

00610 I 2.625E-2,2.571E-2,2.518E-2,2.464E-2,2.411E-2,
00620 I 2.857E-2,2.804E-2,2.750E-2,2.696E-2,2.643E-2,
00630 I 2.927E-2,2.873E-2,2.820E-2,2.766E-2,2.713E-2,
00640 I 3.059E-2,3.005E-2,2.952E-2,2.898E-2,2.845E-2/
00650 DATA NXLP /9/, TKLP /-22.,-4.,14.,32.,50.,68.,86.,104.,122./,
00660 I YXLP /3.473E-4,3.393E-4,3.313E-4,3.232E-4,3.152E-4,3.071E-4,
00670 I 2.991E-4,2.911E-4,2.830E-4/
00680 DATA ALPHA /0.01158/,
00690 I BETA /0.06417/,
00700 I TAUR /1.5/,
00710 I TAUS /21.5/,
00720 I ALPHR /2.641E-2/,
00730 I ALPHS /2.137E-2/,
00740 I TPFRL /296.50/,
00750 I TPFSL /285.00/,
00760 I AUXPC /6.542E-3/,
00770 I TMFR /0.25/,
00780 I THFS /0.26/,
00790 I SMFC /0.05/,
00800 I SHFD /0.109/,
00810 I TURBSS /0.42238/,
00820 I MOPMF /1/
00830 DATA NCEPSR /4/, REPSR /0.25,0.50,0.75,1.00/
00840 DATA NREPSR /6/, CEPSR /30.0,40.0,50.0,60.0,70.0,80.0/
00850 DATA FEPSR /
00860 I .3450, .3440, .3430, .3415, .3310, .3230,
00870 I .3760, .3755, .3745, .3725, .3685, .3615,
00880 I .3843, .3835, .3830, .3820, .3790, .3720,
00890 I .3860, .3855, .3850, .3840, .3800, .3740/
00900 DATA NCEPSS /4/, CEPSS /0.25,0.50,0.75,1.00/
00910 DATA NREPSS /6/, CEPSS /30.0,40.0,50.0,60.0,70.0,80.0/
00920 DATA FEPSR /
00930 I .213, .212, .212, .210, .207, .202,
00940 I .254, .254, .253, .252, .249, .244,
00950 I .267, .267, .266, .265, .262, .257,
00960 I .284, .283, .282, .280, .277, .270/
00970 DATA PFSMAX /255.0/,
00980 I PFSMAX /285.1/,
00990 I EMAX /1800.0/,
01000 I EMIN /70.0/,
01010 I ES /62.0/,
01020 I XLL /0.0025/,
01030 I A /0.003/,
01040 I B /0.00326/,
01050 I ALPHC /0.98/,
01060 I ALPHD /0.98/,
01070 I ALPHL /0.99970/,
01080 I C1 /0.90570/,
01090 I C2 /1.0390E-4/,
01100 I C3 /-5.784E-8/,
01110 I D1 /0.95220/,
01120 I D2 /-6.025E-4/,
01130 I D3 /2.448E-6/,
01140 I LS /2/
01150 DATA ISBR /1/
01160 DATA ISBT /1/, ISUS /0/, IOFR /0/, IOFS /0/, IOFRPS /0/, ISUT /0/
01170 COMMON /NLBLKO/ NF,NI
01180 DATA NF /-17,NT/0/
01190 END

```

ESG-79-2, Vol 1 IV  
55

TABLE 12  
SALIENT ITEMS FOR ACR STEAEC INPUTS

ABARC.BLKDATA.FURT	
00030	BLOCK DATA
00040	COMMON /DATA2/ PTWF, PWF, XT, TR1, TR2, TR2A, TR3, PTS,
00050	I PFS, PFI, PFI
00060	COMMON /STRGE/ SUPTS, UPFS, XES, XPPS, ESMAXP
00070	DATA PTWF /0./, PWF /0./
00080	DATA SUPTS /0./, UPFS /0./, XES /0./, XPPS /0./
00090	COMMON /COMCOE/ ELR(6), NX, AZR(7), NY, FR(6,7), COF(16,5,6),
00100	I LCX, LCY
00110	COMMON /COMCOL/ FS, ASE, AOL, TLIML, TLIMU, ELIM, WSLIM, RFLCTY
00120	COMMON /COMFV/ WEFWS, WSX(8), WSEF(8)
00130	COMMON /COMRCV/ EPS, XHR, RS, ALPHAR, TCS, RMF, CAXP, DEPTF,
00140	I NUDDP, XTD, DIST
00150	COMMON /COMXLR/ NRKLR, NCXLR, RXLR(5), CXLR(6), FXLR(30)
00160	COMMON /COMXLP/ MXLP, TXLP(9), YXLP(9)
00170	COMMON /COMTRB/ ALPHA, BETA, TAUR, TACS, ALPHR, ALPHS, TPFRL,
00180	I TPFSL, AUXPC, TMFR, TMFS, SMFC, SMFD, TRBSS, MOPMF
00190	COMMON /COMEPS/ NREPSR, NCEPSR, REPSR(4), CEPSR(6), FEPSR(24)
00200	COMMON /COMEPS/ NREPSR, NCEPSR, REPSR(4), CEPSR(6), FEPSR(24)
00210	COMMON /COMSTR/ PTSMAX, PFSMAX, EMAX, ES, XLL, A, B,
00220	I ALPHC, ALPHD, ALPHL, C1, C2, C3, D1, D2, D3, LS
00230	COMMON /TSTATU/ ISBR, ISBT, ISUT, ISUS, IOFR, IOFS, IOFRPS,
00240	I GCOP74
00250	DATA AZR /0.,30.,60.,75.,90.,110.,130./, SY /7/
00260	DATA ELK /5.,13.,23.,43.,63.,83./, NX /5/
00270	DATA FR /
00280	I .0001, .0001, .0001, .662, .672, .678,
00290	I .0001, .0001, .597, .660, .667, .0001,
00300	I .300, .472, .578, .657, .660, .0001,
00310	I .290, .462, .570, .644, .0001, .0001,
00320	I .288, .463, .561, .631, .0001, .0001,
00330	I .289, .0001, .0001, .0001, .0001, .0001,
00340	I .0001, .0001, .0001, .0001, .0001, .0001/
00350	DATA FS /692000./,
00360	I ASB /6.12E-7/,
00370	I AOL /8.97E-7/,
00380	I TLIML /32.0/,
00390	I TLIMU /122.0/,
00400	I ELIM /0.0/,
00410	I WSLIM /18.0/,
00420	I RFLCTY /1.0/,
00430	DATA NEFWS /5/,
00440	I WSX /0.0,3.0,7.0,11.0,16.0/,
00450	I WSEF /1.005,1.004,1.003,0.998,0.966/
00460	DATA EPS /0.950/,
00470	I XHR /1.6E-2/,
00480	I RS /390.0/,
00490	I ALPHAR /0.5/,
00500	I TCS /1.5/,
00510	I RMF /0.02/,
00520	I CAXP /0.0/,
00530	I DEPTF /0.10/,
00540	I NUDDP /2/,
00550	I XTD /0.10/,
00560	I DIST /0.55/
00570	DATA NCXLR /4/, RXLR /0.0,5.7,11.0,16.23/
00580	DATA NRKLR /5/, CXLR /-4.0,32.0,68.0,104.0,140.0/
00590	DATA FXLR/
0600	I 4.548E-2,4.548E-2,4.548E-2,4.548E-2,4.548E-2,
0610	I 4.548E-2,4.548E-2,4.548E-2,4.548E-2,4.548E-2,
0620	I 5.230E-2,5.230E-2,5.230E-2,5.230E-2,5.230E-2,
0630	I 5.932E-2,5.932E-2,5.932E-2,5.932E-2,5.932E-2/
0650	DATA NXLP /9/, TXLP /-22.,-4.,14.,32.,50.,65.,86.,104.,122./,
0660	I TILT /0.287E-4,0.134E-4,7.982E-4,7.829E-4,7.577E-4,7.325E-4,
0670	I 7.372E-4,7.220E-4,7.067E-4/
0680	DATA ALPHA /0.0216/,
0690	I BETA /0.00571/,
0700	I TAUR /0./,
0710	I TAUS /0./,
00720	I ALPHR /2.7069E-2/,
00730	I ALPHS /1.745E-2/,
00740	I TPFRL /260.00/,
00750	I TPFSL /250.00/,
00760	I AUXPC /4.595E-3/,
00770	I TMFR /0.14/,
00780	I TMFS /0.14/,
00790	I SMFC /0.02/,
00800	I SMFD /0.10/,
00810	I TRBSS /0.301/,
00820	I MOPMF /1/
00830	DATA NCEPSR /4/, REPSR /0.25,0.50,0.75,1.00/
00840	DATA NREPSR /6/, CEPSR /30.0,40.0,50.0,60.0,70.0,80.0/
00850	DATA FEPSR/
00860	I .404, .401, .396, .388, .378, .367,
00870	I .433, .433, .430, .424, .418, .410,
00880	I .437, .437, .436, .434, .431, .424,
00890	I .435, .435, .435, .435, .434, .430/
00900	DATA NCEPSR /4/, REPSR /0.25,0.50,0.75,1.00/
00910	DATA NREPSR /6/, CEPSR /30.0,40.0,50.0,60.0,70.0,80.0/
00920	DATA FEPSR/
00930	I .404, .401, .396, .388, .378, .367,
00940	I .433, .433, .430, .424, .418, .410,
00950	I .437, .437, .436, .434, .431, .424,
00960	I .435, .435, .435, .435, .434, .430/
00970	DATA PTSMAX /390.0/,
00980	I PFSMAX /260.0/,
00990	I EMAX /812.5/,
01000	I EMIN /60.0/,
01010	I ES /60.0/,
01020	I XLL /0.00021/,
01030	I A /0.0082/,
01040	I B /0.00196/,
0050	I ALPHC /1.0/,
01060	I ALPHD /1.0/,
01070	I ALPHL /0.9973/,
0080	I C1 /1.0/,
01090	I C2 /0.0/,
1100	I C3 /0.0/,
0110	I D1 /1.0/,
01120	I D2 /0.0/,
01130	I D3 /0.0/,
01140	I LS /1/
01150	DATA ISBR /1/
01160	DATA ISBT /1/, ISUS /0/, IOFR /0/, IOFS /0/, IOFRPS /0/, ISUT /0/
01170	COMMON /HLELKG/ NF,NT
01180	DATA NF /-1/, NT /0/
01190	END



all-sodium baseline ACR STEAEC inputs. The shaded areas are the salient items relating to the all-sodium ACR in particular. It should be noted that the input data reflect the choice of "derated" operation capability which is not applicable to the all-sodium ACR. The STEAEC computer output based on the "derated" operation is shown in Table 13 using 10 hypothetical days of Barstow insolation data.

TABLE 13  
PLANT CHARACTERISTICS — DERATED OPERATION CAPABILITY  
(Minimum Flow Options — Turbine Priority)

Hypothetical Insolation and Weather Data (Year 1976)	
Yearly Energy From Turbine (MWh)	6346.55
Collector Field Size (m <sup>2</sup> )	692000.00
Receiver Size — Maximum Thermal Input (MW)	390.00
Gross Maximum Electrical Output of EPGs at 74 Degs. (Wet Bulb, °F) (MW)	112.50
Yearly Electrical Auxiliary Power Drawn From Net (MWh)	307.25
Maximum Storage Charge Rate (MW)	390.00
Maximum Storage Discharge Rate (MW)	260.00
Maximum Storage Capacity (MWh)	812.50
Number of Hours in Year	87.84
Yearly Integral of Energy Storage	20426.56

Table 14 shows the revised ACR all-sodium baseline STEAEC inputs incorporating the "adjusted" field efficiencies and the "no derated" operation option. These are the input data which will be used in subsequent STEAEC computer runs.

Table 15 shows the STEAEC output used for the input to BUCKS. The values from the sample problem are shown along with those for the all-sodium ACR using 36.5 times the STEAEC output for 10 days of Barstow data. The alternate input to BUCKS uses 400,000 MWe-h for the plant electrical generation derived from independent integration of the University of Houston solar insolation data and collector field efficiencies.

## 2. BUCKS

Table 16 presents the miscellaneous inputs required by BUCKS. The entries are noted and are self-explanatory. Base costs, both solar-related and nonsolar-related, are provided in Tables 17 and 18, respectively.

TABLE 14

REVISED ALL-SODIUM BASELINE STEAEC INPUTS WITH "ADJUSTED"  
FIELD EFFICIENCIES AND "NO DERATED" OPERATION

ANARC. BLKDATA. PORT	
00030	BLOCK DATA
00040	COMMON /DATA2/ PTWF, PWF, XT, TRI, TR2, TR2A, TR3, PFS,
00050	1 PFS, PFT, PTT
00060	COMMON /STRGE/ SUPIS, UPFS, XES, XPFS, ZSMAXP
00070	DATA PTWF /0./, PWF /0./
00080	DATA SUPIS /0./, UPFS /0./, XES /0./, XPFS /0./
00090	COMMON /CONCOE/ ELK(6), NK, AZR(7), NY, FR(6,7), COP(16,5,6),
00100	1 LCX, LCT
00110	COMMON /CONCOL/ FS, ASB, AOL, TLIML, TLIMU, ELEM, WSLIM, RPLCTY
00120	COMMON /COMEPW/ NEFWS, WSX(8), WSEF(8)
00130	COMMON /COMRCV/ EPS, XHR, RS, ALPHAR, TCS, RMP, CAXP, DEPTP,
00140	1 MODPO, XTD, DIST
00150	COMMON /CONULM/ NXLK, NCKLN, NXLK(5), CXLR(6), FXLR(30)
00160	COMMON /CONULP/ NXLK, TXLP(9), YXLP(9)
00170	COMMON /CONTRB/ ALPHA, BETA, TAUR, TAUS, ALPHR, ALPHS, TPFR,
00180	1 TPFSL, AUXPC, TMFR, TMFS, SMPC, SMFD, TURBSS, MOPMF
00190	COMMON /COMEPS/ NREPSR, NCEPSR, REPSR(4), CEPSR(6), FEPSR(24)
00200	COMMON /KOMEPS/ NREPSR, NCEPSR, REPSS(4), CEPSS(6), FEPSR(24)
00210	COMMON /CONSTR/ PFSMAX, PFSMAX, ENMAX, EMIN, ES, XLL, A, B,
00220	1 ALPHC, ALPHD, ALPHL, C1, C2, C3, D1, D2, D3, LS
00230	COMMON /TSTATU/ ISBR, ISBT, ISUT, ISUS, IOFR, IOFS, IOFRPS,
00240	1 GCOP74
00250	DATA AZR /0.,.30.,.60.,.75.,.90.,.110.,.130./, NY /7/
00260	DATA ELR /5.,.15.,.25.,.45.,.65.,.89.5/ , NK /6/
00270	DATA FR /
00280	1 .311, .506, .609, .662, .672, .678,
00290	1 .310, .491, .592, .660, .667, .675,
00300	1 .300, .472, .578, .657, .660, .676,
00310	1 .290, .462, .570, .644, .648, .677,
00320	1 .288, .463, .561, .631, .643, .678,
00330	1 .289, .431, .539, .613, .636, .679,
00340	1 .278, .427, .525, .601, .639, .689/
00350	DATA FS /692000./,
00360	1 ASB /6.12E-7/,
00370	1 AOL /8.97E-7/,
00380	1 TLIML /32.0/,
00390	1 TLIMU /122.0/,
00400	1 ELEM /0.0/,
00410	1 WSLIM /16.0/,
00420	1 RPLCTY /1.0/
00430	DATA NEFWS /5/,
00440	1 WSX /0.0,3.0,7.0,11.0,16.0/,
00450	1 WSEF /1.005,1.034,1.003,0.998,0.985/
00460	DATA EPS /0.950/,
00470	1 XHR /1.6E-2/,
00480	1 RS /390.0/,
00490	1 ALPHAR /0.5/,
00500	1 TCS /0.5/,
00510	1 RMP /0.02/,
00520	1 CAXP /0.0/,
00530	1 DEPTP /0.0/,
00540	1 MODPO /1/,
00550	1 XTD /1.0/,
00560	1 DIST /0.55/
00570	DATA NCKLN /4/ , NXLK /0.0,5.7,11.0,16.28/
00580	DATA NXLK /5/ , CXLR /-4.0,32.0,68.0,104.0,140.0/
00590	DATA FXLR/

00600	1 4.548E-2,4.548E-2,4.548E-2,4.548E-2,4.548E-2,
00610	1 4.548E-2,4.548E-2,4.548E-2,4.548E-2,4.548E-2,
00620	1 5.230E-2,5.230E-2,5.230E-2,5.230E-2,5.230E-2,
00630	1 5.932E-2,5.932E-2,5.932E-2,5.932E-2,5.932E-2/
00650	DATA NXLK /9/ , TXLP /-22.,-4.,.14.,.32.,.50.,.68.,.86.,.104.,.122./,
00660	1 TXLP /8.287E-4,8.134E-4,7.982E-4,7.829E-4,7.677E-4,7.525E-4,
00670	1 7.372E-4,7.220E-4,7.067E-4/
00680	DATA ALPHA /0.3216/,
00690	1 BETA /0.00571/,
00700	1 TAUR /0./,
00710	1 TAUS /0./,
00720	1 ALPHR /2.7069E-2/,
00730	1 ALPHS /1.745E-2/,
00740	1 TPFR /260.00/,
00750	1 TPFSL /250.00/,
00760	1 AUXPC /6.995E-3/,
00770	1 TMFR /0.0/,
00780	1 TMFS /0.0/,
00790	1 SMPC /3.0/,
00800	1 SMFD /0.0/,
00810	1 TURBSS /0.381/,
00820	1 MOPMF /1/
00830	DATA NCEPSR /4/ , REPSR /0.25,0.50,0.75,1.00/
00840	DATA NREPSR /6/ , CEPSR /30.0,40.0,50.0,60.0,70.0,80.0/
00850	DATA FEPSR/
00860	1 .404, .401, .396, .388, .378, .367,
00870	1 .433, .433, .430, .424, .418, .410,
00880	1 .437, .437, .436, .434, .431, .424,
00890	1 .435, .435, .435, .435, .434, .430/
00900	DATA NCEPSS /4/ , REPSS /0.25,0.50,0.75,1.00/
00910	DATA NREPSS /6/ , CEPSS /30.0,40.0,50.0,60.0,70.0,80.0/
00920	DATA FEPSR/
00930	1 .404, .401, .396, .388, .378, .367,
00940	1 .433, .433, .430, .424, .418, .410,
00950	1 .437, .437, .436, .434, .431, .424,
00960	1 .435, .435, .435, .435, .434, .430/
00970	DATA PFSMAX /390.0/,
00980	1 PFSMAX /260.0/,
00990	1 ENMAX /812.5/,
01000	1 EMIN /60.0/,
01010	1 ES /60.0/,
01020	1 XLL /0.00021/,
01030	1 A /0.0/,
01040	1 B /0.0/,
01050	1 ALPHC /1.0/,
01060	1 ALPHD /1.0/,
01070	1 ALPHL /0.9973/,
01080	1 C1 /1.0/,
01090	1 C2 /0.0/,
01100	1 C3 /0.0/,
01110	1 D1 /1.0/,
01120	1 D2 /0.0/,
01130	1 D3 /0.0/,
01140	1 LS /1/
01150	DATA ISBR /1/
01160	DATA ISBT /1/ , ISUS /0/ , IOFR /0/ , IOFS /0/ , IOFRPS /0/ , ISUT /0/
01170	COMMON /MLBLKO/ NF,NT
01180	DATA NF /-1/ , NT /0/
01190	END
01200	READY

ESG-79-2, Vol 1 IV  
58

TABLE 15  
 STEAEC OUTPUT → BUCKS INPUT  
 (Plant Performance and Size Information)

	Sample	ACR (36.5 x 10 Days Barstow Data)	Alternate	
PHR Annual Net Electrical Generation From Plant (MWe-h)	400,000	231,649.07	400,000	
SQM Collector Field Reflective Surface Area (m <sup>2</sup> )	1,000,000	692,000.00	No Change	
SMWTH Receiver Peak Input Capacity (MWt)	650	390.00	↓	
PMX Peak Gross Electrical Capacity of Plant (MWe)	100	112.50		
SOLOAD Annual Electrical Energy Required by Plant From Utility Network (MWe-h)	0	11,214.63		
CHGRT Thermal Storage Peak Charging Rate (MWt)	350	390.00		
DCHGRT Thermal Storage Peak Discharge Rate (MWt)	250	260.00		
SMWHR Thermal Storage Capacity (MWt-h)	2,500	812.50		
IYHR Number of Hours in Year	8,760	8,784.00		
XMWH2 Number of Hours in Year That Each MWt-h of Storage Capacity is Charged (MWt-h-h)	5,000,000	745,549.00		1,322,000

The resulting BUCKS output based on 400,000 MWe-h solar plant generation annually is shown in Table 19. It should again be pointed out that the indicated cost of 105.88 mills/kWh represents a levelized busbar cost over the 30-year life of the plant assumed in this BUCKS case to be the years 1988 to 2018. It is the cost per unit of energy which must be charged over the plant lifetime to compensate for all fixed and variable costs, pay interest to bondholders, and provide return to shareholders. Feed pump costs are shown as zero since pump costs were lumped in the receiver and thermal storage systems.

There is an approximate method to obtain estimated BBEC translated to base year dollars. Multiply the BUCKS BBEC by the ratio of total plant base years cost per MWe to the total cost per MWe installed. For this case, the ratio is  $1481041/2355204 = 0.6288$ . The approximate BBEC in 1978 dollars is 66.58 mill/kWh.

TABLE 16  
BUCKS INPUT  
(Miscellaneous)

	Sample	ACR
Capital Cost Escalation Rate	0	6.0
Cost Estimate Base Year	1977	1978
Composite Income Tax Rate	0.50	0.40
Construction Time for Plant	5.5	4.0
Fraction of Capitalization — Stock	0.50	0.50
Fraction of Capitalization — Debt	0.50	0.50
Rate of Return — Stock	0.11	0.10
Rate of Interest — Debt	0.08	0.08
Year of Plant Operation	1977	1988
Depreciation Method DDB	Yes	Yes
<u>Base Sizes</u>		
Collector Size (M <sup>2</sup> Mirrors)	880,000	692,000
Storage Capacity (Mwt-h)	1,600	812.5
Charge-Discharge Rate (Mwt)	240/300	390/260
Gross Output (MWe)	110	112.5
Receiver Capacity (Mwt)	640	390
Base-Solar Related Costs	See Tables	
Base-Nonsolar Related Costs	See Tables	
<u>Maintenance — Annual</u>		
Fixed per Plant	1,050,000	70,000
Receiver	500	308
Storage	50	66.5
Collectors	1	1.15
EPGS		1,422
Contingency Fraction	0.15	0.129
Insurance and Property Tax	0.0045	0.0225
Operations and Maintenance Escalation Rate	0.05	0.08
Thermal Storage Media Replacement Fraction	0.5; 0; 0	0; 0; 0
Plant Life	30	30

TABLE 17  
BASE SOLAR-RELATED COST ESTIMATES

Cost Item	Sample Problem Value (10 <sup>3</sup> )	ACR Value (10 <sup>3</sup> )
Thermal Storage Shed	0.0	0.
Thermal Storage Media Only With Storage Requirements	3,600.	0.
Heliostat Reflective Unit	70,000.	12,460.
Drive Unit	60,000.	18,420.
Sensor-Calibration	1,000.	51.
Field Control	20,000.	1,669.
(Blank - Array Position Unused)	0.	0.
Foundation and Site	7,500.	8,590.
Design-Engineering	2,000.	0.
(Blank)	0.	0.
Packing and Shipping	900.	410.
Assembly and Installation	9,500.	2,720.
Lightning Protection	1,000.	1,500.
Receiver Unit	50,000.	11,744.
Receiver Feed and Return Piping	10,000.	4,942.
Design-Receiver, Piping, Tower	3,000.	0.
Tower and Platform	20,000.	1,356.
Tower Foundation and Site	9,500.	1,000.
(Blank)	0.	0.
Thermal Storage Tank Equipment	10,000.	4,000.
Circulation Equipment	5,500.	688.
(Blank)	0.	0.
Piping From Receiver	300.	0.
Piping to Turbine	600.	0.
(Blank)	0.	0.
Discharging Equipment	5,000.	0.
Charging Equipment	4,000.	0.
Instrumentation and Control	500.	0.
Foundation and Site	700.	300.
Design	2,000.	0.
Storage Material	7,000.	6.400.
Receiver Feed Pumps	1,000.	0.0
Master Control Equipment	2,000.	367.

TABLE 18  
BASE NONSOLAR-RELATED COST ESTIMATES

Cost Item	Sample Problem Value (10 <sup>3</sup> )	ACR Value (10 <sup>3</sup> )
Land and Yard Work	2,000.	1,500.
Turbine Building	1,000.	1,386.
Administration Building	700.	180.
Miscellaneous Buildings	50.	118.
Warehouse	0.	150.
Maintenance Building	700.	150.
Water Treatment Building	300.	0.
Sewage Treatment Building	0.	0.
Control Building	0.	216.
Turbine Generator	15,000.	10,856.
Heat Rejection Equipment	3,000.	4,215.
Condensing System	300.	320.
Feedwater Heating Equipment	1,000.	1,655.
Water Treatment Equipment	1,000.	2,378.
Electrical Plant	4,000.	2,415.
Maintenance and Handling Equipment	1,000.	1,141.
Miscellaneous Equipment	2,000.	1,200.
Transmission Plant	500.	938.
Distributables	5,000.	16,422.
Spare Parts	2,000.	422.
A&E Services	6,000.	1,399.
Construction Manager	4,000.	3,004.
Solar Integrator	1,500.	0.
Solar Design	0.	0.
Master Control Design	0.	0.
Startup and Checkout	2,000.	500.
(Blank)	0.	0.

TABLE 19

ADVANCED CENTRAL RECEIVER - BUCKS OUTPUT  
 (BBEC - Levelized Bus Bar Electrical Costs Over Life of Plant)  
 (Sheet 1 of 3)

PLANT SIZES  
 0.692000E+06 SQ METERS OF MIRRORS 0.812500E+03 MWHR OF STORAGE 0.390000E+03 MWH FOR RECEIVER  
 0.390000E+03 MW(T) CHARGE RATE 0.260000E+03 MW(T) DISCHARGE RATE 112.500 MWE GROSS PEAK OUTPUT

PLANT PERFORMANCE  
 SOLAR GENERATION 0.400000E+06 ANNUAL STORED ENERGY 0.132200E+07

ECONOMIC ASSUMPTIONS  
 YEAR OF FIRST COMMERCIAL OPERATION 1988.  
 DEPRECIATION METHOD DD BALANCE  
 EFFECTIVE COST OF MONEY 0.074

LAND/SITE 0.150000E+07  
 BUILDINGS 0.220000E+07  
 COLLECTOR 0.458199E+08  
 RECEIVER 0.166860E+08  
 TOWER 0.235600E+07  
 THERMAL STORAGE 0.113880E+08  
 CAPACITY 0.107000E+08  
 CHARGE/DISCHARGE 0.688000E+06  
 DESIGN 0.0  
 FEED PUMPS 0.0  
 MASTER CONTROL 0.367000E+06  
 EPGS 0.218390E+08  
 OTHER EQUIP 0.327900E+07  
 DISTRIB/INDIRECTS 0.217470E+08  
 CONTINGENCY 0.164064E+08  
 TOTAL PLANT 0.143588E+09  
 XMED 0.0

TOTAL PLANT  
 \$ 2355204.00 PER GROSS MWE INSTALLED \$ 1481041.00 PER GROSS MWE, BASE YEARS

	AMVAL	BBEC
INVEST-TAX	\$ 0.329130E+06	0.925679E+02 MILLS
DEPTAX	\$ 0.642897E+05	0.180815E+02 MILLS
INS	\$ 0.529921E+05	0.149040E+02 MILLS
FIX O=M	\$ 0.586315E+05	0.164901E+02 MILLS
VAR O=M	\$ 0.0	0.0 MILLS
TOTAL	\$ 0.376464E+06	0.105881E+03 MILLS

ESG-79-2, VOL IV  
 63

TABLE 19  
 ADVANCED CENTRAL RECEIVER — BUCKS OUTPUT  
 (BBEC — Levelized Bus Bar Electrical Costs Over Life of Plant)  
 (Sheet 2 of 3)

COLLECTOR			
\$ 751562.62 PER GROSS MWE INSTALLED		\$ 472610.37 PER GROSS MWE, BASE YEARS	
	AMVAL	BBEC	
INVEST-TAX	\$ 0.105028E+06	0.295391E+02	MILLS
DEPTAX	\$ 0.205153E+05	0.576992E+01	MILLS
INS	\$ 0.169102E+05	0.475598E+01	MILLS
FIX O-M	\$ 0.389238E+05	0.109473E+02	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.140346E+06	0.394724E+02	MILLS
RECEIVER			
\$ 273692.56 PER GROSS MWE INSTALLED		\$ 172108.06 PER GROSS MWE, BASE YEARS	
	AMVAL	BBEC	
INVEST-TAX	\$ 0.382474E+05	0.107571E+02	MILLS
DEPTAX	\$ 0.747091E+04	0.210119E+01	MILLS
INS	\$ 0.615808E+04	0.173196E+01	MILLS
FIX O-M	\$ 0.585425E+04	0.164651E+01	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.427889E+05	0.120344E+02	MILLS
TOWER			
\$ 38644.35 PER GROSS MWE INSTALLED		\$ 24301.00 PER GROSS MWE, BASE YEARS	
	AMVAL	BBEC	
INVEST-TAX	\$ 0.540039E+04	0.151886E+01	MILLS
DEPTAX	\$ 0.105487E+04	0.296681E+00	MILLS
INS	\$ 0.869498E+03	0.244546E+00	MILLS
FIX O-M	\$ 0.0	0.0	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.521502E+04	0.146673E+01	MILLS
THERMAL ST			
\$ 186791.81 PER GROSS MWE INSTALLED		\$ 117461.69 PER GROSS MWE, BASE YEARS	
	AMVAL	BBEC	
INVEST-TAX	\$ 0.261034E+05	0.734158E+01	MILLS
DEPTAX	\$ 0.509883E+04	0.143405E+01	MILLS
INS	\$ 0.420281E+04	0.118204E+01	MILLS
FIX O-M	\$ 0.263429E+04	0.740894E+00	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.278417E+05	0.783047E+01	MILLS



TABLE 19  
 ADVANCED CENTRAL RECEIVER — BUCKS OUTPUT  
 (BBEC — Levelized Bus Bar Electrical Costs Over Life of Plant)  
 (Sheet 3 of 3)

FEED PUMPS			
\$	0.0	PER GROSS MWE INSTALLED \$	0.0 PER GROSS MWE, BASE YEARS
		AMVAL	BBEC
INVEST-TAX	\$ 0.0	0.0	MILLS
DEPTAX	\$ 0.0	0.0	MILLS
INS	\$ 0.0	0.0	MILLS
FIX O-M	\$ 0.0	0.0	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.0	0.0	MILLS
MASTER CTL			
\$	6019.72	PER GROSS MWE INSTALLED \$	3785.43 PER GROSS MWE, BASE YEARS
		AMVAL	BBEC
INVEST-TAX	\$ 0.841232E+03	0.236596E+00	MILLS
DEPTAX	\$ 0.164319E+03	0.462148E-01	MILLS
INS	\$ 0.135444E+03	0.380936E-01	MILLS
FIX O-M	\$ 0.0	0.0	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.812356E+03	0.228475E+00	MILLS
ALL OTHERS			
\$	1098496.00	PER GROSS MWE INSTALLED \$	690775.31 PER GROSS MWE, BASE YEARS
		AMVAL	BBEC
INVEST-TAX	\$ 0.153510E+06	0.431748E+02	MILLS
DEPTAX	\$ 0.299854E+05	0.843341E+01	MILLS
INS	\$ 0.247162E+05	0.695142E+01	MILLS
FIX O-M	\$ 0.112191E+05	0.315538E+01	MILLS
VAR O-M	\$ 0.0	0.0	MILLS
TOTAL	\$ 0.159460E+06	0.448482E+02	MILLS


0

**APPENDIX A**  
**COST SUBSTANTIATION DATA**  
**FOR THE 100-MWe COMMERCIAL PLANT**

**ALL SODIUM STORAGE**







DATE 4-17-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

JOB NO 133-036-001 PROJECT 100 MW LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MATL	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
TRANSPORTATION & LIFTING EQUIP.					Account				
COMMUNICATION EQUIPMENT					4131	STEARNIS-ROGER			1810000
OTHERS					4132	"	"		1100000
MDAC COLLECTOR SYSTEM					4133	"	"		8500000
"EXTRAPOLATED FROM STEARNIS-ROGER ESTIMATE FOR 300 MW PLANT"					4131	MDAC			5400000
4130 MISCELLANEOUS EQUIPMENT									116810000

CODE

4130 MISCELLANEOUS EQUIPMENT



August 8, 1978

ACTION

REPLY *14*

REPLY DUE

REMARKS

Atomics International Division  
Rockwell International  
8900 DeSota Avenue  
Canoga Park, CA 91304

Re: C-20325-34

Attention: Mr. T. H. Springer

Subject: 100 MWe Commercial Plant Building  
Costs and O & M Costs  
Advanced Central Receiver Power System

Reference: AI Contract N311-002FX  
DOE Contract EG-77-C-03-1483

Dear Tom:

Confirming out telecopier transmittal of July 19, 1978, we are pleased to advise the following:

Commercial Plant Building Cost Estimates  
4120 Buildings

- 4121 Turbine Building (20m x 30m x 10m)  
198,000 c.f. x \$7/c.f. = \$1,386,000
- 4122 Administration Building (15m x 15m x 8m)  
60,000 c.f. x \$3/c.f. = 180,000
- 4123 Warehouse/Maintenance Building (25m x 25m x 8m)  
150,000 c.f. x \$2/c.f. = \$300,000
- 4124 Control Building (12m x 12m x 14m)  
72,000 c.f. x \$3/c.f. = \$216,000
- 4125 Other Buildings
  - .1 Water Treatment Building (15m x 15m x 6m)  
50,000 c.f. x \$2/c.f. = \$100,000
  - .2 Steam Generator & Sodium Heat Transport Pad (20m x 20m)  
400 s.y. x \$45/s.y. = \$18,000

*9904 ESS*

ANDERSON, S. H.	
ASHWORTH	
ASQUITH	
BALINT	
BALHMASH	
BOTTS	
BRINDLEY	
CAHDINAS	
COCHRAN, J.C.	
CRAWFORD	
DE LOS PRADOS	
DETERMANN	
FEILER	
GYLFE	
HARTZLER	
HILLIG	
HOLBROOK	
JACOBELLIS	
JACOBSON, J.	
JONES, R.G.	
JULIAN, M.	
KATTAN	
KR	
KUHN	
LULOVICS	
MARTIN, A. B.	
MCCOURT	<input checked="" type="checkbox"/>
MCDERMOTT	
MCDONALD, J.S.	
MCKENZIE, D.E.	
MEYERS, G.W.	
MOREWITZ	
MOSS	
MURPHY	
OLDENKAMP	
PARKER, T.	
PARKINS	
REYNOLDS	
RILEY	
RINECKER	
SANDERS	
SCHIRM	
STONE	
TOBIAS	
W. WAHLE	
WHEELER	
WILSON	
WILLIAMS	
<i>Clean</i>	<input checked="" type="checkbox"/>
<i>Springer</i>	<input checked="" type="checkbox"/>
<i>Rutz</i>	<input checked="" type="checkbox"/>
<i>Wragow</i>	<input checked="" type="checkbox"/>
<i>Worner</i>	
<i>J. Johnson</i>	
<i>Trangas</i>	
<i>T. Balco</i>	

# Stearns-Roger

PAGE 2

Atomics International Division  
Rockwell International  
Canoga Park, CA 91304

August 8, 1978

## 100 MWe O & M Costs (EPGS & BOP only)

### OM100 Operations

#### 1. Operations/Shift:

1 Shift Supervisor  
1 Station Operator (Relief for all classes)  
1 Control Operator  
1 Turbine Operator  
2 Auxiliary Operators  
6 per shift x 3 shifts = 18 per 24 hr. day

#### Additional on Day Shift:

1 Senior Results Engineer  
2 Results Technicians  
1 Chemist  
1 Chemist Technician  
1 Electrical Foreman  
1 Electrical Specialist  
2 Electrical Apprentice  
1 Electrical Helper  
10 per day

#### 2. Administrative:

1 Plant Superintendent  
1 Assistant Plant Superintendent  
2 Secretaries  
2 File Clerks  
6 per day

#### 3. Stores:

2 Storepersons

#### 4. Schedulers:

2 Schedulers

#### 5. Guards:

3 Guards

# Stearns-Roger

Atomics International Division  
Rockwell International  
Canoga Park, CA 91304

August 8, 1978

100 MWe O & M Costs (EPGS & BOP only) - (Cont'd)

6. Total EPGS Operations - 41 Employees on Payroll

Operations Cost, including Administrative (excluding Maintenance):

41 people x \$21,000/yr. x 1.05 overtime = \$904,000/year

OM200 Maintenance Materials

OM210 Spare Parts

OM211 Turbine and Electric Plant - Est. Spare Parts \$150,000

OM220 Materials for Repairs

Maintenance Materials & Supplies

Est. 50% of O & M Labor

0.50 x \$1,188,000/yr. = \$594,000/yr.

OM300 Maintenance Labor

Maintenance:

1 Maintenance Supervisor

1 Work Foreman

3 Classified Mechanics

3 Plant Mechanics

5 Helpers

15 per day

15 people x \$18,000/yr. x 1.05 overtime = \$284,000/year

Very truly yours,

STEARNS-ROGER ENGINEERING CO.


*A.W. McKenzie*

A. W. McKenzie  
Project Engineer

AWM:vr

cc: Steve Chalmers - SRP





National Division  
Regional

JOB NO. 133-026201 PROJECT

DATE 4-17-78

TAKE-OFF JK

PRICED JK

LOCATION

CLIENT

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	CALC. CHKD		APPROVED		SUB-CONTRACT	TOTAL
				LABOR	SUB-CONT.	MATERIAL	LABOR		
TRANSPORTATION LIFTING EQUIP.									181000
COMMUNICATION EQUIPMENT									110000
OTHERS									850000
"EXTRAPOLATED FROM STEARNS-ROGER ESTIMATE FOR 300 MW PLANT"									
MISCELLANEOUS EQUIPMENT									1141000

CODE

4.130


Form 702-D Rev. 11-73

JOB NO. 133-026R1 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 7-20-78 TAKE-OFF \_\_\_\_\_ PRICED \_\_\_\_\_ CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
Telcon with Al McKenzie 5/31/78 2:30 p. m.						<i>J. Chumetz</i>			
ACCOUNT: 4200 TURBINE PLANT EQUIPMENT									
<u>Subaccount No.</u>	<u>Description</u>					<u>Cost</u>			
4210	Turbine generator & accessories					\$10,856,000			
4220	Heat rejection system					4,215,000			
4230	Condensing system					320,000			
4240	Feed heating system					1,655,000			
4250	Working fluid circ., treatment					<u>2,378,000</u>			
TOTAL						<u><u>\$19,424,000</u></u>			
CODE									
4200	TURBINE PLANT EQUIPMENT								

ESG-79-2, Vol IV  
A-9



JOB NO: 33-0216/02 PROJECT 1500 MW

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 9-1-78 TAKE-OFF \_\_\_\_\_ PRICED \_\_\_\_\_ CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION		QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
ELECTRIC PLANT EQUIPMENT SUPPLIED BY STEARNS-ROBEES & MDC										3553000 1281000
4300	ELECTRIC PLANT EQUIPMENT									4834000

Table A

ADVANCED CONCEPT 1ST COMMERCIAL PLANT - 100 MWe  
 BREAKDOWN OF MASTER CONTROL COSTS BY CBS

<u>CBS</u>	<u>COST ELEMENT</u>	<u>1978 DOLLARS AND HOURS IN THOUSANDS</u>			
		<u>HOURS</u>	<u>DOLLARS</u>	<u>NON-LABOR</u>	<u>TOTAL</u>
4351	Hardware				
	LSI-11 Processor			\$ 14.94	\$ 14.94
	RX11 BA Disc Drive and Control			27.22	27.22
	TA11 AB Recorder			9.52	9.52
	LAV11 DA Printers			8.55	8.55
	Terminal			49.65	49.65
	Cabinet	2.99	\$ 83.60	29.43	113.03
	Cables			10.50	10.50
	Data Acquisition			91.11	91.11
	Time			3.83	3.83
	Weather			18.37	18.37
	Timers			2.40	2.40
	Assy, Trans., Install. & C/O	<u>6.48</u>	<u>217.74</u>	<u>13.51</u>	<u>231.25</u>
	Subtotal	8.85	\$301.34	\$279.03	\$580.37
	Visibility		<u>60.66</u>	<u>55.97</u>	<u>116.63</u>
	Total 4351		\$362.00	\$335.00	\$697.00
4352	Hardware Design & Engr	6.65	\$313.00	\$ 19.00	\$332.00
4353	Software Design, Develop & Test	5.04	\$237.00	\$ 15.00	\$252.00
0M300	Maintenance Labor (Subcontract)			\$ 0.05	\$ 0.05

Table A  
 ADVANCED CONCEPT NTH COMMERCIAL PLANT - 100 MWe  
 BREAKDOWN OF MASTER CONTROL COSTS BY CBS

1978 DOLLARS AND HOURS IN THOUSANDS

<u>CBS</u>	<u>COST ELEMENT</u>	<u>LABOR</u>		<u>NON-LABOR</u>	<u>TOTAL</u>
		<u>HOURS</u>	<u>DOLLARS</u>		
4351	Hardware				
	LSI-11 Processor			\$ 12.45	\$ 12.45
	RX11 BA Disc Drive & Control			22.68	22.68
	TA11 AB Recorder			9.52	9.52
	LAV11 DA Printers			8.55	8.55
	Terminal			41.28	41.28
	Cabinet	2.37	\$ 66.19	29.43	95.62
	Cable			10.50	10.50
	Data Acquisition			0	0
	Time			3.83	3.83
	Weather			18.37	18.37
	Timers			2.40	2.40
	Assy, Trans, Install & C/O	<u>5.07</u>	<u>170.04</u>	<u>10.37</u>	<u>180.41</u>
	Subtotal	7.44	\$236.23	\$169.38	\$405.61
	Visibility		<u>47.77</u>	<u>33.62</u>	<u>81.39</u>
	TOTAL 4351		\$284.00	\$203.00	\$487.00
4352	Hardware Design & Engr	3.70	\$174.00	\$ 11.00	\$185.00
4353	Software Design, Develop & Test	1.53	\$ 72.00	\$ 4.00	\$ 76.00
0M300	Maintenance Labor (Subcontract)			\$ 0.05	\$ 0.05

ESG-79-2, Vol 1 IV  
A-12

Table A -2

## 1ST ADVANCED CONCEPT PLANT - HELIOSTAT COST - 100 MWe

(Sheet 1 of 3)

		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
<u>WBS NUMBER AND TITLE</u>		<u>HOURS</u>	<u>DOLL</u>	<u>(\$M)</u>	<u>(\$M)</u>
		<u>(THOU)</u>	<u>(\$M)</u>		
4410	Reflective Unit	101.56	1.43	15.53	16.96
4411	Reflective Surface	31.03	.42	8.87	9.29
4412	Mirror Back Struct	36.68	.52	6.11	6.63
4413	Assy & Bond	33.85	.49	.55	1.04
4420	Drive Unit	183.38	2.58	21.60	24.18
4421	Azimuth	93.10	1.31	5.34	6.65
4422	Elevation	59.25	.83	10.50	11.33
4423	Motor Total	0	0	2.93	2.93
4424	Pos/Limit Indicators	19.74	.28	.32	.60
4425	Power Sply/Dist	0	0	2.50	2.50
4426	Assy Dr/Ped/Elect	11.29	.16	.01	.17
4430	Control/Instrmt Equip	58.92	.84	1.78	2.62
4431	Sensor/Calib Equip	0	0	.02	.02
4432	Field Control	0	0	.01	.01
4433	Cntrl/Sig Equip	56.42	.79	1.47	2.26
44320101	Collector Control	2.50	.05	.28	.33

Table A -2

## 1ST ADVANCED CONCEPT PLANT - HELIOSTAT COST - 100 MWe

(Sheet 2 of 3)

		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
WBS NUMBER AND TITLE	HOURS (THOU)	DOLL (\$M)		(\$M)	(\$M)
4440	Found/Site Prep	259.55	6.01	4.91	10.92
4441	Foundation	187.61	4.35	4.91	9.26
4442	Site Preparation	71.94	1.66	0	1.66
4450	Heliostat Spt St/Pr En	25.39	.35	2.17	2.52
4451	Helio Suppt Struct	25.39	.35	2.17	2.52
4452	Protection Encl	0	0	0	0
4453	Lightning Protect	0	0	0	0
4460	Field Assy and C/O	162.22	3.39	.01	3.40
4461	Heliostat	57.83	1.34	0	1.34
4462	Sensor/Calib Equip	0	0	0	0
4463	Electrical/Distrib	32.44	.76	0	.76
4464	Align Heliostats	14.11	.32	0	.32
4465	Field Support	18.34	.42	0	.42
4466	Pack & Transp	39.50	.55	.01	.56
	TOTAL HELIOSTAT	791.02	14.60	46.00	60.60

Table A -2

## 1ST ADVANCED CONCEPT PLANT - HELIOSTAT COST - 100 MWe

(Sheet 3 of 3)

		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
<u>WBS NUMBER AND TITLE</u>		<u>HOURS (THOU)</u>	<u>DOLL (\$M)</u>	<u>(\$M)</u>	<u>(\$M)</u>
4100	Site, Struct, Misc Equip	2.82	.04	.49	.54
4130	Misc Equipment	2.82	.04	.49	.54
4800	Dist and Indir	0	0	.04	.04
4840	Initial Spares	0	0	.04	.04
OM100	Operations	0	0	0	0
OM200	Maint Material	0	0	.20	.20
OM300	Maintenance Labor	<u>40.17</u>	<u>.60</u>	<u>0</u>	<u>.60</u>
	TOTAL O&M	40.17	.60	.20	.80
	Ongoing O&M	21.13	.31	.15	.46



Table A -3

## NTH COMMERCIAL HELIOSTAT INVESTMENT COST - 100 MWe

(Sheet 1 of 3)

		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
WBS NUMBER AND TITLE	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)	
4410	Reflective Unit	60.65	.85	11.61	12.46
4411	Reflective Surface	18.33	.25	6.39	6.64
4412	Mirror Back Struct	21.16	.31	4.81	5.12
4413	Assy & Bond	21.16	.29	.41	.70
4420	Drive Unit	110.15	1.53	16.89	18.42
4421	Azimuth	56.42	.78	4.21	4.99
4422	Elevation	35.61	.50	8.25	8.75
4423	Motor Total	0	0	2.31	2.31
4424	Pos/Limit Indicators	11.28	.16	.24	.40
4425	Pwr Sply/Dist	0	0	1.84	1.84
4426	Assy Dr/Ped/Elect	6.84	.09	.04	.13
4430	Control/Instrmt Equip	36.30	.51	1.19	1.72
4431	Sensor/Calib Equip	0	0	.03	.03
4432	Field Control	0	0	.01	.01
4433	Cntrl/Sig Equip	33.80	.46	.95	1.43
44320101	Collector Control	2.50	.05	.20	.25
4440	Found/Site Prep	204.53	4.73	3.86	8.59

Table A -3

## NTH COMMERCIAL HELIOSTAT INVESTMENT COST - 100 MWe

(Sheet 2 of 3)


		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
<u>WBS NUMBER AND TITLE</u>		<u>HOURS</u>	<u>DOLL</u>	<u>(\$M)</u>	<u>(\$M)</u>
		<u>(THOU)</u>	<u>(\$M)</u>		
4441	Foundation	148.11	3.42	3.86	7.28
4442	Site Preparation	56.42	1.31	0	1.31
4450	Helio Spt St/Pr En	15.51	.21	1.72	1.91
4451	Helio Supp Struct	15.51	.21	1.72	1.91
4452	Protection Encl	0	0	0	0
4453	Lightning Protection	0	0	0	0
4460	Field Assy & C/O	129.77	2.71	.01	2.72
4461	Helio stat	45.13	1.04	0	1.04
4462	Sensor/Calib Equip	0	0	0	0
4463	Electrical/Distrib	25.39	.61	0	.61
4464	Align Helio stats	11.28	.25	0	.25
4465	Field Support	15.51	.35	0	.35
4466	Pack & Transp	<u>32.46</u>	<u>.46</u>	<u>.01</u>	<u>.47</u>
	Subtotal - Helio stat	556.91	10.54	35.27	45.82
	Visibility	-	<u>2.11</u>	<u>3.52</u>	<u>5.63</u>
	TOTAL HELIOSTAT		12.65	38.79	51.45

Table A -3

## NTH COMMERCIAL HELIOSTAT INVESTMENT COST - 100 MWe

(Sheet 3 of 3)

		CAPITAL INVESTMENT			
		LABOR		MATL \$	TOTAL
WBS NUMBER AND TITLE	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)	
4100 Site, Struc, Misc Equip	2.83	.04	.49	.53	
4130 Misc Equipment	2.83	.04	.49	.53	
4800 Dist and Indir	0	0	.02	.02	
Initial Spares	0	0	.02	.02	
OM100 Operation	0	0	0	0	
OM200 Maint Material	0	0	.17	.17	
OM300 Maintenance Labor	<u>40.17</u>	<u>.60</u>	<u>0</u>	<u>.60</u>	
TOTAL O&M	40.17	.60	.17	.77	
Ongoing O&M	20.70	.31	.14	.45	



Atomic Rental  
JOB NO/33-026-802 PROJECT

DATE 7-27-78 TAKE-OFF JC PRICED JC CALC. CHKD APPROVED LOCATION CLIENT OF SHEET

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
4511									4022000
4512									2370000
4513									1526000
4514									1452000
4515									1315000
RECEIVER SUMMARY									85511000



Atomik Division  
Rockwell

JOB NO 33-024802 PROJECT

DATE 7-27-78

TAKE-OFF .15/JW

PRICED .15/JW

CALC. CHKD

APPROVED


LOCATION

CLIENT

SHEET 1

OF 7

ITEM AND DESCRIPTION	QUANTITY	UNIT	MATL	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SHEET # 2									1108000
3									1128000
4									87000
5									172000
6									107000
7									249753
MANAGEMENT RESERVE @ 20%									
									3351753
									670357
									4022104
CODE 4511 ABSORBER UNIT SUMMARY									4022104
ROUND TO									4022104



JOB NO. 133026R2 PROJECT ABSORBEE PANEL


LOCATION

CLIENT

DATE 4-4-78 TAKE-OFF gaw PRICED gaw CALC. CHKD APPROVED SHEET 2 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF. TABLES & SK 24 PANELS REQD	1	EA	WN						
① TUBING 110 3/4" O.D. X 1/4" X 12' 3/8" 304L	6820	FT	1.73		2502	11799			
② HEADER 1-6 STD IPS X 1/4" X 12' (alts)	14.25	"	31.00		270	441			
③ " ENDS 6-5 TO CAP	2	EA	72.00		13	144			
④ " FTL 6-90' L. BELL	2	EA	192.00		49	384			
⑤ TUBERHEAD 2 R 3/4" X 2 1/2" X 7'	14.25	FT	1.50		91	137			
⑥ SUP 13 L 1/4" X 3/4" X 9' 4.9	16.9	"	1.23		82.8	101.8			
WELD 1049 RW TUBE TO HEADER AKA "	220	EA	4.50		2	9			
HEADER BW 28 V .357 ATA "	2.9	FT	4.50		11	50			
SUPPORT 6x6 W 1/2" 1/2" 1/2" "	50	"	"		5	22			
TUBE BENDS 110°	220	EA	15.00						
WELD TUBES V. 104	5500	FT	4.50		110	495			
FT 6 R. IN 6-70 28 V	4	EA	"		2.5	11			
HEADS 1 L 3/4" X 6 X 6 X 4 (alts)	4	FT	1.50		60	90			
PLY LUMBER 600 P	4	EA	250.00		32				
⑨ TUBE TO HEADER JIG (2-4000)	1/24							1000	
⑩ MISC MARK	L.S					500			
WELD DEVELOPMENT								1000	
SUB-TOTAL					3974	15101		5300	20401
MANL O.H.V. 109°									2084
FABRICATION LABOR	985	HR		31.06			30594		30594
SUB-TOTAL									53034
VENDOR G.T.A. #1090									5366
SUB-TOTAL									58400
VENDOR PROFIT 15.90									8600
ESTIMATED PRICE 1-UNIT CURRENT DOLLAR									67000
X 24									1608000
CODE									
4511									
ABSORBER UNIT									

Form 702-D Rev. 11-75



Job No. 133016 BN PROJECT ABSORBER PANEL PIPING

LOCATION CLIENT

DATE 4-5-78 TAKE-OFF *John* PRICED *John* CALC. CHKD APPROVED SHEET 3 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF TABLES - 4 SK 24 P. 00 1-730V	1	SHOWN	540P		760				
① OUTLET PIPES - STD IPS X 2" 730V	410	FT	31N		760	1240			
② INLET " 1.2" DO 730V	40	FT	"		760	1240			
③ INLET END HANGERS	6	EA		267 <sup>m</sup>				1602	
BENDS 6-570 #7 1/2 NH 1	2	EA		267 <sup>m</sup>				534	
" DO 47	9	FT	4.0		6	27			
④ WELD, 280V 5/8" 1/2 HANG 730V	7	"	"		5	23			
⑤ PIPE HANGERS	10	EA	100 <sup>EA</sup>		500	1000			
⑥ CONTROL VALVE 6"	1	"	600 <sup>m</sup>		400	6000			
⑦ BLOCK VALVE 6"	1	"	300 <sup>m</sup>		300	3000			
SN HANGER HANGERS	2	"	1200 <sup>m</sup>		400	2400			
MISC MATL	L.S.				300	500			
SUB-TOTAL MATL					3431	14940		2136	17076
MATL ON 1070									1724
SHUTL BAR	60	EA		300			1800		1800
FIELD LABORS 5M2D=60X PIPE	160	"		300			4800		4800
HANGERS	50	"		39 <sup>m</sup>			1500		1500
SN HANGERS	80	"		"			2400		2400
FIELD EFFICIENCY 609570									5220
SUB-TOTAL									34520
SHUP G + HANGERS 2060									2060
FIELD HANGERS 200613, 920									4720
SUB-TOTAL									40800
VENDOR PROFIT 1570									6200
ESTIMATED PRICE INSTALLED HUNT CURRENT DOLLAR									47000
TOTAL 24 UNITS									1128000
CODE									
4511									
ABSORBER UNIT									



ALCO RUC  
 International Division  
 National


DATE 4-5-78 TAKE-OFF Open PRICED Open CALC. CHKD Open APPROVED \_\_\_\_\_

JOB NO. 133046207 PROJECT ABSORBER INLET PIPE LOCATION \_\_\_\_\_ SHEET 4 OF 4

	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
5800	REF. TABLE 5.5 YSK INLET LINE		REBDD							
9200	INLET 20' 0" X 18" X 23.8' 78.6' T304	71.25	FT	230"		5600	12880			
155	OUT. = 20' 0" X 18" X 23.8' 121' "	69.3	FT	230"		8385	19286			
46	" " 40' 1-30" 211SE, 40' 1-40' 211SE, 40' 1-40' 211SE	11.6	4	125		197	246		100	
150	" " BOT 1-2" 1/2 V 2.5' X 2.5'	62.5	4	135		144	194			
	N0224 1-2000 X 3/8 W X 2'	2	FT	230		157	361			
	WELD 3/8 V	40	"	450		34	152			
15	SPACERS 3/8 X 5 X 2' (cut 4)	2	"	174		17	30			
200	REL LINE 8 1/2-40 IPS X 20' 2.718	180	"	100"		215	180			
	PIPE BENDS 1/4-40	32	EA		44.00				1408	
	SHAWW 40.145V 1 1/2 IPS 82.5A 54.4mm	6	17	450		3				
	FIELD WELD 2-20" V	14	"	450		10				
	" " 8-1 1/2 V 14C	4	"	"		7				
120	MISC MAT'L					200	300			
14386	PIPE HANGERS	17	EA	500		25	60			
	SUB-TOTAL					14991	34386		1508	35894
	SUPPL + BOB	120	HR		31.00			12400		12400
	FIELD LABOUR VESSEL 5 MIN	200	"		30.00			6000		6000
	" LABOUR 1 1/2 IPS 3 M 2 D X 4	100	"		30.00			3000		3000
	LABOUR EFFICIENCY 60% OF 900							5400		5400
	MAT'L ON 21070 OF 35894							3586		3586
	SUB-TOTAL							66280		66280
	SHOP 9 + A 21070 OF 51550							5130		5130
	FIELD OVER HEAD 3070 OF 14700							4300		4300
	SUB-TOTAL							75700		75700
	VENDOR PROFIT 1590							11300		11300
	ESTIMATED COST INSTALLED CURRENT DOLLARS							87000		87000
	CODE									
	H511 ABSORBER UNIT									

Form 702-D Rev. 11-75





Alor Rex International Division

JOB NO. 133026.002 PROJECT ABSORBER EXPANSION TANKS LOCATION CLIENT

DATE 4-5-78 TAKE-OFF PRICED APPROVED SHEET 5 OF

NET WT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
	TABLES SK 4-6'0" X 14.5' STAINLESS TANKS	98	#	1.20		1666	1999		200	
1308	HEADS 2 PL 7/8" X 7' X 7'	289	"	1.20		4973	5896			
4664	SHR 2 PL 3/8" X 7' X 19'	133	"	1.20		2261	2775			
2238	SHIRT 1 PL 3/8" X 7' X 19'	21	FT	1.20		269	350		100	
240	" BASE 1 PL 1/2" X 4V X 21'	5.34	"	1.20		152	427			
150	BOUNDS 8-570195 X 3.24' 2655	1	EA	4500		50	450			
50	" " FIT 1-8-570 900 L RFL	2.9	FT	1.20		96	134			
55	LINER BRKT 1 PL 3/4" X 33' X 2.5' (cont'd)	3	"	1.20		48	58			
45	" " PAD 1 PL 3/4" X 1' X 8'	4.5	"	1.20		150	300			
100	MISC MATL	2	EA	4.50		12	54			
26	WELDS 3/8" X 156 9/16	38	"	1.20		22	99			
5	" RIS DO 3/8" X 154 .34	76	"	1.20		41	185			
9086	VENDOR 1-1/2" X 40 X 2' (cont'd)	2	FT	1.20		35	20			
	SUB-TOTAL					9686	12885		300	12985
	MATERIAL ON HAND									
	SHR LAB	100	HR		3100			12400		13100
	FIELD INSTALLATION	120	"		3000			3600		12400
	EXPERIENCE	72	"		3000			2160		3600
	SUB-TOTAL									2160
	FIELD OVERHEAD 30% 5760									32370
	SUB-TOTAL BASE COST									1730
	VENDOR 5 + A 21070									34100
	SUB-TOTAL									37500
	VENDOR PROFIT 21570									5500
										43000
	X-4									172000
	4511 ABSORBER UNIT									



Atto  
Rob.

JOB NO. 133026.002 PROJECT A BSOE BBER 047 LST EXPANSION RE PIPING LOCATION CLIENT

DATE 4-6-78 TAKE-OFF JAW PRICED JAW CALC. CHKD APPROVED SHEET 6 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
TABLES-SK									
(1) BOUTHEADERS 2 FL 3/8 X 6' X 6' 7904	72	#	1.20		1152	1382		200	
(2) SHELL " 1 PL 3/8 X 1' X 15.75'	1575	"	1.20		252	302			
(3) " NOZ 24-6-570/PS X 15'	12	FT	34.00		228	372			
(4) EXP " 4-8-570/PS X 15'	2	"	80.00		57	160			
(5) LEG 3-1700 X 3/4 X 17.75' 71	5325	"	2.75		3994	10984			
(6) EXP TIE PIN: F16 S-90 L2 ELL	1	EA	450.00		600	5400			
(7) " 1-8-570/PS X 7.5' (2nd 12)	75	FT	80.00		2141	6000			
WELD 3/8 V000188	42	FT	45.00		37	167			
" 3/8 V .65	51	"			33	148			
" 3/8 FW .54	51	"			28	126			
" PIPE 3/8 V .88	63	"			55	248			
SUNDBERS	4	EA	175.00		400	4800			
PIPE HANGERS	4	"	100.00		200	400			
MISC MAT'L					800	1000			
SUB-TOTAL					9977	31117		200	31317
MAT'L ON A1090							10540		2133
SHUP FABRICATION							3600		10540
FIELD WELD LEGS ON M-30							9000		3600
" 1" EXP PIPE 5M-70-82V4							1200		9000
" HANGERS 4X10							4800		1200
" SUNDBERS 4X40							11520		4800
FIELD EFFICIENCY 6070 DI 192.00									11520
" ON 30 DUOP 30.720									9215
SUB-TOTAL BASE CUST									84920
VENDOR 674 21090									8474
SUB-TOTAL									93400
VENDOR PROFIT 15.90									13600
ESTIMATED PRICE INS TALLED CURRENT DOLLARS									107000
4511 ABSORBER UNIT									

Form 702-D Rev. 11-73



JOB NO. 133-02602 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 4-10-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 7 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
						S.S. OVER				
3" THERMOBESTOS BLOCK INSULATION										
RECEIVER	9540	S.F	4.20	.2	4.26	40068	19088°	40640		
EXPANSION TANKS (4)	1530	S.F	4.20	.2	4.26	6510	3100°	6603		
6" THERMO-12 PIPE INSUL.	30	70	LF	68	3.68	29	4760	2580°	2030	
5/2	18	60		44	2.67	22	2640	1600°	1320	
4	6	336		14	.89	8	4704	2990°	2688	
3	2	40		6	.39	3	240	160°	120	
3	1/2	180		6	.37	3	1080	670°	540	
							3018°	MINI 230		
							90540			
ADD FOR LABOR HEIGHT PRODUCTIVITY ~ 50%							45270			
							60002	135816	53941	249753
CODE										
4511	INSULATION ABSORBER UNIT									

ESG-79-2, Vol 1 IV  
A-26



Alt  
Roc International Division

JOB NO. 13310-61 ROV PROJECT ABSORBER PANEL TRUSS LOCATION CLIENT

DATE 4-21-78 TAKE-OFF JAW PRICED JAW CALC. CHKD APPROVED SHEET 1 OF 1

NET WT

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
REFITABLE 5-5 d 9R 24 REOD 1-SHOWN										
① COIL FACE LEGS 2L3/8 X 6 X 6 X 52' 14.8 AS6	104	F7 22			1550	341				
② TWSIDE " 2 DO X 54' "	108	"			7609	554				
③ SIDEST CROSS 1 DO X 60' (cut 8) "	60	"			894	197				
④ COMP MEMB 4 DO X 40' (cut 8) "	160	"			2384	524				
⑤ RET+BAND DIAGONALS 3- DO X 53' (cut 20) "	265	"			3949	869				
⑥ GUIDE 2L3/8 X 4 X 4 X 46' "	92	"	V		405	89				
WELD 3/8 FW 58 .34 HAND "	350	F7 .60			182	104				
" 1/2 V 122 .86 " "	10	" "			13	8				
" 1/4 FW 125 1.5 " "	30	" "			8	5				
PAINT NI TEMP	10	60250			100	250				
10500 SUB-TOTAL					11094	2746			2746	
MATL OIA ~10%									274	
LABOR	110	HR		31.54			3465		3465	
BASE COST									6485	
VENDOR GTA ~10%									645	
SUB-TOTAL									7130	
VENDOR PROFIT ~15%									1070	
ESTIMATED VENDOR PRICE CURRENT DOLLARS									8200	
X-24									196800	
MANAGEMENT RESERVE @ 20%									39360	
									236160	
CODE										
4512	SUPPORT STRUCTURE SUMMARY								Round To	236000

ESG-19-2, Vol 1 IV  
A-27



Abcon  
Rockwell

Internal Division  
Local

JOB NO. 133-026 ROL-PROJECT

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_


DATE 7-20-78 TAKE-OFF JC PRICED JC APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	CALC. CHKD			APPROVED			TOTAL
			MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	
P-1 RECEIVER Pump. 4500 H.P. 20,000 G.P.M.C. 844 TDH SECT. VIII FAB		EA			60 Ton	11200000	150000		11350000
INSULATION	520	S.F.					155000		155000
TRACE HEATERS	173	L.F.					26760		26760
DRIVE & SPEED CONTROL WITH FLUID COUPLING (FROM 4514)									600000
COOR									
4513 RECEIVER PUMP P-1									2125760
									2125760

Form 702-D Rev. 11-73

UPDATE -

CHARTS

PREPARED BY: L. GLASGOW	 <b>Rockwell International</b> Atomic International Division	SUMMARY
CHECKED BY:		PAGE NO. 1 OF 2
DATE: 7/17/78 4/7/78		REPORT NO.
		MODEL NO.

DATA FOR PRICING PUMPS  
550° F

P-1 PUMP. (RECEIVER PUMP

TYPE - SIMILAR TO CRBRP

SINGLE STAGE

DOUBLE SUCTION - NPSH(REQ) 30 FT

MATERIAL - A - 285

CODE - ASME B&PV - SECTION VIII - DIV. 1

	<u>T D H</u>	<u><del>844</del> FT 722 FT</u>
FLOW	20,000 G.P.M.	N <sub>s</sub> - .6000 F
	CASE DIAM.	6.4 <u>7 FT</u>
	CASE LENGTH	11.4 <u>12 FT</u>
	INLET NOZZLE	<u>36 IN</u>
	OUTLET NOZZLE	<u>24 IN</u>
	DRY WT <u>46,667</u>	<u><del>57,000</del> LBS .84</u>
	SPEED	<u>1130</u> <u><del>1160</del> RPM</u>

MOTOR - SQUIRREL CAGE - VERTICAL  
60HZ 3 φ - SINGLE SPEED - 1130  
~~1160~~ RPM  
4160 VOLTS


4,500 H.P. OK  
(OPERATING H.P. = 4022)

PRODUCTION - 1ST IN A SERIES  
OF 7

ENGINEERING - FINAL ONLY  
SUGGEST A 1.15 FACTOR

*L. S. Glasgow*  
4/7/78

H.B. RETAIN 4 012



JOB NO/33-026-RO2 PROJECT

DATE 5-4-78 TAKE-OFF 1.6 PRICED 1.6

CALC. CHKD JK APPROVED \_\_\_\_\_ SHEET 1 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SHEET # 2									3121.00
3									3005.00
4									1297.00
INSTRUMENTATION SUMMARY									8516.00
ROUND TP									8520.00

CODE

4514

Form 702-D Rev. 11-73



International Division  
national

JOB NO 133-014-RO2 PROJECT

LOCATION

CLIENT

DATE 4-26-78

TAKE-OFF 1.6

PRICED 1.6

CALC. CHKD J.C.

APPROVED

SHEET 2

OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
<b>RECEIVER</b>									
TEMPERATURE CONTROLS	24	EA			1250				30000
PRESS. INDICATORS	2				2500				5000
TEMP. INDICATORS	26				2500				65000
LEVEL CONTROLS	2				2500				5000
<b>PURIFICATION SYSTEM</b>									
<b>Pump P-1</b>									
TEMPERATURE	1	EA			2500				2500
PRESS.	1				2500				2500
PRESS. DIFF	1				3000				3000
POWER, CURRENT SPEED	1				6000				6000
RED. VOLTAGE CIRCUIT BREAKER	1				75,000				75000
100 MCM FEEDER	200	LF			125.50				25100
<b>Pump P-2</b>									
TEMPERATURE	1	EA			2500				2500
PRESS.	1				2500				2500
PRESS. DIFF	1				3500				3500
POWER, CURRENT SPEED	1				6000				6000
CIRCUIT BREAKER	1				20,000				20000
SPEED CONTROLLER	1				2,000				2000
FLOW CONTROLLER	1				1500				1500
SLIP CHANGING	1				25,000				25000
#1 FEEDER	200	LF			22.00				4400
<b>INSTRUMENTATION &amp; CONTROLS</b>									
CODE									
4-514									
									311211.00

Form 702-D Rev. 11-73




JOB NO: 33-026R02 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 4-27-78 TAKE-OFF 1 G PRICED 1 G CALC. CHKD J.C APPROVED \_\_\_\_\_ SHEET 3 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
<u>TANK-T-1</u>									
TEMPERATURE	1	EA			2500				2500
PRESSURE	1				2500				2500
LEVEL	1				2500				2500
PRESS. RELIEF	1				5000				5000
GAS BALANCE VALVE	1				2500				2500
FILL VALVE	1				2500				2500
<u>TANK-T-2</u>									
TEMPERATURE	1				2500				2500
PRESSURE	1				2500				2500
LEVEL	1				2500				2500
PRESS. RELIEF	1				3500				3500
GAS BALANCE VALVE	1				2500				2500
<u>LINE #103</u>									
DRAG VALVE	1				250,000				250,000
PRESS. DIFF.	1				3500				3500
TEMPERATURE	1				2500				2500
<u>LINE #105</u>									
TEMPERATURE	1				2500				2500
PRESSURE	1				2500				2500
<u>REHEATER</u>									
TEMPERATURE	1				2500				2500
<u>SUPER HEATER</u>									
TEMPERATURE	1				2500				2500
FLOWMETER	1				8500				8500
CONTROLLER	1				1500				1500
LOW FLOW CONTROLS	1				43,500				43,500
CODE									
4514	INSTRUMENTATION & CONTROL								
									300,500

ESG-79-2, VOL IV  
 A-32



DATE 4-27-78

TAKE-OFF L.G.

PRICED L.G.

CALC. CHKD J.K.

LOCATION


APPROVED

SHEET 4

OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
<b>EVAPORATOR</b>									
LEVEL	1	EA			1500				1500
PRESSURE	1				1500				1500
TEMPERATURE	1				1500				1500
FLOWMETER	1				12,000				12,000
TEMPERATURE	1				2500				2500
PREHEATING	1	L.S.			INCL. W/COMPONENTS				-0-
MISCELLANEOUS	1	L.S.			60,000				60,000
DATA ACQUISITION	100	EA			600				60,000
COMPUTER INTERFACE	1	L.S.			25,000				25,000
FLOWMETER	1	EA			25,000				25,000
DRIVES & SPEED CONTROL FOR	1	L.S.			60,000			10,000	70,000
PUMP P.I. MOTOR GENERATOR									
SHEET WITH FLOW COUPLER DRIVES									
<b>4514 INSTRUMENTATION &amp; CONTROLS</b>									189,500

Form 702-D Rev. 11-73




JOB NO/33-026 R02 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 7-27-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
ABSORBER PANELS	24	EA	416"				9984°		
P&H OVERHEAD CRANE	1	EA	596K 5000			596000	5000°		
							114924°	M. No 30°	
						596000	449520		
FIELD OVERHEAD							90000		
Q.A							60000		
MANAGEMENT RESERVE							119904		
						596000	719424		1315424

CODE 4515 FIELD ERECTION, TRANSPORTATION & INSTALLATION Round To 1315000

ESG-79-2, Vol IV  
A-34



national Division  
national

JOB NO. 33-016802 PROJECT ADVANCED CENTRAL RECEIVED

LOCATION

CURT

DATE 4-17-78 TAKE-OFF JC Priced JC APPROVED JC SHEET 17 OF

ITEM AND DESCRIPTION		QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
SHEET #2 PURIFICATION & GAS SYSTEM											
1	3 HORIZ. PIPING						761.000	3924.60			
2	4 DOWNCOMER & RISER						403.844	1623.60			
3	5 INSULATION						467.442	4260.30	186.608		
4	6 THRU 9 PIPE SUPPORTS							2942.55	505.00		
FIELD OVERHEAD 30% X D.L											
SHEET # 10 TRACE HEATERS											
ADD FOR AREA PRODUCTIVITY X 60% OF D.L											
							11342.86	12751.65	7497.00		
								5453.10			
							112342.96	118204.15	14868.08	4941.509	
CODE	4520	RISER, DOWNCOMER & HORIZ. PIPING SUMMARY									4942.509
									ROUND 170		

Form 702-D Rev. 11-73



rnational Division  
national

JOB NO. 133-026R02 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 4-6-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 2 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SODIUM HEATING & UNLOADING SYSTEM INCLUDING 100 GPM IEM PUMP						105000	2000 <sup>00</sup>		
PURIFICATION SYSTEM "REF PCTF USE .6 POWER & DROP SEC III/CL.3"						266000	3400 <sup>00</sup>		
COVER GAS SYSTEM "REF. PCTF USE .6 POWER"						150000	7582 <sup>00</sup>		
SODIUM REACTION TANK "REF LLTR"						240000	1000 <sup>00</sup>		
CODE						130820	M.M.C. 3025		
4520	PURIFICATION & GAS SYSTEM					761000	392460		

ESG-79-2, Vol 1V  
A-36




National Division  
national

JOB NO. \_\_\_\_\_ PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 3-31-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 3 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
C.S. A-53 x 3/8 WALL PIPE	20	189	LF	47	3.5	8883	662 <sup>00</sup>			
C.S.	18	189	LF	42	3.4	7938	643 <sup>00</sup>			
C.S.	6	20	LF	11	1.8	220	20 <sup>00</sup>			
90° ELL	20	4	EA	733	11.0	2932	44 <sup>00</sup>			
TEE	18	5		569	9.0	2845	45 <sup>00</sup>			
WELD-O-LET	6	2		926	12.0	1852	24 <sup>00</sup>			
CONC. REQ. 18x12	6	2		58	9.2	116	18 <sup>00</sup>			
C.S. SODIUM VALVE	20	1		285	9.0	855	27 <sup>00</sup>			
C.S. BUTTWELDS	20	1		90K	212 <sup>00</sup>	90000	212 <sup>00</sup>			
	18	18			5.4		97 <sup>00</sup>			
	18	18			4.7		85 <sup>00</sup>			
	6	6			2.3		14 <sup>00</sup>			
S.S. T-304 x 3/8 WALL PIPE	18	336	LF	190	3.4	63840	1142 <sup>00</sup>			
	12	168		170	2.3	28560	386 <sup>00</sup>			
90° ELL	18	6	EA	2600	9.0	15600	54 <sup>00</sup>			
	12	4		1265	6.5	5060	26 <sup>00</sup>			
45° ELL	12	2		797	6.5	1594	13 <sup>00</sup>			
TEE	18	1		4211	12.0	4211	12 <sup>00</sup>			
	12	4		2100	8.6	8400	34 <sup>00</sup>			
S.S. SODIUM VALVE	12	2		40K	90 <sup>00</sup>	80000	180 <sup>00</sup>			
FLIK BURST DISC. 600* FLG.	18	1		70K	150 <sup>00</sup>	70000	150 <sup>00</sup>			
S.S. BUTTWELDS	18	3		3000	12.0	9000	36 <sup>00</sup>			
	18	40			21.0		840 <sup>00</sup>			
	12	35			15.0		525 <sup>00</sup>			
SPRING HANGERS & SUPPORTS	20	10		52	3.0	520	30 <sup>00</sup>			
	18	25		50	3.0	1250	75 <sup>00</sup>			
	12	12		14	1.5	168	18 <sup>00</sup>			
CODE										
4520	HORIZ. PIPING					403844	1162360	M.A.C. 30 <sup>00</sup>		

ESG-79-2, Vol 1 IV  
A-37



AK International  
 International Division  
 International

JOB NO. \_\_\_\_\_ PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_  
 DATE 4-3-78 TAKE-OFF  PRICED  CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 4 OF \_\_\_\_\_


ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
C.S. A-53 PIPE X 3/8" WALL 20"	1000	LF	47	2.5		47000	3500		
20" ELL 20"	28	EA	733	11		20524	308		
BUTTWELDS 20"	88			5.4			475		
S.S. T-304 PIPE X 3/8" WALL 18"	1000	LF	190	3.4		19000	3420		
20" ELL 18"	28	EA	2600	9		72800	252		
BUTTWELDS 18"	88			2.1			1848		
SUPPORT HANGERS HORIZ. 20"	28	EA	1314	60		36792	1680		
#46 18"	28		1355	60		37940	1680		
VERT. 20"	43		52	3		2236	129		
18"	43		50	3		2150	129		
SNUBBERS # 200 X PIPE CLAMP	20		3000	40		60000	800		
CODE									
4520	DOWN COMMER & RISER								
						469442	426030		
						142018	142018	M.H.C.P. 3022	

Form 702-D Rev. 11-75

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
J.M. THERMO-12 w. 010 S.S. OVEN					S.S. OVEN					
EQUIV: LIN FOOTAGE 3"	30	LF	24	2.88	24.00	384.00	460.80	384.00		
5 1/2"	18	LF	44	2.67	23.00	742.00	453.90	391.00		
5"	12	LF	30	1.79	15.00	75.00	44.80	37.50		
2 1/2"	6	LF	10	.89	7.65	25.00	22.00	19.10		
ALUMINUM WEATHER PROOFING 20"	150	LF	1.00	.10		150	15.00			
18"	300	LF	1.00	.10		300	30.00			
							966.20	M.H.C. 23.00		
							222.22			
ADD FOR AREA LABOR PRODUCTIVITY x 60%							133.33			
						1214.00	355.67	814.41		
CONTRACTORS O.H & PROFIT @ 15%						182.10	53.34	122.16		
FIELD OVERHEAD							44.44			
CODE										
4520	INSULATION						1396.10	453.34	936.57	6866.08

ESG-79-2, Vol 1 IV  
A-39





JOB NO. 133-026602 PROJECT

DATE 4-6-78

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_



ITEM AND DESCRIPTION	QUANTITY	PRICED			CALC. CHGD			APPROVED		LABOR	SUB-CONTRACT	SHEET	of	TOTAL	
		UNIT	MAT'L	LABOR	SUB-CONT	MATERIAL	MATERIAL								
SHEET # 7											116500	12			
# 8											6500				
# 9											27500				
														50500	
CODE											4520	STRUCTURAL STEEL PIPE SUPPORTS			50500



National Division  
Laborial

JOB NO. 133.026 PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 4/6/78 TAKE-OFF FIERERZ PRICED FIERERZ CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 7 OF \_\_\_\_\_


ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
24' HIGH $32' \div 7 = 6.4$ USE C.S.									
STEFL W10 x 21 (27+4) 2x7 9114									
L 3x3 @ 4.9 (4x120) 2352									
MISC BRACING ETC 2534									
TOTAL	14000	LBS	1.00					14000	
EXCAV (2x3x6 K7) ÷ 27 + MISC	10	CY	40.00					400	
CONCRETE	10	CY	80.00					800	
REBAR	1000	LBS	0.75					750	
FORM AND MISC	1	LS						550	
 									
$6.5' \times 144 \div 44 = 21.3$ $6.5' \times 48 = 78 \div 20 = 4$									
CODE 4520								116500	

Form 702-D Rev. 11-73

7 @ \$ 2357 EA

ESG-79-2, Vol IV  
A-11





JOB NO. 133,022 PROJECT \_\_\_\_\_

LOCATION \_\_\_\_\_

CLIENT \_\_\_\_\_

DATE 4/6/78


TAKE-OFF FIERER

PRICED FIERER


CALC. CHKD \_\_\_\_\_

APPROVED \_\_\_\_\_

SHEET 9 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
45' HIGH 20' ÷ 6 = 3.33 use 3.5"									
STEEL W 10K21 (50K2+6K4) 6	15624								
L3K3K1/4 @ 4.9 (BK 10S)	4116								
MISC BRACING ETC	4260								
	24000	LBS	1					24000	
EXCAV (2K4K8K6) ÷ 27 + MISC	15	CY	40 <sup>sq</sup>					600	
CONCRETE	15	CY	80 <sup>sq</sup>					1200	
REBAR	1500	LBS	0.75					1125	
FORM & MISC	1	LS						500	
									
3.5 x 72 ÷ 4 ÷ 20 = 3+									
CODE 4520								27500	

ESG-79-2, Vol 1V  
A-43



DATE 4-17-78

TAKE-OFF

PRICED

CALC. CHKD

APPROVED

LOCATION

CLIENT

SHEET 10 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
ELECT. TRACE HEATERS 20"	1600	LF	50	160		80000	254000		
	1700		50	160		85000	272000		
	250		50	160		12500	40000		
	25		40	128		1000	3200		
COST INCLUDES THERMOCOUPLES									
\$ ALL MATERIAL INCLUDING									
SCRS & PANEL & LABOR									
PRODUCTIVITY.									
						178500	571200		749700
CODE	4520 ELECT TRACE HEATERS								
									749700

Form 702-D Rev. 11-73



Head Division  
Rockwell

JOB NO. 133-076602 PROJECT

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE	TAKE-OFF	ITEM AND DESCRIPTION	CALC. CHECK					APPROVED				TOTAL		
			QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	SHEET		OF	
7-27-78 <td>JS <td>SODIUM <td>457.500 <td># @ <td></td> <td>40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td> </td></td></td></td></td>	JS <td>SODIUM <td>457.500 <td># @ <td></td> <td>40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td> </td></td></td></td>	SODIUM <td>457.500 <td># @ <td></td> <td>40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td> </td></td></td>	457.500 <td># @ <td></td> <td>40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td> </td></td>	# @ <td></td> <td>40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td> </td>		40 g/KG. <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>183</td>								183

4530	WICKING MEDIA	183000
------	---------------	--------

Form 702-D Rev. 11-73

Atomics International  
D/798 Correspondence

ACTION

REPLY DUE

REMARKS

- ANDERSON S H
- ANDERSON
- ANDRITH
- BALINI
- BAUMANN
- BOTTIS
- BRINDLEY
- CARDENAS
- COCHRAN J C
- CRAWFORD
- DE LOS PRADOS
- DETERMAN
- FEILER
- GYLFE
- HARTZLER
- HILLIG
- HOLBROOK
- JACOBELLIS
- JACOBSON J
- JONES R G
- JULIAN M
- K
- K
- K
- EAsh*
- LUDOVICS
- MARTIN A B
- MCCOURT
- MCDERMOTT
- MCDONALD J S
- MCKENZIE D L
- MEYERS G W
- MORLWITZ
- T. B. Jones*
- J MURPHY
- GLDENKAMP
- PARKER T
- PARKINS
- C. G. G.*
- HEMLEY
- RYNICKER
- SANDERS
- T. B. Jones*
- L STONE
- W TITNER
- M A WARD
- WITTELER
- WIEDECK
- J S WILLIAMS
- Sprague*
- Katz*
- Blasquez*
- W. Thompson*
- T. Jones*



August 22, 1978

RECEIVED  
AUG 24 1978

Correspondence Dept.

Atomics International Division  
Rockwell International  
8900 DeSota Avenue  
Canoga Park, CA 91304

Re: C-20325-37

Attention: Mr. T. H. Springer  
Project Manager

Subject: 100 MWe Receiver Tower Cost  
Advanced Central Receiver Power System

Reference: AI Contract N311-0002-FX  
DOE Contract EG-77-C-03-1483

Dear Tom:

Please be advised that the 100-MW 159m receiver tower cost presented at the third quarterly review meeting on August 15, 1978 did not include ancillary equipment (see our letter C-20325-27, dated June 9, 1978). The following preliminary equipment and material cost should be added to the tower and foundation cost previously presented:

Caged Ladder 159m	\$ 30,000
Service Platforms, incl. H.R.	125,000
Aircraft Warning Lights	50,000
Lightning Protection & Grounding	15,000
Misc. Electrical & Lighting	20,000
Elevator 159m (Subcontract)	500,000
Direct Field Cost	740,000
Indirect Field Cost	70,000
<b>TOTAL FIELD COST</b>	<b>\$810,000</b>

If you have any questions concerning these additional costs, please advise.

Very truly yours,

STEARNS-ROGER ENGINEERING CO.

*A. W. McKenzie*  
A. W. McKenzie  
Project Engineer *10486ESG*

AWM:vr

FORM 11 (REV. 12-77)

FERRY CREEK DRIVE • P.O. BOX 5888 • DENVER, COLORADO 80217 • PHONE (303) 758-1122 • TWX 010-031-0453 TELE 045-540

CUSTOMER	ATOMICS INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	C-20325
PROJECT	ADVANCED CENTRAL RECEIVER	DATE	5-31-78
	159 METER TOWER - 500 KIP RECUR	BY	A.L.
REV. NO.	REV. DATE	BY	

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL
A	EARTHWORK		15 492	-		15 492
B	CONCRETE		886 615	554 920		1 440 935
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST		901 507	554 920		1 456 427
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70 % OF DIRECT LABOR			631 055
	TOTAL FIELD COST					2 087 482
J	ENGINEERING		BY OTHERS			2 087 482
	TOTAL FIELD & ENG. COST					
Q	SALES TAX		INCLUDED			
R	PREMIUM PAY					
	ESCALATION					
	CONTINGENCY		7.5%			156 561
	SUB TOTAL					
Y	FEE		5%			112 202
	TOTAL					2 356 245



# Stearns-Roger INCORPORATED

CLIENT ATOMICS INTERNATIONAL

SHEET NO. 1

ORDER NO 620325 LOCATION \_\_\_\_\_

BY A.L.


DATE 5-31-78

*159 METER TOWER - 500 KIP RECV.*

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS			LABOR	MATERIAL	OTHER	TOTAL
					UNIT	TOTAL	\$/MH				
	ADVANCED CENTRAL RECEIVER										
	EARTHWORK: EXCAVATION	6908	C.Y.	-	.1	691	12.00	8292	-		8292
	BACKFILL	1500	C.Y.	-	.4	600	12.00	7200	-		7200
	CONCRETE: MAT	5223	C.Y.	40	6	31338	13.00	407,394	208920		616,314
	TOWER	3347	C.Y.	40	11	36817	13.00	478,621	133880		612,501
	REINFORCING: MAT	287.3	TON	400	-	-	15.00	-	114,920		114,920
	TOWER	243.	TON	400	-	-	15.00	-	97,200		97,200
	TOTAL :					69446		901,507	554,920		1,456,427

ESG-79-2, Vol 1 IV  
A-48

JOB NO. C20325 DATE 5/25/78 PAGE 1  
 BY RJC CHK \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER 100MW<sub>e</sub> COMMERCIAL PLANT




RECEIVER WT = 500<sup>K</sup> (FOR FURTHER DETAILS REFER TO SKETCH BY ATOMICS INTERNATIONAL)

SEE PG. 2 FOR DETAILS AT TOP

NOTES :

- 1) CONCRETE  $f'_c = 4 \text{ KSI}$ ;  $E = 3640 \text{ KSI}$ ;  $\nu = .15$
- 2) REBAR  $f_y = 60 \text{ KSI}$
- 3) ALLOW. SOIL BRG. PRESS. = 10 KSF (ALLOW  $\frac{1}{3}$  INCREASE FOR SEISMIC)
- 4) ESTIMATED WT. OF PIPING AND ELEVATOR = 1.5<sup>K/1</sup>.
- 5) TOWER DESIGN BASED ON .25 G MAX. GROUND ACCELERATION IN BOTH VERTICAL AND HORIZONTAL DIRECTIONS W/ 7% DAMPING. RESPONSE SPECTRA FROM NRC REG. GUIDE 1.60 ARE EMPLOYED.
- 6) REFER TO COMPUTER OUTPUT FOR ANALYSIS AND DESIGN RESULTS.

JOB NO. C 20325 DATE 5/25/78 PAGE 2  
BY RJC CH'K. \_\_\_\_\_  
CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
SUBJECT ADVANCED CENTRAL RECEIVER




PROPERTIES OF RECEIVER  
SUPPORT STRUCTURE:  
 $E = 29000 \text{ ksi}; \nu = .3$   
 $A = 12 \times 9.35 / 144 = .779 \text{ ft}^2$   
 $I = \frac{9.35 \cdot 14.5^3 [4(.5^3 + .866^3) + 2(1)^3]}{144}$   
 $= 81.91 \text{ ft}^4$

WALL THICKNESS MUST BE INCREASED  
AT TOP OF TOWER TO ACCOMMODATE  
ATTACHMENT OF RECEIVER SUPPORT  
STRUCTURE TO CONCRETE TOWER.

# Stearns-Roger

JOB NO. C20325 DATE 5/25/78 PAGE 3  
BY RJC CHK \_\_\_\_\_  
CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
SUBJECT ADVANCED CENTRAL RECEIVER

## STRUCTURAL MODEL AT TOP :




# Stearns-Roger

PAGE 4

JOB NO. C20325 DATE 5/26/78 BY RJC CHK. \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER

## SOIL PRESSURES :





FOUNDATION PROP.:

$$A = \pi \times 67^2 = 14103 \text{ ft}^2$$

$$WT = 14103 \times 10 \times .15 = 21154 \text{ K}$$

$$S = \pi \times 67^3 / 4 = 236219 \text{ ft}^3$$



### VERTICAL LOADS:

$$P_{MAX} = 14838 + 5774 + 1.25 \times 21154 = 47055 \text{ K}$$

$$P_{MIN} = 14838 - 5774 + .75 \times 21154 = 24930 \text{ K}$$

### % CONTACT AREA FOR UPLIFT CONDITION ( $P_{MIN}$ ):

$$\% \text{ AREA} = 100 \left[ 1 - \frac{2\alpha - \sin 2\alpha}{2\pi} \right] \text{ Where } \alpha = \cos^{-1} (41.273/67) = 51.974^\circ$$

$$= 100 \left[ 1 - \frac{2 \times .90712 - \sin(2 \times 51.974)}{2\pi} \right] = 86.6 \% \quad \text{OK}$$

SOIL BEARING PRESSURES ARE LOW.

# Stearns-Roger

PAGE 5

JOB NO. C20325 DATE 5/30/78 BY RJC CHK \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER

## TOWER CONCRETE & REBAR

WT. OF TOWER CONCRETE  
 $= 14833 - 500 - 1.5 \times 521.653 = 13556 \text{ K}$

VOLUME OF CONCRETE =  $\frac{13556}{15 \times 27} = 3347 \text{ CY}$

## VERTICAL REBAR QUANTITIES

MEMBER	LENGTH (FT)	STEEL AREA (IN <sup>2</sup> )	STEEL VOL. (FT-IN <sup>3</sup> )
1	25.236	339.28	8562
2	51.418	327.31	16830
3	51.414	299.96	15422
4	51.409	271.79	13972
5	51.403	246.18	12654
6	51.395	224.27	11527
7	51.384	205.91	10580
8	51.370	185.76	9542
9	51.351	160.57	8245
10	51.322	128.13	6576
11	26.785	89.35	2393
12	3.584	57.45	313
13	3.584	57.45	313
<b>TOTAL</b>			<b>116929</b>

WT. =  $\frac{116929 \times 490}{144 \times 2000} = 198.94 \text{ TONS}$

# Stearns-Roger

PAGE 5

JOB NO. C20325 DATE 5/30/78 BY RJC CHK \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER

## TOWER CONCRETE & REBAR

WT. OF TOWER CONCRETE  
 $= 14838 - 500 - 1.5 \times 521.653 = 13556 \text{ K}$

VOLUME OF CONCRETE =  $\frac{13556}{.15 \times 27} = 3347 \text{ CY}$

## VERTICAL REBAR QUANTITIES

MEMBER	LENGTH (FT)	STEEL AREA (IN <sup>2</sup> )	STEEL VOL. (FT-IN <sup>3</sup> )
1	25.236	339.28	8562
2	51.418	327.31	16830
3	51.414	299.96	15422
4	51.409	271.79	13972
5	51.403	246.18	12654
6	51.395	224.29	11527
7	51.384	205.91	10580
8	51.370	185.76	9542
9	51.351	160.57	8245
10	51.322	128.13	6576
11	26.785	89.35	2393
12	3.584	37.45	313
13	3.584	37.45	313
TOTAL			116929

WT. =  $\frac{116929 \times 490}{144 \times 2000} = 198.94 \text{ TONS}$

# Stearns-Roger

PAGE 6

JOB NO. C20325 DATE 5/30/78 BY RJC CHK  
CUSTOMER ATOMICS INTERNATIONAL PROJECT  
SUBJECT ADVANCED CENTRAL RECEIVER

## TOWER CIRCUMFERENTIAL REBAR

REF. TO ACI 307-67, SECTION 4.7

USE  $p = .002$

VOLUME OF REBAR IN A HEIGHT "h"

$$V = \frac{\pi p h}{3} (2t_b r_{mb} + 2t_t r_{mt} + t_b r_{mt} + t_t r_{mb})$$

WHERE

$t_b$  = WALL THICKNESS AT BOTTOM

$t_t$  = " " " TOP

$r_{mb}$  = MEAN RADIUS AT BOTTOM

$r_{mt}$  = " " " TOP

FOR  $h = 6173.832''$ ,  $t_b = 15''$ ,  $t_t = 8''$ ,  $r_{mb} = 484.5''$ ,  $r_{mt} = 174''$

$$V = \pi \times .002 \times 6173.832 (2 \times 15 \times 484.5 + 2 \times 8 \times 174 + 15 \times 174 + 8 \times 484.5) / 3$$
$$= 307809 \text{ in}^3$$

FOR  $h = 86''$ ,  $t_b = t_t = 24''$ ,  $r_{mb} = r_{mt} = 174''$

$$V = \pi \times .002 \times 86 \times 2 \times 24 \times 174 = 4513 \text{ in}^3$$

$$V_{TOT} = 307809 + 4513 = 312322 \text{ in}^3$$

$$WT = \frac{312322 \times 490}{1728 \times 2000} = 44.28 \text{ TONS}$$

$$\text{TOTAL REBAR IN TOWER} = 198.94 + 44.28 = 243.2 \text{ TONS}$$



# Stearns-Roger

JOB NO. C20325 DATE 5/30/78 PAGE 7  
 BY RJC CH'K \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER


## FOUNDATION QUANTITIES

$$\text{VOLUME OF CONCRETE} = \frac{\pi \times 67^2 \times 10}{27} = 5223 \text{ CY}$$

$$\text{ESTIMATE REBAR @ } 110 \#/\text{CY}$$

$$\text{WT. REBAR} = 110 \times 5223 / 2000 = 287.3 \text{ TONS}$$

## SOIL EXCAVATION



$$\text{VOL.} = \pi \times 10 [72^2 + 10 \times (72 + 10/3)] / 27 = 6908 \text{ CY}$$


## SUMMARY

TOWER CONCRETE	=	3347	CY	32'	1004,1000
TOWER REBAR	=	243.2	TONS	40	97,280
MAT CONCRETE	=	5223	CY	150	914,025
MAT REBAR	=	287.3	TONS	400	114,920
SOIL EXCAVATION	=	6908	CY		29,


# Stearns-Roger

JOB NO. C20325 DATE 5/30/78 BY RJC CHK \_\_\_\_\_  
 CUSTOMER ATOMICS INTERNATIONAL PROJECT \_\_\_\_\_  
 SUBJECT ADVANCED CENTRAL RECEIVER


## RESPONSE TO LATERAL E.Q. (.25 G MAX. GROUND ACCEL.)




TOWER



REL. DISPL.  
(IN)



ACCELERATION  
(G'S)



At Ft. International Division National

DATE 4-10-78 TAKE-OFF JC PRICED X


JOB NO. 133-0268 SUBJECT LOCATION APPROVED

CLIENT SHEET OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MATL	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
EVAPORATOR - 4'φ x 95' 1100 5/8" φ TUBES - 2 1/4 CR/1MD.	1	EA		2.106	64 TON	29147000	3509		
SUPERHEATER - 30"φ x 91' 283 - 3/4 φ TUBES - 304 S.S.	1	EA		2.106	20 TON	927500	1609		
REHEATER - 32"φ x 66' 163 - 1 1/2 φ TUBES - 304 S.S.	1	EA		2.106	22 TON	1020000	1609		
CRANE TIME (75 TON)	400	HRS.			150/HR.			60000	
COST REF. A-1 CRBP STEAM GENERATORS LESS SUCT. III/CL. I φ 2. REQUIREMENTS FAB. TO SECTION VIII									
INSULATION	2100	S.F.			21°			44100	
TRACE HEATERS	700	L.F.			150°			105000	
CODE	4560	STEAM GENERATORS							
						49114500	291100	2091000	51143700

Form 702-D Rev. 11-73

Round To \$5744,000



ATOMICS INTERNATIONAL DIVISION  
RESEARCH & DEVELOPMENT

JOB NO. 133-026802 PROJECT

100 MW

LOCATION

CLIENT

DATE 9-1-78 TAKE-OFF PRICED CALC. CHKD APPROVED SHEET OF


ITEM AND DESCRIPTION	QUANTITY	UNIT	MATERIAL	CALC. CHKD			MATERIAL	LABOR	SUB-CONTRACT	TOTAL
				LABOR	LABOR	SUB-CONT.				
ENGINEERING TITLE III										
ESTIMATED @ 6% OF CONSTRUCTION (21,986)										
										13191000

CODE

4570

ENGINEERING

Form 702-D Rev. 11-75



JOB NO. 133-0126R02 PROJECT \_\_\_\_\_

LOCATION \_\_\_\_\_

CLIENT \_\_\_\_\_

DATE 4-10-78

TAKE-OFF JC

PRICED JC

CALC. CHKD \_\_\_\_\_

APPROVED \_\_\_\_\_

SHEET A OF \_\_\_\_\_


ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SHEETS 1 THRU 3 HOT TANK						1360000			
SHEETS 1 THRU 3 COLD TANK						344000			
<u>J.M. CALCIUM SILICATE W/S.S. OVEN ALUM. COVER</u>									
INSULATION HOT TANK 12"	22776	S.F.			43.00/ft <sup>2</sup>			979368	
INSULATION COLD TANK 6"	21520	S.F.			24.00/ft <sup>2</sup>			516480	
TRACE HEATERS	3796	L.F.			120/LF			455520	
	3587	L.F.			120/LF			430440	
HOT TANK CONCRETE SLAB	} "SEE 4660 ACCOUNT"								
COLD TANK CONCRETE SLAB									
TOTAL COST HOT TANK									2794888
TOTAL COST COLD TANK									1290920
DRIP PANS FOR THE FOLLOWING:	SEE BACKUP SHEET "A-1"								
HOT & COLD TANKS									217502
PUMPS									8000
MAIN VALVES									4000
BOTTOM OF TOWER PIPE RUNS									6000
MISC.									35000
CODE									4356310
4610	HOT & COLD TANK SUMMARY								ROUND TO \$4356000

ESG-79-2, Vol 1 IV  
A-60

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
<b>HOT TANK</b>									
OUTER TANK 1/4 S.S. PL	1360	ft <sup>2</sup>			14,000#				
STIFFENER RING 1" X 1/2 S.S.	160	ft <sup>2</sup>			4626#				
OUTER TANK BASE 1" S.S. PL	330	ft <sup>2</sup>			13,665#				
SLIDE PL 2' X 1" W 2" SLOT S.S.	20	ft <sup>2</sup>			528#				
2 X 2 X 1/4 L BRACES S.S.	135	L.F.			435#				
2" Ø X 15' ANCHOR BOLTS S.S.	8	EA	150	150				12000	
2" NUTS & WASHER	8	EA	25	30				240	
INSULATION @ 9" / ft <sup>2</sup>	1510	ft <sup>2</sup>						13600	
CONCRETE @ 200#/CY	24	CY						4800	
					35,554# @ 3 3/4" LA.			100662	126302
<b>COLD TANK</b>									
SAME AS HOT TANK USING									
CARBON STEEL INSTEAD OF S.S.									911000

CODE

4610 SODIUM SAFETY REQ.



133-0-6R02 PROJECT 100' X 1/2" SHELL 1100' F APIS TOWER B&T TANK HOT

DATE 3-29-78 TAKE-OFF JAWN PRICED JAWN APPROVED JAWN

CLIENT LOCATION SHEET 2 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF: SK FRAMING SK 3-22-78 100MMK CR									
1 COMPOSE 10R 1/4 X 9.0833 X 31.34' 7304	2847	#	1.10		32370	35607			
" 10R 7/8 X " X 31.45'	2854	"	1.12		56345	31106			
" 10R 3/8 X " X 31.45'	2854	"	1.10		78485	86334			
" 10R 1/2 X " X 31.5'	2861	"	1.05		101437	126508			
" 10R 1' X " X 31.5'	2861	"	1.00		124482	124482			
207 28R 1/4 X 9.0833 X 30'	7630	"	1.10		86753	95428			
" 1R 50 X 141'	127	"			1444	1588			
" 1R 144.6' X 7'	4	"			478	516			
" 1R 1/4 X 10.6' X 30'	318	"			3616	3978			
3 ROOF DS 28R 3/4 X 9.0833 X 30'	7630	#	1.20		63863	716036			
" 1 00 X 9.1'	826	"			691	829			
" 2 3/4 X 6' X 30'	360	"			3013	3616			
" 2 1/2 X 4' X 10'	80	"			670	804			
4 PURLINS 32R 1/2 X 1' X 30.34'	971	"	1.10		21721	23893			
" 4 PL 1/2 X 1' X 25.1'	1004	"			2246	2471			
5 COLUMNS 1600 X 160 X 230' 8272	220	F	245		19037	43641			
6 BEAM PLS 1R 1/8 X 10' X 36' (cut 4) 468	360	#	1.05		17523	18294			
" WEB 1R 3/4 X 8.20' X 36' (cut 4)	300	"	1.05		9561	10354			
7 COL BASE 70R 1 1/2 X 2' X 10' (cut 5)	20	"	1.15		1340	1541			
" " CR " 1R 2" X 4' X 4'	16	"	1.15		1360	1564			
9 PURLIN 1R 1/2 X 8 X 6 X 18' (cut 36) 22	18	F	1.50		414	621			
10 SHELL 10L 3/8 X 4 X 4 X 30.5' 98	325	"	1.30		3185	4141			
11 STAPLER 1R 3/8 X 4 X 23' (cut 4)	92	#	1.12		1472	1649			
" 1R 3/8 X 4' X 15' (cut 4)	60	"	1.12		960	1075			
" 1R 3/8 X 8' X 17' (cut 5)	136	"	1.12		2176	2437			
14 NOZZLE 1-18" X 24" 100 100 500 100 100	1	"	800		252	2016			
15 INLET 1-1800 X 1/2 X 50' 93.42	50	F	2.15		4671	11444			
620 100 CODE					639865	727688			
4610									

Net wt

620 100 CODE  
4610



International Division  
Houston


JOB NO. 3810261802 PROJECT 100' X 45' STEEL API TYPE 5 TORRE TANK LOCATION CLIENT

DATE 3-30-78 TAKE-OFF PRICED APPROVED SUB-CONTRACT SHEET 3 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF. SK. FRAMGOS 3-22-78 100M W/ACR									
WELD SHELL 1" SS V 4.18 HAND T804	90	FT	4.25		376	1598			
" " 1 3/16 V 2.94	90	"			265	1126			
" " 5/8 V 1.86	90	"			167	712			
" " 7/16 V 1.15	90	"			104	442			
" " 1/2 V .83	90	"			39	161			
WELD CONCRETE RISERS 1/2" FW 1.62 3/A	1257	"			781	3319			
" " 4 " 1 3/16 V 1.91	315	"			604	2567			
" " 3 " 5/8 V 1.21	315	"			381	1619			
" " 2 " 7/16 V .75	315	"			236	1003			
" " 1 " 1/2 V .28	315	"			88	374			
WELD BOT 1/4 V LOWESS 1.25	872	"			244	1037			
" " 1/4 V LOWESS 1.25	315	"			88	374			
WELD BOT 3/16 FW LOWESS 1.01	892	"			946	4021			
" " 5/8 DO 1.06	350	"			371	1577			
" " TUBING 3/16 FW 1.06	320	"			339	1441			
WELD COL 1/2 V 1.88	42	"			56	238			
WELD COL 3/8 V 1.5	7	"			6	26			
" " TO SHELL 1/4 FW 1.5	640	"			96	408			
" COL TO BASE 1/4 FW 1.62 HAND	42	"			42	178			
" " BASE TO BOT 1/4 FW 1.5	48	"			12	51			
14 BEAM 3/4 FW WEAR PL 1.4 5/A	576	"			806	3426			
" " TO COL 3/4 FW 2.15 1/4 HAND	24	"			62	221			
" BRACE CLIP 1/4 FW 1.25	81	"			20	85			
" RUNS UP TO COURSE 1 1.25	84	"			21	89			
" PURLINS 1/4 FW 1.25	350	"			88	374			
" BEAMS TO COL 3/4 FW 2.15 1/4 HAND	48	"			103	438			
" NO 2 (ND) 1" V 4.18	6.25	"			26	110			
WELD DOOR 1/4 FW 1.25	9	"			2	9			
CODE 4610					6358	21927			

Form 702-D Rev. 11-73





13310-0202-7  
PROJECT 100MW ACR COLD NA API STORAGE TANK

LOCATION CLIENT

DATE 3-31-78 TAKE-OFF JAWN PRICED JAWN APPROVED JAWN SHEET 1 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MATL	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REFSK. FRAMGOS 3-22-78									
MATERIALIAL (SEE B.M. PG-2)	1.5				482624	119371			
" " " " PG-3)					3954	8245			
SUB-TOTAL					486580	127586			127586
MATL ON 21090									127147
ENGINEERING DESIGN	160	HR		34W			4800		4800
FABRICATION LABOR	600	HR		8.25			4950		
SHUT FABOR	2500	"		14.75			41875		
FIELD FABRICATION	1500	"		17.75			22188		
" INSPECTION	375	"		19.75			7406		
SUB-TOTAL							76419		76419
SHOP OVERHEAD	600	HR		20.75			12450		
FIELD O.H. 50% 71469							25725		
SUB-TOTAL O.H.							48185		48185
CRANE RENTAL								15000	
SUB-TOTAL BASE COST									284704
VENDOR SVA 21090									28296
SUB-TOTAL									313000
VENDOR PROFIT 15%									31600
ESTIMATED VENDOR PRICE CURRENT DOLLARS									344000
173753/LB									
SHELL BUNKER 100%									

4610 COLD TANK

Form 702-D Rev. 11-73



International Division  
(national)

JOB NO. BB-026-R02 PROJECT 1000 W. L. A. R. C. OLD NA API'S STORAGE TANK LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 3-31-78 TAKE-OFF Jehan PRICED Jehan CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF: SK FRANGUS 3-22-78									
① CURSOR M 10PL X 9.0633 X 2.124 X 1.1478	2847	#	.242		31317	7579			
" 1/2 " 5 1/2 X 3 1/2 X 3/4	2540	"	.2341		34925	8190			
" 3/4 " 7/16 " X 3 1/2 X 3/4	2540	"	.231		48895	11295			
" 1/2 " 9/16 " X 3 1/2 X 3/4	2546	"	.227		63014	14304			
" 5/8 " 1 1/16 " X 3 1/2 X 3/4	2546	"	.227		76380	17338			
② BSTD PL FROM 1 1/4 PL	8117	"	.244		89287	21607			
③ R.O.F.A " 3/16 PL	8153	"	.261		66855	16781			
④ POPLINS 6 L 13 Cont 36 A36	1072	#	.2405		13936	3352			
⑤ COLUMNS 1-12 W 79" X 45"	45	"	.226		3555	981			
⑥ #2-5 41 D0 X 42"	168	"	"		13193	3641			
⑦ BEAMS 4.24 X 160 X 36"	144	"	"		23040	6359			
⑧ COL PARS (TOP) 1 1/2 X 2 1/2 X 10 (cont) 516.70	20	#	.30		1275	383			
" " CH2 1 1/2 X 2 1/2 X 44"	16	"	.30		1360	408			
⑨ PIPES 12 1/2 X 6 X 18 (cont) A36	18	#	.229		414	95			
" SCHEDULE 10 2 1/2 X 4 X 32.5" A36	325	"	.225		3185	717			
⑩ CTG PIPES 6 L 13 X 2.88 (cont) 10	288	"	.2405		3744	900			
⑪ NOZZLES 24" L A 0.5 X 5 7 10.5 (cont) 5"	1	pc	.205		260	520			
⑫ INLET 1-24 X 1/2 X 50 125.5 4068	50	#	.17786		6275	3893			
WELD SHELLS 5.5 1/4 V .73 NOM 516.70	91		.160		39	23			
" 4 1/2 X 5 1/2 V .67	80				51	31			
" 4 1/2 X 7 1/2 V .115	80				92	55			
" 4 1/2 X 9 1/2 V 1.59	80				127	76			
" 4 1/2 X 11 1/2 V 2.28	80				182	109			
" 1 R.S 1/4 V .28 5/A	315				88	53			
" 3 7/16 V .48	315				132	79			
" 3 7/16 V .75	315				236	142			
" 4 9/16 V 1.03	315				325	195			
" 5 3/8 V .35	1259				441	265			
CODE									
A610					48226	119371			

Form 702-D Rev. 11-73



International Division  
National

JOB NO. 133,000-R02-2

PROJECT 100MW ACRO COLONIA API STORAGE TANK

LOCATION

CLIENT

DATE 3-31-78

TAKE-OFF

Jean

PRICED

Jean

CALC. CHKD

APPROVED

SHEET 3

OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
REF SK FRANGOS 3-22-78									
WELD BOT 1/4" .28 S/A51670	1187	FT	60		532	199			
WELD ROOF 3/16FW .1 106 "	1242	"			124	741			
" RIM L 3/16FW .1 106 "	320	"			32	19			
" RIM L 3/8V .82 HAIN "	7	"			6	4			
" TOSHELL 1/4FW .15 9A "	640	"			32	19			
" COL TO ROOF TOP 1/4FW 1.67 HAND "	42	"			42	25			
" BASE TO BOT 1/4FW .25 .15 "	48	"			12	7			
" BEAM TO COL 3/4FW 2.15 1.4 "	24	"			52	31			
" GUSSET TO CLIP 1/4FW .25 .15 "	81	"			20	12			
" PURLIN SUP TOSHELL 1/4FW .25 .15 "	84	"			21	12			
" PURLINS 1/4FW .25 .15 "	350	"			88	53			
" BEAM TO COL 3/4FW 2.15 1.4 "	48	"			103	62			
" NOZZLE SHCL 1/16V .25 228 "	8	"			28	17			
" NOZZLE TO ROOF 1/4FW .25 .15 "	6	"			2	1			
WELD FLUX	2100	LB	180			1680			
MIC (MNT L M H D) STAIRSETS	L.S				3000	6000			
SUB-TOTAL					3954	8215			
CODE									
4610									



Local Division  
Atco Rock, Inc.

JOB NO. 133-02681 PROJECT

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 7-20-78 TAKE-OFF JC PRICED JC CALC. CHKD APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MATERIAL	LABOR	CALC. CHKD		APPROVED		SUB-CONTRACT	TOTAL
					MAT'L	SUB-CONT.	MATERIAL	LABOR		
STEAM GENERATOR PUMP P-2 700 H.P. - 15,000 G.P.M. @ 250' T.D.H. COMPLETE W/ DRIVES, SPEED CONTROL MOTOR GENERATOR	1	EA		75000						575000
INSULATION	438	S.F.							131000	131000
TRACE HEATERS	146	L.F.							17526	17526
STEAM GENERATOR PUMP P-2										
4630										723520
ROUND TO										724000

Form 702-D Rev. 11-73



JOB NO. 100-22-4058-63 PROJECT 100 MW CLIENT LOCATION APPROVED SHEET OF

DATE 9-1-78 TAKE-OFF PRICED CALC. CHKD SUB-CONTRACT LABOR MATERIAL LABOR SUB-CONTRACT TOTAL

ENGINEERING TITLE III  
ESTIMATED @ 6% OF CONSTRUCTION

CODE  
4670 ENGINEERING



General Division  
General

JOB NO. 133-02682 PROJECT

LOCATION CLIENT

DATE 7-27-78 TAKE-OFF JC PRICED JC CALC. CHKO APPROVED SHEET OF

ITEM AND DESCRIPTION		QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SODIUM		16410	LBSS	.40						4400000
WORKING MEDIA.										4400000

CODE  
4680

Form 702-D Rev. 11-73

V.A. THE...

JOB NO. 133-46 PROJECT \_\_\_\_\_

LOCATION \_\_\_\_\_

CLIENT \_\_\_\_\_

DATE 5-3-79

TAKE-OFF JC

PRICED JC

CALC. CHKD \_\_\_\_\_

APPROVED \_\_\_\_\_


SHEET \_\_\_\_\_

OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
<b>"MECHANICAL"</b>									
<b>TEMPORARY CONSTRUCTION</b>									
OFFICE TRAILER									17000
TOILETS									9000
FAB. SHELTER & WAREHOUSE									20000
<b>RENTAL EQUIPMENT</b>									
CRANES & HOISTING EQUIPT.									92000
PICKUP TRUCKS									28000
FLATBED TRUCKS									20000
WELDING MACHINES									30000
PIPE MACHINES									3000
GAS RIGS									4000
<del>TEST PUMPS</del> SMALL TOOLS									10000
SCAFFOLDING ALLOWANCE									10000
<b>JOB OVERHEAD</b>									
SUPERINTENDENT									218000
ENGINEERS									167000
OFFICE MANAGER GENERAL FOREMAN									175000
CLERKS WAREHOUSEMAN									125000
UNALLOCABLE LABOR @ 6% OF DEL X \$	2,282	000							136000
CONSUMABLES @ 6% OF DEL X \$	2,282	000							136000
CODE 4810 5400									1200000
CONTRACTORS FIELD OVERHEAD									

ESG-79-2, Vol IV  
A-71




PREPARED BY: <i>W. Wilcox</i>	 <b>Rockwell International</b> Atomics International Division		PAGE NO.	OF
CHECKED BY:			REPORT NO. <i>Profit/loss</i>	
DATE: <i>9/06/78</i>	<i>100 MWE at southern 1st plant</i>		MODEL NO.	

	<u>4820</u> Space Parts	<u>4830</u> A&E	<u>4840</u> C M	<u>4860</u>	
CBS	_____	_____	_____	_____	
4100		<u>5,381</u>	<u>5,381</u>	<u>5,381</u>	
4200	<u>19,424</u>	<u>19,424</u>	<u>19,424</u>	<u>19,424</u>	
4300	<u>4,834</u>	<u>4,834</u>	<u>4,834</u>	<u>4,834</u>	
4400	<u>60,596</u>			<u>60,596</u>	
4470			<u>10,918</u>		
50			<u>2,525</u>		
60			<u>3,399</u>		
41500	<u>23,305</u>			<u>23,305</u>	
14			<u>1,452</u>		
15			<u>1,315</u>		
20			<u>4,942</u>		
40			<u>3,166</u>		
50			<u>0</u>		
60			<u>5,144</u>		
4600	<u>12,086</u>			<u>12,086</u>	
10			<u>4,356</u>		
20			<u>0</u>		
30			<u>724</u>		
40			<u>0</u>		
50			<u>0</u>		
60			<u>300</u>		
FACTOR	X.005	X.05	X.05	X.29	X.10
10 <sup>6</sup> \$	601	1482	3394	10288	9023
				<u>19311</u>	

N 159-B-2 REV. 3-76

PREPARED BY: <u>W. WILLCOX</u>	 <b>Rockwell International</b> Atomics International Division		PAGE NO. _____	OF _____
CHECKED BY: _____			REPORT NO. _____	
DATE: <u>09/06/78</u>	<u>NTH PLANT NOMINEE</u> <u>ACT No</u>		MODEL NO. _____	

	<u>4820</u> <u>Spare Parts</u>	<u>4830</u> <u>A&amp;E</u>	<u>4840</u> <u>CMA</u>	<u>4860</u> .....
<u>CBS</u>	_____	_____	_____	_____
<u>4100</u>		<u>5,271</u>	<u>5,271</u>	<u>5,271</u>
<u>4200</u>	<u>19,424</u>	<u>19,424</u>	<u>19,424</u>	<u>19,424</u>
<u>4300</u>	<u>4,301</u>	<u>4,301</u>	<u>4,301</u>	<u>4,301</u>
<u>4400</u>	<u>45,820</u>			<u>45,820</u>
<u>4440</u>			<u>8,570</u>	
<u>50</u>			<u>1,910</u>	
<u>60</u>			<u>2,720</u>	
<u>4500</u>	<u>19,852</u>			<u>19,852</u>
<u>14</u>			<u>1,452</u>	
<u>15</u>			<u>1,315</u>	
<u>20</u>			<u>4,942</u>	
<u>40</u>			<u>3,166</u>	
<u>50</u>			<u>4,110</u>	
<u>60</u>			<u>0</u>	
<u>4600</u>	<u>11,400</u>			<u>11,400</u>
<u>10</u>			<u>4,072</u>	
<u>20</u>			<u>0</u>	
<u>30</u>			<u>688</u>	
<u>40</u>			<u>0</u>	
<u>50</u>			<u>0</u>	
<u>60</u>			<u>300</u>	
<u>FACTOR</u>	<u>X.005</u>	<u>X.05</u>	<u>X.05</u>	<u>X.129</u> <u>X.10</u>
<u>10<sup>6</sup>\$</u>	<u>503</u>	<u>1450</u>	<u>3113</u>	<u>4017</u> <u>7482</u>
				<u>11499</u>

M 149-B-2 REV. 2-76

**THREE YEAR O&M COSTS  
AGUA FRIA STATION**

**COSTS FOR SINGLE 100 MW UNIT IN SIX UNIT PLANT, \$'s**

<b>ACCOUNT</b>	<b>1975</b>	<b>1976</b>	<b>1977</b>	<b>AVERAGE</b>
Operations	232,521	272,798	313,610	272,976
Maintenance	265,535	296,540	527,903	363,325
<b>TOTAL</b>	<b>498,056</b>	<b>569,338</b>	<b>841,513</b>	<b>636,301</b>

**COSTS FOR SINGLE 100 MW UNIT IN ONE UNIT PLANT, \$'s**

<b>ACCOUNT</b>	<b>1975</b>	<b>1976</b>	<b>1977</b>	<b>AVERAGE</b>
Operations	534,798	627,435	721,303	627,845
Maintenance	610,731	682,042	1,214,177	835,648
<b>TOTAL</b>	<b>1,145,529</b>	<b>1,309,477</b>	<b>1,935,480</b>	<b>1,463,493</b>

**NOTES:**

1. The above costs are based on removing boiler and fuel related costs from total O&M.
2. The three year period reflects a cycle of O&M events.
3. There is some escalation (6% - 8%/yr) that is occurring over the three year period.
4. Costs are based on actual and of course do not include requirements for sodium or solar systems.

**MINIMUM MANNING TABLE RECOMMENDED BY SRP  
FOR 100 MW SOLAR PLANT  
(Excludes Collector & Sodium Systems Maintenance)**

**ADMINISTRATIVE & OFFICE TOTAL: 10**

- (1) Superintendent
- (1) Asst. Superintendent
- (1) Clerk
- (1) Statistician
- (1) Warehouseman
- (5) Guards

**ENGINEERING, RESULTS & CONTROLS TOTAL: 10**

- (1) Plant Engineer
- (1) Engineer (Controls/Computer)
- (2) Computer Technicians
- (2) Chemists
- (2) Instrument Technicians
- (1) Helper
- (1) Apprentice

**OPERATION TOTAL: 20**

- (5) Shift Foremen
- (5) Control Room Operators
- (5) Asst Control Room Operators
- (5) Auxiliary Operators

**MAINTENANCE TOTAL: 13**

- (1) Maintenance Supervisor
- (2) Working Foremen
- (1) Electrician
- (3) Mechanics
- (1) Machinist/Mechanic
- (1) Welder/Mechanic
- (3) Apprentices
- (1) Janitor

**PLANT TOTAL: 53**

**APPENDIX B**  
**COST SUBSTANTIATION DATA**  
**FOR THE 100 MWe COMMERCIAL PLANT**  
**AIR-ROCKS STORAGE**

JOB NO. 133-D26R02 PROJECT \_\_\_\_\_

LOCATION \_\_\_\_\_

CLIENT \_\_\_\_\_

DATE 7-28-78

TAKE-OFF JC

PRICED JC

CALC. CHKD \_\_\_\_\_

APPROVED \_\_\_\_\_

SHEET \_\_\_\_\_

OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
ALL SODIUM INSTRUMENTATION									14530000
ADD FOLLOWING FOR AIR ROCK: SWITCH GEAR FOR FANS, TANK HEAT EXCHANGERS ETC.									237000
CODE 4514	AIR/ROCK INSTRUMENTATION								22890000

ESG-79-2, Vol 1 IV  
 B-2

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
SHEET # 2 - PURIFICATION & GAS SYSTEM						7611000	292460		
344- HORIZ. PIPING						1055977	233370	11200	
5- DOWNCOMERS & RISER						469442	426030		
6- INSULATION								670037	
7- TRACE HEATERS								769860	
FIELD OVERHEAD 30% X D.L							315550		
							1367418		
							2551218		
ADD FOR AREA LABOR PRODUCTIVITY, 60% X 426030						2288377	1623036	14511097	

4520 Hot Rocks- Riser, Downcomer & Horiz. Summary 5362510






ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
C.S. A-53 x 3/8" WALL PIPE 20"	140	LF	47	3.5		6520	490°		
	18	460	42	3.4		19320	1564°		
	6	20	11	1.0		220	20°		
90° ELL 20	1	EA	733	11.0		733	11°		
	18	5	569	9.0		2845	45°		
TEE 20x18	1		1410	15°		1410	15°		
	18	1	926	12.0		926	12°		
CONC. RED. 18x17	3		285	9.0		855	27°		
3000# F.S. WELD-O-LET	6	2	58	9.2		116	18°		
SODIUM VALVES	20	1	90K	212°		90000	212°		
	18	6	70K	150°		420000	900°		
	12	2	40K	90°		80000	180°		
MIXING TEE 20x18	1		140K	80°		140000	80°		
	18	1	126K	60°		126000	60°		
S.S. T-304 x 3/8 WALL PIPE 18	525	LF	190	3.4		99750	1785°		
	12	168	L.F.	170	2.3	28560	386°		
90° ELL 18	3	EA	2600	9.0		7800	27°		
	12	4	1265	6.5		5060	26°		
TEE 18	2		4211	12°		8422	24°		
	12	4	2100	8.6		8400	34°		
FIKE BURST DISC. ASSEMBLY 600#	12	3	3000	12.0		9000	36°		
STD. C.S. BUTTWELDS	20	13	1	5.4			70°		
	18	40		4.7			188°		
	6	4		2.3			9°		
S.S.	18	42		21.0			882°		
	12	37		15.0			555°		
CODE 4520	HOT ROCKS HORIZ. PIPING						7656°	M.H.P. 30°	
						11055997	229680		

ESG-79-2, Vol 1 IV  
B-5



JOB NO. \_\_\_\_\_ PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_  
 DATE 4-3-78 TAKE-OFF X PRICED JK CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 35 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
C.S. A-53 PIPE x 3/8" WALL 20"	1000	LF	47	3.5		47000	35000		
20" SILL	28	EA	733	11.0		20524	3080		
BUTTWELDS	88			5.4			4750		
S.S.-T-304 PIPE x 3/8" WALL 18"	1000	LF	190	3.4		190000	34000		
20" SILL	28	EA	2600	9.0		72800	2520		
BUTTWELDS	88			21.0			18480		
SUPPORT HANGERS HORIZ. 20"	28	EA	1314	60.0		36792	16800		
VERT. 18"	28		1355	60.0		37940	16800		
VERT. 20"	43		52	3.0		2236	1290		
	43		50	3.0		2150	1290		
SNUBBERS #200 x PIPE CLAMP	20		3050	40.0		60000	8000		
CODE 4-520						469442	426030		
DOWN COMMERCE RISER	1-10T	ROCKS							



JOB NO. \_\_\_\_\_ PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 4-20-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET 6 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL	
					S.S. OVERH					
EQUIV. LIN. FOOTAGE 3"	20	1250	LF	24	2.88	24.00	300.00	3600.00	3000.00	
5 1/2"	18	1700		44	2.67	23.00	748.00	4539.00	3910.00	
5"	12	220		30	1.79	15.00	166.00	394.00	330.00	
2 1/2"	6	20		10	.89	7.65	2.00	1.53	1.53	
3"	18	480		22	1.30	23.00	1056.00	624.00	1104.00	
ALUM. WEATHER PROOFING	20	100	LF	1.00	.10	1.00	10.00	10.00		
	18	1040	LF	1.00	.10	1040	104.00			
							9287.00	1114.273.00		
						123300	213647	83593		
ADD FOR AREA LABOR PRODUCTIVITY x 60%							128188			
CONTRACTORS O.H. & PROFIT @ 15%						123300	341835	83593		
						18495	51275	12539		
FIELD OVERHEAD							39500			
CODE										
4520	1.1qf Rocks Piping INSULATION						141795	432110	96132	670537

ESG-79-2, Vol IV  
B-8



Atomic Rock  
Divisional  
JOB NO. 133-026-R02 PROJECT

DATE 4-21-78 TAKE-OFF JK PRICED JK CALC CHKD APPROVED LOCATION CLIENT SHEET 7 OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR		SUB CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL				
				LABOR	1/2									
ELECT. TRACE HEATERS 20"	1250	LF	50	160			62500	200000						
18"	2180	1	50	160			109000	348800						
12"	220		50	160			11000	35200						
6"	20	1	40	128			800	2560						
<table border="0"> <tr> <td>4520</td> <td>107 ROCKS ELECT. TRACE HEATERS</td> <td>183300</td> <td>586500</td> <td>769800</td> </tr> </table>										4520	107 ROCKS ELECT. TRACE HEATERS	183300	586500	769800
4520	107 ROCKS ELECT. TRACE HEATERS	183300	586500	769800										





JOB NO. 123-038 PROJECT 100 MW

LOCATION \_\_\_\_\_

CLIENT \_\_\_\_\_

DATE 8-2-78

TAKE-OFF JK

PRICED JK


CALC. CHKD \_\_\_\_\_

APPROVED \_\_\_\_\_

SHEET 2 OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR \$	SUB-CONTRACT	TOTAL
				\$					\$000
60 EXCAVATION & BACKFILL	89,000	C.Y.			3% C.Y.			240,000	240
80 INSULATING ROCKS	<sup>124</sup> 76,000	TON	4.20	.66		304,000	50,000		601
10 RIVERBED SAND	34,000	TON	4.50	.65		136,000	22,100		158
40 FORMED CONCRETE HOUSING	54	C.Y.		1	\$300.00			16,200	16
10 CONCRETE SERVICE ROADS 6"	380	C.Y.		1	\$150.00			57,000	57
10 .032 GALV. CORR. SHEETING	70,000	FT <sup>2</sup>	.60	.30		420,000	21,000		63
10 CONCRETE ROOF SEAL 4"	2300	C.Y.		1	\$200/C.Y.			<del>230,000</del> 460,000	230
10 GUNITE EXTERIOR WALL 1"	74,000	FT <sup>2</sup>		1	.41			30,000	30
30 CONCRETE PIPE COL. 12" WITH FOOTINGS INSTALLED	1	L.S.		1				149,000	149
30 HOT DUCT PIPING	324	EA	525	3.50		170,100	21,384	20,000	395
COOL DUCT PIPING	324	EA	495	3.25		160,380	23,166		
CODE	46XX AIR-ROCKS STORAGE								1939

ESG-79-2, Vol 1 IV  
B-11



Atomic Fuel Division  
 Nuclear


JOB NO. 12-038 PROJECT


DATE 6-28-78 TAKE-OFF JC PRICED JC CALC. CHKD APPROVED SHEET 3 OF CLIENT

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
30 100 H.P. FANS W/ VARI-SPEED MOTOR & COOLED BEARINGS & 60" FAN	54	EA.	11000	2000		594000	108000		702000
40 HEAT EXCHANGERS 2'-9" X 8' X 8' 1'-0" X 0.49 2/4" CR/INO. 10.510 FT <sup>2</sup> SURFACE	54	EA.	170K	1200		918000	64800		982800
40 SHEET METAL HOUSING (450#)	54	EA.	600	200		32400	10800		43200
30 12" THERMO FUSION UNIT	3456	FT <sup>2</sup>			30.00			103680	
30 1" FIBERGLASS UNIT (ERT)	3456	FT <sup>2</sup>			3.90			13472	
30 12" THERMO BESTIES @ WALLS	2160	FT <sup>2</sup>			37.00			79920	
30 24" FIBERGLASS @ WALLS (ERT)	2160	FT <sup>2</sup>			4.50			9720	
30 CERIFELT 3# DENSITY	1	L.S.			100			100	
40 FAN & HEAT EXCHANGER STRUCTURES	54	EA.	1200	1300		64800	70200		135000
40 SUPPLY & RETURN PIPING @ UNITS	54	EA.	575	575		27810	31050		58860
40 PIPE INSULATION @ UNITS	1840	L.F.			20			36800	
40 TRACE HEATERS @ UNITS	1840	L.F.			100			220800	
30 COOLING SYSTEM FOR FANS	54	EA.	613	412		33102	22248		55350
40 S.S. FOR HX & FAN STRUCTURE	16,200	LBS.			2.50/LB.			40500	
46XX FANS & HOUSING									6882





PREPARED BY:	 <b>Rockwell International</b> Atomics International Division		PAGE NO.	OF
CHECKED BY:			REPORT NO.	
DATE:	12/2/78	Air 100 Rocks	MODEL NO.	
	4820 Space Parts 1.5%	4830 A&E 5%	4840 C.M. 5%	4860 30% 10%
CBS				
4100		5,381	5321	7,721
4200	18,419	19,824		10,225
4300	4,227	4,230	4,224	4,231
4400	50,506			50,506
4470			10,752	
50			2525	
60			3,397	
4500	21,227			24,588
14			2289	
15			1315	
20			5362	
40			3156	
50				
60			5144	
4600	10721			10721
10			538	
20			1900	
30			1391	
40			6051	
50			-	
60			240	
	120163		73867	38309
	X.005	X.05	X.05	X.29
	600	1982	3693	10240
				9024
				19264

PREPARED BY: <u>RJ</u>	 <b>Rockwell International</b> Atomics International Division	PAGE NO. <u>        </u> OF <u>        </u>
CHECKED BY: <u>        </u>		REPORT NO. <u>        </u>
DATE: <u>12/2/78</u>		MODEL NO. <u>        </u>

AIR RACKS NTH Plant

CBS	4820 Space Parts	4830 A&E	4840 CM	4860 contingency
4100		<u>5381</u>	<u>5381</u>	<u>5381</u>
4200	<u>19424</u>	<u>19424</u>	<u>19424</u>	<u>19424</u>
4300	<u>4301</u>	<u>4301</u>	<u>4301</u>	<u>4301</u>
4400	<u>45820</u>			<u>45820</u>
4440			<u>6590</u>	
50			<u>1910</u>	
60			<u>2720</u>	
4500	<u>21397</u>			<u>21397</u>
14			<u>2289</u>	
15			<u>1315</u>	
20			<u>5362</u>	
40			<u>3156</u>	
50			<u>        </u>	
60			<u>5144</u>	
4600	<u>9978</u>			<u>9978</u>
10			<u>538</u>	
20			<u>1900</u>	
30			<u>1250</u>	
40			<u>5450</u>	
50			<u>        </u>	
60			<u>240</u>	
	<u>100920</u>	<u>29106</u>	<u>68970</u>	<u>31375</u> <u>74926</u>
	X.005	X.05	X.05	X.13    X.10
	<u>505</u>	<u>1455</u>	<u>3449</u>	<u>4079</u> <u>7493</u>
				<u>11572</u>

APPENDIX C

COST SUBSTANTIATION DATA  
FOR THE 281-MWe COMMERCIAL PLANT

JOI NO 133-026802-OBJECT 300 MW

DATE 2-1-78 TAKE-OFF JC PRICED JC LOCATION APPROVED OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	CALC. CHGD		MATERIAL	LABOR	SUB-CONTRACT	TOTAL
			MAT'L	LABOR				
LAND FURNISHED BY USER								
SITE INCLUDING FENCING, UTILITIES								1329000
MRAS" REF ACCOUNT #4400								1581000
								2929000

4001

4100 SITE

REV. 11-75





ION	
LY	
LY DUL	
MARKS	
DERSON, S. H.	
WORTH	
JUTH	
ENT	
JRMASH	
ITS	
NDLEY	
ROENAS	
CHWAN, J.C.	
AWFORD	
LOS PRADOS	
FTERMAN	
LER	
LFE	
RTZLER	
JIG	
LBROOK	
OBELLIS	
OBSON, J.	
ES, R.G.	
JAN, M.	
ATEN	
TINSEP	
LOUIS	
RTIN, A.B.	
COURT	X
DERMOTT	
DONALD, J.S.	
KENZIE, D.E.	
YERS, G.W.	
REWITZ	
MURPHY	
DENKAMP	
RKER, T.	
RKINS	
CRUL	
MLEY	
INECKER	
NDERS	
HIRM	
ITONE	
TOHER	
A. WARD	
HEELER	
ESENECK	
WILLIAMS	
TRCZ	
DRING	
2/25/90	
T. Thomson	
for 4/25/82	
1-4905	
2 Bales	



RECEIVED  
JUN 20 1978

ENGINEERING • CONSTRUCTION

Correspondence Dept.

June 14, 1978

Atomics International Division  
Rockwell International  
8900 DeSota Avenue  
Canoga Park, California 91304

Re: C-20325-29

Attention: Mr. T. H. Springer  
Project Manager

Subject: 300 MWe Plant Cost  
Advanced Central Receiver Power System

Reference: AI Contract N311-002FX

Dear Tom:

In accordance with discussions held at the midterm review on June 6, 1978, we have prepared preliminary turbine selection and cost data for a 300 MWe (net) EPGS. Enclosed herewith are 300 MWe turbine-generator cost and performance data for 1800 psig and 2400 psig reheat turbines dated June 7, 1978. It appears that either the TC2F-33.5" or the TC4F-26" machines at 2400 psig, 1000/1000 °F, 2" HgA would be the best choice in a seven heater cycle, based on cycle efficiency.

Also enclosed is a preliminary cost estimate dated June 13, 1978 showing direct costs for account 4200 Turbine Plant Equipment and account 4300 Electric Plant Equipment for both 100 MW and 300 MW plants. Please note that the 100 MW Electric Plant Equipment costs have been revised since the midterm review. A review of the 100 MW cost estimate revealed that the cost of heliostat power distribution and trenching had inadvertently been included under account 4300 and has been deleted in the revised estimate. Also the costs under 4300 have been redistributed to reflect the proper charges in the various sub-accounts.

Other cost estimates for the 300 MW Balance of Plant include the following:

7680 AT

4120



# Stearns-Roger

Atomics International Division  
Canoga Park, California 91304

June 14, 1978

4121	Turbine Building	\$ 5,500,000	}	7,100,000
4122	Administration Building	)		
4123	Warehouse/Maintenance Building	) Lot 1,600,000		
4123	Control Building	)		
4131	Transportation and Lifting Equipment	350,000	}	1,310,000
4132	Communication Equipment	110,000		
4133	Other	850,000		
		<u>840,000</u>		

(Included are service air and instrument air compressor equipment, and miscellaneous building piping: service water, sanitary, heating, floor drains, roof drains, potable water, fire protection, etc.)

If you have any questions regarding the cost estimates or turbine data, please advise.

Very truly yours,

STEARNS-ROGER ENGINEERING CO.

*A. W. McKenzie*

A. W. McKenzie  
Project Engineer

AWM:vr

Enclosure







ACTION

REPLY

REPLY DUE

REMARKS

RECEIVED

AUG 25 1978

August 22, 1978

Correspondence Dept.

ANDERSON, S H	
ASHWORTH	
ASQUITH	
BALENT	
BAURMASH	
BOTTS	
BRINDLEY	
CARDENAS	
COCHRAN, J C	
CRAWFORD	
DE LOS PRADOS	
DETERMAN	
<i>L. Green</i>	
FELLER	
GYLFE	X
HARTZLER	
HILLIG	
HOLBROOK	
JACOBELLIS	
JACOBSON, J	
JONES, R G	
JULIAN, M	
KATER	
KING	
<i>L. Bates</i>	
LULOVICS	
MARTIN, A B	
MCCOURT	
MCDERMOTT	
MCDONALD, J S	
MCKENZIE, D E	
MEYERS, G W	
MORLIVITZ	
<i>Trapp</i>	
J. MURPHY	
OLDEKAMP	
PARKER, T	
PARKINS	
<i>E. Ash</i>	
REMLEY	
REINICKER	
SANDERS	
SCHIRM	
L. STONE	
W. TISH H	
H. A. WAHID	
WHEELER	
WILSON, C K	X
J S WILLIAMS	
<i>Springer</i>	
<i>Katz</i>	X
<i>Blyskal</i>	X
<i>A. Thomas</i>	
<i>L. E. Johnson</i>	
<i>Boubert</i>	
<i>P. Klaus</i>	

Atomics International Division  
Rockwell International  
8900 DeSota Avenue  
Canoga Park, CA 91304

Re: C-20325-38

Attention: Mr. T. H. Springer  
Project Manager

Subject: 300 MWe Plant Cost (Revised)  
Advanced Central Receiver Power System

Reference: AI Contract N311-0002-FX  
DOE Contract EG-77-C-03-1483

Dear Tom:

Enclosed please find revised preliminary cost estimate dated 8/21/78 (Rev. 1) comparing 100 MWe vs 300 MWe Turbine Plant Equipment and Electric Plant Equipment. This estimate supersedes the previous estimate dated 6/13/78.

Revision 1 changes the 300 MWe turbine-generator cost (account 4210, reflecting the use of a TC2F-33.5" turbine in lieu of a TC4F-26" turbine originally assumed. Also account 4220 (heat rejection system) revised to add an 80 acre evaporation pond (\$3,600,000) to the 300 MWe plant. A 30 acre evaporation pond was already included in this account for the 100 MWe plant at a cost of \$1,500,000.

If you have any questions concerning this revised cost estimate, please let us know.

Very truly yours,

STEARNS-ROGER ENGINEERING CO.

*A. W. McKenzie*  
A. W. McKenzie  
Project Engineer

10507ESG

4200  
4300

AWM:vr  
Encl.

CONCEPTUAL DESIGN OF ADVANCED CENTRAL RECEIVER POWER SYSTEM  
ELECTRIC POWER GENERATION SUBSYSTEM (STEARNS-ROGER)

PRELIMINARY COST ESTIMATE

<u>PLANT SIZE (NET OUTPUT)</u>	<u>100 MWe</u>	<u>300 MWe</u>
<u>4200 TURBINE PLANT EQUIPMENT</u>		
4210 TURBINE-GEN. AND ACCESS.	\$10,856,000	\$21,560,000 $\triangle$ 1
4220 HEAT REJECTION SYSTEM	4,215,000	9,875,000 $\triangle$ 1
4230 CONDENSING SYSTEMS	320,000	577,000
4240 FEED HEATING SYSTEMS	1,655,000	3,203,000
4250 WORKING FLUID CIRC., TREAT., ETC.	<u>2,378,000</u>	<u>3,544,000</u>
TOTAL 4200	\$19,424,000	\$38,759,000 $\triangle$ 1
<u>4300 ELECTRIC PLANT EQUIPMENT</u>		
4310 SWITCHGEAR	\$ 860,000	\$ 1,502,000
4320 STATION SERVICE EQUIP.	1,302,000	2,163,000
4330 PROTECTIVE EQUIPMENT	253,000	300,000
4340 POWER WIRING, ELECT. STRUCTURES AND WIRING CONTAINERS	<u>938,000</u>	<u>2,231,000</u>
TOTAL 4300	\$ 3,353,000	\$ 6,196,000

NOTE:

- 1) Costs are current direct costs, no indirect costs included.
- 2) Heliostat power distribution not included.

4200  
4300

Table C

251  
 ADVANCED CONCEPT NTH COMMERCIAL PLANT - ~~300~~ MWe  
 BREAKDOWN OF MASTER CONTROL COSTS BY CBS

1978 DOLLARS AND HOURS IN THOUSANDS

<u>CBS</u>	<u>COST ELEMENT</u>	<u>LABOR</u>		<u>NON-LABOR</u>	<u>TOTAL</u>
		<u>HOURS</u>	<u>DOLLARS</u>		
4351	Hardware				
	LSI-11 Processor			\$ 14.94	\$ 14.94
	RX11 BA Disc Drive & Control			22.68	22.68
	TA11 AB Recorder			9.52	9.52
	LAV11 DA Printers			8.55	8.55
	Terminal			41.28	41.28
	Cabinet	2.37	\$ 66.19	29.43	95.62
	Cable			10.50	10.50
	Data Acquisition			0	0
	Time			3.83	3.83
	Weather			18.37	18.37
	Timers			2.40	2.40
	Assy, Trans, Install & C/O	<u>5.07</u>	<u>169.94</u>	<u>10.37</u>	<u>180.31</u>
	Subtotal	7.44	\$236.13	\$171.87	\$408.00
	Visibility		<u>47.87</u>	<u>34.13</u>	<u>82.00</u>
	TOTAL 4351		\$284.00	\$206.00	\$490.00
4352	Hardware Design & Engr	3.70	\$174.00	\$ 11.00	\$185.00
4353	Software Design, Develop & Test	1.53	\$ 72.00	\$ 4.00	\$ 76.00
0M300	Maintenance Labor (Subcontract)			\$ 0.50	\$ 0.50

Table C -4

NTH COMMERCIAL HELIOSTAT INVESTMENT COST - <sup>281</sup>300 MWe

		CAPITAL INVESTMENT			
WBS NUMBER AND TITLE		LABOR		MATL \$	TOTAL (\$M)
		HOURS (THOU)	DOLL (\$M)	(\$M)	
4410	Reflective Unit	174.52	2.42	33.41	35.83
4420	Drive Unit	316.96	4.46	48.57	53.03
4430	Control/Instrumentation Equipment	99.76	1.47	3.42	4.89
4440	Foundation/Site Preparation	588.55	13.61	11.11	24.72
4450	Helio Spt St/Pr En	44.63	0.60	4.95	5.55
4460	Field Assembly and Checkout	<u>373.42</u>	<u>7.77</u>	<u>0.03</u>	<u>7.80</u>
	Subtotal - Heliostat	1597.84	30.33	101.49	131.82
	Visibility	-	<u>6.07</u>	<u>10.13</u>	<u>16.20</u>
	Total Heliostat		36.40	111.62	148.02
4100	Site, Struc, Misc Equip.	8.14	0.12	1.41	1.53
4800	Dist. and Indir. (Init. Sprs)	0.00	0.00	0.06	0.06
OM100	OPERATION	0.00	0.00	0.00	0.00
OM200	MAINT MATERIAL	0.00	0.00	0.49	0.49
OM300	MAINTENANCE LABOR	<u>115.59</u>	<u>1.73</u>	<u>0.00</u>	<u>1.73</u>
	TOTAL O&M	115.59	1.73	0.49	2.22
ONGOING O&M		59.57	0.89	0.40	1.29

DATE 8-11-78 TAKE-OFF SC PROJECT 300 MW

LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 8-11-78 TAKE-OFF SC PRICED S.R. CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
PUMP P-1 60,000 GPM @ 1066 TDH, 18,000 H.P.	1	EA.				4637628	2906450		4927628
INSULATION	1056	S.F.			298"				323628
TRACE HEATERS	362	L.F.			120"				43440
1ST COMMERCIAL									5295500
NTH PUMP ~ 18% LEAKING CURVE									4342000
4513 PUMP P-1									4342000



Stearns-Roger

ESTIMATE SUMMARY

CUSTOMER		ATOMIC INTERNATIONAL				PROP NO.	
LOCATION						JOB NO.	20325
PROJECT		ADVANCED CENTRAL RECEIVER				DATE	2-13-78
		(200 METERS HEIGHT / 1,500 KIPS)				BY	J.W.F.
REV. NO.		REV. DATE					
ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	OTHER	TOTAL	
A	EARTHWORK	11930	23160	11600	7370	42130	
B	CONCRETE	177219	2680525	799125		3679650	
C	BUILDINGS & STRUCTURES						
D	PROCESS EQUIPMENT						
E	PIPING						
F	ELECTRICAL						
G	PAINTING						
L	PLANT ITEMS						
N	INSTRUMENTS & CONTROLS						
P	INSULATION						
	DIRECT FIELD COST	179149	21703685	11010725	7370	31721780	
H	FIELD EXPENSE						
H	ALL RISK, PR TAX, BOND						
K	CONSTRUCTION SUPPLIES						
M	STARTUP						
S	TEMPORARY FACILITIES						
V	CRAFT BENEFITS						
V	CONSTRUCTION CAMP.						
W	CONSTRUCTION EQUIP.						
	INDIRECT FIELD COST		70% OF DIRECT LABOR			1892580	
	TOTAL FIELD COST					5164360	
J	ENGINEERING		BY OTHERS				
	TOTAL FIELD & ENG. COST						
Q	SALES TAX		4% OF MAT'L COST			40430	
R	PREMIUM PAY		NONE				
	ESCALATION		CURRENT PRICES AND LABOR RATES				
	CONTINGENCY		7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT			418600	
	SUB TOTAL					6073390	
Y	FEE		5% OF SUBTOTAL			303670	
	TOTAL			200 M		6377060	
			(31.855% / METER X 240 METER, 7'				
				240 M		7652000	



JOB NO 133-037 PROJECT 300 MW LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE 8-11-78 TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
Pump P-2	1	EA				620400	144750		765150
INSULATION	220	SF			298.00				65560
TRACE HEATERS	73	L.F			120.00				8760
1 <sup>ST</sup> COMMERICAL									839470
NTH PLANT 20% LEARNING CURVE									677000
CODES	4630	Pump P-2						ROUND TO	840000



TABLE 9.1-5  
 ADVANCED CENTRAL RECEIVER  
 281 MWe O&M COSTS

O&M Items	First Commercial \$1,000/yr	Nth Plant
OM100 Operations Supervision	843	376
OM200 Maintenance Materials	1,078	469
OM210 Spare Parts	1,078	469
OM211 Turbine and Electric Plant	593	258
OM212 Collector Equipment	363	158
OM212 Receiver Equipment		54
OM214 Thermal Storage Equipment	122	
OM220 Material for Repair		
OM230 Other		
OM300 Maintenance Labor	2,539	1,103
OM310 Scheduled Maintenance	2,539	1,103
OM320 Corrective Maintenance		
Total	4,460	1,948

ESG-79-2, Vol 1 IV  
C-18



Rockwell International  
 Energy Systems Group


## 281 MWe O&amp;M Costs

update 100 MWe O&M costs  
as follows.

OM 100 Increase operating staff  
by 1 per shift 3 men 150K

OM 200 Increase maintenance materials  
by  $(\frac{281}{100})^{.6} = 1.8$

OM 300 Use MADAC estimate Heliostats  
Increase BOP by 50%

PREPARED BY: <u>W. Wilcox</u>	 <b>Rockwell International</b> Atomics International Division	PAGE NO. <u>        </u> OF <u>        </u>
CHECKED BY: <u>        </u>		REPORT NO. <u>        </u>
DATE: <u>09/26/71</u>		300 MWC All Storage (1/2)

CBS	4820 Space Parts 1.5%	4830 A & E 5%	4840 C M 5%	4860 30%	10%
4100		<u>11,239</u>	<u>11,239</u>		<u>11,239</u>
4200	<u>38,759</u>	<u>38,751</u>	<u>38,751</u>		<u>38,751</u>
4300	<u>6,865</u>	<u>6,865</u>	<u>6,865</u>		<u>6,865</u>
4400	<u>131,820</u>				<u>131,820</u>
4440			<u>24,727</u>		
50			<u>5,550</u>		
60			<u>7,852</u>		
4500	<u>42,077</u>				<u>42,077</u>
14			<u>2,272</u>		
15			<u>2,538</u>		
20			<u>9,538</u>		
40			<u>7,652</u>		
50			<u>        </u>		
60			<u>7,742</u>		
4600	<u>30,490</u>				<u>30,490</u>
10			<u>8,025</u>		
20			<u>0</u>		
30			<u>1,886</u>		
40			<u>0</u>		
50			<u>0</u>		
60			<u>579</u>		
<hr/>					
	X .005	X .05	X .05	X .15	X .10
	1250.	2843	6795	10885	18868
				<u>29753</u>	

**APPENDIX D**  
**COST SUBSTANTIATION DATA**  
**FOR THE PILOT PLANT**



WYN check outland

JOB NO 133 PROJECT 10 MW LOCATION CLIENT

DATE 9-1-78 TAKE-OFF JC PRICED JS CALC. CHKD APPROVED SHEET OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR	SUB-CONTRACT	TOTAL
LAND "FURNISHED BY USER"					Account 411				
SITE INCLUDING FENCING, UTILITIES & INPUT FROM MDS UNDER ACCOUNT #400					412				300000

CODE 4110 SITE  
Form 702-D Nov. 11-73



8-30-78 - 2:20 p.m.

Jan Springer

Jack Dudderly from Stern Rogers

Advanced Concept - Pilot Plant

Estimated costs for 10 megawatt

Pilot Plant

1. Jurbin Bldg.	\$ 300,000
2. Administration Bldg.	20,000
3. Warehouse - maintenance	50,000
4. Control Bldg.	100,000
5. Other Bldgs	<u>90,000</u>
Total	560,000

will confirm by mail

Janey

4100





C-20325  
8-29-78

CONCEPTUAL DESIGN OF ADVANCED CENTRAL  
RECEIVER POWER SYSTEM  
ELECTRIC POWER GENERATION SUBSYSTEM (S-R)

Preliminary Cost Estimate

Plant Size (Net Output)

10 MWe

---

<u>4200 Turbine Equipment</u>	
4210 Turbine Generator & Access.....	\$2,600,000
4220 Heat Rejection System.....	740,000
4230 Condensing Systems.....	95,000
4240 Feed Heating Systems.....	440,000
4250 Work Fluid Circulating, Treatment, Etc.....	1,000,000
TOTAL 4200.....	\$4,875,000
<u>4300 Electric Plant Equipment</u>	
4310 Switchgear.....	\$ 290,000
4320 Station Service Equipment.....	410,000
4330 Protective Equipment.....	170,000
4340 Power Wiring, Electrical Structure & Wiring Containers...	170,000
TOTAL 4300.....	\$1,040,000



Table  
 ADVANCED CONCEPT PILOT PLANT  
 BREAKDOWN OF MASTER CONTROL COSTS BY CBS

1978 DOLLARS AND HOURS IN THOUSANDS

<u>CBS</u>	<u>COST ELEMENT</u>	<u>LABOR</u>		<u>NON-LABOR</u>	<u>TOTAL</u>
		<u>HOURS</u>	<u>DOLLARS</u>		
4351	Hardware			\$ 33.78	\$ 33.78
	LSI-11 Processor			27.22	27.22
	RX11 BA Disc Drive and Control			9.52	9.52
	TA11 AB Recorder			8.55	8.55
	LAV11 DA Printers			49.65	49.65
	Terminal			29.43	113.03
	Cabinet	2.99	\$ 83.60	10.50	10.50
	Cables			186.14	186.14
	Data Acquisition			3.83	3.83
	Time			18.37	18.37
	Weather			2.40	2.40
	Timers			18.30	260.47
	Assy, Trans., Install & C/O	<u>7.13</u>	<u>242.17</u>		
	Subtotal	10.12	\$325.77	\$397.69	\$723.46
	Visibility		<u>65.23</u>	<u>79.31</u>	<u>144.54</u>
	Total 4351		\$391.00	\$477.00	\$868.00
4352	Hardware Design & Engr	15.84	\$745.00	\$ 45.00	\$790.00
4353	Software Design, Develop & Test	9.14	\$430.00	\$ 26.00	\$456.00
OM300	Maintenance Labor (Subcontract)			\$ 0.05	\$ 0.05



Section  
COLLECTOR COST ANALYSIS

4400

Costing Results

Summarized costing results relating to the Collector Equipment subsystem are shown for Pilot, First and Nth Commercial power plants that employ liquid sodium as a coolant in the receiver.

COST ELEMENT	1978 DOLLARS IN MILLIONS			
	PILOT	1ST COMM	NTH 100 MWe	300 MWe
Non-Recurring	\$ 4.70	-	-	-
Transport & Lift Equip	\$ .24	\$ 0.54	\$ 0.53	\$ 1.53
Collectors	\$10.55	\$60.60	\$ 45.82	\$ 131.82
Visibility	-	-	\$ 5.63	\$ 16.20
TOTAL Collect	\$10.55	\$60.60	\$ 51.45	\$ 149.55
Initial Spares	\$ .01	\$ 0.04	\$ 0.02	\$ 0.06
1st Year O&M	\$ .09	\$ 0.80	\$ 0.77	\$ 2.22
Follow-On O&M	\$ .06	\$ 0.46	\$ 0.45	\$ 1.29

These costs are based on data developed in association with the Prototype Heliostat study. Tables -1 thru -4 provide further breakdown of these costs. Non-recurring costs for Commercial Plants are shown as nil because those costs that are not already paid for in prior development are allocated over all production and included in the overhead. Visibility is buried in the Pilot and First Commercial costs but has been listed separately for Nth Commercial because of the likelihood of compensating

## ADVANCED CONCEPT PILOT PLANT - HELIOSTAT COST (1065)

(Sheet 1 of 4)

		CAPITAL INVESTMENT				
		LABOR		MATL \$	TOTAL	
WBS NUMBER AND TITLE		NON RECUR (\$K)	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)
→	4410 Reflective Unit	311	21.94	.77	1.86	2.63 ←
	4411 Reflective Surface	88	6.67	.24	1.16	1.40
	4412 Mirror Back Struct	124	7.87	.27	.63	.90
	4413 Assy & Bond	99	7.40	.26	.07	.33
→	4420 Drive Unit	542	39.75	1.42	3.04	4.46 ←
	4421 Azimuth	280	20.24	.72	.59	1.31
	4422 Elevation	175	12.97	.46	1.57	2.03
	4423 Motor Total	0	0	0	.50	.50
	4424 Pos/Limit Indicators	54	4.12	.15	.03	.18
	4425 Power Sply/Dist	0	0	0	.35	.35
	4426 Assy Dr/Ped/Elect	33	2.42	.09	0	.09
→	4430 Control/Instrmt Equip	171	12.85	.45	.54	.99 ←
	4431 Sensor/Calib Equip	0	0	0	.01	.01
	4432 Field Control	1	.13	0	0	0
	4433 Cntrl/Sig Equip	161	12.12	.43	.48	.91

Table D - 1

## ADVANCED CONCEPT PILOT PLANT - HELIOSTAT COST (1065)

(Sheet 2 of 4)

		CAPITAL INVESTMENT				
		LABOR		MATL \$	TOTAL	
WBS NUMBER AND TITLE	NON RECUR (\$K)	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)	
44320101 Collector Control	9	.60	.02	.05	.07	
4440 Found/Site Prep	134	22.54	.53	.43	.96	
4441 Foundation	122	16.36	.38	.43	.81	
4442 Site Preparation	12	6.18	.15	0	.15	
4450 HelioStat Spt St/Pr En	71	5.34	.19	.20	.39	
4451 Helio Suppt Struct	71	5.34	.19	.20	.39	
4452 Protection Encl	0	0	0	0	0	
4453 Lightning Protect	0	0	0	0	0	
4460 Field Assy and C/O	636	24.36	.55	0	.55	
4461 HelioStat	593	12.48	.28	0	.28	
4462 Sensor/Calib Equip	1	.13	0	0	0	
4463 Electrical/Distrib	37	7.03	.16	0	.16	
4464 Align HelioStats	3	3.15	.07	0	.07	

Table -1

ADVANCED CONCEPT PILOT PLANT - HELIOSTAT COST (1065)

(Sheet 3 of 4)

		CAPITAL INVESTMENT				
		LABOR		MATL \$	TOTAL	
WBS NUMBER AND TITLE	NON RECUR (\$K)	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)	
4465	Field Support	1	.60	.01	0	.61
4466	Pack & Transp	1	.97	.03	0	.03
→ 4470	Design/Engineering	2534	13.94	.57	0	.57 ←
4471	Design	1575	0	0	0	0
4472	Sustaining Engr	580	13.94	.57	0	.57
4473	Pre Prod Unit	170	0	0	0	0
4474	Site Activation	510	0	0	0	0
	TOTAL HELIOSTAT	4700	140.72	4.48	6.07	10.55
→ 4100	Site, Struct, Misc Equip	0	1.22	.02	.22	.24
→ 4130	Misc Equipment	0	1.22	.02	.22	.24
→ 4800	Dist and Indir	0	0	0	.01	.01

ESG-79-2, Vol IV  
D-13

Table -1

ADVANCED CONCEPT PILOT PLANT - HELIOSTAT COST (1065)

(Sheet 4 of 4)

CAPITAL INVESTMENT

WBS NUMBER AND TITLE	LABOR			MATL \$	TOTAL
	NON RECUR (\$K)	HOURS (THOU)	DOLL (\$M)	(\$M)	(\$M)
4840 Initial Spares	0	0	0	.01	.01
OM100 Operations	0	0	0	0	0
OM200 Maint Material	0	0	0	.03	.03
OM300 Maintenance Labor	<u>0</u>	<u>4.09</u>	<u>.06</u>	<u>0</u>	<u>.06</u>
TOTAL O&M	0	4.09	.06	.03	.09
Ongoing O&M	0	1.80	.04	.02	.06

ESG-79-2, Vol IV  
D-14




Atomic International Division

JOB NO. \_\_\_\_\_ PROJECT 10 MW LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_

DATE \_\_\_\_\_ TAKE-OFF JC PRICED JC CALC. CHKD \_\_\_\_\_ APPROVED \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L	LABOR	SUB-CONT.	MATERIAL	LABOR \$	SUB-CONTRACT	TOTAL
					ACCOUNT				
RECEIVER PANELS (115,107 EA)	3	EA			4511	"REF 100 MW"		345321	345321
SUPPORT STRUCTURE (8200 EA)					4512	" "		24600	24600
RECEIVER PUMP (REWORK) P-5 SCT					4513	31000	5000	44000	80000
INSTRUMENTATION & CONTROLS (REF 100MW)					4514			798000	798000
TRANSPORTATION, FIELD ERECTION (REF 100MW)					4515		54000		54000
PIPING SYSTEMS					4520	709810	768510	948002	2426322
SODIUM	69,100	LB.	.40		4530			27640	27640
TOWER & FOUNDATIONS STEARS-ROGGER					4540			159500	159500
STEAM GENERATOR A-1 MSG (LESS NUCLEAR CODES)					4560			900000	900000
DESIGN & ENGINEERING (SEE BACKUP)					4570				
CODE									
4500	RECEIVER EQUIPMENT								

ESG-79-2, Vol 1 IV  
D-15



Alonius & Sons  
 General Division  
 Rockwell

JOB NO. \_\_\_\_\_ PROJECT \_\_\_\_\_ LOCATION \_\_\_\_\_ CLIENT \_\_\_\_\_ SHEET \_\_\_\_\_ OF \_\_\_\_\_

DATE	ITEM AND DESCRIPTION	QUANTITY	UNIT	CALC. CHGD			APPROVED	LABOR	SUB-CONTRACT	TOTAL
				MAT'L	LABOR	SUB-CONT.				
	SCH. 40 S.S. PIPE A.S.3	8	LF	26	8.7				13050.0	
	S.S.	6	LF	153	6.54				10464.0	
	SODIUM VALVES S.S.	3	EA	19K	50.0				1510.0	
	S.S.	2		14K	17.0				34.0	
		4		9100	10.0				110.0	
		3		7000	8.0				8.0	
		2		4660	2.0				6.0	
		1		2330	1.0				1.0	
	DRAG VALVE	6		19K	17.0				117.0	
	BRIST DISC	6		1500	3.0				3.0	
	PIPE SUPPLIES	3		18	1.3				180.0	
		6		15	1.0				160.0	
	SCH. 40 S.S. FITTINGS	3		1	7.3				591.0	
	S.S.	6			10.0				870.0	
		4			8.0				114.0	
		3			7.0				114.0	
		2			5.5				33.0	
		1			5.0				10.0	
	SODIUM REACTION TANK	1		U.S. REF 100MM ± 6 P.WORK					6030.0	
	"	1		U.S. "					924.62	
	PURIFICATION SYSTEM	8		1500 L.F.	62.0				9300.0	
	INSULATION 4 1/2"	6		1600 L.F.	44.0				704.00	
	" 4"	6		2100 L.F.	120/LF				3720.00	
	TRACE HEATERS									
	SODIUM HEATING & UNLOADING	1		U.S. REF 100MM PLANT					14500.0	
	COVER GAS SYSTEM	1		U.S. "					9483.9	
	COOR									
	4520								76981.0	
	PIPING SYSTEMS BACKUP								76851.0	
									94800.0	
									24263.22	

DATE: \_\_\_\_\_ APPROVED: \_\_\_\_\_

CUSTOMER	ATOMIC INTERNATIONAL	PROP NO.	
LOCATION		JOB NO.	20325
PROJECT	ADVANCED CENTRAL RECEIVER (100 METERS HIGH / NONE KIPS)	DATE	2-6-78
REV. NO.		REV. DATE	
		BY	J.W.F.

ACT	DESCRIPTION	CRAFT HOURS	LABOR	MATERIAL	SUBCONTRACT	TOTAL
A	EARTHWORK	462	5540	21800	1770	10110
B	CONCRETE	29037	438540	163090		601630
C	BUILDINGS & STRUCTURES					
D	PROCESS EQUIPMENT					
E	PIPING					
F	ELECTRICAL					
G	PAINTING					
L	PLANT ITEMS					
N	INSTRUMENTS & CONTROLS					
P	INSULATION					
	DIRECT FIELD COST	29499	444080	165890	1770	611740
H	FIELD EXPENSE					
H	ALL RISK, PR TAX, BOND					
K	CONSTRUCTION SUPPLIES					
M	STARTUP					
S	TEMPORARY FACILITIES					
V	CRAFT BENEFITS					
V	CONSTRUCTION CAMP.					
W	CONSTRUCTION EQUIP.					
	INDIRECT FIELD COST		70% OF DIRECT LABOR			310855
	TOTAL FIELD COST					922595
J	ENGINEERING BY OTHERS					
	TOTAL FIELD & ENG COST					
Q	SALES TAX 4% OF MAT'L COST					6625
R	PREMIUM PAY NONE					
	ESCALATION CURRENT PRICES AND LABOR RATES					
	CONTINGENCY 7 1/2% OF TOTAL FIELD COST PLUS SALES TAX MINUS SUBCONTRACT					69560
	SUB TOTAL					998770
Y	FEE 5% OF SUBTOTAL					49940
	TOTAL					1048730
			4540			



# Stearns-Roger INCORPORATED

CLIENT ATOMIC INTERNATIONAL  
 ORDER NO. 20325 LOCATION \_\_\_\_\_

SHEET NO. 1  
 BY J. W. F.  
 DATE 2-10-78

ACCOUNT	ITEM AND DESCRIPTION	QUANTITY	UNIT	MAT'L UNIT COST	MANHOURS						
					UNIT	TOTAL	\$/MH	LABOR	MATERIAL	OTHER	TOTAL
	<u>TOWER:</u>										
	<u>HEIGHT 100 METERS</u>										
	<u>RECV. WT NONE KIPS</u>										
<u>A</u>	<u>SOIL EXCAVATION</u>	<u>2,719</u>	<u>CY</u>	<u>-</u>	<u>.08</u>	<u>217</u>	<u>12.00</u>	<u>2,600</u>	<u>-</u>	<u>1,070</u>	<u>3,670</u>
<u>A</u>	<u>BACK-FILL (COMPACTED STRUCT.)</u>	<u>700</u>	<u>CY</u>	<u>1.00</u>	<u>.35</u>	<u>245</u>	<u>12.00</u>	<u>2,940</u>	<u>2,800</u>	<u>710</u>	<u>6,450</u>
<u>B</u>	<u>TOWER CONCRETE - <math>f'_c = 4000 \text{ psi}</math></u>	<u>1,058</u>	<u>CY</u>	<u>30.00</u>	<u>10</u>	<u>10,580</u>	<u>15.00</u>	<u>158,700</u>	<u>31,740</u>		<u>190,440</u>
<u>B</u>	<u>TOWER STEEL - <math>f_y = \text{GR. 60}</math></u>	<u>66</u>	<u>TONS</u>	<u>440.00</u>	<u>10</u>	<u>660</u>	<u>17.00</u>	<u>11,220</u>	<u>29,040</u>		<u>40,260</u>
<u>B</u>	<u>MAT CONCRETE - <math>f'_c = 4000 \text{ psi}</math></u>	<u>1,985</u>	<u>CY</u>	<u>30.00</u>	<u>9</u>	<u>16,965</u>	<u>15.00</u>	<u>254,475</u>	<u>56,550</u>		<u>311,025</u>
<u>B</u>	<u>MAT STEEL - <math>f_y = \text{GR. 60}</math></u>	<u>104</u>	<u>TONS</u>	<u>440.00</u>	<u>8</u>	<u>832</u>	<u>17.00</u>	<u>14,145</u>	<u>45,760</u>		<u>59,905</u>
	<u>TOTAL</u>					<u>29,499</u>		<u>444,020</u>	<u>165,890</u>	<u>1,770</u>	<u>611,740</u>

ESG-79-2, Vol 1 IV  
D-18





JOB NO

DATE

PROJECT

LOCATION

CLIENT

DATE

TIME OFF

PRICE

CALL INFO

APPROVED

SHEET

OF

ITEM AND DESCRIPTION	QUANTITY	UNIT	UNIT PRICE	TOTAL	SUB CONTRACT	TOTAL
Hot Tank Detail (241611)	1	EA	4614	4614	* 16,435.14	
Cold Tank Detail (241611)	1	EA	4610	4610	* 11,482.23	
Circulation Pump Review	1	EA	4630	4630	3500	
Foundations (Detail)	1	L.S.	4660	4660	13,500	
Design Engineering	1	L.S.	4610	4610		
Sewer	620K	LOS .40	4680	243000		
* INSULATION & TRACER HEATING						
CODE	4600	THERMAL STORAGE EQUIPMENT				



Summary 4800

- 4810 - Temporary Facilities - See Breakdown Sheet
- 4820 - Spare Parts 1/2% of 4200 through 4600
- 4830 - A&E Services 5% of 4100 through 4300
- 4840 - Construction Management 5% of 4100 through 4300;  
4400, 50, and 60; 4514, 15, 20, 40, 50, and 60;  
4610 through 4660.
- 4850 - Startup and Checkout - 20 Man-Years at \$50K/yr.
- 4860 - Contingency - 10% of 4100 through 4400  
30% of 4500 and 4600
- 4860 - Contingency on Nth Plant  
10% of FAC & S-R  
15% of ESG.



Rockwell International  
Energy Systems Group